

EXPERIMENTAL EVALUATION OF HEAT TRANSFER IMPACTS OF TUBE PITCH ON
HIGHLY ENHANCED SURFACE TUBE BUNDLE

by

EVRAAM GORGY

M.S., Kansas State University, 2008

AN ABSTRACT OF A DISSERTATION

submitted in partial fulfillment of the requirements for the degree

DOCTOR OF PHILOSOPHY

Department of Mechanical and Nuclear Engineering
College of Engineering

KANSAS STATE UNIVERSITY
Manhattan, Kansas

2011

Abstract

The current research presents the experimental investigation of the effect of tube pitch on enhanced tube bundles' performance. The typical application of this research is flooded refrigerant evaporators. Boosting evaporator's performance through optimizing tube spacing reduces cost and energy consumption. R-134a with the enhanced tube Turbo BII-HP and R-123 with Turbo BII-LP were used in this study. Three tube pitches were tested P/D 1.167, P/D 1.33, and P/D 1.5. Each tube bundle includes 20 tubes (19.05 mm outer diameter and 1 m long each) constructed in four passes. The test facility's design allows controlling three variables, heat flux, mass flux, and inlet quality.

The type of analysis used is local to one location in the bundle. This was accomplished by measuring the water temperature drop in the four passes. The water-side pressure drop is included in the data analysis. A new method called the EBHT (Enthalpy Based Heat Transfer) was introduced, which uses the water-side pressure drop in performing the heat transfer analysis.

The input variables ranges are: 15-55 kg/m².s for mass flux, 5-60 kW/m² for heat flux, and 10-70% for inlet quality. The effect of local heat flux, local quality, and mass flux on the local heat transfer coefficient was investigated. The comparison between the bundle performance and single tube performance was included in the results of each tube bundle. The smallest tube pitch has the lowest performance in both refrigerants, with a significantly lower performance in the case of R-134a. However, the two bigger tube pitches have very similar performance at low heat flux. Moreover, the largest tube pitch performance approaches that of the single tube at medium and high heat fluxes.

For the R-123 study, the smallest tube bundle experienced quick decrease in performance at high qualities, exhibiting tube enhancement dry-out at certain flow rates and high qualities. The flow pattern effect was demonstrated by the dry-out phenomena. At medium and high heat fluxes, as the tube pitch increases, the performance approaches that of the single tube. All tube bundles experience quick decrease in performance at high qualities. Evidently, P/D 1.33 is the optimum tube pitch for the studied refrigerants and enhanced tubes combinations.

EXPERIMENTAL EVALUATION OF HEAT TRANSFER IMPACTS OF TUBE PITCH ON
HIGHLY ENHANCED SURFACE TUBE BUNDLE

by

EVRAAM GORGY

M.S., Kansas State University, 2008

A DISSERTATION

submitted in partial fulfillment of the requirements for the degree

DOCTOR OF PHILOSOPHY

Department of Mechanical and Nuclear Engineering
College of Engineering

KANSAS STATE UNIVERSITY
Manhattan, Kansas

2011

Approved by:

Major Professor
Steven Eckels

Copyright

EVRAAM GORGY

2011

Abstract

The current research presents the experimental investigation of the effect of tube pitch on enhanced tube bundles' performance. The typical application of this research is flooded refrigerant evaporators. Boosting evaporator's performance through optimizing tube spacing reduces cost and energy consumption. R-134a with the enhanced tube Turbo BII-HP and R-123 with Turbo BII-LP were used in this study. Three tube pitches were tested P/D 1.167, P/D 1.33, and P/D 1.5. Each tube bundle includes 20 tubes (19.05 mm outer diameter and 1 m long each) constructed in four passes. The test facility's design allows controlling three variables, heat flux, mass flux, and inlet quality.

The type of analysis used is local to one location in the bundle. This was accomplished by measuring the water temperature drop in the four passes. The water-side pressure drop is included in the data analysis. A new method called the EBHT (Enthalpy Based Heat Transfer) was introduced, which uses the water-side pressure drop in performing the heat transfer analysis.

The input variables ranges are: 15-55 kg/m².s for mass flux, 5-60 kW/m² for heat flux, and 10-70% for inlet quality. The effect of local heat flux, local quality, and mass flux on the local heat transfer coefficient was investigated. The comparison between the bundle performance and single tube performance was included in the results of each tube bundle. The smallest tube pitch has the lowest performance in both refrigerants, with a significantly lower performance in the case of R-134a. However, the two bigger tube pitches have very similar performance at low heat flux. Moreover, the largest tube pitch performance approaches that of the single tube at medium and high heat fluxes.

For the R-123 study, the smallest tube bundle experienced quick decrease in performance at high qualities, exhibiting tube enhancement dry-out at certain flow rates and high qualities. The flow pattern effect was demonstrated by the dry-out phenomena. At medium and high heat fluxes, as the tube pitch increases, the performance approaches that of the single tube. All tube bundles experience quick decrease in performance at high qualities. Evidently, P/D 1.33 is the optimum tube pitch for the studied refrigerants and enhanced tubes combinations.

Table of Contents

List of Figures.....	ix
List of Tables..	xiii
Acknowledgements	xiv
Dedication.....	xv
Nomenclature..	xvi
Chapter 1 Introduction.....	1
1.1 Background.....	1
1.2 The significance of the research	2
1.3 Objective.....	2
1.4 Scope of work	2
1.5 Document organization.....	3
Chapter 2 Literature Review	5
2.1 Introduction.....	5
2.2 Enhanced tubes advancement	5
2.3 Boiling over enhanced tube bundles.....	6
2.4 Effect of tube pitch	10
2.4.1 Effect of tube pitch for submerged tube bundles	10
2.4.2 Effect of tube pitch for tube bundles under forced convection.....	11
2.5 Bundle models	12
2.5.1 Void fraction	14
2.5.2 Flow pattern of boiling on tube bundle.....	14
2.6 Conclusion	15
Chapter 3 Test Circuit and Equipment Description	16
3.1 Introduction.....	16
3.2 Test Section.....	17
3.2.1 Tube pitches	18
3.2.2 Tube bundle installation.....	18
3.2.3 Water and refrigerant flow distribution	19
3.2.4 Test section instrumentation	19
3.3 Refrigerant circuit	23
3.3.1 Refrigerant circuit instrumentation	24
3.4 Water circuits	25
3.4.1 Test section primary water circuit.....	25
3.4.2 Pre-boiler primary water circuit.....	25
3.4.3 Test section and pre-boiler secondary circuit	26
3.4.4 Hot water circuit	26

3.4.5 Water circuits instrumentation	27
3.5 Data acquisition	27
3.6 Conclusion	28
Chapter 4 Data Reduction.....	29
4.1 Introduction.....	29
4.2 Finite heat transfer governing equations.....	29
4.3 Local heat transfer coefficient	31
4.4 Local heat flux	32
4.5 Water heat transfer coefficient.....	32
4.5.1 The modified Wilson plot technique.....	33
4.6 Total heat transfer governing equations.....	34
4.7 The tube-average heat transfer coefficient.....	35
4.7.1 The enthalpy-based heat transfer analysis (EBHT).	35
4.7.2 The governing equations of the enthalpy-based heat transfer analysis.....	36
4.8 Local quality	38
4.9 Mass flux.....	40
4.10 Uncertainty analysis.....	40
4.10.1 Input variables.....	41
4.10.2 Average refrigerant heat transfer coefficient uncertainty	43
4.10.3 Local refrigerant heat transfer coefficient uncertainty.....	43
4.11 Conclusion	45
Chapter 5 Introduction to Results.....	46
5.1 Introduction.....	46
5.2 Energy balance.....	46
5.3 Test matrix	47
5.4 Data presentation	48
5.5 Water temperature drop	48
5.6 Pool boiling results	50
5.7 Wilson plot results	52
Chapter 6 Effect of Tube Pitch for R-134a.....	54
6.1 Introduction.....	54
6.2 P/D 1.167 results	54
6.2.1 Heat flux effect	56
6.2.2 Mass flux effect.....	59
6.2.3 Quality effect.....	59
6.3 P/D 1.33 results	62
6.3.1 Heat flux effect	64
6.3.2 Mass flux effect.....	66
6.3.3 Quality effect	66
6.4 P/D 1.5 results.....	70

6.4.1 Heat flux effect	72
6.4.2 Mass flux effect.....	74
6.4.3 Quality effect	74
6.5 Saturation pressure change in the tube bundles	79
6.6 Heat transfer impact of varying the tube pitch	81
6.7 Conclusion	86
Chapter 7 Effect of Tube Pitch for R-123.....	87
7.1 Introduction.....	87
7.2 P/D 1.167 results.....	87
7.2.1 Heat flux effect	90
7.2.2 Mass flux effect.....	92
7.2.3 Quality effect	92
7.3 P/D 1.33 results.....	96
7.3.1 Heat flux effect	98
7.3.2 Mass flux effect.....	101
7.3.3 Quality effect	101
7.4 P/D 1.5 results.....	103
7.4.1 Heat flux effect	105
7.4.2 Mass flux effect.....	108
7.4.3 Quality effect	108
7.5 Saturation pressure change in the tube bundles	111
7.6 Heat transfer impact of varying the tube pitch	113
7.7 Conclusion	119
Chapter 8 Discussion	120
8.1 Introduction.....	120
8.2 Boiling mechanism in enhanced tubes.....	120
8.3 Pool boiling trend analysis.....	122
8.4 Bundle boiling trend analysis.....	124
8.4.1 R-134a bundles' trend analysis	124
8.4.2 R-123 bundles' trend analysis.....	125
8.4.3 The two refrigerants comparison	126
8.5 Conclusion	127
Chapter 9 Conclusion	128
Bibliography... ..	130
Appendix A Test Section Drawings	135
Appendix B Visuals of the Test Facility	145
Appendix C Boiling Visuals.....	154
Appendix D Example of an Uncertainty Worksheet.....	158
Appendix E Data Tables.....	179

List of Figures

Figure 3-1 Refrigerant circuit	16
Figure 3-2 Test section inner dimensions	18
Figure 3-3 Thermistor probe (the element is inside the set screw).....	20
Figure 3-4 Cross sectional view of test tube and insert tube	22
Figure 3-5 Test section cross sectional view	23
Figure 3-6 Pre-boiler circuit.....	26
Figure 3-7 Hot water system and secondary circuits	27
Figure 4-1 Thermal resistances illustration.....	31
Figure 4-2 Test section side view for quality calculations	39
Figure 4-3 Test section cross section for quality calculation.....	40
Figure 5-1 Tube A1 temperature drop	49
Figure 5-2 Tube A2 temperature drop	49
Figure 5-3 Tube A3 temprature drop	50
Figure 5-4 Tube A4 temperature drop	50
Figure 5-5 Pool boiling of R-134a on Turbo BII-HP	51
Figure 5-6 Pool boiling of R-123 on Turbo BII-LP.....	52
Figure 5-7 Wilson plot of R-134a on Turbo BII-HP	53
Figure 5-8 Wilson plot of R-123 on Turbo BII-LP.....	53
Figure 6-1 R-134a P/D 1.167 all data	55
Figure 6-2 R-134a P/D 1.167 all data sorted by quality	56
Figure 6-3 R-134a P/D 1.167 effect of heat flux at 10-20% Quality.....	57
Figure 6-4 R-134a P/D 1.167 effect of heat flux 35-40% Quality.....	57
Figure 6-5 R-134a P/D 1.167 effect of heat flux 55-60% Quality.....	58
Figure 6-6 R-134a P/D 1.167 effect of heat flux 70-85% Quality.....	58
Figure 6-7 R-134a P/D 1.167 effect of quality at 15 kg/m ² .s	59
Figure 6-8 R-134a P/D 1.167 effect of quality at 20 kg/m ² .s	60
Figure 6-9 R-134a P/D 1.167 effect of quality at 25 kg/m ² .s	60
Figure 6-10 R-134a P/D 1.167 effect of quality at 35 kg/m ² .s	61

Figure 6-11 R-134a P/D 1.167 effect of quality at 45 kg/m ² .s	61
Figure 6-12 R-134a P/D 1.167 effect of quality at 55 kg/m ² .s	62
Figure 6-13 R-134a P/D 1.33 all data	63
Figure 6-14 R-134a P/D 1.33 all data sorted by quality	64
Figure 6-15 R-134a P/D 1.33 effect of heat flux at 10-15% Quality.....	65
Figure 6-16 R-134a P/D 1.33 effect of heat flux at 35-40% Quality.....	65
Figure 6-17 R-134a P/D 1.33 effect of heat flux at 50-60% Quality.....	66
Figure 6-18 R-134a P/D 1.33 effect of quality at 15 kg/m ² .s	67
Figure 6-19 R-134a P/D 1.33 effect of quality at 20 kg/m ² .s	68
Figure 6-20 R-134a P/D 1.33 effect of quality at 25 kg/m ² .s	68
Figure 6-21 R-134a P/D 1.33 effect of quality at 35 kg/m ² .s	69
Figure 6-22 R-134a P/D 1.33 effect of quality at 45 kg/m ² .s	69
Figure 6-23 R-134a P/D 1.33 effect of quality at 55 kg/m ² .s	70
Figure 6-24 R-134a P/D 1.5 all data	71
Figure 6-25 R-134a P/D 1.5 all data sorted by quality	72
Figure 6-26 R-134a P/D 1.5 effect of heat flux at 10-15% Quality.....	73
Figure 6-27 R-134a P/D 1.5 effect of heat flux at 35-40% Quality.....	73
Figure 6-28 R-134a P/D 1.5 effect of heat flux at 50-60% Quality.....	74
Figure 6-29 R-134a P/D 1.5 effect of quality at 10 kg/m ² .s	75
Figure 6-30 R-134a P/D 1.5 effect of quality at 15 kg/m ² .s	76
Figure 6-31 R-134a P/D 1.5 effect of quality at 20 kg/m ² .s	76
Figure 6-32 R-134a P/D 1.5 effect of quality at 25 kg/m ² .s	77
Figure 6-33 R-134a P/D 1.5 effect of quality at 35 kg/m ² .s	77
Figure 6-34 R-134a P/D 1.5 effect of quality at 45 kg/m ² .s	78
Figure 6-35 R-134a P/D 1.5 effect of quality at 55 kg/m ² .s	78
Figure 6-36 R-134a P/D 1.167 bundle saturation pressure.....	79
Figure 6-37 R-134a P/D 1.33 bundle saturation pressure.....	80
Figure 6-38 R-134a P/D 1.5 bundle saturation pressure.....	80
Figure 6-39 R-134a tube pitch comparison	81
Figure 6-40 R-134a bundles comparison at 15 kg/m ² .s	82
Figure 6-41 R-134a bundles comparison at 25 kg/m ² .s	83

Figure 6-42 R-134a bundles comparison at 0.35 kg/s	83
Figure 6-43 R-134a bundles comparison at 0.45 kg/s	84
Figure 6-44 R-134a bundles comparison at 10-20 kW/m ² and 15 kg/m ² .s.....	84
Figure 6-45 R-134a bundles comparison at 30-40 kW/m ² and 15 kg/m ² .s.....	85
Figure 6-46 R-134a bundles comparison at 40-50 kW/m ² and 25 kg/m ² .s.....	85
Figure 6-47 R-134a bundles comparison at 10-20 kW/m ² and 0.45 kg/s.....	86
Figure 7-1 R-123 P/D 1.167 all data.....	88
Figure 7-2 R-123 P/D 1.167 saturation temperature comparison.....	88
Figure 7-3 R-123 P/D 1.167 all data sorted by quality	89
Figure 7-4 R-123 P/D 1.167 effect of heat flux at 10-20% Quality	90
Figure 7-5 R-123 P/D 1.167 effect of heat flux at 30-40% Quality	91
Figure 7-6 R-123 P/D 1.167 effect of heat flux at 50-60% Quality	91
Figure 7-7 R-123 P/D 1.167 effect of heat flux at 70-80% Quality	92
Figure 7-8 R-123 P/D 1.167 effect of quality at 15 kg/m ² .s.....	93
Figure 7-9 R-123 P/D 1.167 effect of quality at 20 kg/m ² .s.....	94
Figure 7-10 R-123 P/D 1.167 effect of quality at 25 kg/m ² .s.....	94
Figure 7-11 R-123 P/D 1.167 effect of quality at 35 kg/m ² .s.....	95
Figure 7-12 R-123 P/D 1.167 effect of quality at 45 kg/m ² .s.....	95
Figure 7-13 R-123 P/D 1.167 effect of quality at 55 kg/m ² .s.....	96
Figure 7-14 R-123 P/D 1.33 all data.....	97
Figure 7-15 R-123 P/D 1.33 saturation temperature comparison.....	97
Figure 7-16 R-123 P/D 1.33 all data sorted by quality	98
Figure 7-17 R-123 P/D 1.33 effect of heat flux at 10-20% Quality	99
Figure 7-18 R-123 P/D 1.33 effect of heat flux at 30-40% Quality	99
Figure 7-19 R-123 P/D 1.33 effect of heat flux at 50-60% Quality	100
Figure 7-20 R-123 P/D 1.33 effect of heat flux at 70-83% Quality	100
Figure 7-21 R-123 P/D 1.33 effect of quality at 15 kg/m ² .s.....	102
Figure 7-22 R-123 P/D 1.33 effect of quality at 20 kg/m ² .s.....	102
Figure 7-23 R-123 P/D 1.33 effect of quality at 25 kg/m ² .s.....	103
Figure 7-24 R-123 P/D 1.5 all data.....	104
Figure 7-25 R-123 P/D 1.5 two saturation temperatures	104

Figure 7-26 R-123 P/D 1.5 all data sorted by quality	105
Figure 7-27 R-123 P/D 1.5 effect of heat flux at 10-20% Quality	106
Figure 7-28 R-123 P/D 1.5 effect of heat flux at 30-40% Quality	107
Figure 7-29 R-123 P/D 1.5 effect of heat flux at 50-60% Quality	107
Figure 7-30 R-123 P/D 1.5 effect of heat flux at 70-80% Quality	108
Figure 7-31 R-123 P/D 1.5 effect of quality at 10 kg/m ² .s	109
Figure 7-32 R-123 P/D 1.5 effect of quality at 15 kg/m ² .s	110
Figure 7-33 R-123 P/D 1.5 effect of quality at 20 kg/m ² .s	110
Figure 7-34 R-123 P/D 1.167 bundle saturation pressure.....	111
Figure 7-35 R-123 P/D 1.33 bundle saturation pressure.....	112
Figure 7-36 R-123 P/D 1.5 bundle saturation pressure.....	112
Figure 7-37 R-123 tube pitch comparison	114
Figure 7-38 R-123 bundles comparison at 15 kg/m ² .s.....	115
Figure 7-39 R-123 bundles comparison at 25 kg/m ² .s.....	115
Figure 7-40 R-123 bundles comparison at 0.35 kg/s	116
Figure 7-41 R-123 bundles comparison at 0.45 kg/s	116
Figure 7-42 R-123 bundles comparison at 15 kg/m ² .s and 10-20 kW/m ²	117
Figure 7-43 R-123 bundles comparison at 15 kg/m ² .s and 30-40 kW/m ²	117
Figure 7-44 R-123 bundles comparison at 25 kg/m ² .s and 40-50 kW/m ²	118
Figure 7-45 R-123 bundles comparison at 0.45 kg/s and 10-20 kW/m ²	118
Figure 7-46 R-123 bundle comparison at 0.45 kg/s and 40-50 kW/m ²	119
Figure 8-1 Microscopic picture of the tube surface	121
Figure 8-2 Pool boiling of R-134a on Turbo BII-HP	123
Figure 8-3 Pool boiling of R-123 on Turbo BII-LP.....	123
Figure 8-4 R-134a tube pitch comparison	125
Figure 8-5 R-123 tube pitch comparison	126

List of Tables

Table 1-1 Test matrix inputs	3
Table 3-1 Enhanced tubes dimensions.....	21
Table 5-1 Test matrix inputs	47

Acknowledgements

I want to start my acknowledgement with the biblical verse “The Lord has done great things for us, and we are glad” Psalm 126:3. Truly, the Lord has done great things throughout the difficult time of this project and I am very pleased and thankful. Firstly, I would like to thank Dr. Steve Eckels who has been a great teacher and advisor. I actually learned from the way Dr. Eckels deals with students and people in general. He is patient and forgiving and these are two great virtues. This also makes me responsible for following his example.

Secondly, I would like to thank my committee members Dr. Larry Glasgow, Dr. Terry Beck, and Dr. Don Fenton for their guidance. I learned from them that to be a faculty member is to be a giving person; and indeed they gave a lot of their time and knowledge. Many thanks for Dr. Medhat Morcos for his support and his kind heart. I am appreciative of ASHRAE RP-1316 supervisory committee and to Wolverine Tube Inc. for donating the enhanced tubes to the project.

Special thanks to David Huddleston of K-State’s EDL for his diligent work and brilliant ideas in manufacturing the thermistors. This research would not have been possible without the hard work of Luke Schooler, whose skills and talents helped solving the construction problems of the complicated test facility. I am indebted also to Jacob Wagner who is a talented and bright engineer; it was a pleasure working with him. I am grateful for Eric Waters’ skills and experience. Thanks to all the current and past IER students, among those Bill Sharp, Greg May, Mathew Kluitenberg, Andrew Featherstone. For all the engineering graduates who helped me and I have forgotten to mention their names I say, many thanks and please forgive my weak memory. Thanks to all IER staff, it has been a pleasure working with you.

Thanks to my dad who implanted in me the value of science and its positive impact on humanity. I am grateful for my family and friends for their support and prayers. Thanks for St. Mary Magdalene for being a strong intercessor during the hard times of this project. Finally, thanks to K-State; I had a wonderful time there and it will always be in my memory. I have to say that my almost six years at K-State have gone by fast.

Dedication

I decided to dedicate this work to someone who had a significant impact on my life. Although God has blessed me with a lot of good examples, I cannot think of anyone better than my beloved mother. My mother departed this life on February 23rd, 2009 after a battle with cancer. Her life and her death have an impact on my life; she lived and died in Egypt. I was working on this research during the time of her sickness and death. I was with her about a month before she departed this world. May God repose her soul.

To my beloved mother Victoria

Nomenclature

A Area	Pr Prandtl number
C Constant	q'' Heat flux
C_i Internal correction factor	Q Total heat transfer
C_o External correction factor	ρ Density
C_p Specific heat at constant pressure	Re Reynolds number
Cap Capillary number	R Electrical resistance
D Diameter	R_{wall} Wall thermal resistance
D_h Hydraulic diameter	R'_{wall} Modified wall thermal resistance
ε Void fraction	Ri Richardson number
f Friction factor	σ Surface tension
g Gravitational acceleration	T Temperature
G Mass flux	T_{sat} Saturation temperature
h Heat transfer coefficient	T_∞ Fluid temperature
h_{fg} Specific heat of vaporization	U Overall heat transfer coefficient
i Enthalpy	u Uncertainty
k Thermal conductivity	V Voltage
k_c Copper thermal conductivity	v Specific volume
L Length	x Quality
L_c Characteristic length	
L_T Test section length	
μ_L Liquid viscosity	
\dot{m} Mass flow rate	
Nu Nusselt number	
P Pressure	
P/D Pitch to diameter ratio	

Subscripts

<i>c</i>	Cold-side
<i>CB</i>	Convective boiling
<i>G</i>	Gas or vapor
<i>h</i>	Hot-side
<i>i</i>	Inside or internal
<i>L</i>	Liquid
<i>LQ</i>	Liquid phase
<i>NB</i>	Nucleate boiling
<i>o</i>	Outside or outer
<i>r</i>	Refrigerant-side
<i>ref</i>	Refrigerant
<i>w</i>	Water-side

Chapter 1 Introduction

1.1 Background

The current document presents experimental research for investigating the heat transfer effect of tube pitch on enhanced tube bundles. This research project is funded by ASHRAE (RP-1316), and supervised by TC 8.5 “Liquid to Refrigerant Heat Transfer” under the chairmanship of Dr. Petur Thors. The application of this research is flooded refrigerant evaporators, which have wide application in the HVAC&R industry, for example in high capacity centrifugal chillers.

A flooded evaporator is a shell and tube heat exchanger in which a fluid circulates inside the tube bundle and is cooled by a refrigerant circulating in the shell and over the tube bundle. Cooling takes place through boiling (phase change) of the refrigerant. In flooded evaporators, the refrigerant flows over the tube bundle from the bottom up; it enters the shell at a quality of about 10%, due to the expansion device, and leaves at 100% quality (saturated vapor). This application is usually called “shell boiling.” The tube bundles used in this application can be smooth or enhanced.

The current enhanced copper tubes have been introduced to increase evaporator efficiency by providing active vapor traps. Numerous studies have focused on developing and evaluating enhanced tubes for shell boiling. Since boiling over a tube bundle represents a very complex two-phase flow problem, such phenomenon is often understood through experimental investigation. However, the goal of bundle studies is to introduce a predictive model for designing flooded evaporators.

Studying shell boiling involves examining the effect of different variables on the bundle performance: fluid properties, saturation pressure, mass flux, heat flux, etc. In particular, enhanced tubes are considered a modern development in flooded evaporators and although were included in several shell boiling studies, the influence of tube pitch on the bundle performance has not been examined in depth.

1.2 The significance of the research

Striving for energy resources in a troubled economy raises even more awareness of energy conservation, and in some cases, energy conservation is mandatory. This is becoming a challenging problem for the HVAC&R community (and for cooling applications in particular). All possible solutions to reduce energy consumption and initial cost are being considered, including better design tools for large cooling systems such as centrifugal chillers. In 2004, the market size of centrifugal chillers with cooling capacities exceeding 500 tons approximated \$390 million and was shared by both the manufacturer and the customer.

Such a high cost scale leads to demand for all possible solutions to reduce both initial and running costs. While the flooded refrigerant evaporator is only one component of the chiller system or other cooling application, maximizing the knowledge and the development of this one component is important. Increasing the evaporator heat transfer efficiency leads to less required compressor work and a lighter weight shell and tube heat exchanger. Therefore, studying the effect of tube pitch along with expanding the database of flow boiling in flooded evaporators is worthwhile.

1.3 Objective

The goal of the current study is to investigate the effect of tube pitch on the heat transfer performance of flooded refrigerant evaporators that utilize highly enhanced tubes. This includes testing both high and low pressure refrigerants; however, boiling of low pressure refrigerants (high specific volume) over enhanced tubes can lead to dry-out. Therefore, using investigating the effect of tube pitch using low pressure refrigerant could help with researching this phenomenon.

Accordingly this research is accomplished by investigating the change of the heat transfer coefficient with respect to three variables: heat flux, mass flux, and quality, each to be controlled one at a time. In addition, the study provides an experimental database to expand the understanding of shell boiling on enhanced tubes and to produce evaporator models.

1.4 Scope of work

The project includes testing three tube pitches for two refrigerants using the staggered bundle arrangement (equilateral triangles). The three tube pitches are P/D 1.167 (commonly used

in industry), P/D 1.33, and P/D 1.5. The test section can accommodate the three tube pitches and employs 20 tubes, each with a 0.01905 m (0.75 inch) outer diameter. The type of enhanced tube used is Turbo BII, which includes two versions one tailored for high and one for low pressure refrigerants. The tubes were manufactured and donated by Wolverine Tube, Inc.

The test section has sight glasses for flow visualization extending from the bottom to the top of the test section to show the full tube bundle and the inlet ports. Pure refrigerant (oil free) was used in testing, which was conducted at a saturation temperature of 4.44 °C (40 °F) for R-134a and 14.44 °C (58 °F) for R-123.

A test matrix is composed for each tube bundle, and testing is conducted according to three controlling variables in the test matrix: heat flux, mass flux, and inlet quality. Table 1-1 below shows the general range of these input variables. The type of data analysis used is local to one location in the bundle. Additionally, a new method, the research introduces the Enthalpy Based Heat Transfer analysis or “EBHT”, to determine the heat transfer analysis as a function of the tube-side pressure drop. This method is particularly useful in heat exchangers that experience large tube-side pressure drop.

Table 1-1 Test matrix inputs

<i>Mass flux (kg/s.m²)</i>	15	20	25	35	45	55
<i>Heat flux (kW/m²)</i>	5	15	30	45	60	
<i>Inlet Quality</i>	0.10	0.35	0.55	0.70		

Pool boiling study of the two tube-refrigerant combinations is presented as part of this study, and each tube bundle result is compared to the single tube performance. This comparison is an important tool in clarifying the convective effect in enhanced tube bundles. It is also useful for investigating the effect of tube pitch compared to the single tube performance.

1.5 Document organization

This document is divided into eight chapters and five appendices. The current chapter is the research introduction. The second chapter presents the literature review of enhanced tubes, enhanced tube bundles, effect of tube pitch on bundle performance, and bundle modeling. Chapter three presents the test facility’s test section, refrigerant and water loops, and instruments.

Chapter 4 presents the data reduction, including the equations and methods to determine the local and tube-average heat transfer coefficients, local heat flux, the EBHT, and the uncertainty analysis.

Chapters 5, 6, and 7 present the research results specifically Chapter 5 is a general introduction to the results, dealing with the common results of the two refrigerants as well as presenting the pool boiling results. Chapters 6 and 7 present the results for R-134a and R-123, respectively. Each chapter presents the result of each tube pitch, from the smallest to the largest, and each ends with a comparison of the three tube pitches and the effect of tube pitch on tube bundle performance.

Chapter 8 presents the discussion of the different trends of the boiling curves and a comparison between the two refrigerants in light of different tube pitches. It also present a recommendation based on the experimental data. Finally, Chapter 9 presents the conclusion of the research and the appendices present test section drawings, visuals of the test facility, boiling visuals, an example of a MathCad worksheet, and the data tables, respectively.

Chapter 2 Literature Review

2.1 Introduction

Boiling on a tube bundle has been in use for decades and has many applications: fire tube steam boilers, kettle re-boilers, waste heat boilers, and flooded refrigerant evaporators. The focus of this study is flooded refrigerant evaporators, which are widely used in centrifugal chillers, a high capacity cooling application. In flooded evaporators, refrigerant enters the tube bundle as a two phase mixture (approximately 10% quality) due to the expansion device effect, and refrigerant typically leaves the bundle as saturated vapor. The possible heat transfer regimes of the flooded evaporator from bottom to top are as follows: convective heat transfer, sub-cooled boiling, nucleate boiling, sliding bubbles evaporation, and film boiling. In some cases, the top tubes may experience dry-out.

The types of tubes used in flooded refrigerant evaporators are smooth, integral fin, and enhanced. Recently, enhanced tubes have been the focus of many research projects because of their high efficiency. Furthermore, enhanced tube technology has been on the rise as machining techniques continue to advance, previously an obstacle to developing these tubes.

The following sub-sections discuss: an overview of enhanced tubes and their advancement, enhanced tube bundles studies, effect of tube pitch, available bundle models, and general conclusion.

2.2 Enhanced tubes advancement

In the early 1960s, chiller manufacturers used integral fin tubes (for the refrigerant side) to increase heat transfer performance by increasing surface area, hence offering better heat transfer. This concept, however, is different from that of enhanced tubes, as the main focus of enhanced tubes is creating nucleation sites.

Enhanced surfaces used in boiling applications are, concisely, surfaces that contain artificial nucleation sites, unlike smooth surfaces that gain their nucleation sites from natural surface imperfections. The purpose of an enhanced surface then is to create stable vapor traps. Therefore, as the area density of nucleation sites increases, the onset of boiling occurs at a lower wall superheat.

Webb (2004) gives an excellent discussion of the development of enhanced surfaces reporting that it started in 1960 when researchers investigated the development of reentrant cavities after proving that a reentrant cavity provides a stable vapor trap. In spite of this discovery, machining tubes that contain reentrant cavities was still an obstacle. In his patent in 1970, Webb suggested creating nucleation sites on integral fin tubes by simply warping a wire at the base of the fins.

Continuing with developing tubes with artificial nucleation sites on integral fin tubes, Webb considered bending the tube fins to create a cavity with an opening on the tip of the fin. This tube was called the “bent fin” tube, and was first produced by Trane. Some consider the configuration of the bent fin as a cavity with pores design. Developing such enhanced tubes flourished among researchers and manufacturers. They even started working on enhancing the inside of the tubes (the water side). Well-known tube manufacturers making enhanced tubes included Hitachi (introduced Thermoexcel-E tube), Wieland (GEWA-T), Furukawa (ECR-40), and Wolverine (Turbo-B). The Turbo-B family evolved to what is now known as the Turbo-BIII tube. The current research uses one of the tubes in this family, the Turbo-BII.

All the previously mentioned tubes use the idea of cavities with pores, or rather tunnels with pores, and they are what is now known as “enhanced tubes”; some also call the concept structured tubes. Although some of those tube configurations are available in literature, the detailed configuration and methods of manufacturing remain proprietary.

Nakayama et al. (1982) studied the tunnel with pores configuration and came up with an explanation of evaporation modes at different heat flux ranges. They also developed a semi-analytical model to predict the heat transfer performance. Chien and Webb (1998) Part I and Part II presented a parametric study of the effect of tunnel and pore dimensions on tube performance, studying the flow visualization and presenting an enhanced version of Nakayama’s model. Notably, the previously mentioned studies and model are for single tube pool boiling. Consequently, studying enhanced tube performance in a tube bundle became imperative since enhanced tubes are produced mainly for tube bundles of shell and tube heat exchangers.

2.3 Boiling over enhanced tube bundles

Studying convective boiling over a tube bundle is relatively difficult compared to studying pool boiling. First, pool boiling experimental setup normally utilizes one tube in a pool

of liquid, often driven by natural circulation. Also, pool boiling measurements are relatively simple. On the other hand, in a tube bundle experiment, the test section employs a bundle of tubes where the shell fluid is usually driven by a pump. The experiment setup also includes multiple and sophisticated measurements. Therefore, tube bundle studies are few compared to those for pool boiling.

Researchers have used different approaches in assessing bundle performance. Some focused their work on studying the effect of tube position within the tube bundle, bundle height, static pressure, saturation temperature, and so forth. Additionally, often, bundle studies compare convective boiling and single tube pool boiling; this comparison is known as “bundle effect” or “bundle factor.” Among those who provided tube bundle reviews are Ribatski and Thome (2007), Webb (2005), Casciaro and Thome (2001) Part 1, Browne and Bansal (1999), Thome (1998), Thome (1996), Collier and Thome (1994), Thome (1990), Jensen and Hsu (1988).

This section of the literature review focuses only on enhanced tube bundles studies and on local analysis because this is the best method to clarify tube bundle behavior as well as provide data useful for producing flooded evaporator models. Three variables have the most significant effect on the heat transfer coefficient (often referred to as “bundle performance”): heat flux, quality, and mass flux. Those variables are also the center of the analysis of the current study. Notably, Fujita et al. (1986), Memory et al. (1992), and Memory et al. (1994) studied boiling over smooth and enhanced tube bundles in a pool of liquid. However, this is considered a different application than that in the current study, since it does not present the effect of mass velocity on convective boiling; in some cases, the calculation of quality is not possible. Therefore, the effect of quality cannot be assessed.

The following authors reported varied enhanced tube bundle studies highlighting the effect of heat flux, quality, and mass flux. Chyu et al. (2009) studied boiling of ammonia/lubricant mixture on a horizontal enhanced tube bundle, conducting tests over a range of saturation temperatures (-13.2 to 7.2 °C). Data showed that the heat transfer coefficient increased with the increase in saturation temperature, heat flux, and from the bottom row to the top row; ultimately, the bundle effect was more significant at higher saturation temperatures. Meanwhile, the performance at the bottom row was lower than that of the single tube heat transfer coefficient at a low saturation temperature, and the opposite was true at a higher

saturation temperature. Thus, saturation temperature had a more significant effect on the tube bundle performance than on the pool boiling performance.

Schafer et al. (2007) studied the effect of novel plasma-coated tubes on the bundle performance using R-134a as the working fluid. In that study, coated-tube bundle performance was compared to smooth tube bundle and single tube performances and coated tubes showed a significant increase in the bundle as well as the single tube performances. At higher heat fluxes, bundle performance approached that of a single tube.

Chien and Wu (2004) studied convective boiling of R-123 and R-134a over smooth and low fin tube bundles and conducted pool boiling tests as well. They reported that the heat transfer coefficient increased with the increase of quality (at the test range of 0-0.34) for R-134a on smooth tube, while the mass flux (10-40 kg/m².s) had small effect on performance. Also, low fin tubes showed significant performance enhancement over smooth tubes.

Robinson and Thome (2004) presented one of the most comprehensive studies on this topic, studying the local bundle heat transfer coefficient for three types of tube bundles: smooth (with R-134a), integral fin (with R-134a and R-507a), and enhanced (R-134a, R-410a, R-507a). The tube bundles were P/D 1.167. They also conducted pool boiling experiments for each set. For smooth tube bundles, they reported that the local heat transfer coefficient did show a significant change with the change of mass flux. Specifically, the bundle effect (defined as the local bundle heat transfer coefficient divided by pool boiling heat transfer coefficient) decreased with the increase of heat flux. Next, for a constant mass flux over a range of quality, the heat transfer coefficient increased with the increase of heat flux. However, for constant heat flux and mass flux, the heat transfer coefficient did not show a significant effect with the change of quality.

For the integral fin (1024 fins/m (26 fins/inch)) tube bundle study, Robinson and Thome (2004) reported that the heat transfer coefficient did not show a significant change with the change of mass flux over a range of quality and constant heat flux. In particular, the bundle effect decreased with the increase of heat flux. Meanwhile, for constant heat flux and over a range of quality, the heat transfer coefficient increased with the increase of heat flux. Finally, for constant mass flux and heat flux, the heat transfer coefficient did not show a significant change with the change of quality.

For the enhanced tube portion of the study (Turbo BII tube), and for a range of quality and constant mass flux, the heat transfer coefficient did not show a significant change with mass flux. Again, for constant mass and heat fluxes, the heat transfer coefficient did not show a significant change with quality. Meanwhile, the bundle effect ranged from 0.8 to 1.6 for R-134a, and from 0.6 to 1.2 for R-410a and R-507a.

Kim et al. (2002) presented a study of different types of enhanced tube bundles under R-134a and R-123 at different saturation temperatures. They conducted tests for smooth tube bundles as well and reported that the heat transfer coefficient was dominated by heat flux with negligible dependency on mass flux or quality. The increase in saturation temperature enhanced the heat transfer coefficient. Finally, they reported that the convective effect for R-134a was higher than for R-123 for the enhanced tubes, but the smooth tube bundle showed the opposite.

Tatara and Payvar (2000) Part I presented an experimental investigation of the effect of oil on boiling of R-123 on staggered pitch enhanced tube bundle, P/D 1.167 and calculated the local heat transfer coefficient. They conducted tests for different oil concentrations including 0% concentration and reported that the increase of oil concentration decreased tube performance.

Similar to Part I, Tatara and Payvar (2000) Part II presented an experimental investigation of the effect of oil on boiling of R-134a on a staggered pitch enhanced tube bundle, P/D 1.167 and calculated the local heat transfer coefficient. They conducted tests for different oil concentrations including 0% concentration and was reported that the increase of oil concentration decreased tube performance.

Tatara and Payvar (1999) reported the experimental work of the effect of oil concentration on an integral fin (1024 fins/m (26 fins/inch)) tube bundle under R-123 and R-134a, finding general, that the heat transfer coefficient increased with the increase of oil concentration.

Gupta and Webb (1995) Part I conducted experiments for an integral fin (1024 fins/m (26 fins/inch)) tube bundle with P/D 1.25 for R-11 at two different saturation temperatures (4.4 and 26.7 °C). They studied the effect of convective boiling and pool boiling finding that convective boiling coefficients were twice as high as pool boiling coefficients.

Similar to Part I, Gupta and Webb (1995) Part II conducted experiments for enhanced tube bundles (GEWA SE and Turbo B) with P/D 1.25 under R-11, R-123 and R-134a at 4.4 and 26.7 °C saturation temperatures. Data showed convective behavior similar to that for pool

boiling data. Also, the enhanced tubes' convective effect was much less than that for integral fin tubes.

Danilova and Dyundin (1972) presented experimental work for boiling of R-12 and R-22 over smooth and finned tube bundles (registering different fin geometry). They reported that for the bigger fin spacing, the effect of the number of rows of tubes was considerable. Specifically for small fin spacing, the effect of convective boiling was more pronounced.

2.4 Effect of tube pitch

The following studies point out the effect of tube pitch, or tube spacing, on boiling performance over a tube bundle, which is the focus of the current study. This section is divided into two: studies about the effect of tube spacing in a bundle submerged in a pool of liquid at all times and the studies about the effect of tube pitch for tube bundles under forced convection.

2.4.1 Effect of tube pitch for submerged tube bundles

Liao and Liu (2007) studied boiling of water over a smooth tube bundle at atmospheric and sub-atmospheric pressures focusing on the effect of tube spacing and tube positioning on bundle performance. For sub-atmospheric pressure, the optimum tube spacing is between P/D 1.0556 and 1.0277, and when P/D reaches 1.1112, the effect of tube position becomes apparent. When P/D is less than 1.0556, tube position becomes insignificant. Also, bundle pressure has an effect on the optimum spacing.

Liu and Liao (2006) used the same test facility and test conditions as their previously mentioned study. In this study, and in the one above, they tested in-line vs. staggered tube bundle configuration. At atmospheric pressure, the in-line tube bundle had better performance than the staggered tube bundle.

Qiu and Liu (2004) studied the effect of tube spacing, tube positioning, and bundle pressure on boiling of water over a smooth tube bundle and reported that P/D 1.0166 had the best heat transfer performance at low and moderate heat fluxes. For higher tube spacing, the tube position had a significant effect on heat transfer. For the tightest tube pitch, the heat transfer performance increased with the increase of pressure. Also, Liu and Chen (2001) presented a study similar to the previously mentioned study (Qiu and Liu (2004)). In addition, they

investigated the differences between falling film and flooded type evaporators, discovering that flooded evaporators show better heat transfer performance.

Liu and Qiu (2004) and Liu and Qiu (2002) presented experimental results for boiling of water/salt mixture on smooth tube and roll-worked enhanced tube bundles (the latter is similar to the Wolverine Turbo B). The goals of this study, however, included the effect of tube spacing and tube position within the bundle. The smooth tube results were the same as in their study above, while for the enhanced tube bundle, tube position did not show any difference from the heat transfer perspective. Also, the tight spacing provided heat transfer enhancement for the enhanced tube bundle.

In another study by Liu and Qiu (2004) using the same test facility and methods but with R-11 as the working fluid, they reported that the P/D has an optimum value of 1.0277 (not the tightest pitch) for best performance enhancement. Liu and Tong (2002) presented similar work to Liu and Qiu (2004) in addition to producing a model for predicting the CHF, which agreed well with the experimental results.

2.4.2 Effect of tube pitch for tube bundles under forced convection

Gupta (2005) studied the effect of tube position for saturated water boiling over a 5×3 (P/D 1.5) in-line tube bundle and other tube arrangements (P/D 3.0, 4.5, and 6.0) and reported that at low heat flux, the mass flux was significant and diminished as the heat flux increased. Concerning the effect of P/D, Gupta found that the bundle heat transfer coefficient increased as the tube spacing decreased.

Fujita and Hidaka (1998) studied boiling of R-113 over in-line and staggered smooth tube bundles based on two tube pitches for each bundle configuration, P/D 1.3 and 1.5. They reported no significant effect on the heat transfer coefficient due to changing the tube pitch.

Jensen et al. (1992) conducted an experimental investigation of smooth and enhanced tube bundles. The enhanced tubes used in the analysis were smooth, Turbo B, and HIGHFLUX tubes with R-113 as the working fluid, and the two P/Ds used were 1.17 and 1.5. The effect of tube pitch on the smooth tube bundle was significant at low heat flux and high mass flux. Also, the effect of the change of mass flux and quality was negligible for the enhanced tube bundles.

Dowlati et al. (1990) studied void fraction and friction pressure drop of two phase flow of air-water across in-line tube bundles for P/D 1.3 and 1.75. This type of research is known as

“adiabatic two-phase flow”. Dowlati et al. reported that void fraction does not show strong dependency on tube pitch; increasing the pitch increases two phase pressure drop. Ultimately, the presented void fraction and two-phase friction multiplier predicted the bundle pressure drop for R-113.

Jensen et al. (1989) studied the effect of tube geometry on a smooth tube bundle testing in-line and staggered tube bundles with P/D 1.3 and 1.7 for each tube bundle. They reported that at low heat flux, the higher tube pitch showed a higher heat transfer coefficient, while at medium heat flux, the heat transfer coefficient showed insignificant dependency on tube pitch.

Hsu and Jensen (1988) studied boiling of R-113 on a stainless steel smooth tube bundle testing different tube pitches to document the effect on heat transfer performance. The tube arrangement was an in-line tube bundle, with two P/Ds, 1.3 and 1.7. They reported that at high heat flux range, the high pitch bundle had the highest heat transfer coefficient while at medium heat flux range, the effect of tube pitch did not appear to be significant. Finally, the change of mass flux and saturation pressure had a negligible effect on the heat transfer coefficient for the different tube pitches.

Mueller (1986) studied boiling of R-11 over a finned tube bundle with different tube spacing and reported that tube spacing had little effect on heat transfer for the fully developed boiling regime, while tube pitch had considerable effect at the nexus between natural convection and nucleate boiling.

The above mentioned studies show that the effect of tube pitch on enhanced tubes under convective boiling has not yet been addressed. Also, for the studies focused on effect of tube pitch on submerged tube bundles, small tube spacing provided better heat transfer enhancement. Finally, for the studies of smooth tube bundles under convective boiling, results fluctuated between enhancing performance and having an insignificant effect.

2.5 Bundle models

Theoretical knowledge of boiling heat transfer in flooded refrigerant evaporator is fairly limited compared to that of in-tube boiling, which has a solid foundation of knowledge. Since mathematical and empirical models for in-tube boiling are available extensively and are well-defined in literature, researchers have made those models the starting point for working on boiling in a tube bundle. Although some might be opposed to that idea as mentioned in Casciaro

and Thome (2001) Part I, others find it justifiable to apply in-tube convective boiling models to shell side boiling.

Webb (1991) defends the latter concept by explaining that convective boiling is, essentially, a combination of boiling and convection; which is further explained as a combination of nucleate (pool) boiling and single phase convection. Therefore, all convection heat transfer models can be expressed that way, whether in-tube or bundle flow boiling. He then says “there is no rational reason why one basic model should not be applicable to both flow geometries.” Hence, Chen’s model, the one developed for in-tube boiling, could be used in bundle boiling since it supports that concept.

By way of his extensive and pioneering work in developing enhanced tubes, pool boiling experiments and modeling, and tube bundle experiments (both smooth and enhanced), Webb proposed what he called “the modified model.” This model is presented in Gupte and Webb (1992) as one that can take into account the simultaneous occurrence of nucleate and convective boiling, and is presented as

$$h^n = (Fh_{LQ})^n + (Sh_{NB})^n, \quad (2-1)$$

where the parameters of the above equation are determined using empirical constants obtained from experimental data. Kim et al. (2002) used this model but without using the asymptotic element (the exponent n).

The previously mentioned paper presented three other models: the first model is the superposition (Chen’s model), defined as

$$h = h_{CB} + h_{NB}. \quad (2-2)$$

The second is the asymptotic model, defined as

$$h^n = h_{CB}^n + h_{NB}^n. \quad (2-3)$$

The third is the enhancement model, developed by Shah (1976), defined as

$$h = E \cdot h_{LQ}, \quad (2-4)$$

where E is the enhancement factor.

The other approach for modeling flow boiling over a tube bundle is using expanded models developed for single tube pool boiling. This approach is very useful for enhanced tubes, since enhanced tubes’ performance is dominated mainly by heat flux as studies prove. Thome

and Robinson (2006) used that approach and presented a bundle model for the Turbo BII tube bundle as

$$h = F_p \cdot F_\varepsilon \cdot h_{NB}, \quad (2-5)$$

where F_p and F_ε are function of the reduced pressure and void fraction, respectively.

2.5.1 Void fraction

Boiling over a flooded tube bundle is governed by many parameters, mass velocity, heat flux, flow pattern, static pressure, friction pressure, saturation temperature, thermodynamic quality, and void fraction, to name a few. One of the complexities of two-phase flow is how to determine the void fraction, upon which the very nature of flow depends. Void fraction helps clarify other flow parameters like phase velocity, phase density, flow pattern, and pressure drop. Thome (2004) explained the different geometries used for specifying void fraction: local, chordal, cross-sectional, and volumetric void fraction.

An accurate method to predict void fraction in vertical flow in tube bundles is presented in Feenstra et al. (2000), who developed an empirical expression that is a function of quality, velocity ratio, liquid and vapor densities, tube diameter, tube pitch, mass velocity (based on the minimum area), liquid viscosity, gas velocity, and surface tension. This model was recommended by Thome and Robinson (2006), and its equations are presented as follows:

$$\varepsilon = \frac{1}{1 + \left(S(1-x) / x \cdot \rho_G / \rho_L \right)}, \quad (2-6)$$

$$S = 1 + 25.7 (Ri \cdot Cap)^{0.5} (P/D)^{-1}, \quad (2-7)$$

$$Ri = \frac{(\rho_L - \rho_G)^2 g \cdot (P/D - 1) D}{G^2}, \quad (2-8)$$

$$Cap = \frac{x \cdot G}{\varepsilon \cdot \rho_G} \frac{\mu_L}{\sigma}. \quad (2-9)$$

2.5.2 Flow pattern of boiling on tube bundle

Although the term “flow pattern” can be quite descriptive, it actually characterizes a complicated physical phenomenon. The meaning of flow pattern includes, for example, convective movement between liquid and bubbles. Studying flow pattern requires more than a visual of the flow or bubbles; it aims for a clear understanding of variables like the interaction of

bubbles and their convection influence on tube wetting. As mentioned in the sub-section before, flow pattern is linked to void fraction. Thus, understanding flow pattern helps clarify boiling heat transfer of tube bundles. In particular, flow pattern influence becomes evident where the heat transfer coefficient has two different rates at the same heat flux, mass flux, and quality.

However, flow pattern studies of vertical flow boiling on tube bundles have been fairly limited to, for example, Casciaro and Thome (2001) Part 2, who provided a review for the two-phase pressure drop and flow pattern, and Collier and Thome (1996), who described the visual flow pattern from bottom up as single phase liquid, bubbly flow, bubble jet flow, chugging flow, and spray flow.

2.6 Conclusion

Enhanced tubes are extensively used in flooded refrigerant evaporators for their high efficiency; however, developing enhanced tubes and evaluating their performance in boiling over tube bundles has been one of the ongoing two-phase problems. Due to the complexity of experimental study of flow over a tube bundle, researchers often use pool boiling experiments to predict the behavior of enhanced tubes in tube bundles.

However, studies of enhanced tube bundles showed that there is discrepancy in the data presentation and conclusions based on a pool of information of the different aspects that can be used in evaluating the performance of enhanced tube bundles: saturation pressure, heat flux, mass flux, quality, tube arrangement, tube position, and bundle height. Most studies agreed that enhanced tubes are dominated mainly by heat flux. Mass flux and quality have little effect on the heat transfer coefficient; however, mass flux effect becomes significant at low heat flux. Moreover, some studies showed that increasing saturation pressure increases bundle performance.

Studies that documented the effect of tube pitch (tube spacing) on submerged enhanced tube bundles, showed that tight spacing provides performance enhancement. As for those with forced convection, the effect of increasing tube pitch fluctuates between enhancing performance and having no influence. In general, available bundle models are based on the in-tube superposition model introduced by Chen. Other models use a modified version of the nucleate boiling models. In all cases, experimental data must be available in order to determine the empirical constants associated with those models.

Chapter 3 Test Circuit and Equipment Description

3.1 Introduction

The test circuit was constructed to investigate the heat transfer performance for shell-side boiling of enhanced surface tube bundles. The tube bundle was set up in the test section, the main component in the test facility, which is located at the highest point of the test facility. The height of the test section was calculated to provide the required NPSH for the refrigerant pump. The NPSH was determined according to R-123 calculations, since it operates at low pressure.

Next to the test section in the refrigerant flow direction are the condenser, the refrigerant pump, and the pre-boiler as shown in Figure 3-1 below. The test section is water heated; the water circuit associated with the test section was given the name “primary test section water circuit.” In that circuit, water circulates throughout the test section and a secondary heat exchanger, the heat input to the test section.




Figure 3-1 Refrigerant circuit

Tube bundle experiments entail testing at different bundle inlet vapor qualities, which are controlled by the pre-boiler. The pre-boiler, sometimes called pre-conditioner, raises the

refrigerant thermodynamic quality from sub-cooled liquid to the desired bundle inlet quality. Similar to the test section, the pre-boiler is water heated; its water circuit is called “the primary pre-boiler water circuit.” The latter receives its heat input from a secondary heat exchanger.

The two secondary heat exchangers (the test section and the pre-boiler) are connected to the hot water reservoir, that part of the hot water system that uses the energy available from the building’s steam. Therefore, there are five different circuits in the test facility; the refrigerant circuit, the primary test section water circuit, the primary pre-boiler water circuit, the secondary test section water circuit, and the secondary pre-boiler water circuit. Each of these will be reviewed in the following sub-sections.

3.2 Test Section

The test section is a rectangular pressure vessel designed for high and low pressure refrigerants that is essentially a rectangular-shape shell and tube heat exchanger; the refrigerant flows across the tube bundle while water circulates in the tubes. Its inner dimensions are 0.4254 m (16.75 inch) high, 0.0984 m (3.875 inch) wide, and 1 m (39.37 inch) deep as shown in Figure 3-2; please refer to Appendix “A” for other test section drawings and dimensions. The idea behind a rectangular test section is to create symmetry boundaries for the two sides of the tube bundle. This makes the tube bundle look as if it is a 1 m long specimen taken from a large evaporator. The test section has four sight glasses, two on each side, where one side is a mirror image of the other. Each of the four sight glasses is an oblong quartz glass 0.3048 m (12 inch) high by 0.0762 m (3 inch) wide. This provided a full view of the tube bundle covering the refrigerant inlet up to the top of the tube bundle.




Figure 3-2 Test section inner dimensions

3.2.1 Tube pitches

The test section was designed to accommodate three tube bundles for three different tube pitches, P/D 1.167, P/D, 1.33, and P/D 1.5, which is equivalent to 3.5/3, 4/3, and 4.5/3. Each bundle has 20 tubes arranged in staggered equilateral triangles as shown in Figure 3-5 on Page 23. Each tube has an outside diameter (D) of 0.01905 m (0.75 inch), and tube pitch (P) is measured from one tube center line to the neighboring tube center line. Given the P/D ratio and the tube outside diameter, P can be calculated such that P for the above mentioned three cases are 0.0222 m (7/8 inch), 0.0254 m (1 inch), and 0.0285 m (1 1/8 inch), respectively; this represents a 0.0031 m (1/8 inch) step increase.

3.2.2 Tube bundle installation

The tube bundle installation begins by mounting two endplates, sometimes called tube-sheets, on each side of the test section, passing the copper tubes through the hole pattern of the endplates, and swaging (mechanically rolling) the copper tubes into the endplates. Tubes are sealed with steel endplates by expanding the copper tube, i.e. welding the tubes without fusing

the two metals. Each tube bundle (each P/D bundle) has its two endplates and two inside plates. The endplate holds the hole pattern and hole contours and dimensions specified for swaging the tube. The inside plates with the endplates form a box for the tube bundle. The inside plates have two purposes: to add thickness to the test section walls for maintaining the symmetry of the bundle, and to mount half dummy tubes. The half dummy tubes create symmetry for the refrigerant flow around the tubes and simulate an actual evaporator, i.e. making one side a mirror image of the other.

3.2.3 Water and refrigerant flow distribution

The test section is a four-pass heat exchanger. Water passes four times in alternating directions through the tubes before exiting the test section and flows in five channels as a result of dividing the total of 20 tubes by four passes. Therefore, each channel (path) includes four tubes. Water enters the test section from at the top of the bundle and leaves at the bottom. Refrigerant enters the test section at the bottom of the bundle and leaves at the top, i.e. counter to the flow of water.

Refrigerant enters the test section via a distributor at the bottom, which splits the inlet tube into four tubes. Each tube enters the bottom of the test section and goes through a tee where the flow is further split into two ports. Therefore, the total number of inlet ports is 8, equally spaced along the length of the test section. The ports are aimed downward, opposite to the flow direction, to reduce the flow kinetic, thus making the vapor equally distributed. In addition, four dummy tubes having the same diameter and tube pitch as the active tubes are swaged in the endplates as a part of the bundle. The dummy tubes further provide an even distribution of the two phase flow before entering the heated section of the bundle. Meanwhile, refrigerant exits the tube bundle through rollover rectangular openings on the sides of the test section. The total number of openings is six, three on each side.

3.2.4 Test section instrumentation

This subsection covers the test section's water and refrigerant instrumentation beginning with the water instruments. Since the water entering the test section is divided into five channels (paths) parallel to each other, it is sufficient to have the water measurements only on one of the five paths. This instrument path was chosen to be the middle tube of the three-tube-set at each row, and was given the name "A." The water measurements include temperature and pressure

measurements. Temperature drop is measured for each of the four tubes of path “A,” while pressure drop is measured across the first and last tubes; that also can be used for determining the total pressure drop across the four tubes. The other four paths were given the names “B”, “C”, “D”, and “E” for which inlet and outlet temperatures and flow rate were measured in each path. A gate valve is installed upstream of the flow meter of each path to control the water flow rate to and consequently match the heat flux of each path to that of path “A”.

3.2.4.1 Water instruments

Total temperature drop in path “A” is determined by measuring the temperature drop in each of the four tubes. An “insert tube” made of Stainless steel wrapped with thick helical cable is placed in the center of each enhanced tube. The insert tube carries seven thermistors, two for measuring the inlet and outlet water temperatures and five internal thermistors for determining the local heat transfer coefficient. Details about the insert tube are mentioned in the next subsection. The thermistors were manufactured in the lab by encapsulating each thermistor in a set screw as shown in Figure 3-3 below. Once manufactured, the thermistor probes were calibrated and checked before being affixed to the insert tube.



Figure 3-3 Thermistor probe (the element is inside the set screw)

3.2.4.1.1 Insert tube

The water entering the test section flows within the test tube and over the insert tube as illustrated in Figure 3-4. The insert tube has two purposes: to increase the water velocity and thus the water heat transfer coefficient, and to support the seven thermistors. The higher the water heat transfer coefficient, the better the accuracy of the calculated refrigerant heat transfer coefficient. Two of the seven thermistors, the outermost ones, measure the inlet and outlet temperatures and are located at the endplates of the test section. The advantage of this location is to decrease any inaccuracy of the temperature measurement due to ambient loss. The other five thermistors are evenly distributed along the insert tube. The insert tube is centered inside the 1.3

m (51.5 inch) long and 0.01905 m (0.75 inch) nominally wide test tube. Dimensions of the test tubes are provided in Table 3-1 below.

The insert tube is made of stainless steel, 1.828 m (72 inch) length and 0.00635 m (0.25 inch) outer diameter, helically wrapped with a 0.00381 m (0.15 inch) outer diameter insulated tinned copper wire. The wire wrapping is approximately at a 45 degree angle with a 0.0254 m (1 inch) pitch. This configuration provides a helical channel path for the water to flow inside. Meanwhile, the wire wrap is to decrease the effect of thermal and velocity boundary layer, and thereby to provide the conditions for measuring the mixed cup temperature.

Table 3-1 Enhanced tubes dimensions

	<i>Outside Dia. mm (inch)</i>	<i>Nominal Wall mm (inch)</i>	<i>Finished fin Fin/inch</i>	<i>Min. wall OD mm (inch)</i>	<i>Root Dia. under fins mm (inch)</i>
Turbo BII- HP	19.05 (0.75)	0.635 (0.025)	48	18.69 (0.736)	0.559 (0.022)
Turbo BII- LP	19.05 (0.75)	0.635 (0.025)	48	18.75 (0.738)	17.27 (0.680)

Four pressure transducers were used to measure the bundle water pressure. Two higher range transducers were installed on the first tube (at the top of the bundle) of path “A”, where the water pressure is the highest. The other two transducers were installed on the last tube (at the bottom of the bundle). The measuring range of the pressure transducers on the first and the last tubes are 0- 2068.4 kPa (0-300 PSIA) and 0-1034.2 kPa (0-150 PSIA), respectively. All pressure transducers were manufactured by Viatran.

For the other four paths, the inlet and outlet temperatures are measured using thermistor probes, 10,000 ohm 0.1524 m (6 inch) long probes. Also, the water flow rate to each path, including path “A,” is measured using Coriolis type flow meters manufactured by Micro Motion model ELITE CMF025.




Figure 3-4 Cross sectional view of test tube and insert tube

3.2.4.2 Refrigerant instruments

For the refrigerant instruments, temperature and pressure are measured at five levels (heights) in the shell: one at the bundle inlet and four located above the plane of the four instrumented tubes of path “A” as illustrated in Figure 3-5 over. Only pressure measurements were used in the analysis; temperature measurements were used only to check the agreement between the temperature and the corresponding saturation temperature determined from the pressure transducers’ measurement. The concurrence of the temperature and the saturation pressure readings indicates that the test section is free from non-condensable gases. Temperature probes and pressure transducers are connected to the half dummy tubes installed on the bundle’s inside plates. The temperature probes were 100 ohm RTDs. Each refrigerant has its own set of pressure transducers, high pressure transducers for R-134a and low pressure transducers for R-123, 0- 517.1 kPa (0-75 PSIA) and 0-103.4 kPa (0-15 PSIA), respectively. In addition to the five measurement heights, the refrigerant exit pressure is measured. All pressure transducers were manufactured by Viatran.




Figure 3-5 Test section cross sectional view

3.3 Refrigerant circuit

Next to the test section in the refrigerant flow direction is the condenser (see Figure 3-1). The two-phase flow refrigerant leaving the test section enters the condenser and goes through a 211 kW (60 Ton Refrigeration) plate heat exchanger made by FlatPlate, Inc. and supplied by a 50% water-glycol solution (or glycol for simplicity) to provide the cooling source. A 10 HP centrifugal pump draws the glycol from a reservoir, and heat is drawn from the reservoir using an 81 kW (23 Ton Refrigeration) reciprocating compressor chiller.

The refrigerant leaves the condenser as sub-cooled liquid and next goes through a strainer before entering the refrigerant pump. The refrigerant pump is a magnetically driven gear pump manufactured by Liquiflo with a capacity of 1.3 L/s (21 GPM) and delivers up to 1551.3 kPa (225 PSI) maximum pressure. A storage tank is installed parallel to the line connecting the condenser and the refrigerant pump to adjust the refrigerant charge to the desired test point. The

test facility runs as a “critically charged system,” meaning for every data point, the refrigerant charge is adjusted. The storage tank contains cooling and heating coils such that the cooling coil is connected to the facility’s glycol supply, and the heating coil is connected to industrial water. The storage tank is linked to the test facility at three points: top, middle and bottom.

A filter dryer is located upstream of the refrigerant pump while the refrigerant flow meter, a Coriolis type flow meter manufactured by Micro Motion model ELITE CMF050, is located downstream of the filter dryer. The sub-cooled liquid refrigerant leaving the flow meter enters the pre-boiler, which adds heat to the refrigerant to raise its quality from sub-cooled to the desired test section inlet quality. The pre-boiler is a water heated shell and tube heat exchanger, with the refrigerant circulating in the tubes and the water circulating in the shell. The two-phase flow leaves the pre-boiler and enters the test section through the test section’s flow distributor explained in “Test Section” above. A control valve, a butterfly valve, is located between the test section and pre-boiler whose is to help adjust the refrigerant flow supply to the test section to bring the system to steady state. Steady state is reached when the change in the inlet saturation pressure is within 0.3 °C.

The last component of the refrigerant circuit is the purge unit. For R-123 testing, and before taking data points, the system must be free of non-condensable gases. This is accomplished through the purge unit, an EarthWise Purge made by Trane. It is installed above the test section level and connected to the top of the test section. When the unit is on, refrigerant vapor and non-condensable gases travel from the test section to the purge tank. The purge tank condenses the refrigerant and returns it to the system whereupon the non-condensable gases are purged to a carbon regeneration tank.

3.3.1 Refrigerant circuit instrumentation

Instruments in the refrigerant circuit include those used to monitor the operation of the test facility and to analyze data. The monitoring instruments include the following: the condenser inlet temperature and refrigerant pump inlet pressure and temperature. The temperature of the two-phase flow entering the condenser is measured, using a 1000 ohm RTD. Also, a sight glass is mounted on the line leading to the refrigerant pump, and a second sight glass is mounted on the line leaving the pre-boiler and entering the test section.

The data analysis instruments include refrigerant flow rate, pre-boiler inlet pressure and temperature, and pre-boiler outlet pressure and temperature. Refrigerant temperature entering and leaving the pre-boiler are measured using a 30,000 ohm thermistor probe and 1000 ohm, RTD, respectively. Refrigerant pressure entering and leaving the pre-boiler is measured using pressure transducers with the same measuring range and brand name as those used in the test section. Pressure transducers are switched according to each refrigerant.

3.4 Water circuits

3.4.1 Test section primary water circuit

The test facility has four water circuits, two primary circuits and two secondary circuits; one each for the test section and the other for the pre-boiler. For the test section primary water circuit, a 14.9 kW (20 HP) water pump (centrifugal pump) pumps water to the top of the test section. Water passes four times through the tube bundle and exits at the bottom. Initially, water is split into five channels (paths) before entering the test section, and when it exits the test section, it passes through five water flow meters. Downstream of the flow meters, the five paths merge and enter the filter tank, a high flow rate water filter with stainless steel housing. Water exits the filter and enters the test section secondary heat exchanger. The latter is a shell and tube heat exchanger; the primary water (heated water) circulates in the tubes and the secondary water (heating water) circulates in the shell. Heated water exits the heat exchanger to the pump inlet. A riser is connected to the pump suction pipe between the secondary heat exchanger and the pump. The riser provides the required NPSH for the pump and a filling port for the circuit. The height of the riser extends higher than the test section to ensure that the circuit is air free. In addition, an air release valve is installed on the pump delivery pipe before entering the test section.

3.4.2 Pre-boiler primary water circuit

The pre-boiler is a shell and tube heat exchanger; the refrigerant circulates in the tubes (two passes), and the heating water circulates in the shell. The components of the primary pre-boiler water circuit are similar to those of the test section: water pump, flow meter, filters, and secondary heat exchanger. The water pump is a 2.2 kW (3 HP) centrifugal pump and the flow meter is made by Micro Motion model ELITE CMF100. The secondary heat exchanger is the heat source of the circuit. Specifically, heating water flows in the tubes of the secondary heat

exchanger while heated water flows in the shell. The system schematic and flow direction is illustrated in Figure 3-6.




Figure 3-6 Pre-boiler circuit

3.4.3 Test section and pre-boiler secondary circuit

The two secondary circuits are linked to the hot water reservoir, where two pumps, one for each heat exchanger, circulate the hot water between the reservoir and the secondary heat exchangers. A gate valve is installed downstream of each pump, 2.23 kW (3 HP) centrifugal pump, to control the water flow rate, hence the heat load. Therefore, each secondary circuit is independently controlled to provide the specified heat load to each primary water circuit. Meanwhile, the hot water reservoir provides the heat load to both circuits; its capacity is 0.4504 m³ (120 Gallons). Figure 3-7 over shows a schematic for the hot water system and the secondary circuits.

3.4.4 Hot water circuit

The hot water system, from a previous ASHRAE project (RP-984), uses the energy available from the building steam. First, steam pressure is regulated down to 170.2 kPaG (10 PSIG) and then steam leaves the pressure regulator and goes to a pneumatically controlled ball valve with a PID temperature controller. The controller uses a thermocouple for measuring the water temperature; the thermocouple is located at the pump delivery and upstream of the steam heat exchanger. When steam enters the tube side of a shell and tube heat exchanger, Water circulates in the shell side where it picks up the heat and delivers it to the hot water reservoir.

Next, the stream condensate leaving the heat exchanger is handled by a condensate tank. Since the steam condensate is under vacuum, it can't be connected directly to the building condensate. The condensate pump then pumps the steam condensate accumulated in the tank to the building condensate line.




Figure 3-7 Hot water system and secondary circuits

3.4.5 Water circuits instrumentation

The instrumentation of the primary test section water circuit was explained in Section 3.2.4.1. However, the pre-boiler primary water circuit requires measuring the inlet and outlet temperature of the pre-boiler and the water flow rate. Therefore, temperature was measured using thermistors, 30,000 ohm 0.3048 m (12 inch) probes. Also, water flow rate was measured using a Micro Motion model ELITE CMF100 flow meter. The pre-boiler instrumentation is necessary for energy balance to determine the thermodynamic quality entering the test section. Meanwhile, the secondary circuits don't carry any instruments. Finally, for the hot water reservoir, the temperature of the water entering the steam heat exchanger was measured using a type K thermocouple, which is linked in the PID controller to control the water temperature.

3.5 Data acquisition

The data acquisition switch unit used is an Agilent 34980A whose accuracy has been adjusted to 6½ digits. The unit is connected to a PC via USB and controlled by Labview 8.5 made by National Instruments. The total number of instruments is 69 and they read resistance,

voltage, and frequency. When the system reaches steady state, the software starts recording data every 25 seconds over a 25 minute period. Recorded data is saved in a Microsoft Excel (.csv) sheet.

3.6 Conclusion

This chapter presented the details of the test facility and test section. It also presented the facility's equipments and instrumentations. The test section was designed to accommodate three tube pitches: P/D 1.167, P/D 1.33, and P/D 1.5. Each bundle has 20 tubes arranged in staggered equilateral triangles, and all tubes were mechanically swaged into the endplates. The test section was designed as a four pass heat exchanger. Tubes were divided into five paths, each containing four tubes. The four middle tubes were chosen to be the "instrumented path." Water temperature drop was measured in each tube using an insert tube, which carried seven thermistors. The refrigerant pressure and temperature were measured at each height of the test section and above the plane of each instrumented tube.

Inlet quality to the test section was controlled via the pre-boiler, which, like the test section, used secondary water circuits to deliver heat from the hot water reservoir. Each secondary circuit was independently controlled to provide the specified heat load to each primary water circuit. The hot water reservoir used the energy available from the building steam.

Chapter 4 Data Reduction

4.1 Introduction

Tube bundle heat transfer performance is evaluated over a range of heat fluxes, mass fluxes, and other qualities. Notably, the heat transfer coefficients reported in this study are local to one location in the bundle. Moreover, the local heat transfer coefficient is determined by first measuring the water temperature distribution, hence the need for multiple measurement locations. Additionally, water temperature is measured at five locations in each of the four tubes of the instrumented water path, supported by a second degree polynomial aid to produce the curve fit $T = f(x)$. Once the temperature distribution is determined, the local heat flux can be calculated, and the local heat transfer coefficient can be determined using thermal resistance and local heat flux.

Although the main focus of the data analysis is the local analysis, the average analysis (per tube) is necessary as well for determining the average heat transfer coefficient and the overall heat transfer coefficient. Furthermore, the uncertainty analysis for the local heat transfer coefficient requires the overall heat transfer coefficient of each tube which is determined using a new method called the EBHT (Enthalpy Based Heat Transfer) analysis, explained in a later subsection.

The water heat transfer coefficient had to be measured using the modified Wilson plot technique before determining the refrigerant heat transfer coefficient. This method is applied in the single tube pool boiling study part of the research, which was performed in a separate test facility; details are available in Gorgy (2008).

4.2 Finite heat transfer governing equations

A finite heat transfer analysis determines the local heat transfer coefficient. In Figure 4-1 on Page 31, heat is transferred from the water to the cylinder's inner wall by convection, from the inner wall to its outer wall by conduction, and from the outer wall to the refrigerant by convection. Consequently, applying conservation of energy and the 1-D heat transfer equations on the finite control, assuming no fouling resistance, yields

$$h_w dA_i (T_{hot} - T_{wall,in}) = \frac{2\pi k_c dx}{\ln\left(\frac{D_o}{D_i}\right)} (T_{wall,in} - T_{wall,out}) \equiv dQ \quad (4-1)$$

and

$$h_r dA_o (T_{wall,out} - T_{cold}) = \frac{2\pi k_c dx}{\ln\left(\frac{D_o}{D_i}\right)} (T_{wall,in} - T_{wall,out}) \equiv dQ \quad (4-2)$$

where

$$dA_i = \pi D_i dx, \quad (4-3)$$

and

$$dA_o = \pi D_o dx. \quad (4-4)$$

Applying Newton's law of cooling yields

$$dQ = U \cdot dA_o (T_{hot} - T_{cold}). \quad (4-5)$$

Defining the thermal resistance of the tube wall as

$$R_{wall} = \frac{1}{2\pi dx k_c} \ln\left(\frac{D_o}{D_i}\right). \quad (4-6)$$

Using Equations (4-1), (4-2), (4-5), and (4-6), yields the following thermal resistances model

$$\frac{1}{U dA_o} = \frac{1}{h_w dA_i} + \frac{1}{2\pi dx k_c} \ln\left(\frac{D_o}{D_i}\right) + \frac{1}{h_r dA_o}. \quad (4-7)$$

Substituting Equations (4-3) and (4-4) yields

$$\frac{1}{U} = \frac{1}{h_w} \frac{D_o}{D_i} + R'_{wall} + \frac{1}{h_r}. \quad (4-8)$$

Solving for the heat transfer coefficient h_r in the above equation yields

$$h_r = \left(\frac{1}{U} - R'_{wall} - \frac{1}{h_w} \frac{D_o}{D_i} \right)^{-1}. \quad (4-9)$$




Figure 4-1 Thermal resistances illustration

4.3 Local heat transfer coefficient

Notably, Equation (4-9) is length independent. Therefore, all the variables of Equation (4-9) can be used in the local or average analysis. To determine the local heat transfer coefficient, Equation (4-9) is modified to

$$h_{local} = \left(\frac{1}{U_{local}} - R'_{wall} - \frac{1}{h_w} \frac{D_o}{D_i} \right)^{-1}, \quad (4-10)$$

where U_{local} is the local overall heat transfer coefficient. Following the definition of Newton's law of cooling yields

$$U_{local} = \frac{q''_{local}}{T_{local} - T_{\infty}}. \quad (4-11)$$

Substituting in Equation (4-10) above yields

$$h_{local} = \left(\frac{T_{local} - T_{\infty}}{q''_{local}} - R'_{wall} - \frac{1}{h_w} \frac{D_o}{D_i} \right)^{-1}. \quad (4-12)$$

As stated in Equation(4-12), the local heat transfer coefficient is determined at each local temperature measurement.

4.4 Local heat flux

In Equation (4-12) above, the local temperature T_{local} and refrigerant temperature T_{∞} are obtained by direct measurements while the local heat flux q''_{local} is determined by the enthalpy change on the finite element as

$$dQ = \dot{m} \cdot di . \quad (4-13)$$

For incompressible fluid, the finite enthalpy di can be expressed as

$$di = C_p \cdot dT + v \cdot dP . \quad (4-14)$$

Substituting in Equation (4-13) above and dividing by $\pi \cdot D_o \cdot dx$ yields

$$\underbrace{\frac{dQ}{\pi dx D_o}}_{q''_{local}} = \frac{\dot{m}}{\pi D_o} \left(C_p \frac{dT}{dx} + v \frac{dP}{dx} \right) . \quad (4-15)$$

The LHS of the above equation represents the definition of the local heat flux. For the temperature slope, the five temperature measurement locations of each tube determine the temperature profile equation, which is determined using a second order polynomial curve fit as

$$T = C_1 x^2 + C_2 x + C_3 , \quad (4-16)$$

and the slope is found by taking the derivative

$$\frac{dT}{dx} = 2C_1 x + C_2 . \quad (4-17)$$

The pressure drop term of Equation (4-15) can be determined by assuming a linear water pressure drop across the tube since the pressure can be determined at the inlet and outlet of each tube. Therefore, dP/dx is reduced to $\Delta P/L$. The last necessary component in Equation (4-12) is the water heat transfer coefficient, which is determined using the modified Wilson plot method.

4.5 Water heat transfer coefficient

The water flows between the enhanced tube and the insert tube following the swirl shape of the insert tube as illustrated in Figure 3-4 on Page 22. For flow inside a tube, the heat transfer coefficient for no phase change can be determined using

$$h_i = \frac{Nu_D \cdot k_w}{D_h}, \quad (4-18)$$

where all the water properties are evaluated at the average inlet and outlet temperatures.

For a turbulent internal flow, the Nusselt number can be determined using Gnielinski's correlation (1976) presented as

$$Nu_D = \frac{(f/8)(Re_D - 1000)Pr}{1 + 12.7(f/8)^{1/2}(Pr^{2/3} - 1)}. \quad (4-19)$$

The above correlation, also called the modified Petukhove's correlation (1970), is widely applied in flow inside tubes; Gnielinski's correlation works over a wide range of Reynolds numbers (3000 to 5×10^6) and Prandtl numbers (0.5 to 2000) with accurate results, the friction factor is defined as

$$f = (0.79 \ln(Re_D) - 1.64)^{-2}. \quad (4-20)$$

The friction factor proposed by Gnielinski in the above equation is that of a smooth tube. Since the tubes used are internally enhanced, the friction factor is calculated according to its basic definition as

$$f = \frac{\Delta P}{\rho} \cdot \frac{D_h}{L_c} \cdot \frac{2}{V^2}. \quad (4-21)$$

The internal enhancement of the tubes (micro-fins) and the insert tube's swirls affect accuracy in measuring both the characteristic length and the hydraulic diameter of the above equation (calculation of the hydraulic diameter is explained in 3.2.4.1.1). Therefore, the Gnielinski correlation needs a correction factor multiplier, which is determined using the modified Wilson plot technique. Accordingly, the correction factor becomes the leading coefficient of the water heat transfer coefficient as

$$h_w = C_i \cdot h_i. \quad (4-22)$$

4.5.1 The modified Wilson plot technique

The modified Wilson plot technique introduced by Briggs and Young (1969) is for obtaining heat transfer correlations for shell and tube heat exchangers. This technique was applied in the pool boiling part of the research, which requires choosing a model for the boiling

heat transfer coefficient is chosen. Literature shows that for enhanced tubes, the refrigerant heat transfer coefficient is assumed to be a function only of the heat flux and can be expressed as

$$h_r = C_o (q'')^n. \quad (4-23)$$

Recalling the thermal resistance equation

$$\frac{1}{UA_o} = \frac{1}{h_w A_i} + R_{wall} + \frac{1}{h_r A_o}. \quad (4-24)$$

After substituting Equations (4-22) and (4-23), and multiplying both sides of the equation by $h_i \cdot A_i$, the thermal resistance equation is transformed into the straight line equation

$$\underbrace{\left(\frac{h_i A_i}{U_o A_o} - R_{wall} h_i A_i \right)}_Y = \frac{1}{C_i} + \underbrace{\frac{1}{C_o} \left(\frac{h_i A_i}{(q'')^n A_o} \right)}_{Y_{predicted}}. \quad (4-25)$$

Data points are collected at different flow rates on either side of the heat exchanger to determine the above straight line equation, while the linear regression of the data points determines the slope and intercept. Meanwhile, the inverse of the intercept is the correction factor for the tube side heat transfer coefficient and the inverse of the slope is the correction factor for the shell side heat transfer coefficient. Six data points are taken at different water flow rates covering the full range of Reynolds numbers of the test facility; the selected number of points gives the narrowest confidence interval of the linear regression.

The exponent n must be assumed first to perform the linear regression between Y and X in the above straight line equation (Equation (4-25)). Through trial and error, n is iterated to produce the minimum sum of the absolute percentage difference between Y and $Y_{predicted}$. To decrease the effect of the chosen boiling model, the points are taken at one selected value of heat flux with a maximum change of 8% between any of the six points.

4.6 Total heat transfer governing equations

Defining a tube as the control volume and applying the 1st law of thermodynamics yields

$$\frac{dE_{st}}{dt} = \dot{E}_{in} + \dot{E}_{gen} - \dot{E}_{out}. \quad (4-26)$$

Since the problem is steady state with no energy generation, the above equation reduces to

$$\dot{E}_{in} = \dot{E}_{out}. \quad (4-27)$$

The energies entering the tube are the inlet water enthalpy and the refrigerant inlet enthalpy; meanwhile, the energies leaving the test section are the outlet water enthalpy and the refrigerant outlet enthalpy. Thus, the above SS equation can be rewritten as

$$\dot{m} \cdot i_{w,in} + \dot{m}_r \cdot i_{r,in} = \dot{m}_r \cdot i_{r,out} + \dot{m} \cdot i_{w,out} . \quad (4-28)$$

Rearranging yields,

$$\dot{m} \cdot i_{w,in} - \dot{m} \cdot i_{w,out} = \dot{m}_r \cdot i_{r,out} - \dot{m}_r \cdot i_{r,in} \equiv Q . \quad (4-29)$$

Assuming incompressible flow for the water side yields

$$Q = \dot{m} \left(C_p (T_{in} - T_{out}) + v \underbrace{(P_{in} - P_{out})}_{\Delta P} \right) . \quad (4-30)$$

Thus Equation (4-30) determines the average heat transfer coefficient, specially the average overall heat transfer coefficient.

4.7 The tube-average heat transfer coefficient

Determining the average heat transfer coefficient requires the thermal resistances equation obtained from “4.2”

$$\frac{1}{U} = \frac{1}{h_w} \frac{D_o}{D_i} + R'_{wall} + \frac{1}{h_r} . \quad (4-31)$$

Substituting U_o for U and rearranging yields

$$h_{avg} = \left(\frac{1}{U_o} - R'_{wall} - \frac{1}{h_w} \frac{D_o}{D_i} \right)^{-1} . \quad (4-32)$$

Meanwhile the overall heat transfer coefficient is determined according to a new method, the EBHT (Enthalpy Based Heat Transfer), where the pressure drop energy is taken into account.

4.7.1 The enthalpy-based heat transfer analysis (EBHT).

Classically, the overall heat transfer coefficient of the heat exchanger is determined using the Log Mean Temperature Difference “LMTD” method as

$$Q = U_o A_o \Delta T_{LMTD} . \quad (4-33)$$

Where ΔT_{LMTD} is defined as $(\Delta T_1 - \Delta T_2) / \ln(\Delta T_1 / \Delta T_2)$. Therefore, to determine the overall heat transfer coefficient, equations Equation (4-30), with the pressure term equal to zero, and Equation (4-33) are solved simultaneously.

The derivation of the LMTD method starts by defining the change of the water enthalpy as the product of the temperature difference and the fluid specific heat. Essentially, this is a simplified definition of the enthalpy, where the effect of the change in pressure is neglected. This simplification is usually useful since it leads to solving the overall heat transfer coefficient with simple algebraic equations. This is because the majority of the shell and tube heat exchangers do not experience large change of the water enthalpy due to pressure drop. In other words, the temperature difference term is much higher than the pressure drop term.

However, in the current study, the water flow inside the test tube experiences a large pressure drop which makes a significant change in the water enthalpy. Therefore, the study must consider the pressure drop energy in the calculation of the overall heat transfer coefficient and also in the energy equation (Equation (4-30)).

A new method called the Enthalpy Based Heat Transfer was derived from first principles for calculating the overall heat transfer coefficient in terms of the heat exchanger temperatures and pressures. This derivation follows that of the LMTD method. The EBHT works for parallel flow, counter flow heat exchangers, no phase change and phase change problems. For solving the phase change problem, the specific heat of the cold side is set equal to infinity in the case of boiling and the specific heat of the hot side is set equal to infinity in the case of condensation.

4.7.2 The governing equations of the enthalpy-based heat transfer analysis

Hot side energy balance assuming incompressible flow is expressed as

$$dQ = -\dot{m}_h (C_{p,h} \cdot dT_h + v_h \cdot dP_h). \quad (4-34)$$

Rearranging yields

$$dT_h = -\frac{1}{C_{p,h}} \left(\frac{dQ}{\dot{m}_h} + v_h \cdot dP_h \right). \quad (4-35)$$

For the cold side energy balance assuming incompressible flow

$$dQ = \dot{m}_c (C_{p,c} \cdot dT_c + v_c \cdot dP_c). \quad (4-36)$$

Rearranging yields

$$dT_c = \frac{1}{C_{p,c}} \left(\frac{dQ}{\dot{m}_c} - v_c \cdot dP_c \right). \quad (4-37)$$

An extended form of Newton's law of cooling can be expressed as

$$dQ = U \cdot dA \cdot \Delta T, \quad (4-38)$$

where,

$$\Delta T \equiv T_h - T_c. \quad (4-39)$$

Combining the above equations yields

$$\frac{d(\Delta T(x))}{dx} + \left(\frac{1}{\dot{m}_h \cdot C_{p,h}} + \frac{1}{\dot{m}_c \cdot C_{p,c}} \right) \cdot U \cdot \frac{d}{dx} A(x) \cdot (\Delta T) = \frac{v_c}{C_{p,c}} \cdot \frac{d}{dx} P_c(x) - \frac{v_h}{C_{p,h}} \cdot \frac{d}{dx} P_h(x). \quad (4-40)$$

The solution to the above 1st order ODE can be expressed as

$$\Delta T(x) = e^{-\left(\frac{1}{\dot{m}_h \cdot C_{p,h}} + \frac{1}{\dot{m}_c \cdot C_{p,c}} \right) U \cdot A(x)} \int \left(\frac{v_c}{C_{p,c}} \cdot \frac{d}{dx} P_c(x) - \frac{v_h}{C_{p,h}} \cdot \frac{d}{dx} P_h(x) \right) \cdot e^{\left(\frac{1}{\dot{m}_h \cdot C_{p,h}} + \frac{1}{\dot{m}_c \cdot C_{p,c}} \right) U \cdot A(x)} dx + C \cdot e^{-\left(\frac{1}{\dot{m}_h \cdot C_{p,h}} + \frac{1}{\dot{m}_c \cdot C_{p,c}} \right) U \cdot A(x)} \quad (4-41)$$

The constant C in the above equation is determined using the inlet boundary condition $\Delta T(x) = \Delta T_1|_{x=0}$. For the case of pool boiling, the specific heat of the cold side is set equal to infinity. Also, the pressure drop of the water side is assumed to be linear along the test section. The area is defined as

$$A(x) = \pi D_o x \quad (4-42)$$

Substituting the inlet boundary condition, the area definition, and the linear pressure drop assumption, Equation (4-41) reduces to the following equation, which gives the temperature difference between the water side and the refrigerant side at any distance x

$$\Delta T(x) = \frac{-(\dot{m}_h \cdot v_h \cdot \Delta p_h)}{U \cdot A} + \left(\frac{\Delta T_1 \cdot U \cdot A + (\dot{m}_h \cdot v_h \cdot \Delta p_h)}{U \cdot A} \right) \cdot e^{-\left(\frac{U \cdot \pi \cdot D_o}{\dot{m}_h \cdot C_{p,h}} \right) x}. \quad (4-43)$$

Substituting the outlet boundary condition $\Delta T(x) = \Delta T_2|_{x=L}$ in Equation (4-43) and rearranging yields

$$\ln \left(\frac{\Delta T_2 + \frac{(\dot{m}_h \cdot v_h \cdot \Delta p_h)}{U_o \cdot A}}{\Delta T_1 + \frac{(\dot{m}_h \cdot v_h \cdot \Delta p_h)}{U_o \cdot A}} \right) + \frac{U_o \cdot A}{\dot{m}_h \cdot C_{p,h}} = 0. \quad (4-44)$$

The only unknown in the above Equation is the overall heat transfer coefficient, which is determined by trial and error. Note that Equation (4-44) reduces to the LMTD as Δp_h goes to zero.

4.8 Local quality

Similar to the local heat transfer coefficient, the local quality is determined at each temperature measurement location (thermistor) and at the minimum flow area between the tubes. The thermodynamic quality is determined by performing an energy balance between the refrigerant side and the water side as

$$\dot{m}_{ref} \cdot \Delta x \cdot h_{fg} = q''_{local} \cdot \pi DL. \quad (4-45)$$

To calculate the quality entering the instrumented tube, the test section's 1 m side is theoretically divided into four horizontal planes and five vertical sections, producing 20 control volumes as shown in Figure 4-2 over. The test section then becomes a (4×5) matrix. Above each plane (row) lies a group of five tubes; the vertical sections (columns) divide the test section so that the thermistors are centered in each vertical section. Therefore, applying the energy balance on each control volume yields

$$\frac{\dot{m}_{ref}}{5} \cdot \underbrace{\Delta x}_{(x_{i+1,j} - x_{i,j})} \cdot h_{fg} = 5q''_{local_{i,j}} \pi D \frac{L}{5}, \quad (4-46)$$

or

$$x_{i+1,j} = \frac{5q''_{local_{i,j}} \cdot \pi DL}{\dot{m}_{ref} \cdot h_{fg}} + x_{i,j}. \quad (4-47)$$

Since the quality at the bundle bottom is constant at all five locations and equals the test section inlet quality, the quality at each row is determined from the bottom up. The subscript i, j in the above equation corresponds to (row,column); with the quality at row i and the local heat flux $q''_{local_{i,j}}$, the quality at the next row $i + 1$ is determined.

The local quality (the quality at the minimum cross-sectional area) is calculated by adding the quality entering the instrumented tube to the quality rise due to the local heat flux at the tube centerline. The latter quality is determined by performing an energy balance around the instrumented tube (i.e. within each of the 20 control volumes) as shown in Figure 4-3 over. Therefore, the refrigerant mass flow rate used in the energy balance is the mass flow assigned for each control volume divided by three, and the local heat flux is half of the heat flux determined at that location. Thus, the energy balance can be expressed as

$$\frac{\dot{m}_{ref}/5}{3} \cdot \underbrace{\Delta x}_{(x_{local,i,j} - x_{i,j})} \cdot h_{fg} = \frac{q''_{local}}{2} \cdot \pi D \frac{L}{5}, \quad (4-48)$$

or

$$x_{local,i,j} = \frac{q''_{local}/2 \cdot \pi DL}{\dot{m}_{ref}/3 \cdot h_{fg}} + x_{i,j}. \quad (4-49)$$

According to this method, there are 20 tube-entrance qualities and 20 local qualities.




Figure 4-2 Test section side view for quality calculations




Figure 4-3 Test section cross section for quality calculation

4.9 Mass flux

The mass flux (also called mass velocity) is calculated based on the minimum area between tubes as

$$G = \dot{m} / A_{\min} , \quad (4-50)$$

where

$$A_{\min, P/D} = ((P/D) \times D - D)(L_T) \text{ m}^2 . \quad (4-51)$$

Then, the minimum area for each tube bundle, P/D 1.167, P/D 1.33, and P/D 1.5 is calculated as follows

$$\begin{aligned} A_{\min, P/D \ 1.167} &= ((1.167) \times 0.01905 - 0.01905)(1) \text{ m}^2 \\ &= 3.18135 \times 10^{-3} \text{ m}^2 \\ A_{\min, P/D \ 1.33} &= 6.2865 \times 10^{-3} \text{ m}^2 \\ A_{\min, P/D \ 1.5} &= 9.525 \times 10^{-3} \text{ m}^2 \end{aligned} \quad (4-52)$$

4.10 Uncertainty analysis

The uncertainty analysis is performed for the average and the local refrigerant heat transfer coefficients using the Kline-McClintock (1953) second order law using MathCAD for the uncertainty analysis and simulation (an example sheet is provided in Appendix C). To determine the final uncertainty in the heat transfer coefficient first required defining the input variables uncertainty.

4.10.1 Input variables

The input variables can be the measured variables (temperature, pressure, and flow rate) or the calculated variables such as saturation temperatures, water heat transfer coefficient, and so forth. The flow rate uncertainty is determined from the flow meter's uncertainty listed by the manufacturer, which is $\pm 0.1\%$ of reading. In the following subsections, the uncertainty of the measured and calculated variables is discussed in detail.

4.10.1.1 Temperature uncertainty

The device to measure the temperature is the thermistor (high resistance element) which is well-known for its accuracy, stability, and fast response. The sources of uncertainty are the constant temperature bath used for calibration, the data acquisition system, and the calibration curve fit $T = f(R)$. First, the accuracy of the constant temperature bath u_{CTB} is 0.01°C while the average slope (for all 10,000 ohm thermistors) of the curve fit is $\frac{dT}{dR} \sim -2.284 \times 10^{-3} \frac{^\circ\text{C}}{\Omega}$. Next, the accuracy of the data acquisition system, including measurement error, switching error, and transducer conversion error u_{RM} is calculated as $(0.008\% \cdot \text{Reading} + 0.001\% \cdot \text{Range})$ while the reading is $10\text{ k}\Omega$ and the range is $100\text{ k}\Omega$. Then, the accuracy of the curve fit is calculated as $(t\text{-stat} \times \text{the standard error})$ and the uncertainty of the curve fit u_{TCF} is $1.28348 \times 10^{-6}^\circ\text{C}$. Finally, the overall uncertainty is calculated using propagation of error as

$$u_T = \sqrt{\left(u_{CTB}^2 + \left(\frac{dT}{dR} \cdot u_{RM} \right)^2 + u_{TCF}^2 \right)} = \pm 0.015^\circ\text{C}. \quad (4-53)$$

4.10.1.2 Saturation temperature uncertainty for R-134a

The sources of uncertainty for the pressure transducers are the data acquisition system and the calibration curve fit equation $P = f(V)$. First, the accuracy of the data acquisition system, including measurement error, switching error, and transducer conversion error u_{VM} is calculated according to $(0.002\% \cdot \text{Reading} + 0.0005\% \cdot \text{Range})$. The reading is 5 VDC , and the range is 10 VDC . Second, the slope of the calibration curve fit is $\frac{dP}{dV} \sim 103.455 \frac{\text{VDC}}{\text{kPa}}$. The

uncertainty of the curve fit u_{PCF} is 0.0806 kPa (t-stat \times the standard error). Then, the overall uncertainty is calculated using propagation of error as

$$u_p = \sqrt{\left(\frac{dP}{dV} \cdot u_{VM}\right)^2 + u_{PCF}^2} = \pm 0.08 \text{ kPa} . \quad (4-54)$$

The uncertainty given by the manufacturer, $u_{P,R134a}$, is 0.05% of the range 0-75 PSIA (0-517.106 kPa), which is ± 0.25 kPa. Since, this uncertainty is higher than that calculated above, for more careful uncertainty calculations, the manufacturer's uncertainty is used. Finally, the saturation temperature change between 3 and 6 °C corresponding to 0.25 kPa increments is 0.022°C. Therefore, R-134a saturation temperature uncertainty is

$$u_{Tsat,R134a} = \pm 0.022 \text{ } ^\circ\text{C} . \quad (4-55)$$

4.10.1.3 Saturation temperature uncertainty for R-123

As for R-134a, the uncertainty listed by the manufacturer is used. The manufacturer's uncertainty, $u_{P,R123}$, is 0.05% of the range 0-15 PSIA (0-103.421 kPa), which is ± 0.05 kPa. The maximum saturation temperature change over the range 3 to 6 °C, and 13 to 16 °C, corresponding to 0.05 kPa increments, is 0.03°C. Therefore, R-123 saturation temperature uncertainty is

$$u_{Tsat,R123} = \pm 0.03 \text{ } ^\circ\text{C} . \quad (4-56)$$

4.10.1.4 Water properties

Water properties were called in Excel from RefProp 8.0 without using curve fit equations. Therefore, the water properties uncertainty is considered negligible.

4.10.1.5 Water pressure uncertainty

The water pressure uncertainty used in the analysis is the uncertainty listed by the manufacturer, which is 0.05% full range. The two different range pressure transducers, 0-300 PSIA (0-2068.427 kPa) and 0-150 PSIA (0-1034.213 kPa) have the uncertainty of ± 1.0342 kPa and ± 0.5171 kPa, respectively.

4.10.1.6 Water heat transfer coefficient uncertainty

The water heat transfer coefficient is a function of the water flow rate, water properties and the correction factor obtained from the Wilson plot technique. The correction factor is the dominant uncertainty of the water heat transfer coefficient and it is assumed to be the 95% confidence interval of the slope of the linear curve fit of the Wilson plot data. This confidence interval of the correction factor for R-134a on a Turbo BII-HP tube equals that of R-123 on Turbo BII-LP tube equal to 4 %

$$u_{h_w,HP} = u_{h_w,LP} = 0.04 \cdot h_w . \quad (4-57)$$

4.10.2 Average refrigerant heat transfer coefficient uncertainty

For the average heat transfer coefficient, based on the input variables discussed above, the final uncertainty can be determined by applying the propagation of uncertainties to the following equation

$$h_{avg} \approx \left(\frac{\frac{\Delta T_1 - \Delta T_2}{\ln(\Delta T_1 / \Delta T_2)} A_o}{\dot{m} (C_p (T_{in} - T_{out}) + v (P_{in} - P_{out}))} - R'_{wall} - \frac{1}{h_w} \frac{D_o}{D_i} \right)^{-1} . \quad (4-58)$$

Due to the difficulty of solving for the overall heat transfer coefficient using the EBHT (trial and error method), the overall heat transfer coefficient term in the above equation is replaced by the total heat transfer (Equation(4-30)) divided by the LMTD. This does not significantly change the estimated uncertainty in the average heat transfer coefficient.

$$u_{h_{avg}} = \sqrt{\left(\frac{\partial h_{avg}}{\partial \Delta T_1} \cdot u_{\Delta T_1} \right)^2 + \left(\frac{\partial h_{avg}}{\partial \Delta T_2} \cdot u_{\Delta T_2} \right)^2 + \left(\frac{\partial h_{avg}}{\partial \dot{m}} \cdot u_{\dot{m}} \right)^2 + \left(\frac{\partial h_{avg}}{\partial C_p} \cdot u_{C_p} \right)^2 + \dots} \quad (4-59)$$

Uncertainties are calculated for each data point and are error bars on the results plots. The percentage uncertainty ranges from 1.5% (high heat flux) to 45% (low heat flux).

4.10.3 Local refrigerant heat transfer coefficient uncertainty

Similar to the average heat transfer coefficient, the local heat transfer coefficient is determined by applying propagation of error on Equation (4-60) over. The uncertainty in all the variables in the previously mentioned equation is given above, except the local temperature T_{local} and the temperature slope dT/dx . The uncertainty of the local temperature is the same as the

temperature uncertainty (note: the uncertainty of the temperature slope is discussed in the next subsection)

$$h_i = \left(\frac{T_{local} - T_{sat}}{\dot{m} / \pi D_o (C_p |dT/dx| + v \Delta P/L)} - R'_{wall} - \frac{1}{h_w} \frac{D_o}{D_i} \right)^{-1}. \quad (4-60)$$

4.10.3.1 Uncertainty of the local temperature slope

The uncertainty in the temperature derivative (temperature slope) is difficult to determine using the propagation of error method for the other inputs. Therefore, a Monte Carlo type simulation is conducted to determine the temperature slope uncertainty. The overall description of this method is as follows. Using the inlet and outlet temperature measurements enables the prediction of the average heat transfer coefficient and using the inlet temperature and the predicted heat transfer coefficient, the temperature drop curve $T_{theor}(x)$ is determined. The temperature measurement uncertainty is added to each $T_{theor}(x)$ location according to a normal distribution of the uncertainty. A second order polynomial is then added to the “error imposed” points. The final uncertainty is then the percentage difference between the actual slope and the slope of the curve fit generated from the “error imposed” points.

Recalling that the insert tube measures seven temperature locations, each test point returns a temperature matrix (one by seven), and a curve fit equation is generated (Equation(4-62)). Substituting the inlet temperature and the overall heat transfer coefficient in Equation (4-61) below gives five theoretical values of the five internal local positions (even though those local temperatures are already measured). Consequently, each test point returns a theoretical one by seven matrix. The theoretical temperatures are calculated as

$$T_{theor}(x) = \frac{-\dot{m}_h v_h \Delta P_h}{UA} + \left(\frac{\Delta T_1 UA + \dot{m}_h v_h \Delta P_h}{UA} \right) e^{-(U \pi D / \dot{m}_h C_{p,h})x} + T_\infty. \quad (4-61)$$

12,000 random number, generated by normal distribution, matrices (again each matrix is one by seven) between -0.015 °C and +0.015 °C (representing the uncertainty in the temperature measurement) on the theoretical temperature matrix is added, one of the 12,000 matrixes at a time, to the theoretical temperature matrix. A 2nd order polynomial curve fit is used to fit all the 12,000 temperature matrices to produce 12,000 equations in the form

$$T_{model} = C_1 x^2 + C_2 x + C_3. \quad (4-62)$$

The slope of the 2nd order polynomial above (the first derivative) is compared to the theoretical slope as shown in the following equations

$$\left. \frac{dT}{dx} \right|_{theor} = - \left(\frac{U \pi D_o}{\dot{m} C_p} \right) \left(T(x) - T_\infty + \frac{\dot{m} v \Delta P}{UA} \right), \quad (4-63)$$

$$\left. \frac{dT}{dx} \right|_{model} = 2C_1 x + C_2, \quad (4-64)$$

$$u_{dT/dx} = \frac{\left. \frac{dT}{dx} \right|_{model} - \left. \frac{dT}{dx} \right|_{theor}}{\left. \frac{dT}{dx} \right|_{theor}}. \quad (4-65)$$

Each set of temperatures generates five local temperature slopes at positions 1 through 5 along the tube. The 12,000 estimates of the temperature slope at position 1 are then sorted from minimum to maximum; the 11400th point (95% confidence interval of the 12,000 points) is the uncertainty in the temperature slope. Finally, Equation (4-66) below can be applied on all variables used in calculating the local heat transfer coefficient. Moreover, the local heat transfer uncertainty was calculated for each data point ranges from 1.0% (high heat flux) to 115% (low heat flux).

$$u_{h_t} = \sqrt{\left(\frac{\partial h_t}{\partial T_{lcoal}} \cdot u_{T_{lcoal}} \right)^2 + \left(\frac{\partial h_t}{\partial T_{sat}} \cdot u_{T_{sat}} \right)^2 + \left(\frac{\partial h_t}{\partial \dot{m}} \cdot u_{\dot{m}} \right)^2 + \left(\frac{\partial h_t}{\partial C_p} \cdot u_{C_p} \right)^2 + \dots} \quad (4-66)$$

4.11 Conclusion

This chapter presented the methods and equations used in determining the local heat transfer coefficient, local heat flux, local quality, mass flux, and average heat transfer coefficient. It also presented the modified Wilson plot method for determining the water heat transfer coefficient. Also, the chapter introduces a new method (Enthalpy Based Heat Transfer) to determine the heat exchanger's overall heat transfer coefficient using enthalpy change. This method is very useful for designing heat exchangers that experience significant pressure drop. Next, the local quality and mass flux are determined at the minimum cross sectional area, and finally, for calculating the uncertainty in the temperature derivative, a Monte Carlo type simulation was conducted.

Chapter 5 Introduction to Results

5.1 Introduction

The presentation of results is divided into two sections; the first is the effect of tube pitch on high pressure refrigerant (R-134a in Chapter 6), and the second is the effect on low pressure refrigerant (R-123 in Chapter 7). Each chapter addresses the experimental results for the two refrigerants based on three tube pitches: P/D 1.167, 1.33 and 1.5; the tube outer diameter is 0.01905 m (0.75 inch). Each chapter also covers heat transfer performance with respect to the change of heat flux, mass flux and quality. Two analyses (average and local) were used in this study; however, the results plots are for the local analysis, since it is the study focus. The method and equations used in determining the local heat transfer coefficient, local heat flux, and local quality are in Chapter 4.

5.2 Energy balance

An energy balance is performed on each of the six bundles before data collection begins, on both the refrigerant side and the water side, to verify the accuracy of the instruments, since the total heat load can be calculated using the refrigerant side or the water side independent of the other. This is the case when of the refrigerant leaving the test section is superheated; in this case, the total heat transfer is calculated as

$$Q = \dot{m}_{ref} (i_{superheated} - i_{subcooled}). \quad (5-1)$$

The sub-cooled and the superheated states in the equation above are defined at the pre-boiler inlet and at the test section exit, respectively. Sub-cooled liquid is the state of the refrigerant at the pre-boiler inlet at all test conditions, but the superheated state is not normally reached at the test section exit. However, it can be reached when the liquid refrigerant level in the test section is lowered, and the outlet temperature reads higher than the saturation temperature at the outlet pressure. The water total heat transfer is the sum of the pre-boiler heat load and the test section heat load as

$$Q = Q_{pre-boiler} + Q_{test\ section}, \quad (5-2)$$

where both the pre-boiler load and the test section load can be determined as,

$$Q_{water} = \dot{m}_{water} (i_{in} - i_{out}). \quad (5-3)$$

The energy balance results for all bundles showed an agreement of 0.1 to 1.8% between the refrigerant and water sides.

5.3 Test matrix

The primary global variables for designing flooded refrigerant evaporators are heat duty, mass flux, tube arrangement, and tube pitch. Within the tube bundle, variables like heat flux and quality vary considerably. Therefore, data collection is mapped through changing the heat flux, mass flux, and inlet quality; these are the control variables for operating the test facility. A range of heat flux, mass flux (based on the minimum cross sectional area), and bundle inlet quality (test matrix inputs) are proposed according to actual flooded evaporator design parameters. Therefore, the test matrix is a three dimensional matrix (5×6×4), where the number of points corresponds to the input variables as shown in Table 5-1 below.

Table 5-1 Test matrix inputs

<i>Mass flux (kg/s.m²)</i>	15	20	25	35	45	55
<i>Heat flux (kW/m²)</i>	5	15	30	45	60	
<i>Inlet Quality</i>	0.10	0.35	0.55	0.70		

The chiller providing the cooling source to the test facility has a capacity of 83 kW, which in turn becomes the capacity of the test facility. Meanwhile, the total heat load (bundle load plus pre-boiler load) and outlet quality are calculated for each element of the matrix. The points exceeding 100% outlet quality and a total load of 83 kW are considered out of range and thus eliminated from the test matrix.

Comparing the performance of the three bundles required holding the proposed input variables constant between the tube pitches. However, for the same mass flux, the mass flow rate increases with the increase of tube pitch; thus, a higher heat load is required. Therefore, the bigger tube pitch had more points that exceeded 83 kW. As a result, the P/D 1.167 has more runs than P/D 1.33, and P/D 1.33 has more runs than P/D 1.5. For the P/D 1.5 bundle, an extra mass flux (10 kg/s.m²) added to the test matrix increased the number data points of this bundle, hence

offering a better chance of a fair comparison among all three bundles. The results section contains the number of points in each test matrix.

5.4 Data presentation

Data points are sorted according to heat flux, mass flux and local quality. Those three variables are interrelated, which makes it difficult to determine the change in the heat transfer coefficient with respect to one variable independent of the other two (i.e. the other two held constant). Rather, the range of the other two variables is kept as narrow as possible. Next, the bundles' heat transfer coefficient vs. heat flux plots often includes the single pool boiling curve for comparing the convective and pool boiling for each tube pitch. Ultimately, heat flux proves to be the most influential variable for enhanced tubes rather than mass flux or quality; therefore, the first and most indicative plot of the bundle performance is the heat transfer coefficient vs. heat flux.

5.5 Water temperature drop

The water temperature drop is observed in the bundle through four instrumented tubes as explained in Chapter 3. Each tube carries inlet and outlet thermistors and five local thermistors. A second order polynomial is used to curve fit the temperature drop over each individual 1 m long tube. The local heat transfer coefficient, local heat flux, local quality are determined using the polynomial curve fit as explained in Chapter 4. The following set of figures (Figure 5-1 through Figure 5-4) show one selected run. Since each tube carries five local thermistors, each run of the test matrix produces 20 local points of heat transfer coefficient, heat flux, and local quality. Curve fitting each tube individually gives a more accurate curve fit equation than would curve fitting all four tubes at once, and the better the curve fit, the more accurate the temperature slope. In addition, the uncertainty of the temperature slope is narrower than that for a curve fitting all four tubes. Note: the figures below are arranged from highest (maximum temperature difference) to the lowest (minimum temperature difference) heat flux. Ultimately, the second order polynomial provided the best curve fit for the experimental data via a Monte-Carlo simulation on the different curve fits to find out which produces the minimum error.




Figure 5-1 Tube A1 temperature drop




Figure 5-2 Tube A2 temperature drop




Figure 5-3 Tube A3 temperature drop




Figure 5-4 Tube A4 temperature drop

5.6 Pool boiling results

Pool boiling is considered much simpler than bundle boiling; since mass flux and inlet quality are not involved. Instead, the refrigerant entering the test section is sub-cooled or saturated liquid. Pool boiling testing requires activating one tube of the tube bundle or using a single tube test section. A comprehensive study of pool boiling, done as a part of this research on a single tube test facility, is accessible through Gorgy (2008). Also, some pool boiling data was

taken in the current test facility to expand the heat flux range of the nucleate boiling curve of R-123.

Pool boiling (nucleate boiling) study is considered necessary for the following reasons. Firstly, pool boiling tests are needed in performing the Wilson plot method to determine the water-side heat transfer coefficient. Secondly, it provides the nucleate boiling data needed to design flooded evaporators. Thirdly, it provides an approach for understanding the boiling mechanism of enhanced tubes. Comparisons between nucleate boiling and bundle boiling can help studying convective effects in tube bundles. This sub-section presents, in the following visuals, the pool boiling results of R-134a and R-123 as well as the Wilson plot results.

Figure 5-5 and Figure 5-6 present the nucleate boiling of R-134a on Turbo BII-HP and R-123 on Turbo BII-LP, respectively. Both figures show a quick increase in performance at low heat flux changing to a slightly decreasing trend. The physical interpretation of this phenomenon is explained in detail in Chapter 8 of this document.




Figure 5-5 Pool boiling of R-134a on Turbo BII-HP




Figure 5-6 Pool boiling of R-123 on Turbo BII-LP

5.7 Wilson plot results

The figures over (Figure 5-7 and Figure 5-8) present the Wilson plot regression for Turbo BII-HP and Turbo BII-LP, respectively. On each plot, “X” represents the quotient $(h_i A_i / (q'')^n A_o)$, and “Y” represents the quotient $(h_i A_i / U_o A_o - R_{wall} h_i A_i)$. The calculation of each parameter, data collection method, and linear regression are explained at length in Chapter 4 of this document. The inverse of the intercept is the correction factor for the water-side heat transfer coefficient (C_i). This value is 1.931 and 1.866 for Turbo BII-HP and Turbo BII-LP, respectively. The figures show that the experimental data collapsed properly to a linear trend indicating that a good Wilson plot was obtained.




Figure 5-7 Wilson plot of R-134a on Turbo BII-HP




Figure 5-8 Wilson plot of R-123 on Turbo BII-LP

Chapter 6 Effect of Tube Pitch for R-134a

6.1 Introduction

Testing was performed at a saturation temperature of 4.44 °C using an enhanced Turbo BII-HP tube used with R-134a. The following subsections explain the results of each tube bundle along with the related conclusions. The results are presented as plots of the effect of heat flux, mass flux, and quality. Following the results of the third bundle, comparisons between the three bundles are presented along with the final conclusion of the effect of tube pitch on bundle performance.

6.2 P/D 1.167 results

Data were collected according to the proposed test matrix of the P/D 1.167 tube bundle based on a total of 55 runs. Each run produces 20 data points of local heat transfer coefficients, local heat fluxes, and local qualities, thus, 1100 total data points. Figure 6-1 over presents all 1100 points. The data is compared to that of the single tube pool boiling of the Turbo BII-HP tube. At low heat flux range (minimum heat flux to 20 kW/m²), all points show enhanced performance due to convective boiling and as heat flux increases, the bundle performance becomes significantly lower than does the single tube performance.




Figure 6-1 R-134a P/D 1.167 all data

The data presented above were sorted by quality as shown in Figure 6-2. Data points of a quality at 10% and 20% show enhanced performance at low heat flux, which increases with the increase in quality. Some points of the 55-60% Quality range show twice the performance of the single tube, while all the points above the 20 kW/m² mark show a much lower performance than does the single tube. This performance deterioration reaches 50% at the 55-60% Quality points range. Also, at higher heat fluxes, the higher the quality, the lower the performance. Next, all the points above 10 kW/m² show a decreasing trend with the increase of heat flux. Finally, at 60 kW/m² and above, the heat transfer coefficient does not show a significant change with the increase in heat flux.




Figure 6-2 R-134a P/D 1.167 all data sorted by quality

6.2.1 Heat flux effect

Figures 6-3 through 6-6 present a different view of the change of the heat transfer coefficient with heat flux for different mass fluxes and different ranges of qualities. In the first plot (10-15% Quality), the heat transfer coefficient increases with the increase in heat flux with a near flat trend after. In the 35-40% Quality plot, the heat transfer coefficient increases with the increase in heat flux up to 10 kW/m² and then changes to a decreasing trend, to near flat trend at higher heat fluxes; the same trend persists for the higher quality plots. Those plots show that the heat transfer coefficient is strongly dependent on heat flux.




Figure 6-3 R-134a P/D 1.167 effect of heat flux at 10-20% Quality




Figure 6-4 R-134a P/D 1.167 effect of heat flux 35-40% Quality




Figure 6-5 R-134a P/D 1.167 effect of heat flux 55-60% Quality




Figure 6-6 R-134a P/D 1.167 effect of heat flux 70-85% Quality

6.2.2 Mass flux effect

The mass flux effect can also be interpreted from the plots in Figure 6-3 to Figure 6-6. In Figure 6-3 (10-15% Quality), at the same heat flux, the heat transfer coefficient slightly increases with the increase in mass flux. For the higher quality plots and taking into account the heat transfer coefficient uncertainty, hardly any change occurs in the heat transfer coefficient with mass flux at the same heat flux. Therefore, the mass flux does not significantly affect performance.

6.2.3 Quality effect

For the effect of quality on the bundle performance, the heat transfer coefficient was plotted against quality for each mass flux point of the test matrix over a narrow range of heat flux points as presented in Figures 6-7 through 6-12. For 4-5 and 10 kW/m² for all mass fluxes, the heat transfer coefficient shows in all figures an increasing trend with the increase in quality. For higher heat fluxes, the heat transfer coefficient slightly decreases with the increase in quality. The fact that the heat transfer coefficient vs. quality trends are similar at all mass flux points reinforces the conclusion that the effect of mass flux is insignificant.




Figure 6-7 R-134a P/D 1.167 effect of quality at 15 kg/m².s




Figure 6-8 R-134a P/D 1.167 effect of quality at 20 kg/m².s




Figure 6-9 R-134a P/D 1.167 effect of quality at 25 kg/m².s




Figure 6-10 R-134a P/D 1.167 effect of quality at 35 kg/m².s




Figure 6-11 R-134a P/D 1.167 effect of quality at 45 kg/m².s




Figure 6-12 R-134a P/D 1.167 effect of quality at 55 kg/m².s

6.3 P/D 1.33 results

Data were collected according to the proposed test matrix of the P/D 1.33 tube bundle based on a total of 44 runs. Each run produces 20 data points of local heat transfer coefficients, local heat fluxes, and local qualities, thus, 880 total data points. Figure 6-13 over presents all 880 points. The data is compared to that from the single tube pool boiling of the Turbo BII-HP tube. At low heat flux range (minimum heat flux to 25 kW/m²), all points show enhanced performance due to convective boiling. At medium heat flux range, the bundle performance falls slightly below the single tube pool boiling performance while at high heat flux, both performances overlap.




Figure 6-13 R-134a P/D 1.33 all data

The data presented above were sorted by quality as shown in Figure 6-14. Data points for a quality at 10% and 20% show enhanced performance at low heat flux, which increases with the increase in quality. Some points with a quality in the 70-80% range show 2.7 times the performance of the single tube pool boiling, while all the points above the 35 kW/m² mark show a slightly lower performance than does the single tube. This lower trend persists up to 75 kW/m². Also, at higher heat fluxes, high quality points (70-80%) have lower performance than do lower quality points (35-40%), next all the points above 10 kW/m² show a decreasing trend with the increase of heat flux. Finally, at 70 kW/m² and above, the heat transfer coefficient does not significantly change with the increase in heat flux.




Figure 6-14 R-134a P/D 1.33 all data sorted by quality

6.3.1 Heat flux effect

Figures 6-15 through 6-17 present the change in heat transfer coefficient with heat flux for different mass fluxes and different ranges of quality. In the first plot (10-15% Quality), the heat transfer coefficient increases with the increase in heat flux with a near flat trend after. For the 35-40% Quality (Figure 6-16), the heat transfer coefficient increases with the increase in heat flux up to 10 kW/m² and then changes to a decreasing trend, to a near flat trend at higher heat fluxes, and the same trend persists for higher quality plots. Those plots show that the heat transfer coefficient is strongly dependent on heat flux.




Figure 6-15 R-134a P/D 1.33 effect of heat flux at 10-15% Quality




Figure 6-16 R-134a P/D 1.33 effect of heat flux at 35-40% Quality




Figure 6-17 R-134a P/D 1.33 effect of heat flux at 50-60% Quality

6.3.2 Mass flux effect

The mass flux effect can also be interpreted from the plots in Figures 6-15 to 6-17. In Figure 6-15 (10-15% Quality), at the same heat flux, the heat transfer coefficient slightly increases with the increase in mass flux. For the higher quality plots and taking into account the heat transfer coefficient uncertainty, hardly any change registers in the heat transfer coefficient with mass flux at the same heat flux. Therefore, the mass flux does not show a significantly affect performance.

6.3.3 Quality effect

The heat transfer coefficient was plotted against quality for each mass flux point of the test matrix over a narrow range of heat flux points as presented in Figures 6-18 through 6-23. For the 4-5 and 9-15 kW/m² marks for all mass fluxes, the heat transfer coefficient shows an increasing trend with the increase in quality. For higher heat fluxes at 15, 20, 25, and 35 kg/m².s marks, the heat transfer coefficient does not significantly change with quality. However, the heat

transfer coefficient shows an increasing trend for 20-40 kW/m² for 45 and 55 kg/m².s plots (Figure 6-22 and Figure 6-23).




Figure 6-18 R-134a P/D 1.33 effect of quality at 15 kg/m².s




Figure 6-19 R-134a P/D 1.33 effect of quality at 20 kg/m².s




Figure 6-20 R-134a P/D 1.33 effect of quality at 25 kg/m².s




Figure 6-21 R-134a P/D 1.33 effect of quality at 35 kg/m².s




Figure 6-22 R-134a P/D 1.33 effect of quality at 45 kg/m².s




Figure 6-23 R-134a P/D 1.33 effect of quality at 55 kg/m².s

6.4 P/D 1.5 results

Data were collected according to the proposed test matrix of the P/D 1.33 tube bundle for a total of 38 runs. Each run produces 20 data points of local heat transfer coefficients, local heat fluxes, and local qualities, thus, 760 total data points as in Figure 6-24 below. The data is compared to that for the single tube pool boiling of the Turbo BII-HP tube and reveals at low heat flux range (minimum heat flux to 40 kW/m²), all points show enhanced performance due to convective boiling. For the 40-50 kW/m² mark, the performance is slightly lower than for the single tube performance. However, above 50 kW/m², both performances overlap.




Figure 6-24 R-134a P/D 1.5 all data

The data presented above were sorted by quality as shown in Figure 6-25. First, data points of a quality at 10% and 20% show performance enhancement at low heat flux, which increases with the increase in quality. For example, some points of 70-80% Quality show 2.7 times the performance of the single tube, and all the points above the 40 kW/m² mark show slightly lower performance than does the single tube. Also, at higher heat fluxes, high quality points (70-80%) have slightly lower performance than do lower quality points (35-40%); however, all the points above 20 kW/m² show a decreasing trend with the increase in heat flux. At 70 kW/m² and above, the heat transfer coefficient does not significantly change with the increase in heat flux.




Figure 6-25 R-134a P/D 1.5 all data sorted by quality

6.4.1 Heat flux effect

Figures 6-26 through 6-28 show the change in heat transfer coefficient with heat flux for different mass fluxes and a different range of qualities. In the first plot (10-15% Quality), the heat transfer coefficient increases with the increase in heat flux with a near flat trend after. In the 35-40% Quality range, the heat transfer coefficient increases with the increase in heat flux up to 10 kW/m² and then changes to a decreasing trend, to a near flat trend at higher heat fluxes, and the same trend persists at higher quality plots. The plots overleaf show that the heat transfer coefficient is strongly dependent on heat flux.




Figure 6-26 R-134a P/D 1.5 effect of heat flux at 10-15% Quality




Figure 6-27 R-134a P/D 1.5 effect of heat flux at 35-40% Quality




Figure 6-28 R-134a P/D 1.5 effect of heat flux at 50-60% Quality

6.4.2 Mass flux effect

Figures 6-26 through 6-28 can also help determine the effect of mass flux. In Figure 6-26 (10-15% Quality), at the same heat flux, the heat transfer coefficient slightly increases with the increase in mass flux. For the higher quality plots and taking into account the heat transfer coefficient uncertainty, hardly any change register in the heat transfer coefficient with mass flux at the same heat flux. Therefore, the mass flux does not significantly affect performance.

6.4.3 Quality effect

For the effect of quality on bundle performance, the heat transfer coefficient was plotted against quality for each mass flux point of the test matrix over a narrow range of heat flux points in Figures 6-29 through 6-35. For 4-5 and 9-15 kW/m² for 10, 15, 20, 25 and 35 kg/m².s plots (Figure 6-29 through Figure 6-32), the heat transfer coefficient shows an increasing trend with the increase in quality. For 45 and 55 kg/m².s plots (Figure 6-34 and Figure 6-35), the 9-15 kW/m² show a decreasing trend. For higher heat fluxes at 10, 15, 20, 25, and 35 kg/m².s plots (Figures 6-29 through 6-33), the heat transfer coefficient does not significantly change with

quality. Finally, the heat transfer coefficient shows an increasing trend for 15-40 kW/m² for 45 kg/m².s plots.




Figure 6-29 R-134a P/D 1.5 effect of quality at 10 kg/m².s




Figure 6-30 R-134a P/D 1.5 effect of quality at 15 kg/m².s




Figure 6-31 R-134a P/D 1.5 effect of quality at 20 kg/m².s




Figure 6-32 R-134a P/D 1.5 effect of quality at 25 kg/m².s




Figure 6-33 R-134a P/D 1.5 effect of quality at 35 kg/m².s




Figure 6-34 R-134a P/D 1.5 effect of quality at 45 kg/m².s



Figure 6-35 R-134a P/D 1.5 effect of quality at 55 kg/m².s

6.5 Saturation pressure change in the tube bundles

The following plots (Figures 6-36 through 6-38) show the saturation pressure change in the three tube pitches. Each plot shows the pressure change at each height in the bundle starting from the inlet. The saturation pressure (tube-average pressure) is measured at locations A4, A3, A2, and A1 (refer to Figure 3-5 in Page 23). Each plot includes the various mass flux ranges; each mass flux represents a test point with the maximum change in quality. The change in the saturation pressure is due to three components, hydrostatic pressure, dynamic pressure, and the frictional loss. The trends show that the saturation pressure change in the bundle is insignificant even for the smallest tube pitch (P/D 1.167), since the pressure change does not show a uniform trend within any of the bundles.




Figure 6-36 R-134a P/D 1.167 bundle saturation pressure




Figure 6-37 R-134a P/D 1.33 bundle saturation pressure




Figure 6-38 R-134a P/D 1.5 bundle saturation pressure

6.6 Heat transfer impact of varying the tube pitch

Studying the effect of heat flux, mass flux, and quality for the three tube pitches proved that the dominant variable is heat flux. That is not an unexpected conclusion since it has also been reported in open literature for enhanced tubes. Accordingly, tube pitch effect on bundle performance is conducted by comparing the heat transfer coefficient vs. heat flux plots of each bundle. Figure 6-39 below illustrates that comparison. The P/D 1.167 tube bundle shows that it has the lowest performance of the three tube pitches; its performance is significantly lower than that of the other two tube pitches and pool boiling. In fact, the heat transfer coefficient of some points is 1.5 times lower than that of the other two tube pitches. P/D 1.33 and P/D 1.5 show similar performance; nevertheless, the performance of P/D 1.5 is slightly higher than that of P/D 1.33 since it approaches pool boiling at medium and high heat fluxes.




Figure 6-39 R-134a tube pitch comparison

The study compares all three tube bundles' performance based on same heat flux, same mass flux, and same flow rate. Although the same flow rate comparison is not the focus of this study, it is somewhat important to understand the effect of switching a tube bundle to a bigger tube pitch in a flooded evaporator under the same operating condition. The following

comparisons were conducted: the heat transfer coefficient vs. heat flux at the same mass flux, heat transfer coefficient vs. heat flux at the same mass flow rate, heat transfer coefficient vs. quality at the same mass flux and heat flux, and heat transfer coefficient vs. quality at the same mass flow rate and heat flux. Figures 6-40 through 6-47 present those comparisons. For the heat transfer coefficient vs. heat flux comparison at 15 and 25 kg/m².s (Figure 6-40 and Figure 6-41), P/D 1.33 and P/D 1.5 show similar performance and increasing trend, but P/D 1.167 shows a fairly flat trend. For 0.35 and 0.45 kg/s (Figure 6-42 and Figure 6-43), P/D 1.33 and P/D 1.5 do not show significant change in performance, but in P/D 1.167, the heat transfer coefficient decreases with the increase in heat flux. For the heat transfer coefficient vs. quality at the same mass flux, mass flow rate, and low heat flux (Figure 6-44 through Figure 6-47), P/D 1.33 and P/D 1.5 show an increasing trend, and P/D 1.167 shows a flat trend. For the heat transfer coefficient vs. quality at the same mass flux and medium and high heat fluxes, P/D 1.33 and P/D 1.5 show a near flat trend while P/D 1.167 shows a decreasing trend. The comparison plots clearly show that the bigger tube pitch bundles revealed significantly low heat flux enhancement compared to P/D 1.167. Moreover, both P/D 1.33 and P/D 1.5 demonstrated similar results.




Figure 6-40 R-134a bundles comparison at 15 kg/m².s




Figure 6-41 R-134a bundles comparison at 25 kg/m².s




Figure 6-42 R-134a bundles comparison at 0.35 kg/s




Figure 6-43 R-134a bundles comparison at 0.45 kg/s




Figure 6-44 R-134a bundles comparison at 10-20 kW/m² and 15 kg/m².s




Figure 6-45 R-134a bundles comparison at 30-40 kW/m² and 15 kg/m².s




Figure 6-46 R-134a bundles comparison at 40-50 kW/m² and 25 kg/m².s




Figure 6-47 R-134a bundles comparison at 10-20 kW/m² and 0.45 kg/s

6.7 Conclusion

This chapter presented the experimental results from testing three tube pitches, P/D 1.167, P/D 1.33, and P/D 1.5 for R-134a over Turbo BII-HP enhanced tube bundles. The results of each tube bundle showed that the dominant parameter in the bundle performance is heat flux. Specifically, the heat transfer coefficient increases with the increase in quality at low heat flux. Moreover, the P/D 1.167 tube bundle showed significantly lower performance than P/D 1.33 and P/D 1.5 while the P/D 1.33 and P/D 1.5 tube bundles showed similar performance with P/D 1.5 slightly higher at medium and high heat flux. Evidently, the peak of the pool boiling curve exists in bundle boiling as well, but is shifted to the left; i.e. the curve peaks at a lower heat flux for convective boiling. All tube bundles experience “the low heat flux enhancement” at the same heat flux. Since P/D 1.33 and P/D 1.5 have the same low heat flux enhancement, predictably, increasing the tube pitch beyond P/D 1.33 will not increase low heat flux enhancement. Also, as tube pitch increases, the medium and high heat flux region approaches that for the single tube performance.

Chapter 7 Effect of Tube Pitch for R-123

7.1 Introduction

Most of the testing was performed at a saturation temperature of 14.44 °C. Originally, the desired saturation temperature was 4.44 °C as is the case for R-134a tests, but the current test facility's configuration has a limited range of high heat fluxes and mass fluxes at 4.44 °C for the low pressure refrigerant. The low pressure nature of R-123 increases the vapor volume considerably at low temperatures; thus, it is harder for the system's condenser to accommodate high mass velocity and vapor volume. Since the specific volume of R-123 at 4.44 °C is 1.5 times the specific volume at 14.44 °C, and to construct the proposed test matrix, data were primarily collected at 14.44 °C; moreover, data taken at 4.44 °C were limited to low heat flux and mass flux. No significant difference between the two saturation temperatures was noticed for any of the three tube bundles, which is also clear in the results plots.

The enhanced tube used with R-123 is the Turbo BII-LP, and the following subsections explain the results of testing each tube bundle. Each bundle's results are presented with related conclusions, and the results are presented as plots of the effect of heat flux, mass flux, and quality. Following the results of the third bundle, the study compares the three bundles and concludes as to the effect of tube pitch on bundle performance.

7.2 P/D 1.167 results

Data were collected according to the proposed test matrix of the P/D 1.167 tube bundle based on a total of 23 runs. Each run produces 20 data points of local heat transfer coefficients, local heat fluxes and, local qualities, thus, 460 data points total as shown in Figure 7-1 over. Data is also compared to that of the single tube pool boiling of the Turbo BII-LP tube. At low heat flux range (minimum heat flux to 30 kW/m²), all points show enhanced performance due to convective boiling. Moreover, as heat flux increases, bundle performance becomes lower than that of the single tube performance, with some points experiencing a sharp decline. Figure 7-2 compares the two saturation temperatures, showing no significant difference.




Figure 7-1 R-123 P/D 1.167 all data




Figure 7-2 R-123 P/D 1.167 saturation temperature comparison

The data presented on the previous page were sorted by quality as shown in Figure 7-3. At low heat flux, all qualities show enhanced performance compared to that of the single tube, while at 50% Quality and beyond, performance declines and deteriorates; meanwhile, all the points above 30 kW/m² show a decreasing trend with increase in heat flux.

The points for 50-80% Quality at the bottom of the curve show performance similar to that of a smooth tube (see also Figure 7-1); their heat transfer coefficient is much lower than that of other points that share the same heat flux and quality. Those points are located at the top of the bundle, suggesting that this effect is due to flow pattern (spray flow). Also, this phenomenon occurs at high wall superheat ($T_{wall} - T_{sat}$) and high bundle-average heat flux, so as the bundle average heat flux increases, the top of the tube bundle (water inlet) experiences tube enhancement dry-out at which point the water temperature difference becomes small; hence the low local heat flux of those points. This phenomenon was also observed by Arshad and Thome (1983).




Figure 7-3 R-123 P/D 1.167 all data sorted by quality

7.2.1 Heat flux effect

Figures 7-4 through 7-7 show the change in the heat transfer coefficient with heat flux for different mass fluxes and different ranges of quality. In the first plot (10-15% Quality), the heat transfer coefficient increases with the increase in heat flux up to 25 kW/m² and then changes to a decreasing trend. The same trend persists for the 30-40% and 50-60% Quality plots (Figure 7-5 and Figure 7-6). Additionally, the performance of some points drops to that of a smooth tube for the 50-60% and 70-80% Quality plots.

These plots show that the heat transfer coefficient is dependent on heat flux, average bundle heat flux, and flow pattern. The dependency on flow pattern can be interpreted from Figure 7-6 and Figure 7-7 for 35 and 45 kg/m².s mass flux points, which show that for the same heat flux, two different values for the heat transfer coefficient exist. According to Collier and Thome (1996), flow pattern from bottom to top is described as single phase liquid, bubbly flow, bubble jet flow, chugging flow, and spray flow. At the top of the bundle and at high bundle-average heat flux, the flow pattern is likely to be spray flow, which can cause enhancement dry-out. This phenomenon is explained at length in the next chapter.




Figure 7-4 R-123 P/D 1.167 effect of heat flux at 10-20% Quality




Figure 7-5 R-123 P/D 1.167 effect of heat flux at 30-40% Quality




Figure 7-6 R-123 P/D 1.167 effect of heat flux at 50-60% Quality




Figure 7-7 R-123 P/D 1.167 effect of heat flux at 70-80% Quality

7.2.2 Mass flux effect

The mass flux effect can also be interpreted from the previous set of plots. In Figure 7-4 (10-15% Quality), at the same heat flux, the heat transfer coefficient slightly increases with the increase in mass flux. For the higher quality plots, except 70-80% Quality, and taking into account the heat transfer coefficient uncertainty, hardly any change in the heat transfer coefficient registers for mass flux at the same heat flux. However, some points on Figure 7-7 show that mass flux has an effect on the heat transfer coefficient at high qualities, for as the mass flux increases, the heat transfer coefficient drops quickly.

7.2.3 Quality effect

The following plots (Figures 7-8 through 7-13) present the heat transfer coefficient vs. quality for each mass flux point of the test matrix over a narrow range of heat flux points. For 15, 20 and 25 kg/m²·s mass fluxes for all heat flux ranges, the heat transfer coefficient doesn't significantly change with the increase in quality, whereas for higher mass fluxes, the heat transfer coefficient experiences a sharp decrease at 50% quality and higher. Therefore, the heat

transfer coefficient shows a strong dependency on quality at high mass fluxes (the curve fits in the plots below are just to help the reader interpret the trend of the points). Figure 7-12 demonstrates that the heat transfer coefficient shows a slight increase with quality up to 50%, then sharply declines at higher qualities.




Figure 7-8 R-123 P/D 1.167 effect of quality at 15 kg/m².s




Figure 7-9 R-123 P/D 1.167 effect of quality at 20 kg/m².s




Figure 7-10 R-123 P/D 1.167 effect of quality at 25 kg/m².s




Figure 7-11 R-123 P/D 1.167 effect of quality at 35 kg/m².s




Figure 7-12 R-123 P/D 1.167 effect of quality at 45 kg/m².s




Figure 7-13 R-123 P/D 1.167 effect of quality at 55 kg/m².s

7.3 P/D 1.33 results

Data were collected according to the proposed test matrix of the P/D 1.33 tube bundle for a total of 22 runs. Each run produces 20 data points of local heat transfer coefficients, local heat fluxes, and local qualities, thus, 440 data points total as in Figure 7-14 below. The data is compared to that for the single tube pool boiling of the Turbo BII-LP tube. Ultimately, at low heat flux range (minimum heat flux to 30 kW/m²), all points show enhanced performance due to convective boiling. Finally, Figure 7-15 compares the two saturation temperatures, showing no significant difference.




Figure 7-14 R-123 P/D 1.33 all data




Figure 7-15 R-123 P/D 1.33 saturation temperature comparison

The data on the page before were sorted by quality as shown in Figure 7-16. At low heat flux, all qualities show enhanced performance compared to that of the single tube; however, at 50% Quality and beyond, the performance declines. Meanwhile, all the points above 30 kW/m² show a decreasing trend with the increase in heat flux; in fact, high quality points show a quick declining trend with the increase in heat flux. At medium and high heat fluxes, bundle performance is slightly lower than that of the single tube with some points overlapping.




Figure 7-16 R-123 P/D 1.33 all data sorted by quality

7.3.1 Heat flux effect

Figures 7-17 through 7-20 show the change in heat transfer coefficient with heat flux for different mass fluxes and different ranges of quality. In the first plot (10-15% Quality), the heat transfer coefficient increases with the increase in heat flux up to 25 kW/m² and then changes to a near flat trend while the same trend persists for the 30-40% and 50-60% Quality plots; meanwhile, the 70-83% Quality plot shows that the heat transfer coefficient decreases with the increase in heat flux. Those plots show that the heat transfer coefficient is dependent on heat flux and flow pattern. Figure 7-20 demonstrates this flow pattern dependency.




Figure 7-17 R-123 P/D 1.33 effect of heat flux at 10-20% Quality




Figure 7-18 R-123 P/D 1.33 effect of heat flux at 30-40% Quality




Figure 7-19 R-123 P/D 1.33 effect of heat flux at 50-60% Quality




Figure 7-20 R-123 P/D 1.33 effect of heat flux at 70-83% Quality

7.3.2 *Mass flux effect*

The mass flux effect can also be interpreted from the previous plots (Figures 7-17 through 7-20) to show hardly any change in the heat transfer coefficient with mass flux at the same heat flux. Therefore, mass flux does not significantly affect performance.

7.3.3 *Quality effect*

For the effect of quality on bundle performance, the heat transfer coefficient was plotted against quality for each mass flux point of the test matrix over a narrow range of heat flux points as presented in Figures 7-21 through 7-23. For 15 kg/m².s mass flux (Figure 7-21) and for all heat flux ranges, the heat transfer coefficient doesn't significantly change with increase in quality. Specifically, for 20 kg/m².s mass flux (Figure 7-22), the heat transfer coefficient experiences a sharp decrease at 75% quality and higher. For 25 kg/m².s mass flux and given that the quality range is narrow compared to that for the other mass fluxes, the heat transfer coefficient doesn't significantly change with quality. For the rest of the mass fluxes (35, 45, and 55 kg/m².s), there were not enough data points from which to draw a strong conclusion. Ultimately, the plots presented over show that the heat transfer coefficient strongly depends on quality for 25 kg/m².s mass fluxes at high qualities.




Figure 7-21 R-123 P/D 1.33 effect of quality at 15 kg/m².s




Figure 7-22 R-123 P/D 1.33 effect of quality at 20 kg/m².s




Figure 7-23 R-123 P/D 1.33 effect of quality at 25 kg/m².s

7.4 P/D 1.5 results

Data were collected according to the proposed test matrix of the P/D 1.33 tube bundle for a total number of 23 runs. Each run produces 20 data points of local heat transfer coefficients, local heat fluxes, and local qualities, thus, 460 data points total as in Figure 7-24. The data is compared to that for the single tube pool boiling of the Turbo BII-LP tube showing that at low heat flux range (minimum heat flux to 30 kW/m²), all points reveal enhanced performance due to convective boiling. Figure 7-25 compares the two saturation temperatures showing no significant difference.




Figure 7-24 R-123 P/D 1.5 all data




Figure 7-25 R-123 P/D 1.5 two saturation temperatures

The data on the previous page were sorted by quality as shown in Figure 7-26. At low heat flux, all qualities show enhanced performance compared to that of the single tube. Specifically, at 50% Quality and beyond, the heat transfer coefficient shows a decreasing trend, whereas at 70-84% Quality, the performance deteriorates faster. In fact, all the points above 30 kW/m² show a decreasing trend with the increase in heat flux. Finally, at medium and high the heat fluxes, the bundle shows performance similar to that of the single tube.




Figure 7-26 R-123 P/D 1.5 all data sorted by quality

7.4.1 Heat flux effect

Figures 7-27 through 7-30 present the change in the heat transfer coefficient with heat flux for different mass fluxes and different ranges of quality. In Figure 7-27 (10-20% Quality), the heat transfer coefficient increases with the increase in heat flux up to 25 kW/m² and then changes to a decreasing trend with the increase in heat flux, and the same trend persists for the 30-40% and 50-60% Quality plots (Figure 7-28 and Figure 7-29). Meanwhile, the 70-80% Quality plot shows that the heat transfer coefficient decreases quickly with the increase in heat flux. Finally, Figure 7-30 shows that at high quality, performance deteriorates faster as mass flux

increases. It also shows a flow pattern dependency, as the heat transfer coefficient demonstrates two different values for the same heat flux and quality ranges.




Figure 7-27 R-123 P/D 1.5 effect of heat flux at 10-20% Quality




Figure 7-28 R-123 P/D 1.5 effect of heat flux at 30-40% Quality




Figure 7-29 R-123 P/D 1.5 effect of heat flux at 50-60% Quality




Figure 7-30 R-123 P/D 1.5 effect of heat flux at 70-80% Quality

7.4.2 Mass flux effect

The mass flux effect can also be interpreted from the plots in Figures 7-27 through 7-30. Primarily, hardly any change registers in the heat transfer coefficient with mass flux at the same heat flux. Indeed, except at 70-80% Quality, the mass flux does not significantly affect performance.

7.4.3 Quality effect

For the effect of quality on bundle performance, the heat transfer coefficient was plotted against quality for each mass flux point of the test matrix over a narrow range of heat flux points as presented in Figures 7-31 through 7-33. For 10 kg/m².s mass flux (Figure 7-31) and for all heat flux ranges, the heat transfer coefficient doesn't significantly change with the increase in quality. However, for 15 kg/m².s mass fluxes, the heat transfer coefficient experiences a sharp decrease at 75% quality and higher. Meanwhile, for 20 kg/m².s mass fluxes, and given that the quality range is narrow compared to that for the other mass fluxes, the heat transfer coefficient doesn't significantly change with quality. For the remaining mass fluxes (25, 35, 45, and 55

kg/m².s), there were not enough data points from which to draw a strong conclusion. The plots presented next show that the heat transfer coefficient is strongly dependent on quality for high mass fluxes at high qualities.




Figure 7-31 R-123 P/D 1.5 effect of quality at 10 kg/m².s




Figure 7-32 R-123 P/D 1.5 effect of quality at 15 kg/m².s




Figure 7-33 R-123 P/D 1.5 effect of quality at 20 kg/m².s

7.5 Saturation pressure change in the tube bundles

The following plots (Figures 7-34 through 7-36) show the saturation pressure change in the three tube pitches. The change in the saturation pressure is due to three components, hydrostatic pressure, dynamic pressure, and frictional loss. Each plot shows the saturation pressure (tube-average pressure) change at each height in the bundle starting from the inlet. Locations A4, A3, A2, and A1 refer to the different heights in the tube bundle (refer to Figure 3-5 in Page 23). Each plot includes the measured mass flux ranges; each mass flux represents a test point with the maximum change in quality. The trends show that the saturation pressure change in the bundle is insignificant (i.e. the pressure change within the tube bundle does not show a steady trend) even for the smallest tube pitch.




Figure 7-34 R-123 P/D 1.167 bundle saturation pressure




Figure 7-35 R-123 P/D 1.33 bundle saturation pressure




Figure 7-36 R-123 P/D 1.5 bundle saturation pressure

7.6 Heat transfer impact of varying the tube pitch

The main conclusion from the results of testing the three tube bundles is that the heat transfer coefficient is dependent on both heat flux and quality. The effect of quality, however, is not as dominant as the effect of heat flux, since it is only significant at some mass fluxes and when the quality exceeds 50% (in the case of the smallest tube pitch) and 75% (in the cases of the other two tube pitches). Therefore, comparing performance of tube pitch for the three bundles is done by plotting the heat transfer coefficient against the heat flux.

Aside from dry-out of the smallest tube pitch, all three bundles show very similar performance at low heat flux. At medium and high heat fluxes, there is a slight difference in performance among the three tube pitches since as the tube pitch increases, the performance gets closer to that of the single tube.

Just as the pool boiling curve experiences a peak in performance, so does bundle performance. Moreover, all three bundles experience a peak in performance at a lower heat flux than that of the single tube as presented in Figure 7-37. Concerning tube dry-out, only the smallest tube pitch experiences a drop in performance to that of a smooth tube at certain flow rates and high qualities. This phenomenon does not occur in the bigger tube pitches; only a quick decline in performance is experienced at high qualities. Also, the effect of flow pattern becomes significant at high qualities. This effect is noticeable for the points with two different values for the heat transfer coefficient for the same heat flux, mass flux, and quality.




Figure 7-37 R-123 tube pitch comparison

The second step for assessing tube pitch performance is to compare the three tube pitches' heat transfer coefficient with respect to heat flux, quality, mass flux, and mass flow. Although flow rate comparison is not the focus of this study, it is somewhat important to understand the effect of switching a tube bundle to a bigger tube pitch in a flooded evaporator under the same operating conditions. Accordingly, Figure 7-38 and Figure 7-39 present the change in the heat transfer coefficient with respect to heat flux at the same mass flux for the three bundles. At low heat flux, the smallest tube pitch shows the highest performance, but taking into account the uncertainty of the points, predictably, the three bundles have the same performance. Also, the three bundles overlap at the range of 15-20 kW/m². Additionally, the biggest tube pitch shows the highest performance at the 30-50 kW/m² range; moreover, the same trends persist in Figure 7-40 and Figure 7-41, with the overlapping taking place at a higher heat flux.

Figures 7-42 through 7-46 show the change in the heat transfer coefficient with quality at the same heat and mass flux, and at the same heat flux and mass flow rate. Indeed, all plots show insignificant change in the heat transfer coefficient with change in quality except in Figure 7-46, where the heat transfer coefficient drops drastically for P/D 1.167 at high quality; this shows tube dry-out.




Figure 7-38 R-123 bundles comparison at 15 kg/m².s




Figure 7-39 R-123 bundles comparison at 25 kg/m².s




Figure 7-40 R-123 bundles comparison at 0.35 kg/s




Figure 7-41 R-123 bundles comparison at 0.45 kg/s




Figure 7-42 R-123 bundles comparison at 15 kg/m².s and 10-20 kW/m²




Figure 7-43 R-123 bundles comparison at 15 kg/m².s and 30-40 kW/m²




Figure 7-44 R-123 bundles comparison at 25 kg/m².s and 40-50 kW/m²




Figure 7-45 R-123 bundles comparison at 0.45 kg/s and 10-20 kW/m²




Figure 7-46 R-123 bundle comparison at 0.45 kg/s and 40-50 kW/m²

7.7 Conclusion

This chapter presented the experimental results of testing three tube pitches P/D 1.167, P/D 1.33, and P/D 1.5 for R-123 over Turbo BII-LP enhanced tube bundles. The most influential parameter affecting bundle performance is heat flux; next is quality. The effect of quality, however, is apparent only at certain flow rates and high qualities. Particularly, the flow pattern effect is noticeable for the points with two different values for the heat transfer coefficient for the same heat flux, mass flux, and quality. In general, all bundles show a similar performance at low heat flux, and evidently, the peak of the pool boiling curve exists in bundle boiling as well, but is shifted to the left (i.e. the curve peaks at a lower heat flux for convective boiling). Moreover, all tube bundles experience “the low heat flux enhancement” at the same heat flux; therefore, predictably, increasing the tube pitch beyond P/D 1.167 does not increase the low heat flux enhancement. Only the smallest tube pitch experiences a drop in performance at high qualities to that of a smooth tube. This phenomenon does not occur in the bigger tube pitches; there, only a quick decline in performance is experienced at high qualities. Also, the effect of flow pattern becomes significant at high qualities.

Chapter 8 Discussion

8.1 Introduction

This chapter interprets the trends observed in pool boiling and the different tube pitches, focusing mainly on the boiling mechanism in the tube enhancement and the flow patterns in a tube bundle. Examining the boiling mechanism can help clarify the different trends of pool as well as bundle boiling. In both pool and bundle boiling, three types of performance can be identified; rapid increase at low heat flux, decline at medium heat flux, and no change at high heat flux. These phenomena are explained at length in the coming sub-sections. As for bundle boiling, the factor of flow pattern is interconnected with the boiling mechanism and adds another level of complexity. This chapter also compares the two refrigerants and makes a recommendation based on the research results.

8.2 Boiling mechanism in enhanced tubes

Researchers usually use experiments with flow visualization capabilities to help explain the boiling mechanisms in enhanced tubes. In particular, pool boiling is the best condition under which flow visualization is beneficial. Figure 8-1 shows a microscopic photograph of the current enhanced tube surface configuration, revealing sub-surface tunnels with pores. Nakayama et al. (1980) Part I and Part II and Nakayama et al. (1982) are among the first to study the boiling mechanism and heat transfer modes of enhanced surfaces. Recalling that enhanced tubes, also called structured tubes, are essentially tunnels (sub-surface) with pores, they explained that in this configuration, boiling takes place in three phases as follows.



Figure 8-1 Microscopic picture of the tube surface

Phase I is called pressure build-up, and it occurs when the liquid inside the tunnels forms a meniscus; as the heat flux increases, the liquid starts evaporating, and the vapor pressure increases until a bubble starts to appear at the surface pore. In Phase II, as the heat flux continues to increase, the bubble continues to grow causing the pressure inside the tunnel to decrease; but due to the inertial force of the retreating immediate-liquid, the bubble growth increases, and the pressure in the tunnel decreases. In Phase III, once the pressure inside the tunnel decreases to below the pressure of the liquid pool, liquid enters the tunnel through inactive pores and closes all the pores by meniscus, and the cycle repeats.

Nakayama et al. (1980) Part II proposed that the enhanced tube heat flux for this cycle can be expressed as the summation of tunnel and external heat fluxes as expressed in Equation (8-1). The heat transfer taking place in the tunnels is due to liquid evaporation (latent heat), while the heat transfer taking place outside the tunnel is due to bubble agitation on the surface (convective heat). This can be expressed as

$$q'' = q''_{tunnel} + q''_{external} \cdot \quad (8-1)$$

They reported that the liquid evaporation in the tunnels causes most of the performance enhancement rather than the bubble convection on the outer surface. In other words, q''_{tunnel} outweighs $q''_{external}$ due to evaporation of the liquid presence in the tunnels.

8.3 Pool boiling trend analysis

Recalling the pool boiling performance of R-134a on Turbo BII-HP and R-123 on Turbo BII-LP, the pool boiling curve can be divided into three regions (I, II, and III) as illustrated in Figure 8-2 and Figure 8-3. Region I is characterized by an increase in performance at low heat flux, while Region II is characterized by a slight decrease in performance; meanwhile, Region III is characterized by an insignificant change in performance with heat flux. The interpretation of the three regions follows, starting with the first.

- Inactive pores start to activate by evaporating the excess liquid in the tunnels; this process continues until the number of active pores reaches its maximum.
- As the heat flux continues increasing, another factor comes into play, the rate of liquid supply to the tunnels. Specifically, as the surface temperature increases, liquid supply to the tunnels decreases; thus, the performance starts to decrease.
- The flat region is considered one of the most controversial trends, and, to the author's best knowledge, it has not been observed or studied in literature. In this region, the increase in the surface temperature does not affect the tube performance. One interpretation could be that as surface temperature continues increasing, the liquid amount entering the tunnels continues to go down, but some enters the tunnels by capillary action, even at high bubble density.

One can summarize this hypothesis as the change in trend being due mainly to liquid feed to the tunnels. Therefore, too much or not enough liquid in the tunnels can greatly affect the performance. This problem can be expressed as tunnel liquid flow optimization. At higher surface temperatures, the capillary action keeps the tunnels wet, which helps maintain a flattened trend for the heat transfer coefficient.




Figure 8-2 Pool boiling of R-134a on Turbo BII-HP




Figure 8-3 Pool boiling of R-123 on Turbo BII-LP

8.4 Bundle boiling trend analysis

Usually, convection on tube bundles increases the heat transfer performance for smooth tube bundles. But for enhanced tube bundles, this is not necessarily the case. One of the striking facts about boiling on enhanced tube bundles is that mass velocity has an insignificant effect on the bundle performance; this was observed in this study and elsewhere in literature. Furthermore, the effect of mass velocity is slightly significant at the low heat flux range (also low vapor qualities) only.

In general, the mass flux range for flooded evaporators is much smaller than that for in-tube boiling; hence, the pressure drop across the bundle is due mainly to static pressure rather than for friction pressure. For enhanced tube bundles, the current study showed that the pressure change across the bundle is insignificant for all studied tube pitches, mass velocities, and refrigerants. This reinforces the conclusion that frictional pressure drop is insignificant in enhanced tube bundles, hence the trivial effect due to flow convection. Therefore, neither static pressure nor mass velocity affects the bundle performance.

In all tested tube bundles, the following themes are observed; the steep rise in performance at low heat flux, performance decrease at medium heat flux, and flat trend at high heat flux. Given the pool boiling discussion of pore activation, the low heat flux enhancement in bundle performance is due to pore activation rather than flow convection. Pore activation takes place at a lower heat flux as a result of an impinging two-phase flow on the tube pores.

The performance declines at medium heat flux due to the decrease in liquid flow to the tunnels. Also, the bubble movement in the bundle as well as the tube bubble growth at medium heat flux causes the decrease in liquid flow to the tunnels, which is not as apparent in pool boiling because of the slight bubble convection.

At high heat flux range, the liquid feed becomes more restricted, but liquid is able to penetrate the pores by capillary action to keep the tunnels wet, producing an even heat transfer coefficient. In the case of high quality points and spray flow pattern, liquid depletes faster, and the tunnels start to dry-out causing the performance to revert to that of a smooth tube.

8.4.1 *R-134a bundles' trend analysis*

In the all bundles comparison plot (Figure 8-4), the low heat flux enhancement for the two higher pitches is much greater than for the lowest tube pitch. One plausible explanation is

better pore activation caused by less restricted bubble impingement on inactive pores. Given that at P/D 1.33 the low heat flux enhancement reaches its maximum, beyond this tube spacing, the heat transfer coefficient does not show a significant increase. However, the tightest tube pitch (P/D 1.167) presents an unexpected trend. One assumption for this behavior could be that as bubbles travel in tight spaces, they restrict the growth of bubbles from the adjacent tubes. Ultimately then, restriction of flow of liquid to the tunnels seems to be responsible for the drop in performance of the smallest tube pitch.




Figure 8-4 R-134a tube pitch comparison

8.4.2 R-123 bundles' trend analysis

Similar to the case of R-134a, this trend analysis shows significant enhancement at low heat flux as presented in Figure 8-5. The smallest tube pitch experiences a quick drop in performance similar to that of a smooth tube at high qualities. This is due to tunnel dry-out, a phenomenon reported in literature. The tunnel dry-out supports the hypothesis that liquid feed to the tunnels plays a major role in dictating the tube performance. It also supports the flow pattern effect being significant in that case. At the top of the bundle, the observed flow pattern is spray

flow. The study also shows that although the bigger tube pitches show a quick drop in performance, such a drop in performance is not as severe as for the tightest tube pitch.




Figure 8-5 R-123 tube pitch comparison

8.4.3 The two refrigerants comparison

For the high heat flux range in all bundles, the increase in tube pitch causes the performance to approach that of pool boiling. This can be due to bubbles' free travel in wider spaces, which makes bubbles on the tubes form without much restriction. Also, all cases show a low heat flux enhancement. Notably, the P/D 1.167 tube pitch in the R-134a and R-123 shows the special behaviors explained previously.

Obviously, from the heat transfer point of view, P/D 1.5 shows the best results, but P/D 1.33 shows almost comparable performance. However and just as in a lot of engineering applications, the improvement of one variable causes a drawback in another; for with the increase in tube spacing comes the increase in refrigerant charge. For an optimum refrigerant charge, then, the P/D 1.33 seems to present the best results for the two refrigerants.

8.5 Conclusion

Based on the understanding of the boiling mechanism in tube enhancement and flow pattern in tube bundles, the trends of pool boiling and different bundle pitches can be clarified. Indeed, the persistent trend in all studied cases can be described as follows: the heat transfer coefficient experiences steep increase at low heat flux, decline at medium heat flux, and no change at high heat flux. Liquid feed to the tube tunnels seems to be a strong reason for this phenomenon. Excess liquid in the tunnels causes a performance decrease, and the tunnel dry-out causes the performance to revert to that of a smooth tube. Meanwhile, in tube bundles, the mass velocity has an insignificant effect on the performance. The smallest tube pitch for the two refrigerants shows the most varied behavior of all tested bundles. Additionally, flow restriction in the smallest tube pitch in both cases seems to be the reason for the significant low performance in R-134a, and tunnel dry-out for R-123. Therefore, P/D 1.33 seems to be the tube pitch offering optimum performance for the two refrigerants.

Chapter 9 Conclusion

The current research, funded by ASHRAE, addresses the experimental investigation of the heat transfer impact of tube pitch on highly enhanced tube bundle, which is particularly applicable for flooded evaporators. This study, considered the first to address the effect of tube pitch on enhanced tube bundles under convective heat transfer, focused on three tube pitches (P/D 1.167, 1.33, and 1.5) and two refrigerants (R-134a and R-123). The types of tubes are Turbo BII-HP for R-134a and Turbo BII-LP for R-123. The test section utilized 20 staggered tubes, designed as a four passes heat exchanger. Also, tube diameter and length are 0.01905 (0.75 inches) and 1 m (39.37 inch), respectively.

The water passage of the middle four tubes was instrumented with thermistors for measuring the local temperature; each tube carried seven thermistors, two for measuring tube inlet and outlet and five local thermistors. Water pressure measurement was also included. Also, refrigerant pressure and temperature were measured at each height of the bundle. Additionally, a pre-boiler was installed upstream of the test section for controlling the inlet vapor quality, and the test section and the pre-boiler were water heated.

The data analysis in this research is local to one location in the tube bundle and included determining the local heat transfer coefficient, local heat flux, and local quality. The tube average heat transfer coefficient was also determined. Next, water pressure was taken into account when determining the local and average heat flux. This introduced a new method called the Enthalpy Based Heat Transfer analysis or “EBHT,” which replaced the Log Mean Temperature or “LMTD”, as the former also accounts for energy added due to friction.

A Modified Wilson plot method was performed to determine the water-side heat transfer coefficient yielding the determined temperature measurement uncertainty as low as ± 0.015 °C. Also, a Monte Carlo-based simulation was devised for determining the uncertainty in the temperature slope, and the heat transfer coefficient uncertainty was calculated for each data point.

For the six tube bundles were tested, and before data collection began for each bundle, an energy balance between the water side and the refrigerant side was conducted to verify instrument accuracy. Then, data was collected according to a test matrix based on three

controlling variables: heat flux, mass flux, and inlet quality. The range of each variable was fixed for all six bundles to produce data helpful for comparison among the three bundles.

Pool (nucleate) boiling investigation was part of this study for which the trend of the heat transfer coefficient vs. heat flux was produced for each refrigerant-tube combination. Bundle results were presented as outcomes of the effect of heat flux, mass flux, and local quality on the heat transfer coefficient and bundle data were compared to the single tube data. All bundles results showed that flow convection has an insignificant effect on performance.

For R-134a results, the data showed that the performance is dominated mainly by heat flux. The smallest tube pitch (P/D 1.167) presented significantly lower results than did P/D 1.33 and P/D 1.5. Also, at low heat flux, all three tube bundles showed more enhancement than did nucleate boiling. Finally, the results for P/D 1.5 are slightly higher than for P/D 1.33. For R-123 results, all three bundles showed performance enhancement at low heat flux. Moreover, both heat flux and local quality have a significant effect on the bundle performance, with the effect of heat flux outweighing the effect of quality. At high qualities and for certain flow patterns, the P/D 1.167 bundle showed a rapid decrease in performance, reaching that of the smooth tube. This does not appear to be the case for the bigger tube pitches.

The trends in these results reveal that all bundles experience an increase in performance at low heat flux, a decrease at medium heat flux, and even trend at high heat flux. An interpretation for those trends according to flow mechanism in enhanced tubes and bundle flow pattern shows that the rate of liquid feed to the tunnels could be the main cause. Also, excess liquid in tunnels and tunnel dry-out have a negative effect on the tube performance. The rapid increase in performance in tube bundles is understood to be the result of faster pore activation caused by impinging two phase flow on the tubes. Ultimately, for optimum refrigerant charge, P/D 1.33 is the best tube pitch for optimal performance for both refrigerants.

Bibliography

- Arshad, J., and J.R. Thome. 1983. Enhanced boiling surfaces: Heat transfer mechanism and mixture boiling. *Proceedings of ASME-JSME Therm. Eng. Joint Conf* 1:191-197.
- Briggs, D.E, and E.H. Young. 1969. Modified wilson plot techniques for obtaining heat transfer correlations for shell and tube heat exchangers. *Chemical Engineering Progress Symposium Series* 65(92):35.
- Browne, M., and P. Bansal. 1999. Heat transfer characteristics of boiling phenomenon in flooded refrigerant evaporators. *Applied Thermal Engineering* 19(6):595-624.
- Casciari, S., and J.R. Thome. 2001. Thermal performance of flooded evaporators, part 1: Review of boiling heat transfer studies. *ASHRAE Transactions* 107:903-918.
- Casciari, S., and J.R. Thome. 2001. Thermal performance of flooded evaporators, part 2: Review of void fraction, two-phase pressure drop, and flow pattern studies. *ASHRAE Transactions* 107:919-930.
- Chien, L.H., and R. Webb. 1998. A parametric study of nucleate boiling on structured surfaces, part I: Effect of tunnel dimensions. *Journal of Heat Transfer* 120:1042.
- Chien, L.H., and R. Webb. 1998. A parametric study of nucleate boiling on structured surfaces, part II: Effect of pore diameter and pore pitch. *Journal of Heat Transfer* 120:1049.
- Chien, L.H., and J.S. Wu. 2004. Convective evaporation on plain tube and low-fin tube banks using R-123 and R-134a. *Transactions of ASHRAE* 110 (1): 101-8.
- Chyu, M.C., et al. 2009. Bundle effect of ammonia/lubricant mixture boiling on a horizontal bundle with enhanced tubing and inlet quality. *International Journal of Refrigeration* 32(8):1876-85.
- Collier, J.G., and J.R. Thome. 1994. *Convective boiling and condensation*, 3rd Ed. Oxford University Press, USA.
- Danilova, G., and V. Dyundin. 1972. Heat transfer with freons 12 and 22 boiling at bundles of finned tubes. *Heat Transfer: Soviet Research* 4(4):48-54.
- Dowlati, R., et al. 1990. Pitch-to-diameter effect on two-phase flow across an in-line tube bundle. *AIChE Journal* 36(5):765-72.
- Feenstra, P., et al. 2000. An improved void fraction model for two-phase cross-flow in horizontal tube bundles. *International Journal of Multiphase Flow* 26(11):1851-73.

- Fujita, Y., H. Ohta, S. Hidaka, and K. Nishikawa. Nucleate boiling heat transfer on horizontal tubes in bundles. *Proceedings of the 8th Int. Heat Transfer Conference* 5:2131-2136.
- Gnielinski, V. 1976. New equations for heat and mass transfer in turbulent pipe and channel flow. *Int.Chem.Eng* 16(2):359-68.
- Gorgy, E. I. 2008. *Pool boiling of R-134a and R-123 on smooth and enhanced tubes*. Kansas State University.
- Gupta, A. 2005. Enhancement of boiling heat transfer in a 5 3 tube bundle. *International Journal of Heat and Mass Transfer* 48(18):3763-72.
- Gupte, N. S., and R. L. Webb. 1992. Convective vaporization of refrigerants in tube banks. *Proceedings of ASHRAE Winter Meeting* 98:411-424.
- Gupte, N.S., and R.L. Webb. 1995. Shell-side boiling in flooded refrigerant evaporators part I: Integral finned tubes. *HVAC and R Research* 1(1):35-47.
- Gupte, N.S., and R.L. Webb. 1995. Shell-side boiling in flooded refrigerant evaporators part II: Enhanced tubes. *HVAC and R Research* 1(1):48-60.
- Hsu, J. -T, and M. K. Jensen. 1988. Effect of pitch-to-diameter ratio on crossflow boiling heat transfer in an inline tube bundle. *Proceedings of ASME, Collected Papers in Heat Transfer* 104:239-245.
- Jensen, M., and J.T. Hsu. 1988. A parametric study of boiling heat transfer in a horizontal tube bundle. *Journal of Heat Transfer* 110:976.
- Jensen, M.K., et al. 1989. Influence of tube bundle geometry on cross-flow boiling heat transfer and pressure drop. *Experimental Thermal and Fluid Science* 2(4):465-76.
- Jensen, Michael K., Richard R. Trewin, and Arthur E. Bergles. 1992. Crossflow boiling in enhanced tube bundles. *Proceedings of ASME, Winter Annual Meeting* 220:11-17.
- Kim, N.H., et al. 2002. Forced convective boiling of pure refrigerants in a bundle of enhanced tubes having pores and connecting gaps. *International Journal of Heat and Mass Transfer* 45(12):2449-63.
- Kline, S.J., and F. McClintock. 1953. Describing uncertainties in single-sample experiments. *Mechanical Engineering* 75(1):3-8.
- Liao, L., and Z.H. Liu. 2007. Enhanced boiling heat transfer of the compact staggered tube bundles under sub-atmospheric pressures. *Heat Transfer Engineering* 28(5): 444-50.
- Liu, Z.H., and Y.M. Chen. 2001. Enhancement of boiling heat transfer in restricted spaces in compact horizontal tube bundles. *Heat Transfer—Asian Research* 30(5):394-401.

- Liu, Z.H., and Y.H. Qiu. 2002. Enhanced boiling heat transfer in restricted spaces of a compact tube bundle with enhanced tubes. *Applied Thermal Engineering* 22(17):1931-41.
- Liu, Z.H., and T.F. Tong. 2002. Boiling heat transfer of water and R-11 on horizontally smooth and enhanced tubes enclosed by a concentric outer tube with two horizontal slots. *Experimental Heat Transfer* 15(3):161-75.
- Liu, Z., and L. Liao. 2006. Enhancement boiling heat transfer study of a newly compact in-line bundle evaporator under reduced pressure conditions. *Chemical Engineering and Technology* 29(3):408-13.
- Liu, Z., and Y. Qiu. 2004. Boiling heat transfer enhancement of water/salt mixtures on roll-worked enhanced tubes in compact staggered tube bundles. *Chemical Engineering and Technology* 27(11):1187-94.
- Liu, Z., and T. Tong. 2002. Boiling heat transfer of water and R-11 on horizontally smooth and enhanced tubes enclosed by a concentric outer tube with two horizontal slots. *Experimental Heat Transfer* 15(3):161-75.
- Memory, S., et al. 1994. Nucleate pool boiling of a TURBO-B bundle in R-113. *Journal of Heat Transfer* 116(3):670-8.
- Memory, S.B., SV Chilman, and PJ Marto. 1992. Nucleate boiling characteristics of a small enhanced tube bundle in a pool of R-113. *28th National Heat Transfer Conference and Exhibition* 129-138.
- Muller, J. 1986. Boiling heat transfer on finned tube bundles—the effect of tube position and intertube spacing. *Proceedings of the 8th International Heat Transfer Conference* 4:2111-2116.
- Nakayama, W., et al. 1980. Dynamic model of enhanced boiling heat transfer on porous Surfaces—Part I: Experimental investigation. *Journal of Heat Transfer* 102:445.
- Nakayama, W., et al. 1980. Dynamic model of enhanced boiling heat transfer on porous Surfaces—Part II: Analytical modeling. *Journal of Heat Transfer* 102:451.
- Nakayama, W., et al. 1982. Effects of pore diameters and system pressure on saturated pool nucleate boiling heat transfer from porous surfaces. *Journal of Heat Transfer* 104:286.
- Petukhov, B. 1970. Heat transfer and friction in turbulent pipe flow with variable physical properties. *Advances in Heat Transfer* 6:503-64.
- Qiu, Y., and Z. Liu. 2004. Boiling heat transfer of water on smooth tubes in a compact staggered tube bundle. *Applied Thermal Engineering* 24(10):1431-41.


- Ribatski, G., and J.R. Thome. 2007. Two-phase flow and heat transfer across horizontal tube bundles-a review. *Heat Transfer Engineering* 28(6):508-24.
- Robinson, D.M., and J. Thome. 2004. Local bundle boiling heat transfer coefficients on a integral finned tube bundle (RP-1089). *HVAC and R Research* 10(3):331-44.
- Robinson, D.M., and J.R. Thome. 2004. Local bundle boiling heat transfer coefficients on a plain tube bundle (RP-1089). *HVAC and R Research* 10(1):33-51.
- Robinson, D.M., and J.R. Thome. 2004. Local bundle boiling heat transfer coefficients on a turbo-BII HP tube bundle (RP-1089). *HVAC and R Research* 10(4):441-57.
- Schäfer, D., et al. 2007. The effect of novel plasma-coated compact tube bundles on pool boiling. *Heat Transfer Engineering* 28(1):19-24.
- Shah, M. 1976. A new correlation for heat transfer during boiling flow through pipes. *ASHRAE Trans* 82(2):66-86.
- Tatara, R.A., and P. Payvar. 2000. Effects of oil on boiling of replacement refrigerants flowing normal to a tube bundle - part I: R-123. *Proceedings of ASHRAE Winter Meeting* 106.
- Tatara, R.A., and P. Payvar. 2000. Effects of oil on boiling of replacement refrigerants flowing normal to a tube bundle - part II: R-134a. *Proceedings of ASHRAE Winter Meeting* 106.
- Tatara, R.A., and P. Payvar. 1999. Effects of oil on boiling R-123 and R-134a flowing normal to an integral-finned tube bundle. *ASHRAE Transactions* 105.
- Thome, J.R. 2004. *Engineering data book III of Wolverine Tube Inc.* Wolverine Tube Inc.
- Thome, J.R. 1996. Boiling of new refrigerants: A state-of-the-art review. *International Journal of Refrigeration* 19(7): 435-57.
- Thome, J.R. 1990. *Enhanced boiling heat transfer* Hemisphere Pub. Corp.
- Thome, J. 1998. Boiling and evaporation of fluorocarbon and other refrigerants: A state-of-the-art review. *Air-Conditioning and Refrigeration Institute (ARI), Arlington, Virginia.*
- Thome, J.R., and D.M. Robinson. 2006. Prediction of local bundle boiling heat transfer coefficients: Pure refrigerant boiling on plain, low fin, and turbo-BII HP tube bundles. *Heat Transfer Engineering* 27(10):20-9.
- Webb, R.L., and N-H Kim. 2005. *Principles of enhanced heat transfer*, 2nd Ed. Taylor & Francis, LLC
- Webb, R.L. 1991. Advances in shell side boiling of refrigerants. *Proceedings of the Institute of Refrigeration* 87: 75-86.

Webb, R.L. 2004. Odyssey of the enhanced boiling surface. *Journal of Heat Transfer* 126(6):1051-9.


Liu, Z-H., and Y-H. Qiu. 2004. Boiling characteristics of R-11 in compact tube bundles with smooth and enhanced tubes. *Experimental Heat Transfer* 17(2)(04):91-102.

Liu, Z-H., and Y-H. Qiu. 2002. Enhanced boiling heat transfer in restricted spaces of a compact tube bundle with enhanced tubes. *Applied Thermal Engineering* 22(17)(12):1931-41.


Appendix A Test Section Drawings




P/D 1.167
FULL SECTION ISOMETRIC
DIMENSIONS IN INCHES




P/D 1.167
FULL SECTION - SIDE VIEW
DIMENSIONS IN INCHES





P/D 1.167
FULL SECTION - HIDDEN SIDE
DIMENSIONS IN INCHES




SECTION L-L




P/D 1.167
FRONT SECTION VIEW



P/D 1.167
WATER INLET DETAIL VIEW
DIMENSIONS IN INCHES




P/D 1.167
REFRIGERANT INSTRUMENTATION DETAIL VIEW
DIMENSIONS IN INCHES




P/D 1.167
FULL SECTION - SIDE SECTION VIEW
DIMENSIONS IN INCHES


P/D 1.167



P/D 1.33





P/D 1.5





FULL TEST SECTION
TUBE PITCH COMPARISON


Appendix B Visuals of the Test Facility














Refrigerant Flowmeter Transmitter


Test Section



Refrigerant Supply Line

Refrigerant Supply Line


Refrigerant Flowmeter



Pre-boiler Secondary Heat Exchanger
Circulation Pump







Appendix C Boiling Visuals









Appendix D Example of an Uncertainty Worksheet

The following pages show a screen shot of a MathCad worksheet (due to the difficulty of importing a MathCad worksheet directly into MS Word) of one test run. The table at the beginning of the worksheet lists all the variables needed for calculating the heat transfer coefficient uncertainty. This table was generated and copied from the MS Excel file of the same run. The uncertainty analysis was calculated for each tube. It starts with the average heat transfer coefficient then the five local heat transfer coefficient. The uncertainty analysis was discussed at length in the Section 4.10.

Data :=

	0	1	2	3	4	5	6	7
0	"Flow Rate (kg/s)"	""	"Pw,in (kPa)"	"Ti (°C) "	"T1 (°C) "	"T2 (°C) "	"T3 (°C) "	"T4 (°C) "
1	0.281	""	752.765	14.631	13.817	13.092	12.415	11.787
2	0.281	""	621.755	10.683	10.295	9.839	9.333	8.927
3	0.281	""	521.755	8.211	7.903	7.558	7.222	6.912
4	0.281	""	365.386	6.523	6.369	6.19	6.017	...

$$A_o := \pi \cdot 0.75 \cdot 0.0254 \cdot 1$$

$$\dot{m} := \text{Data}_{1,0}$$

Tube A1

Average Heat Transfer Coefficient Uncertainty Calculation

$$\dot{m}_{\text{dot}} := \frac{0.1}{100} \cdot \dot{m}$$

$$\rho_1 := \text{Data}_{1,15}$$

$$u_{\rho_1} := 7 \cdot 10^{-13} \cdot \rho_1$$

$$\Delta P_1 := (\text{Data}_{1,10} - \text{Data}_{1,2}) \cdot \frac{1 \text{ m}}{59.5 \text{ in}} \cdot 1000$$

$$u_{\Delta P} := \sqrt{2} \cdot 1034.21359$$

$$T_{\text{inlet1}} := \text{Data}_{1,3}$$

$$T_{\text{outlet1}} := \text{Data}_{1,9}$$

$$u_T := 0.015$$

$$C_{p1} := 1000 \cdot \text{Data}_{1,13}$$

$$u_{C_{p1}} := 6 \cdot 10^{-14} \cdot C_{p1}$$

$$h_{w1} := \text{Data}_{1,29}$$

$$u_{h_{w1}} := 0.04 \cdot h_{w1}$$

$$R_w := \text{Data}_{1,30}$$

$$T_{\text{sat1}} := \text{Data}_{1,19}$$

$$u_{T_{\text{sat}}} := 0.022$$

$$h_{A1}(\dot{m}, C_{p1}, T_{\text{inlet1}}, T_{\text{outlet1}}, T_{\text{sat1}}, \rho_1, \Delta P_1, h_{w1}) := \left[\frac{1}{\dot{m} \cdot C_{p1} \cdot (T_{\text{inlet1}} - T_{\text{outlet1}}) + \dot{m} \cdot \frac{1}{\rho_1} \cdot (-\Delta P_1)} - A_o \cdot R_w - \frac{1}{h_{w1}} \cdot \frac{0.75}{0.7} \right]^{-1} \cdot \frac{T_{\text{inlet1}} - T_{\text{outlet1}}}{\ln \left(\frac{T_{\text{inlet1}} - T_{\text{sat1}}}{T_{\text{outlet1}} - T_{\text{sat1}}} \right) \cdot \pi \cdot 0.75 \cdot 0.0254}$$

$$u_{h_{A1}} := \left[\left[\left(\frac{d}{d\dot{m}} h_{A1}(\dot{m}, C_{p1}, T_{\text{inlet1}}, T_{\text{outlet1}}, T_{\text{sat1}}, \rho_1, \Delta P_1, h_{w1}) \right) \cdot u_{\dot{m}} \right]^2 + \left[\left(\frac{d}{dC_{p1}} h_{A1}(\dot{m}, C_{p1}, T_{\text{inlet1}}, T_{\text{outlet1}}, T_{\text{sat1}}, \rho_1, \Delta P_1, h_{w1}) \right) \cdot u_{C_{p1}} \right]^2 + \left[\left(\frac{d}{dT_{\text{inlet1}}} h_{A1}(\dot{m}, C_{p1}, T_{\text{inlet1}}, T_{\text{outlet1}}, T_{\text{sat1}}, \rho_1, \Delta P_1, h_{w1}) \right) \cdot u_T \right]^2 + \left[\left(\frac{d}{dT_{\text{outlet1}}} h_{A1}(\dot{m}, C_{p1}, T_{\text{inlet1}}, T_{\text{outlet1}}, T_{\text{sat1}}, \rho_1, \Delta P_1, h_{w1}) \right) \cdot u_T \right]^2 + \left[\left(\frac{d}{dT_{\text{sat1}}} h_{A1}(\dot{m}, C_{p1}, T_{\text{inlet1}}, T_{\text{outlet1}}, T_{\text{sat1}}, \rho_1, \Delta P_1, h_{w1}) \right) \cdot u_{T_{\text{sat}}} \right]^2 + \left[\left(\frac{d}{d\rho_1} h_{A1}(\dot{m}, C_{p1}, T_{\text{inlet1}}, T_{\text{outlet1}}, T_{\text{sat1}}, \rho_1, \Delta P_1, h_{w1}) \right) \cdot u_{\rho_1} \right]^2 + \left[\left(\frac{d}{d\Delta P_1} h_{A1}(\dot{m}, C_{p1}, T_{\text{inlet1}}, T_{\text{outlet1}}, T_{\text{sat1}}, \rho_1, \Delta P_1, h_{w1}) \right) \cdot u_{\Delta P} \right]^2 + \left[\left(\frac{d}{dh_{w1}} h_{A1}(\dot{m}, C_{p1}, T_{\text{inlet1}}, T_{\text{outlet1}}, T_{\text{sat1}}, \rho_1, \Delta P_1, h_{w1}) \right) \cdot u_{h_{w1}} \right]^2 \right]^{0.5}$$

$$uha_{A1} = 153.788$$

$$\frac{uha_{A1}}{Data_{1,31}} \cdot 100 = 1.249$$

Local Heat Transfer Coefficient Uncertainty Calculations

$$\Delta P \Delta x_{A1} = \frac{-(Data_{1,10} - Data_{1,2}) \cdot 1000}{59.5 \cdot 0.0254}$$

Monte Carlo Simulation For Determining The Uncertainty in dT/dx

$$Ti_{A1} := Data_{1,3}$$

$$T1_{A1} := Data_{1,32}$$

$$T1a_{A1} := Data_{1,4}$$

$$T2_{A1} := Data_{1,33}$$

$$T2a_{A1} := Data_{1,5}$$

$$T3_{A1} := Data_{1,34}$$

$$T3a_{A1} := Data_{1,6}$$

$$T4_{A1} := Data_{1,35}$$

$$T4a_{A1} := Data_{1,7}$$

$$T5_{A1} := Data_{1,36}$$

$$T5a_{A1} := Data_{1,8}$$

$$To_{A1} := Data_{1,9}$$

$$i := 0..12000$$

$$Z_1 := \text{mom}(7, 0, 0.0075)$$

$$TT_{A1_i} = \begin{pmatrix} Ti_{A1} \\ T1_{A1} \\ T2_{A1} \\ T3_{A1} \\ T4_{A1} \\ T5_{A1} \\ To_{A1} \end{pmatrix} + Z_1 \quad \text{Dist}_1 = \begin{pmatrix} 0 \\ 0.17 \\ 0.33 \\ 0.5 \\ 0.67 \\ 0.83 \\ 1 \end{pmatrix}$$

$$REG_{A1_i} := \text{regress}(\text{Dist}_1, TT_{A1_i}, 2)$$

$$Un17_{A1_i} = \frac{2 \left(REG_{A1_i} \right)_5 \cdot (0.17) + \left(REG_{A1_i} \right)_4 - Data_{1,37}}{Data_{1,37}}$$

$$Un33_{A1_i} = \frac{2 \left(REG_{A1_i} \right)_5 \cdot (0.33) + \left(REG_{A1_i} \right)_4 - Data_{1,38}}{Data_{1,38}}$$

$$Un50_{A1_i} = \frac{2 \left(REG_{A1_i} \right)_5 \cdot (0.5) + \left(REG_{A1_i} \right)_4 - Data_{1,39}}{Data_{1,39}}$$

$$Un67_{A1_i} = \frac{2 \left(REG_{A1_i} \right)_5 \cdot (0.67) + \left(REG_{A1_i} \right)_4 - Data_{1,40}}{Data_{1,40}}$$

$$Un83_{A1_i} = \frac{2 \left(REG_{A1_i} \right)_5 \cdot (0.83) + \left(REG_{A1_i} \right)_4 - Data_{1,41}}{Data_{1,41}}$$

$$TT_{A1_i} = \begin{pmatrix} T_{iA1} \\ T1_{A1} \\ T2_{A1} \\ T3_{A1} \\ T4_{A1} \\ T5_{A1} \\ T_{oA1} \end{pmatrix} + Z_i \quad \text{Dist}_i = \begin{pmatrix} 0 \\ 0.17 \\ 0.33 \\ 0.5 \\ 0.67 \\ 0.83 \\ 1 \end{pmatrix}$$

$$REG_{A1_i} = \text{regress}(\text{Dist}_i, TT_{A1_i}, 2)$$

$$Un17_{A1_i} = \frac{[2 \cdot (REG_{A1_i})_5 \cdot (0.17) + (REG_{A1_i})_4 - \text{Data}_{1,37}]}{\text{Data}_{1,37}}$$

$$Un33_{A1_i} = \frac{[2 \cdot (REG_{A1_i})_5 \cdot (0.33) + (REG_{A1_i})_4 - \text{Data}_{1,38}]}{\text{Data}_{1,38}}$$

$$Un50_{A1_i} = \frac{[2 \cdot (REG_{A1_i})_5 \cdot (0.5) + (REG_{A1_i})_4 - \text{Data}_{1,39}]}{\text{Data}_{1,39}}$$

$$Un67_{A1_i} = \frac{[2 \cdot (REG_{A1_i})_5 \cdot (0.67) + (REG_{A1_i})_4 - \text{Data}_{1,40}]}{\text{Data}_{1,40}}$$

$$Un83_{A1_i} = \frac{[2 \cdot (REG_{A1_i})_5 \cdot (0.83) + (REG_{A1_i})_4 - \text{Data}_{1,41}]}{\text{Data}_{1,41}}$$

$$udTdx_{A1} = \begin{pmatrix} \text{sort}(Un17_{A1})_{11400} \\ \text{sort}(Un33_{A1})_{11400} \\ \text{sort}(Un50_{A1})_{11400} \\ \text{sort}(Un67_{A1})_{11400} \\ \text{sort}(Un83_{A1})_{11400} \end{pmatrix}$$

$$dTdx1_{A1} = \text{Data}_{1,42}$$

$$uT1_{A1} = \sqrt{uT^2 + [dTdx1_{A1} \cdot (1.5875 \times 10^{-3})]^2}$$

$$dTdx2_{A1} = \text{Data}_{1,43}$$

$$uT2_{A1} = \sqrt{uT^2 + [dTdx2_{A1} \cdot (1.5875 \times 10^{-3})]^2}$$

$$dTdx3_{A1} = \text{Data}_{1,44}$$

$$uT3_{A1} = \sqrt{uT^2 + [dTdx3_{A1} \cdot (1.5875 \times 10^{-3})]^2}$$

$$dTdx4_{A1} = \text{Data}_{1,45}$$

$$uT4_{A1} = \sqrt{uT^2 + [dTdx4_{A1} \cdot (1.5875 \times 10^{-3})]^2}$$

$$dTdx5_{A1} = \text{Data}_{1,46}$$

$$uT5_{A1} = \sqrt{uT^2 + [dTdx5_{A1} \cdot (1.5875 \times 10^{-3})]^2}$$

1st Local HTC Uncertainty Calculation

$$h1_{A1}(T1_{A1}, Tsat1, \text{mdot}, Cp1, dTdx1_{A1}, \rho1, \Delta P \Delta x_{A1}, hw1) := \left[\frac{(T1_{A1} - Tsat1)}{\text{mdot} \cdot Cp1 \cdot dTdx1_{A1} + \text{mdot} \cdot \frac{1}{\rho1} \cdot \Delta P \Delta x_{A1}} - A_o R_w - \frac{1}{hw1} \cdot \frac{0.75}{0.7}}{\pi \cdot 0.75 \cdot 0.0254} \right]^{-1}$$

$$udTdx_{A1} := \begin{pmatrix} \text{sort}(\text{Un17}_{A1})_{11400} \\ \text{sort}(\text{Un33}_{A1})_{11400} \\ \text{sort}(\text{Un50}_{A1})_{11400} \\ \text{sort}(\text{Un67}_{A1})_{11400} \\ \text{sort}(\text{Un83}_{A1})_{11400} \end{pmatrix}$$

$$\begin{aligned} dTdx1_{A1} &:= \text{Data}_{1,42} & uT1a_{A1} &:= \sqrt{uT^2 + [dTdx1_{A1} \cdot (1.5875 \times 10^{-3})]^2} \\ dTdx2_{A1} &:= \text{Data}_{1,43} & uT2a_{A1} &:= \sqrt{uT^2 + [dTdx2_{A1} \cdot (1.5875 \times 10^{-3})]^2} \\ dTdx3_{A1} &:= \text{Data}_{1,44} & uT3a_{A1} &:= \sqrt{uT^2 + [dTdx3_{A1} \cdot (1.5875 \times 10^{-3})]^2} \\ dTdx4_{A1} &:= \text{Data}_{1,45} & uT4a_{A1} &:= \sqrt{uT^2 + [dTdx4_{A1} \cdot (1.5875 \times 10^{-3})]^2} \\ dTdx5_{A1} &:= \text{Data}_{1,46} & uT5a_{A1} &:= \sqrt{uT^2 + [dTdx5_{A1} \cdot (1.5875 \times 10^{-3})]^2} \end{aligned}$$

1st Local HTC Uncertainty Calculation

$$h1_{A1}(T1a_{A1}, Tsat1, \text{mdot}, Cp1, dTdx1_{A1}, \rho1, \Delta P\Delta x_{A1}, hwl) := \left[\frac{(T1a_{A1} - Tsat1)}{\text{mdot} \cdot Cp1 \cdot dTdx1_{A1} + \text{mdot} \cdot \frac{1}{\rho1} \cdot \Delta P\Delta x_{A1}} - A_o \cdot R_w - \frac{1}{hwl} \cdot \frac{0.75}{0.7} \right]^{-1}$$

$$uh1_{A1} := \left[\left[\left(\frac{d}{dT1a_{A1}} h1_{A1}(T1a_{A1}, Tsat1, \text{mdot}, Cp1, dTdx1_{A1}, \rho1, \Delta P\Delta x_{A1}, hwl) \right) \cdot uT1a_{A1} \right]^2 + \left[\left(\frac{d}{dTsat1} h1_{A1}(T1a_{A1}, Tsat1, \text{mdot}, Cp1, dTdx1_{A1}, \rho1, \Delta P\Delta x_{A1}, hwl) \right) \cdot uTsat \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{d\text{mdot}} h1_{A1}(T1a_{A1}, Tsat1, \text{mdot}, Cp1, dTdx1_{A1}, \rho1, \Delta P\Delta x_{A1}, hwl) \right) \cdot u\text{mdot} \right]^2 + \left[\left(\frac{d}{dCp1} h1_{A1}(T1a_{A1}, Tsat1, \text{mdot}, Cp1, dTdx1_{A1}, \rho1, \Delta P\Delta x_{A1}, hwl) \right) \cdot uCp1 \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dTdx1_{A1}} h1_{A1}(T1a_{A1}, Tsat1, \text{mdot}, Cp1, dTdx1_{A1}, \rho1, \Delta P\Delta x_{A1}, hwl) \right) \cdot dTdx1_{A1} \cdot uTdx_{A10} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{d\rho1} h1_{A1}(T1a_{A1}, Tsat1, \text{mdot}, Cp1, dTdx1_{A1}, \rho1, \Delta P\Delta x_{A1}, hwl) \right) \cdot u\rho1 \right]^2 + \left[\left(\frac{d}{d\Delta P\Delta x_{A1}} h1_{A1}(T1a_{A1}, Tsat1, \text{mdot}, Cp1, dTdx1_{A1}, \rho1, \Delta P\Delta x_{A1}, hwl) \right) \cdot u\Delta P \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dhwl} h1_{A1}(T1a_{A1}, Tsat1, \text{mdot}, Cp1, dTdx1_{A1}, \rho1, \Delta P\Delta x_{A1}, hwl) \right) \cdot uhwl \right]^2 \right]^{0.5}$$

$$\frac{uh1_{A1}}{\text{Data}_{1,47}} \cdot 100 = 1.251$$

2nd Local HTC Uncertainty Calculation

$$h_{L2A1}(T_{2aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx2A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) = \left[\frac{(T_{2aA1} - T_{sat1})}{\frac{\dot{m} \cdot Cp1 \cdot dT_{dx2A1} + \dot{m} \cdot \frac{1}{\rho1} \cdot \Delta P_{\Delta x_{A1}}}{\pi \cdot 0.75 \cdot 0.0254}} - A_o \cdot R_w - \frac{1}{hw1} \cdot \frac{0.75}{0.7}} \right]^{-1}$$

$$u_{hL2A1} = \left[\left[\left(\frac{d}{dT_{2aA1}} h_{L2A1}(T_{2aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx2A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) \right) \cdot u_{T_{2aA1}} \right]^2 + \left[\left(\frac{d}{dT_{sat1}} h_{L2A1}(T_{2aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx2A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) \right) \cdot u_{T_{sat1}} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{d\dot{m}} h_{L2A1}(T_{2aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx2A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) \right) \cdot u_{\dot{m}} \right]^2 + \left[\left(\frac{d}{dCp1} h_{L2A1}(T_{2aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx2A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) \right) \cdot u_{Cp1} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dT_{dx2A1}} h_{L2A1}(T_{2aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx2A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) \right) \cdot dT_{dx2A1} \cdot u_{dT_{dx2A1}} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{d\rho1} h_{L2A1}(T_{2aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx2A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) \right) \cdot u_{\rho1} \right]^2 + \left[\left(\frac{d}{d\Delta P_{\Delta x_{A1}}} h_{L2A1}(T_{2aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx2A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) \right) \cdot u_{\Delta P} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dhw1} h_{L2A1}(T_{2aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx2A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) \right) \cdot u_{hw1} \right]^2 \right]^{-0.5}$$

$$\frac{u_{hL2A1}}{Data_{1,48}} \cdot 100 = 1.843$$

3rd Local HTC Uncertainty Calculation

$$h_{L3A1}(T_{3aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx3A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) = \left[\frac{(T_{3aA1} - T_{sat1})}{\frac{\dot{m} \cdot Cp1 \cdot dT_{dx3A1} + \dot{m} \cdot \frac{1}{\rho1} \cdot \Delta P_{\Delta x_{A1}}}{\pi \cdot 0.75 \cdot 0.0254}} - A_o \cdot R_w - \frac{1}{hw1} \cdot \frac{0.75}{0.7}} \right]^{-1}$$

$$u_{hL3A1} = \left[\left[\left(\frac{d}{dT_{3aA1}} h_{L3A1}(T_{3aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx3A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) \right) \cdot u_{T_{3aA1}} \right]^2 + \left[\left(\frac{d}{dT_{sat1}} h_{L3A1}(T_{3aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx3A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) \right) \cdot u_{T_{sat1}} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{d\dot{m}} h_{L3A1}(T_{3aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx3A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) \right) \cdot u_{\dot{m}} \right]^2 + \left[\left(\frac{d}{dCp1} h_{L3A1}(T_{3aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx3A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) \right) \cdot u_{Cp1} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dT_{dx3A1}} h_{L3A1}(T_{3aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx3A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) \right) \cdot dT_{dx3A1} \cdot u_{dT_{dx3A1}} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{d\rho1} h_{L3A1}(T_{3aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx3A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) \right) \cdot u_{\rho1} \right]^2 + \left[\left(\frac{d}{d\Delta P_{\Delta x_{A1}}} h_{L3A1}(T_{3aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx3A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) \right) \cdot u_{\Delta P} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dhw1} h_{L3A1}(T_{3aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx3A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) \right) \cdot u_{hw1} \right]^2 \right]^{-0.5}$$

$$\frac{u_{hL3A1}}{Data_{1,49}} \cdot 100 = 2.068$$

4th Local HTC Uncertainty Calculation

$$h_{L4A1}(T_{4aA1}, T_{sat1}, \dot{m}, Cp1, dT_{dx4A1}, \rho1, \Delta P_{\Delta x_{A1}}, hw1) = \left[\frac{(T_{4aA1} - T_{sat1})}{\frac{\dot{m} \cdot Cp1 \cdot dT_{dx4A1} + \dot{m} \cdot \frac{1}{\rho1} \cdot \Delta P_{\Delta x_{A1}}}{\pi \cdot 0.75 \cdot 0.0254}} - A_o \cdot R_w - \frac{1}{hw1} \cdot \frac{0.75}{0.7}} \right]^{-1}$$

$$uhl4_{A1} := \left[\left[\left(\frac{d}{dT4_{A1}} hL4_{A1}(T4_{A1}, Tsat1, mdot, Cp1, dTdx4_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) \right) \cdot uT4_{A1} \right]^2 + \left[\left(\frac{d}{dTsat1} hL4_{A1}(T4_{A1}, Tsat1, mdot, Cp1, dTdx4_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) \right) \cdot uTsat \right]^2 \dots \right]^{0.5}$$

$$+ \left[\left(\frac{d}{dmdot} hL4_{A1}(T4_{A1}, Tsat1, mdot, Cp1, dTdx4_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) \right) \cdot umdot \right]^2 + \left[\left(\frac{d}{dCp1} hL4_{A1}(T4_{A1}, Tsat1, mdot, Cp1, dTdx4_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) \right) \cdot uCp1 \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dTdx4_{A1}} hL4_{A1}(T4_{A1}, Tsat1, mdot, Cp1, dTdx4_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) \right) \cdot dTdx4_{A1} \cdot udTdx_{A13} \right]^2 \dots$$

$$+ \left[\left(\frac{d}{d\rho1} hL4_{A1}(T4_{A1}, Tsat1, mdot, Cp1, dTdx4_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) \right) \cdot u\rho1 \right]^2 + \left[\left(\frac{d}{d\Delta P \Delta x_{A1}} hL4_{A1}(T4_{A1}, Tsat1, mdot, Cp1, dTdx4_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) \right) \cdot u\Delta P \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dhwl} hL4_{A1}(T4_{A1}, Tsat1, mdot, Cp1, dTdx4_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) \right) \cdot uhwl \right]^2$$

$$\frac{uhl4_{A1}}{Data_{1,50}} \cdot 100 = 1.944$$

5th Local HTC Uncertainty Calculation

$$hl5_{A1}(T5_{A1}, Tsat1, mdot, Cp1, dTdx5_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) := \left[\frac{(T5_{A1} - Tsat1)}{\frac{mdot \cdot Cp1 \cdot dTdx5_{A1} + mdot \cdot \frac{1}{\rho1} \cdot \Delta P \Delta x_{A1}}{\pi \cdot 0.75 \cdot 0.0254}} - Ao \cdot Rw - \frac{1}{hw1} \cdot \frac{0.75}{0.7}} \right]^{-1}$$

$$uhl5_{A1} := \left[\left[\left(\frac{d}{dT5_{A1}} hl5_{A1}(T5_{A1}, Tsat1, mdot, Cp1, dTdx5_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) \right) \cdot uT5_{A1} \right]^2 + \left[\left(\frac{d}{dTsat1} hl5_{A1}(T5_{A1}, Tsat1, mdot, Cp1, dTdx5_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) \right) \cdot uTsat \right]^2 \dots \right]^{0.5}$$

$$+ \left[\left(\frac{d}{dmdot} hl5_{A1}(T5_{A1}, Tsat1, mdot, Cp1, dTdx5_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) \right) \cdot umdot \right]^2 + \left[\left(\frac{d}{dCp1} hl5_{A1}(T5_{A1}, Tsat1, mdot, Cp1, dTdx5_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) \right) \cdot uCp1 \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dTdx5_{A1}} hl5_{A1}(T5_{A1}, Tsat1, mdot, Cp1, dTdx5_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) \right) \cdot dTdx5_{A1} \cdot udTdx_{A14} \right]^2 \dots$$

$$+ \left[\left(\frac{d}{d\rho1} hl5_{A1}(T5_{A1}, Tsat1, mdot, Cp1, dTdx5_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) \right) \cdot u\rho1 \right]^2 + \left[\left(\frac{d}{d\Delta P \Delta x_{A1}} hl5_{A1}(T5_{A1}, Tsat1, mdot, Cp1, dTdx5_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) \right) \cdot u\Delta P \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dhwl} hl5_{A1}(T5_{A1}, Tsat1, mdot, Cp1, dTdx5_{A1}, \rho1, \Delta P \Delta x_{A1}, hwl) \right) \cdot uhwl \right]^2$$

$$\frac{uhl5_{A1}}{Data_{1,51}} \cdot 100 = 1.349$$

Tube A2

Average Heat Transfer Coefficient Uncertainty Calculation

$$\rho2 := Data_{2,15}$$

$$up2 := 7 \cdot 10^{-13} \cdot \rho2$$

$$\Delta P2 := (Data_{2,10} - Data_{2,2}) \cdot \frac{1m}{59.5in} \cdot 1000$$

$$Tinlet2 := Data_{2,3}$$

$$Toutlet2 := Data_{2,9}$$

$$Cp2 := 1000 \cdot Data_{2,13}$$

$$u_{Cp2} = 6 \cdot 10^{-14} \cdot Cp2$$

$$hw2 := Data_{2,29}$$

$$uhw2 := 0.04 \cdot hw2$$

$$T_{sat2} := Data_{2,19}$$

$$ha_{A2}(mdot, Cp2, Tinlet2, Toutlet2, T_{sat2}, \rho2, \Delta P2, hw2) := \left[\frac{1}{mdot \cdot Cp2 \cdot (T_{inlet2} - T_{outlet2}) + mdot \cdot \frac{1}{\rho2} \cdot (-\Delta P2)} - A_o \cdot R_w - \frac{1}{hw2} \cdot \frac{0.75}{0.7}} \right]^{-1} \cdot \frac{T_{inlet2} - T_{outlet2}}{\ln\left(\frac{T_{inlet2} - T_{sat2}}{T_{outlet2} - T_{sat2}}\right) \cdot \pi \cdot 0.75 \cdot 0.0254}$$

$$uha_{A2} := \left[\left[\left(\frac{d}{dmdot} \cdot ha_{A2}(mdot, Cp2, Tinlet2, Toutlet2, T_{sat2}, \rho2, \Delta P2, hw2) \right) \cdot umdot \right]^2 + \left[\left(\frac{d}{dCp2} \cdot ha_{A2}(mdot, Cp2, Tinlet2, Toutlet2, T_{sat2}, \rho2, \Delta P2, hw2) \right) \cdot uCp2 \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dT_{inlet2}} \cdot ha_{A2}(mdot, Cp2, Tinlet2, Toutlet2, T_{sat2}, \rho2, \Delta P2, hw2) \right) \cdot uT \right]^2 + \left[\left(\frac{d}{dT_{outlet2}} \cdot ha_{A2}(mdot, Cp2, Tinlet2, Toutlet2, T_{sat2}, \rho2, \Delta P2, hw2) \right) \cdot uT \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dT_{sat2}} \cdot ha_{A2}(mdot, Cp2, Tinlet2, Toutlet2, T_{sat2}, \rho2, \Delta P2, hw2) \right) \cdot uT_{sat} \right]^2 + \left[\left(\frac{d}{d\rho2} \cdot ha_{A2}(mdot, Cp2, Tinlet2, Toutlet2, T_{sat2}, \rho2, \Delta P2, hw2) \right) \cdot u\rho2 \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{d\Delta P2} \cdot ha_{A2}(mdot, Cp2, Tinlet2, Toutlet2, T_{sat2}, \rho2, \Delta P2, hw2) \right) \cdot u\Delta P \right]^2 + \left[\left(\frac{d}{dhw2} \cdot ha_{A2}(mdot, Cp2, Tinlet2, Toutlet2, T_{sat2}, \rho2, \Delta P2, hw2) \right) \cdot uhw2 \right]^2 \right]^{0.5}$$

$$uha_{A2} = 224.173$$

$$\frac{uha_{A2}}{Data_{2,31}} \cdot 100 = 1.712$$

Local Heat Transfer Coefficient Uncertainty Calculations

$$\Delta P \Delta x_{A2} = \frac{-(Data_{2,10} - Data_{2,2}) \cdot 1000}{59.5 \cdot 0.0254}$$

Monte Carlo Simulation For Determining The Uncertainty in dT/dx

$$T_{1A2} := Data_{2,3}$$

$$T_{1A2} := Data_{2,32}$$

$$T_{2A2} := Data_{2,33}$$

$$T_{3A2} := Data_{2,34}$$

$$T_{4A2} := Data_{2,35}$$

$$T_{5A2} := Data_{2,36}$$

$$T_{oA2} := Data_{2,9}$$

$$T_{1aA2} := Data_{2,4}$$

$$T_{2aA2} := Data_{2,5}$$

$$T_{3aA2} := Data_{2,6}$$

$$T_{4aA2} := Data_{2,7}$$

$$T_{5aA2} := Data_{2,8}$$

$$i := 0..12000$$

$$Z_1 := \text{norm}(7, 0, 0.0075)$$

$$TT_{A2,1} = \begin{pmatrix} T_{iA2} \\ T1_{A2} \\ T2_{A2} \\ T3_{A2} \\ T4_{A2} \\ T5_{A2} \\ T_{oA2} \end{pmatrix} + Z_i$$

$$REG_{A2,1} = \text{regress}(\text{Dist}_1, TT_{A2,1}, 2)$$

$$Un17_{A2,1} = \frac{2 \left((REG_{A2,1})_5 \cdot (0.17) + (REG_{A2,1})_4 - \text{Data}_{2,37} \right)}{\text{Data}_{2,37}}$$

$$Un33_{A2,1} = \frac{2 \left((REG_{A2,1})_5 \cdot (0.33) + (REG_{A2,1})_4 - \text{Data}_{2,38} \right)}{\text{Data}_{2,38}}$$

$$Un50_{A2,1} = \frac{2 \left((REG_{A2,1})_5 \cdot (0.5) + (REG_{A2,1})_4 - \text{Data}_{2,39} \right)}{\text{Data}_{2,39}}$$

$$Un67_{A2,1} = \frac{2 \left((REG_{A2,1})_5 \cdot (0.67) + (REG_{A2,1})_4 - \text{Data}_{2,40} \right)}{\text{Data}_{2,40}}$$

$$Un83_{A2,1} = \frac{2 \left((REG_{A2,1})_5 \cdot (0.83) + (REG_{A2,1})_4 - \text{Data}_{2,41} \right)}{\text{Data}_{2,41}}$$

$$udTdx_{A2} = \begin{pmatrix} \text{sort}(Un17_{A2})_{11400} \\ \text{sort}(Un33_{A2})_{11400} \\ \text{sort}(Un50_{A2})_{11400} \\ \text{sort}(Un67_{A2})_{11400} \\ \text{sort}(Un83_{A2})_{11400} \end{pmatrix}$$

$$dTdx1_{A2} = \text{Data}_{2,42} \quad uT1_{A2} = \sqrt{uT^2 + \left[dTdx1_{A2} \cdot (1.5875 \times 10^{-3}) \right]^2}$$

$$dTdx2_{A2} = \text{Data}_{2,43} \quad uT2_{A2} = \sqrt{uT^2 + \left[dTdx2_{A2} \cdot (1.5875 \times 10^{-3}) \right]^2}$$

$$dTdx3_{A2} = \text{Data}_{2,44} \quad uT3_{A2} = \sqrt{uT^2 + \left[dTdx3_{A2} \cdot (1.5875 \times 10^{-3}) \right]^2}$$

$$dTdx4_{A2} = \text{Data}_{2,45} \quad uT4_{A2} = \sqrt{uT^2 + \left[dTdx4_{A2} \cdot (1.5875 \times 10^{-3}) \right]^2}$$

$$dTdx5_{A2} = \text{Data}_{2,46} \quad uT5_{A2} = \sqrt{uT^2 + \left[dTdx5_{A2} \cdot (1.5875 \times 10^{-3}) \right]^2}$$

1st Local HTC Uncertainty Calculation

$$hll_{A2}(T1_{A2}, Tsat, mdot, Cp2, dTdx1_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) = \left[\frac{(T1_{A2} - Tsat)}{\frac{mdot \cdot Cp2 \cdot dTdx1_{A2} + mdot \cdot \frac{1}{\rho2} \cdot \Delta P \Delta x_{A2}}{\pi \cdot 0.75 \cdot 0.0254}} - A_o \cdot R_w - \frac{1}{hw2} \cdot \frac{0.75}{0.7}} \right]^{-1}$$

$$uh1_{A2} = \left[\left[\left(\frac{d}{dT1_{A2}} h1_{A2}(T1_{A2}, Tsat2, m\dot{c}p2, dTdx1_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uT1_{A2} \right]^2 + \left[\left(\frac{d}{dTsat2} h1_{A2}(T1_{A2}, Tsat2, m\dot{c}p2, dTdx1_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uTsat2 \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dm\dot{c}p2} h1_{A2}(T1_{A2}, Tsat2, m\dot{c}p2, dTdx1_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot um\dot{c}p2 \right]^2 + \left[\left(\frac{d}{d\rho2} h1_{A2}(T1_{A2}, Tsat2, m\dot{c}p2, dTdx1_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot u\rho2 \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dTdx1_{A2}} h1_{A2}(T1_{A2}, Tsat2, m\dot{c}p2, dTdx1_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot dTdx1_{A2} \cdot udTdx_{A2_0} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dP} h1_{A2}(T1_{A2}, Tsat2, m\dot{c}p2, dTdx1_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uP \right]^2 + \left[\left(\frac{d}{dhw2} h1_{A2}(T1_{A2}, Tsat2, m\dot{c}p2, dTdx1_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uhw2 \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dhw2} h1_{A2}(T1_{A2}, Tsat2, m\dot{c}p2, dTdx1_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uhw2 \right]^2 \right]^{0.5}$$

$$\frac{uh1_{A2}}{Data_{2,47}} \cdot 100 = 1.579$$

2nd Local HTC Uncertainty Calculation

$$h2_{A2}(T2_{A2}, Tsat2, m\dot{c}p2, dTdx2_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) = \left[\frac{(T2_{A2} - Tsat2)}{m\dot{c}p2 \cdot dTdx2_{A2} + m\dot{c}p2 \cdot \frac{1}{\rho2} \cdot \Delta P \Delta x_{A2}} - A_o \cdot R_w - \frac{1}{hw2} \cdot \frac{0.75}{0.7} \right]^{-1} \\ \pi \cdot 0.75 \cdot 0.0254$$

$$uh2_{A2} = \left[\left[\left(\frac{d}{dT2_{A2}} h2_{A2}(T2_{A2}, Tsat2, m\dot{c}p2, dTdx2_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uT2_{A2} \right]^2 + \left[\left(\frac{d}{dTsat2} h2_{A2}(T2_{A2}, Tsat2, m\dot{c}p2, dTdx2_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uTsat2 \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dm\dot{c}p2} h2_{A2}(T2_{A2}, Tsat2, m\dot{c}p2, dTdx2_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot um\dot{c}p2 \right]^2 + \left[\left(\frac{d}{d\rho2} h2_{A2}(T2_{A2}, Tsat2, m\dot{c}p2, dTdx2_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot u\rho2 \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dTdx2_{A2}} h2_{A2}(T2_{A2}, Tsat2, m\dot{c}p2, dTdx2_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot dTdx2_{A2} \cdot udTdx_{A2_1} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dP} h2_{A2}(T2_{A2}, Tsat2, m\dot{c}p2, dTdx2_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uP \right]^2 + \left[\left(\frac{d}{dhw2} h2_{A2}(T2_{A2}, Tsat2, m\dot{c}p2, dTdx2_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uhw2 \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dhw2} h2_{A2}(T2_{A2}, Tsat2, m\dot{c}p2, dTdx2_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uhw2 \right]^2 \right]^{0.5}$$

$$\frac{uh2_{A2}}{Data_{2,48}} \cdot 100 = 2.176$$

3rd Local HTC Uncertainty Calculation

$$h3_{A2}(T3_{A2}, Tsat2, m\dot{c}p2, dTdx3_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) = \left[\frac{(T3_{A2} - Tsat2)}{m\dot{c}p2 \cdot dTdx3_{A2} + m\dot{c}p2 \cdot \frac{1}{\rho2} \cdot \Delta P \Delta x_{A2}} - A_o \cdot R_w - \frac{1}{hw2} \cdot \frac{0.75}{0.7} \right]^{-1} \\ \pi \cdot 0.75 \cdot 0.0254$$

$$uh_{3A2} = \left[\begin{aligned} & \left[\left(\frac{d}{dT_{3A2}} h_{3A2}(T_{3A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uT_{3A2} \right]^2 + \left[\left(\frac{d}{dT_{sat2}} h_{3A2}(T_{3A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uT_{sat2} \right]^2 \dots \\ & + \left[\left(\frac{d}{d\dot{m}} h_{3A2}(T_{3A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot u\dot{m} \right]^2 + \left[\left(\frac{d}{dCp2} h_{3A2}(T_{3A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uCp2 \right]^2 \dots \\ & + \left[\left(\frac{d}{dT dx_{A2}} h_{3A2}(T_{3A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot dT dx_{A2} \cdot uT dx_{A2} \right]^2 \dots \\ & + \left[\left(\frac{d}{d\rho2} h_{3A2}(T_{3A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot u\rho2 \right]^2 + \left[\left(\frac{d}{d\Delta P \Delta x_{A2}} h_{3A2}(T_{3A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot u\Delta P \right]^2 \dots \\ & + \left[\left(\frac{d}{dhw2} h_{3A2}(T_{3A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uhw2 \right]^2 \end{aligned} \right]^{0.5}$$

$$\frac{uh_{3A2}}{Data_{2,49}} \cdot 100 = 2.414$$

4th Local HTC Uncertainty Calculation

$$h_{4A2}(T_{4A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) = \left[\frac{(T_{4A2} - T_{sat2})}{\frac{\dot{m} \cdot Cp2 \cdot dT dx_{A2} + \dot{m} \cdot \frac{1}{\rho2} \cdot \Delta P \Delta x_{A2}}{\pi \cdot 0.75 \cdot 0.0254}} - A_o \cdot R_w - \frac{1}{hw2} \cdot \frac{0.75}{0.7}} \right]^{-1}$$

$$uh_{4A2} = \left[\begin{aligned} & \left[\left(\frac{d}{dT_{4A2}} h_{4A2}(T_{4A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uT_{4A2} \right]^2 + \left[\left(\frac{d}{dT_{sat2}} h_{4A2}(T_{4A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uT_{sat2} \right]^2 \dots \\ & + \left[\left(\frac{d}{d\dot{m}} h_{4A2}(T_{4A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot u\dot{m} \right]^2 + \left[\left(\frac{d}{dCp2} h_{4A2}(T_{4A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uCp2 \right]^2 \dots \\ & + \left[\left(\frac{d}{dT dx_{A2}} h_{4A2}(T_{4A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot dT dx_{A2} \cdot uT dx_{A2} \right]^2 \dots \\ & + \left[\left(\frac{d}{d\rho2} h_{4A2}(T_{4A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot u\rho2 \right]^2 + \left[\left(\frac{d}{d\Delta P \Delta x_{A2}} h_{4A2}(T_{4A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot u\Delta P \right]^2 \dots \\ & + \left[\left(\frac{d}{dhw2} h_{4A2}(T_{4A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uhw2 \right]^2 \end{aligned} \right]^{0.5}$$

$$\frac{uh_{4A2}}{Data_{2,50}} \cdot 100 = 2.507$$

5th Local HTC Uncertainty Calculation

$$h_{5A2}(T_{5A2}, T_{sat2}, \dot{m}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) = \left[\frac{(T_{5A2} - T_{sat2})}{\frac{\dot{m} \cdot Cp2 \cdot dT dx_{A2} + \dot{m} \cdot \frac{1}{\rho2} \cdot \Delta P \Delta x_{A2}}{\pi \cdot 0.75 \cdot 0.0254}} - A_o \cdot R_w - \frac{1}{hw2} \cdot \frac{0.75}{0.7}} \right]^{-1}$$

$$uh_{A2} := \left[\left(\frac{d}{dT^{5a_{A2}}} h_{A2}(T^{5a_{A2}}, T_{sat2}, m_{dot}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uT^{5a_{A2}} \right]^2 + \left[\left(\frac{d}{dT_{sat2}} h_{A2}(T^{5a_{A2}}, T_{sat2}, m_{dot}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uT_{sat} \right]^2 \dots^{0.5}$$

$$+ \left[\left(\frac{d}{dm_{dot}} h_{A2}(T^{5a_{A2}}, T_{sat2}, m_{dot}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot um_{dot} \right]^2 + \left[\left(\frac{d}{dCp2} h_{A2}(T^{5a_{A2}}, T_{sat2}, m_{dot}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uCp2 \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dT dx_{A2}} h_{A2}(T^{5a_{A2}}, T_{sat2}, m_{dot}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot dT dx_{A2} \cdot udT dx_{A2} \right]^2 \dots$$

$$+ \left[\left(\frac{d}{d\rho2} h_{A2}(T^{5a_{A2}}, T_{sat2}, m_{dot}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot u\rho2 \right]^2 + \left[\left(\frac{d}{d\Delta P \Delta x_{A2}} h_{A2}(T^{5a_{A2}}, T_{sat2}, m_{dot}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot u\Delta P \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dhw2} h_{A2}(T^{5a_{A2}}, T_{sat2}, m_{dot}, Cp2, dT dx_{A2}, \rho2, \Delta P \Delta x_{A2}, hw2) \right) \cdot uhw2 \right]^2$$

$$\frac{uh_{A2}}{Data_{2,51}} \cdot 100 = 2.133$$

Tube A3

Average Heat Transfer Coefficient Uncertainty Calculation

$$\rho3 := Data_{3,15}$$

$$up3 := 7 \cdot 10^{-13} \cdot \rho3$$

$$\Delta P3 := (Data_{3,10} - Data_{3,2}) \cdot \frac{1m}{59.5in} \cdot 1000$$

$$Tinlet3 := Data_{3,3}$$

$$Toutlet3 := Data_{3,9}$$

$$Cp3 := 1000 \cdot Data_{3,13}$$

$$uCp3 := 6 \cdot 10^{-14} \cdot Cp3$$

$$hw3 := Data_{3,29}$$

$$uhw3 := 0.04 \cdot hw3$$

$$Tsat3 := Data_{3,19}$$

$$ha_{A3}(m_{dot}, Cp3, Tinlet3, Toutlet3, Tsat3, \rho3, \Delta P3, hw3) := \left[\frac{1}{m_{dot} \cdot Cp3 \cdot (Tinlet3 - Toutlet3) + m_{dot} \cdot \frac{1}{\rho3} \cdot (-\Delta P3)} - A_o \cdot R_w - \frac{1}{hw3} \cdot \frac{0.75}{0.7} \right]^{-1}$$

$$\frac{Tinlet3 - Toutlet3}{\ln\left(\frac{Tinlet3 - Tsat3}{Toutlet3 - Tsat3}\right)} \cdot \pi \cdot 0.75 \cdot 0.0254$$

$$uha_{A3} := \left[\left(\frac{d}{dm_{dot}} ha_{A3}(m_{dot}, Cp3, Tinlet3, Toutlet3, Tsat3, \rho3, \Delta P3, hw3) \right) \cdot um_{dot} \right]^2 + \left[\left(\frac{d}{dCp3} ha_{A3}(m_{dot}, Cp3, Tinlet3, Toutlet3, Tsat3, \rho3, \Delta P3, hw3) \right) \cdot uCp3 \right]^2 \dots^{0.5}$$

$$+ \left[\left(\frac{d}{dTinlet3} ha_{A3}(m_{dot}, Cp3, Tinlet3, Toutlet3, Tsat3, \rho3, \Delta P3, hw3) \right) \cdot uT \right]^2 + \left[\left(\frac{d}{dToutlet3} ha_{A3}(m_{dot}, Cp3, Tinlet3, Toutlet3, Tsat3, \rho3, \Delta P3, hw3) \right) \cdot uT \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dT_{sat3}} ha_{A3}(m_{dot}, Cp3, Tinlet3, Toutlet3, Tsat3, \rho3, \Delta P3, hw3) \right) \cdot uT_{sat} \right]^2 + \left[\left(\frac{d}{d\rho3} ha_{A3}(m_{dot}, Cp3, Tinlet3, Toutlet3, Tsat3, \rho3, \Delta P3, hw3) \right) \cdot u\rho3 \right]^2 \dots$$

$$+ \left[\left(\frac{d}{d\Delta P3} ha_{A3}(m_{dot}, Cp3, Tinlet3, Toutlet3, Tsat3, \rho3, \Delta P3, hw3) \right) \cdot u\Delta P \right]^2 + \left[\left(\frac{d}{dhw3} ha_{A3}(m_{dot}, Cp3, Tinlet3, Toutlet3, Tsat3, \rho3, \Delta P3, hw3) \right) \cdot uhw3 \right]^2$$

$$uha_{A3} = 481.355$$

$$\frac{uha_{A3}}{Data_{3,31}} \cdot 100 = 2.739$$

Local Heat Transfer Coefficient Uncertainty Calculations

$$\Delta P_{\Delta x_{A3}} = \frac{-(Data_{3,10} - Data_{3,2}) \cdot 1000}{59.5 \cdot 0.0254}$$

Monte Carlo Simulation For Determining The Uncertainty in dT/dx

$$T_{i_{A3}} := Data_{3,3}$$

$$T_{1_{A3}} := Data_{3,32}$$

$$T_{1a_{A3}} := Data_{3,4}$$

$$T_{2_{A3}} := Data_{3,33}$$

$$T_{2a_{A3}} := Data_{3,5}$$

$$T_{3_{A3}} := Data_{3,34}$$

$$T_{3a_{A3}} := Data_{3,6}$$

$$T_{4_{A3}} := Data_{3,35}$$

$$T_{4a_{A3}} := Data_{3,7}$$

$$T_{5_{A3}} := Data_{3,36}$$

$$T_{5a_{A3}} := Data_{3,8}$$

$$T_{o_{A3}} := Data_{3,9}$$

$$i := 0..12000$$

$$Z_i := \text{mom}(7,0,0.0075)$$

$$TT_{A3_i} := \begin{pmatrix} T_{i_{A3}} \\ T_{1_{A3}} \\ T_{2_{A3}} \\ T_{3_{A3}} \\ T_{4_{A3}} \\ T_{5_{A3}} \\ T_{o_{A3}} \end{pmatrix} + Z_i$$

$$REG_{A3_i} := \text{regress}(\text{Dist}_i, TT_{A3_i}, 2)$$

$$Un_{17_{A3_i}} := \frac{[2 \cdot (REG_{A3_i})_5 \cdot (0.17) + (REG_{A3_i})_4 - Data_{3,37}]}{Data_{3,37}}$$

$$Un_{33_{A3_i}} := \frac{[2 \cdot (REG_{A3_i})_5 \cdot (0.33) + (REG_{A3_i})_4 - Data_{3,38}]}{Data_{3,38}}$$

$$Un_{50_{A3_i}} := \frac{[2 \cdot (REG_{A3_i})_5 \cdot (0.5) + (REG_{A3_i})_4 - Data_{3,39}]}{Data_{3,39}}$$

$$Un_{67_{A3_i}} := \frac{[2 \cdot (REG_{A3_i})_5 \cdot (0.67) + (REG_{A3_i})_4 - Data_{3,40}]}{Data_{3,40}}$$

$$Un_{83_{A3_i}} := \frac{[2 \cdot (REG_{A3_i})_5 \cdot (0.83) + (REG_{A3_i})_4 - Data_{3,41}]}{Data_{3,41}}$$

$$udTdx_{A3} = \begin{pmatrix} \text{sort}(Un17_{A3})11400 \\ \text{sort}(Un23_{A3})11400 \\ \text{sort}(Un50_{A3})11400 \\ \text{sort}(Un67_{A3})11400 \\ \text{sort}(Un83_{A3})11400 \end{pmatrix}$$

$$dTdx1_{A3} = Data_{3,42} \quad uT1_{A3} = \sqrt{uT^2 + [dTdx1_{A3} (1.5875 \times 10^{-3})]^2}$$

$$dTdx2_{A3} = Data_{3,43} \quad uT2_{A3} = \sqrt{uT^2 + [dTdx2_{A3} (1.5875 \times 10^{-3})]^2}$$

$$dTdx3_{A3} = Data_{3,44} \quad uT3_{A3} = \sqrt{uT^2 + [dTdx3_{A3} (1.5875 \times 10^{-3})]^2}$$

$$dTdx4_{A3} = Data_{3,45} \quad uT4_{A3} = \sqrt{uT^2 + [dTdx4_{A3} (1.5875 \times 10^{-3})]^2}$$

$$dTdx5_{A3} = Data_{3,46} \quad uT5_{A3} = \sqrt{uT^2 + [dTdx5_{A3} (1.5875 \times 10^{-3})]^2}$$

1st Local HTC Uncertainty Calculation

$$hl1_{A3}(T1_{A3}, Tsat3, mdot, Cp3, dTdx1_{A3}, \rho3, \Delta P \Delta x_{A3}, hw3) := \left[\frac{(T1_{A3} - Tsat3)}{\frac{mdot \cdot Cp3 \cdot dTdx1_{A3} + mdot \cdot \frac{1}{\rho3} \cdot \Delta P \Delta x_{A3}}{\pi \cdot 0.75 \cdot 0.0254}} - Ao \cdot Rw - \frac{1}{hw3} \cdot \frac{0.75}{0.7}} \right]^{-1}$$

$$uh11_{A3} = \left[\left[\left(\frac{d}{dT1_{A3}} hl1_{A3}(T1_{A3}, Tsat3, mdot, Cp3, dTdx1_{A3}, \rho3, \Delta P \Delta x_{A3}, hw3) \right) \cdot uT1_{A3} \right]^2 + \left[\left(\frac{d}{dTsat3} hl1_{A3}(T1_{A3}, Tsat3, mdot, Cp3, dTdx1_{A3}, \rho3, \Delta P \Delta x_{A3}, hw3) \right) \cdot uTsat \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dmdot} hl1_{A3}(T1_{A3}, Tsat3, mdot, Cp3, dTdx1_{A3}, \rho3, \Delta P \Delta x_{A3}, hw3) \right) \cdot umdot \right]^2 + \left[\left(\frac{d}{dCp3} hl1_{A3}(T1_{A3}, Tsat3, mdot, Cp3, dTdx1_{A3}, \rho3, \Delta P \Delta x_{A3}, hw3) \right) \cdot uCp3 \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dTdx1_{A3}} hl1_{A3}(T1_{A3}, Tsat3, mdot, Cp3, dTdx1_{A3}, \rho3, \Delta P \Delta x_{A3}, hw3) \right) \cdot dTdx1_{A3} \cdot uTdx_{A3_0} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{d\rho3} hl1_{A3}(T1_{A3}, Tsat3, mdot, Cp3, dTdx1_{A3}, \rho3, \Delta P \Delta x_{A3}, hw3) \right) \cdot u\rho3 \right]^2 + \left[\left(\frac{d}{d\Delta P \Delta x_{A3}} hl1_{A3}(T1_{A3}, Tsat3, mdot, Cp3, dTdx1_{A3}, \rho3, \Delta P \Delta x_{A3}, hw3) \right) \cdot u\Delta P \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dhw3} hl1_{A3}(T1_{A3}, Tsat3, mdot, Cp3, dTdx1_{A3}, \rho3, \Delta P \Delta x_{A3}, hw3) \right) \cdot uhw3 \right]^2 \right]^{0.5}$$

$$\frac{uh11_{A3}}{Data_{3,47}} \cdot 100 = 2.59$$

2nd Local HTC Uncertainty Calculation

$$hl2_{A3}(T2_{A3}, Tsat3, mdot, Cp3, dTdx2_{A3}, \rho3, \Delta P \Delta x_{A3}, hw3) := \left[\frac{(T2_{A3} - Tsat3)}{\frac{mdot \cdot Cp3 \cdot dTdx2_{A3} + mdot \cdot \frac{1}{\rho3} \cdot \Delta P \Delta x_{A3}}{\pi \cdot 0.75 \cdot 0.0254}} - Ao \cdot Rw - \frac{1}{hw3} \cdot \frac{0.75}{0.7}} \right]^{-1}$$

$$uh_{2A3} = \left[\left[\left(\frac{d}{dT_{2A3}} h_{2A3}(T_{2A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx2A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) \right) \cdot u_{T_{2A3}} \right]^2 + \left[\left(\frac{d}{dT_{sat3}} h_{2A3}(T_{2A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx2A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) \right) \cdot u_{T_{sat3}} \right]^2 \dots \right]^{0.5}$$

$$+ \left[\left(\frac{d}{d\dot{m}} h_{2A3}(T_{2A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx2A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) \right) \cdot u_{\dot{m}} \right]^2 + \left[\left(\frac{d}{dC_{p3}} h_{2A3}(T_{2A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx2A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) \right) \cdot u_{C_{p3}} \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dT_{dx2A3}} h_{2A3}(T_{2A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx2A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) \right) \cdot dT_{dx2A3} \cdot u_{dT_{dx2A3}} \right]^2 \dots$$

$$+ \left[\left(\frac{d}{d\rho_3} h_{2A3}(T_{2A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx2A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) \right) \cdot u_{\rho_3} \right]^2 + \left[\left(\frac{d}{d\Delta P_{\Delta x_{A3}}} h_{2A3}(T_{2A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx2A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) \right) \cdot u_{\Delta P} \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dhw_3} h_{2A3}(T_{2A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx2A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) \right) \cdot u_{hw_3} \right]^2$$

$$\frac{uh_{2A3}}{Data_{3,48}} \cdot 100 = 3.577$$

3rd Local HTC Uncertainty Calculation

$$h_{3A3}(T_{3A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx3A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) := \left[\frac{(T_{3A3} - T_{sat3})}{\dot{m} \cdot C_{p3} \cdot dT_{dx3A3} + \dot{m} \cdot \frac{1}{\rho_3} \cdot \Delta P_{\Delta x_{A3}}} - A_o \cdot R_w - \frac{1}{hw_3} \cdot \frac{0.75}{0.7} \right]^{-1}$$

$$\frac{1}{\pi \cdot 0.75 \cdot 0.0254}$$

$$uh_{3A3} = \left[\left[\left(\frac{d}{dT_{3A3}} h_{3A3}(T_{3A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx3A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) \right) \cdot u_{T_{3A3}} \right]^2 + \left[\left(\frac{d}{dT_{sat3}} h_{3A3}(T_{3A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx3A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) \right) \cdot u_{T_{sat3}} \right]^2 \dots \right]^{0.5}$$

$$+ \left[\left(\frac{d}{d\dot{m}} h_{3A3}(T_{3A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx3A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) \right) \cdot u_{\dot{m}} \right]^2 + \left[\left(\frac{d}{dC_{p3}} h_{3A3}(T_{3A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx3A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) \right) \cdot u_{C_{p3}} \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dT_{dx3A3}} h_{3A3}(T_{3A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx3A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) \right) \cdot dT_{dx3A3} \cdot u_{dT_{dx3A3}} \right]^2 \dots$$

$$+ \left[\left(\frac{d}{d\rho_3} h_{3A3}(T_{3A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx3A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) \right) \cdot u_{\rho_3} \right]^2 + \left[\left(\frac{d}{d\Delta P_{\Delta x_{A3}}} h_{3A3}(T_{3A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx3A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) \right) \cdot u_{\Delta P} \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dhw_3} h_{3A3}(T_{3A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx3A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) \right) \cdot u_{hw_3} \right]^2$$

$$\frac{uh_{3A3}}{Data_{3,49}} \cdot 100 = 3.949$$

4th Local HTC Uncertainty Calculation

$$h_{4A3}(T_{4A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{dx4A3}, \rho_3, \Delta P_{\Delta x_{A3}}, hw_3) := \left[\frac{(T_{4A3} - T_{sat3})}{\dot{m} \cdot C_{p3} \cdot dT_{dx4A3} + \dot{m} \cdot \frac{1}{\rho_3} \cdot \Delta P_{\Delta x_{A3}}} - A_o \cdot R_w - \frac{1}{hw_3} \cdot \frac{0.75}{0.7} \right]^{-1}$$

$$\frac{1}{\pi \cdot 0.75 \cdot 0.0254}$$

$$uh_{A3} = \left[\left[\left(\frac{d}{dT_{A3}} h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) \right) \cdot uT_{A3} \right]^2 + \left[\left(\frac{d}{dT_{sat3}} h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) \right) \cdot uT_{sat} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{d\dot{m}} h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) \right) \cdot u\dot{m} \right]^2 + \left[\left(\frac{d}{dC_{p3}} h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) \right) \cdot uC_{p3} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dT_{A3}} h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) \right) \cdot dT_{A3} \cdot u dT_{A3} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{d\rho_3} h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) \right) \cdot u\rho_3 \right]^2 + \left[\left(\frac{d}{d\Delta P_{A3}} h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) \right) \cdot u\Delta P \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dhw_3} h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) \right) \cdot uhw_3 \right]^2 \right]^{0.5}$$

$$\frac{uh_{A3}}{Data_{3,50}} \cdot 100 = 4.057$$

5th Local HTC Uncertainty Calculation

$$h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) = \left[\frac{(T_{A3} - T_{sat3})}{\dot{m} \cdot C_{p3} \cdot dT_{A3} + \dot{m} \cdot \frac{1}{\rho_3} \cdot \Delta P_{A3}} - A \cdot R_w - \frac{1}{hw_3} \cdot \frac{0.75}{0.7} \right]^{-1}$$

$$\frac{uh_{A3}}{Data_{3,50}} \cdot 100 = 3.301$$

$$uh_{A3} = \left[\left[\left(\frac{d}{dT_{A3}} h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) \right) \cdot uT_{A3} \right]^2 + \left[\left(\frac{d}{dT_{sat3}} h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) \right) \cdot uT_{sat} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{d\dot{m}} h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) \right) \cdot u\dot{m} \right]^2 + \left[\left(\frac{d}{dC_{p3}} h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) \right) \cdot uC_{p3} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dT_{A3}} h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) \right) \cdot dT_{A3} \cdot u dT_{A3} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{d\rho_3} h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) \right) \cdot u\rho_3 \right]^2 + \left[\left(\frac{d}{d\Delta P_{A3}} h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) \right) \cdot u\Delta P \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dhw_3} h_{A3}(T_{A3}, T_{sat3}, \dot{m}, C_{p3}, dT_{A3}, \rho_3, \Delta P_{A3}, hw_3) \right) \cdot uhw_3 \right]^2 \right]^{0.5}$$

$$\frac{uh_{A3}}{Data_{3,51}} \cdot 100 = 3.301$$

Tube A4

Average Heat Transfer Coefficient Uncertainty Calculation

$$\rho_4 = Data_{4,15}$$

$$u\rho_4 = 7 \cdot 10^{-13} \cdot \rho_4$$

$$\Delta P_4 = (Data_{4,10} - Data_{4,2}) \cdot \frac{1m}{59.5in} \cdot 1000$$

$$T_{inlet4} = Data_{4,3}$$

$$T_{outlet4} = Data_{4,9}$$

$$C_{p4} = 1000 \cdot Data_{4,13}$$

$$u_{Cp4} := 6 \cdot 10^{-14} \cdot Cp4$$

$$hw4 := Data_{4,29}$$

$$uhw4 := 0.04 \cdot hw4$$

$$T_{sat4} := Data_{4,19}$$

$$ha_{A4}(m\dot{o}t, Cp4, T_{inlet4}, T_{outlet4}, T_{sat4}, p4, \Delta P3, hw4) := \left[\frac{1}{m\dot{o}t \cdot Cp4 \cdot (T_{inlet4} - T_{outlet4}) + m\dot{o}t \cdot \frac{1}{p4} \cdot (-\Delta P3)} - A \cdot R_w - \frac{1}{hw4} \cdot \frac{0.75}{0.7} \right]^{-1} \cdot \frac{T_{inlet4} - T_{outlet4}}{\ln\left(\frac{T_{inlet4} - T_{sat4}}{T_{outlet4} - T_{sat4}}\right) \cdot \pi \cdot 0.75 \cdot 0.0254}$$

$$uha_{A4} := \left[\left[\left(\frac{d}{d \cdot m\dot{o}t} \cdot ha_{A4}(m\dot{o}t, Cp4, T_{inlet4}, T_{outlet4}, T_{sat4}, p4, \Delta P3, hw4) \right) \cdot u_{m\dot{o}t} \right]^2 + \left[\left(\frac{d}{d \cdot Cp4} \cdot ha_{A4}(m\dot{o}t, Cp4, T_{inlet4}, T_{outlet4}, T_{sat4}, p4, \Delta P3, hw4) \right) \cdot u_{Cp4} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{d \cdot T_{inlet4}} \cdot ha_{A4}(m\dot{o}t, Cp4, T_{inlet4}, T_{outlet4}, T_{sat4}, p4, \Delta P3, hw4) \right) \cdot u_T \right]^2 + \left[\left(\frac{d}{d \cdot T_{outlet4}} \cdot ha_{A4}(m\dot{o}t, Cp4, T_{inlet4}, T_{outlet4}, T_{sat4}, p4, \Delta P3, hw4) \right) \cdot u_T \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{d \cdot T_{sat4}} \cdot ha_{A4}(m\dot{o}t, Cp4, T_{inlet4}, T_{outlet4}, T_{sat4}, p4, \Delta P3, hw4) \right) \cdot u_{T_{sat}} \right]^2 + \left[\left(\frac{d}{d \cdot p4} \cdot ha_{A4}(m\dot{o}t, Cp4, T_{inlet4}, T_{outlet4}, T_{sat4}, p4, \Delta P3, hw4) \right) \cdot u_{p4} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{d \cdot \Delta P3} \cdot ha_{A4}(m\dot{o}t, Cp4, T_{inlet4}, T_{outlet4}, T_{sat4}, p4, \Delta P3, hw4) \right) \cdot u_{\Delta P} \right]^2 + \left[\left(\frac{d}{d \cdot hw4} \cdot ha_{A4}(m\dot{o}t, Cp4, T_{inlet4}, T_{outlet4}, T_{sat4}, p4, \Delta P3, hw4) \right) \cdot u_{hw4} \right]^2 \right]^{-0.5}$$

$$uha_{A4} = 662.395$$

$$\frac{uha_{A4}}{Data_{4,31}} \cdot 100 = 4.274$$

Local Heat Transfer Coefficient Uncertainty Calculations

$$\Delta P \Delta x_{A4} = \frac{-(Data_{4,10} - Data_{4,2}) \cdot 1000}{59.5 \cdot 0.0254}$$

Monte Carlo Simulation For Determining The Uncertainty in dT/dx

$$T_{1A4} := Data_{4,3}$$

$$T_{1A4} := Data_{4,32}$$

$$T_{2A4} := Data_{4,33}$$

$$T_{3A4} := Data_{4,34}$$

$$T_{4A4} := Data_{4,35}$$

$$T_{5A4} := Data_{4,36}$$

$$T_{oA4} := Data_{4,9}$$

$$i := 0 \dots 12000$$

$$Z_i := \text{norm}(7, 0, 0.0075)$$

$$T_{1aA4} := Data_{4,4}$$

$$T_{2aA4} := Data_{4,5}$$

$$T_{3aA4} := Data_{4,6}$$

$$T_{4aA4} := Data_{4,7}$$

$$T_{5aA4} := Data_{4,8}$$

$$TT_{A4_1} = \begin{pmatrix} T_{1A4} \\ T_{2A4} \\ T_{3A4} \\ T_{4A4} \\ T_{5A4} \\ T_{oA4} \end{pmatrix} + Z_1$$

$$REG_{A4_1} = \text{regress}(\text{Dist}_1, TT_{A4_1}, 2)$$

$$Un17_{A4_1} = \frac{[2 \cdot (REG_{A4_1})_5 \cdot (0.17) + (REG_{A4_1})_4 - \text{Data}_{4,37}]}{\text{Data}_{4,37}}$$

$$Un33_{A4_1} = \frac{[2 \cdot (REG_{A4_1})_5 \cdot (0.33) + (REG_{A4_1})_4 - \text{Data}_{4,38}]}{\text{Data}_{4,38}}$$

$$Un50_{A4_1} = \frac{[2 \cdot (REG_{A4_1})_5 \cdot (0.5) + (REG_{A4_1})_4 - \text{Data}_{4,39}]}{\text{Data}_{4,39}}$$

$$Un67_{A4_1} = \frac{[2 \cdot (REG_{A4_1})_5 \cdot (0.67) + (REG_{A4_1})_4 - \text{Data}_{4,40}]}{\text{Data}_{4,40}}$$

$$Un83_{A4_1} = \frac{[2 \cdot (REG_{A4_1})_5 \cdot (0.83) + (REG_{A4_1})_4 - \text{Data}_{4,41}]}{\text{Data}_{4,41}}$$

$$udTdx_{A4} = \begin{pmatrix} \text{sort}(Un17_{A4})11400 \\ \text{sort}(Un33_{A4})11400 \\ \text{sort}(Un50_{A4})11400 \\ \text{sort}(Un67_{A4})11400 \\ \text{sort}(Un83_{A4})11400 \end{pmatrix}$$

$$dTdx1_{A4} = \text{Data}_{4,42} \quad uT1_{A4} = \sqrt{uT^2 + [dTdx1_{A4} \cdot (1.5875 \times 10^{-3})]^2}$$

$$dTdx2_{A4} = \text{Data}_{4,43} \quad uT2_{A4} = \sqrt{uT^2 + [dTdx2_{A4} \cdot (1.5875 \times 10^{-3})]^2}$$

$$dTdx3_{A4} = \text{Data}_{4,44} \quad uT3_{A4} = \sqrt{uT^2 + [dTdx3_{A4} \cdot (1.5875 \times 10^{-3})]^2}$$

$$dTdx4_{A4} = \text{Data}_{4,45} \quad uT4_{A4} = \sqrt{uT^2 + [dTdx4_{A4} \cdot (1.5875 \times 10^{-3})]^2}$$

$$dTdx5_{A4} = \text{Data}_{4,46} \quad uT5_{A4} = \sqrt{uT^2 + [dTdx5_{A4} \cdot (1.5875 \times 10^{-3})]^2}$$

1st Local HTC Uncertainty Calculation

$$hl1_{A4}(T1_{A4}, Tsat4, mdot, Cp4, dTdx1_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) = \left[\frac{(T1_{A4} - Tsat4)}{\frac{mdot \cdot Cp4 \cdot dTdx1_{A4} + mdot \cdot \frac{1}{\rho4} \cdot \Delta P \Delta x_{A4}}{\pi \cdot 0.75 \cdot 0.0254}} - A_o \cdot R_w - \frac{1}{hw4} \cdot \frac{0.75}{0.7}} \right]^{-1}$$

$$uh1_{A4} = \left[\left[\left(\frac{d}{dT1_{A4}} h1_{A4}(T1_{A4}, Tsat4, mdot, Cp4, dTdx1_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uT1_{A4} \right]^2 + \left[\left(\frac{d}{dTsat4} h1_{A4}(T1_{A4}, Tsat4, mdot, Cp4, dTdx1_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uTsat4 \right]^2 \dots \right]^{0.5}$$

$$+ \left[\left(\frac{d}{dmdot} h1_{A4}(T1_{A4}, Tsat4, mdot, Cp4, dTdx1_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot umdot \right]^2 + \left[\left(\frac{d}{dCp4} h1_{A4}(T1_{A4}, Tsat4, mdot, Cp4, dTdx1_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uCp4 \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dTdx1_{A4}} h1_{A4}(T1_{A4}, Tsat4, mdot, Cp4, dTdx1_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot dTdx1_{A4} \cdot udTdx_{A4_0} \right]^2 \dots$$

$$+ \left[\left(\frac{d}{d\rho4} h1_{A4}(T1_{A4}, Tsat4, mdot, Cp4, dTdx1_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot u\rho4 \right]^2 + \left[\left(\frac{d}{d\Delta P \Delta x_{A4}} h1_{A4}(T1_{A4}, Tsat4, mdot, Cp4, dTdx1_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot u\Delta P \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dhw4} h1_{A4}(T1_{A4}, Tsat4, mdot, Cp4, dTdx1_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uhw4 \right]^2$$

$$\frac{uh1_{A4}}{Data_{4,47}} \cdot 100 = 6.349$$

2nd Local HTC Uncertainty Calculation

$$h2_{A4}(T2_{A4}, Tsat4, mdot, Cp4, dTdx2_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) := \left[\frac{(T2_{A4} - Tsat4)}{\frac{mdot \cdot Cp4 \cdot dTdx2_{A4} + mdot \cdot \frac{1}{\rho4} \cdot \Delta P \Delta x_{A4}}{\pi \cdot 0.75 \cdot 0.0254}} - A \cdot o \cdot R \cdot w - \frac{1}{hw4} \cdot \frac{0.75}{0.7}} \right]^{-1}$$

$$uh2_{A4} = \left[\left[\left(\frac{d}{dT2_{A4}} h2_{A4}(T2_{A4}, Tsat4, mdot, Cp4, dTdx2_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uT2_{A4} \right]^2 + \left[\left(\frac{d}{dTsat4} h2_{A4}(T2_{A4}, Tsat4, mdot, Cp4, dTdx2_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uTsat4 \right]^2 \dots \right]^{0.5}$$

$$+ \left[\left(\frac{d}{dmdot} h2_{A4}(T2_{A4}, Tsat4, mdot, Cp4, dTdx2_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot umdot \right]^2 + \left[\left(\frac{d}{dCp4} h2_{A4}(T2_{A4}, Tsat4, mdot, Cp4, dTdx2_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uCp4 \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dTdx2_{A4}} h2_{A4}(T2_{A4}, Tsat4, mdot, Cp4, dTdx2_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot dTdx2_{A4} \cdot udTdx_{A4_1} \right]^2 \dots$$

$$+ \left[\left(\frac{d}{d\rho4} h2_{A4}(T2_{A4}, Tsat4, mdot, Cp4, dTdx2_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot u\rho4 \right]^2 + \left[\left(\frac{d}{d\Delta P \Delta x_{A4}} h2_{A4}(T2_{A4}, Tsat4, mdot, Cp4, dTdx2_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot u\Delta P \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dhw4} h2_{A4}(T2_{A4}, Tsat4, mdot, Cp4, dTdx2_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uhw4 \right]^2$$

$$\frac{uh2_{A4}}{Data_{4,48}} \cdot 100 = 6.497$$

3rd Local HTC Uncertainty Calculation

$$h3_{A4}(T3_{A4}, Tsat4, mdot, Cp4, dTdx3_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) := \left[\frac{(T3_{A4} - Tsat4)}{\frac{mdot \cdot Cp4 \cdot dTdx3_{A4} + mdot \cdot \frac{1}{\rho4} \cdot \Delta P \Delta x_{A4}}{\pi \cdot 0.75 \cdot 0.0254}} - A \cdot o \cdot R \cdot w - \frac{1}{hw4} \cdot \frac{0.75}{0.7}} \right]^{-1}$$

$$uh_{3A4} = \left[\left[\left(\frac{d}{dT_{3a_{A4}}} h_{3A4}(T_{3a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uT_{3a_{A4}} \right]^2 + \left[\left(\frac{d}{dT_{sat4}} h_{3A4}(T_{3a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uT_{sat4} \right]^2 \dots \right]^{0.5}$$

$$+ \left[\left(\frac{d}{d\dot{m}} h_{3A4}(T_{3a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot u\dot{m} \right]^2 + \left[\left(\frac{d}{dCp4} h_{3A4}(T_{3a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uCp4 \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dT dx_{A4}} h_{3A4}(T_{3a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot dT dx_{A4} \cdot u dT dx_{A4} \right]^2 \dots$$

$$+ \left[\left(\frac{d}{d\rho4} h_{3A4}(T_{3a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot u\rho4 \right]^2 + \left[\left(\frac{d}{d\Delta P \Delta x_{A4}} h_{3A4}(T_{3a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot u\Delta P \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dhw4} h_{3A4}(T_{3a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uhw4 \right]^2$$

$$\frac{uh_{3A4}}{Data_{4,49}} \cdot 100 = 6.387$$

4th Local HTC Uncertainty Calculation

$$hl_{4A4}(T_{4a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) = \left[\frac{(T_{4a_{A4}} - T_{sat4})}{\dot{m} \cdot Cp4 \cdot dT dx_{A4} + \dot{m} \cdot \frac{1}{\rho4} \cdot \Delta P \Delta x_{A4}} - A_o \cdot R_w - \frac{1}{hw4} \cdot \frac{0.75}{0.7}}{\pi \cdot 0.75 \cdot 0.0254} \right]^{-1}$$

$$uh_{4A4} = \left[\left[\left(\frac{d}{dT_{4a_{A4}}} hl_{4A4}(T_{4a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uT_{4a_{A4}} \right]^2 + \left[\left(\frac{d}{dT_{sat4}} hl_{4A4}(T_{4a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uT_{sat4} \right]^2 \dots \right]^{0.5}$$

$$+ \left[\left(\frac{d}{d\dot{m}} hl_{4A4}(T_{4a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot u\dot{m} \right]^2 + \left[\left(\frac{d}{dCp4} hl_{4A4}(T_{4a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uCp4 \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dT dx_{A4}} hl_{4A4}(T_{4a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot dT dx_{A4} \cdot u dT dx_{A4} \right]^2 \dots$$

$$+ \left[\left(\frac{d}{d\rho4} hl_{4A4}(T_{4a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot u\rho4 \right]^2 + \left[\left(\frac{d}{d\Delta P \Delta x_{A4}} hl_{4A4}(T_{4a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot u\Delta P \right]^2 \dots$$

$$+ \left[\left(\frac{d}{dhw4} hl_{4A4}(T_{4a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uhw4 \right]^2$$

$$\frac{uh_{4A4}}{Data_{4,50}} \cdot 100 = 7.278$$

5th Local HTC Uncertainty Calculation

$$hl_{5A4}(T_{5a_{A4}}, T_{sat4}, \dot{m}, Cp4, dT dx_{A4}, \rho4, \Delta P \Delta x_{A4}, hw4) = \left[\frac{(T_{5a_{A4}} - T_{sat4})}{\dot{m} \cdot Cp4 \cdot dT dx_{A4} + \dot{m} \cdot \frac{1}{\rho4} \cdot \Delta P \Delta x_{A4}} - A_o \cdot R_w - \frac{1}{hw4} \cdot \frac{0.75}{0.7}}{\pi \cdot 0.75 \cdot 0.0254} \right]^{-1}$$

$$uhl5_{A4} = \left[\left[\left(\frac{d}{dT5_{A4}} hL5_{A4}(T5_{A4}, Tsat4, mdot, Cp4, dTdx5_{A4}, p4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uT5_{A4} \right]^2 + \left[\left(\frac{d}{dTsat4} hL5_{A4}(T5_{A4}, Tsat4, mdot, Cp4, dTdx5_{A4}, p4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uTsat4 \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dm\dot{d}ot} hL5_{A4}(T5_{A4}, Tsat4, mdot, Cp4, dTdx5_{A4}, p4, \Delta P \Delta x_{A4}, hw4) \right) \cdot um\dot{d}ot \right]^2 + \left[\left(\frac{d}{dCp4} hL5_{A4}(T5_{A4}, Tsat4, mdot, Cp4, dTdx5_{A4}, p4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uCp4 \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dTdx5_{A4}} hL5_{A4}(T5_{A4}, Tsat4, mdot, Cp4, dTdx5_{A4}, p4, \Delta P \Delta x_{A4}, hw4) \right) \cdot dTdx5_{A4} \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dp4} hL5_{A4}(T5_{A4}, Tsat4, mdot, Cp4, dTdx5_{A4}, p4, \Delta P \Delta x_{A4}, hw4) \right) \cdot up4 \right]^2 + \left[\left(\frac{d}{d\Delta P \Delta x_{A4}} hL5_{A4}(T5_{A4}, Tsat4, mdot, Cp4, dTdx5_{A4}, p4, \Delta P \Delta x_{A4}, hw4) \right) \cdot u\Delta P \right]^2 \dots \right. \\ \left. + \left[\left(\frac{d}{dhw4} hL5_{A4}(T5_{A4}, Tsat4, mdot, Cp4, dTdx5_{A4}, p4, \Delta P \Delta x_{A4}, hw4) \right) \cdot uhw4 \right]^2 \right]^{0.5}$$

$$\frac{uhl5_{A4}}{Data_{4,51}} \cdot 100 = 8.014$$

uavrg :=	$\begin{pmatrix} uha_{A1} \\ uha_{A2} \\ uha_{A3} \\ uha_{A4} \end{pmatrix}$		
			0
		0	153.788
		1	224.173
		2	481.355
3	662.395		

ulocals :=	$\begin{pmatrix} uhl1_{A1} \\ uhl2_{A1} \\ uhl3_{A1} \\ uhl4_{A1} \\ uhl5_{A1} \\ uhl1_{A2} \\ uhl2_{A2} \\ uhl3_{A2} \\ uhl4_{A2} \\ uhl5_{A2} \\ uhl1_{A3} \\ uhl2_{A3} \\ uhl3_{A3} \\ uhl4_{A3} \\ uhl5_{A3} \\ uhl1_{A4} \\ uhl2_{A4} \\ uhl3_{A4} \\ uhl4_{A4} \\ uhl5_{A4} \end{pmatrix}$		
			0
		0	155.446
		1	231.509
		2	259.277
		3	241.108
		4	165.529
		5	189.54
		6	275.23
		7	327.435
		8	358.39
		9	323.642
		10	469.597
		11	666.228
		12	749.218
		13	775.546
		14	607.786
		15	1006.898
		16	1054.862
17	1051.484		
18	1198.395		
19	1267.122		

Appendix E Data Tables

The following tables present the temperatures, pressures, flow rates, heat fluxes, heat transfer coefficients, and qualities for each test run. All of which were used in the data analysis and data plots. The data tables are arranged R-134a-P/D 1.167, R-134a-P/D 1.33, R-134a-P/D 1.5, R-123-P/D 1.167, R-123-P/D 1.33, R-123-P/D 1.5, respectively. The Point ID on the top of each table is used to identify the test run's position within the test matrix starting with the refrigerant type and tube pitch. The Point ID is interpreted as follows "Mass-flux Heat-flux Inlet-quality". For example, the first table presents the data of a test run of 15 kg/m².s mass flux, 5 kW/m² heat flux, and 10 % inlet quality.

Point ID	R-134a, P/D 1.167, 15 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.90	5.18	4.86	4.70	14961.69	0.25	0.2653	15.15
T ₁ (°C)	5.75	5.14	4.83	4.69	15457.19	0.25	0.2778	
T ₂ (°C)	5.61	5.07	4.80	4.67	15586.68	0.25	0.2884	
T ₃ (°C)	5.48	5.00	4.76	4.66	15614.16	0.25	0.2962	
T ₄ (°C)	5.36	4.94	4.74	4.64	15575.58	0.25	0.3011	
T ₅ (°C)	5.25	4.89	4.71	4.63	9453.86	0.19	0.1959	
T _{out} (°C)	5.18	4.85	4.70	4.62	9889.50	0.19	0.2020	
m _{water} (kg/s)			0.23		10489.48	0.19	0.2079	
P _{water,in} (kPa)	568.66	N/A	N/A	291.67	10833.28	0.19	0.2131	
P _{water,out} (kPa)	473.98	N/A	N/A	183.66	11287.86	0.19	0.2174	
P _{sat} (kPa)	340.92	341.83	340.67	341.71	9524.31	0.14	0.1484	
P _{bundle,in} (kPa)			341.70		9344.18	0.14	0.1514	
P _{bundle,out} (kPa)			340.15		9201.74	0.14	0.1540	
m _{ref} (kg/s)			0.14		8747.41	0.14	0.1559	
	Path B	Path C	Path D	Path E	8254.14	0.14	0.1572	
T _{water,in} (°C)	5.84	5.83	5.84	5.90	4811.33	0.11	0.1124	
T _{water,out} (°C)	4.82	4.99	4.92	4.91	4838.82	0.11	0.1141	
m _{water} (kg/s)	0.31	0.34	0.32	0.31	4828.09	0.11	0.1157	
	Pre-boiler				4840.39	0.11	0.1172	
T _{water,in} (°C)			8.49		4789.79	0.11	0.1185	
T _{water,out} (°C)			6.37					
m _{water} (kg/s)			0.48					
T _{ref,in} (°C)			-1.43					
P _{ref,in} (kPa)			362.75					
P _{ref,out} (kPa)			357.31					

Point ID	R-134a, P/D 1.167, 15 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.98	5.26	4.93	4.77	14.67	15699.60	0.5267	15.29
T ₁ (°C)	5.83	5.22	4.90	4.76	13.52	16222.16	0.5248	
T ₂ (°C)	5.70	5.14	4.87	4.75	12.30	16696.84	0.5229	
T ₃ (°C)	5.56	5.07	4.83	4.73	11.07	16993.98	0.5213	
T ₄ (°C)	5.44	5.01	4.81	4.72	9.92	17341.21	0.5200	
T ₅ (°C)	5.33	4.96	4.78	4.71	6.99	11115.08	0.4437	
T _{out} (°C)	5.26	4.92	4.77	4.70	6.58	11563.86	0.4430	
m _{water} (kg/s)			0.23		6.14	12208.53	0.4423	
P _{water,in} (kPa)	569.83	N/A	N/A	291.80	5.71	12312.15	0.4419	
P _{water,out} (kPa)	474.80	N/A	N/A	183.32	5.30	12523.34	0.4415	
P _{sat} (kPa)	342.39	343.33	342.20	343.27	3.59	11346.39	0.3877	
P _{bundle,in} (kPa)			343.06		3.27	11067.77	0.3880	
P _{bundle,out} (kPa)			341.74		2.93	10871.28	0.3883	
m _{ref} (kg/s)			0.15		2.59	10254.57	0.3888	
	Path B	Path C	Path D	Path E	2.28	9479.74	0.3892	
T _{water,in} (°C)	5.92	5.92	5.91	5.98	1.78	5693.06	0.3519	
T _{water,out} (°C)	4.90	5.06	4.98	4.99	1.67	5574.40	0.3516	
m _{water} (kg/s)	0.31	0.34	0.32	0.31	1.55	5395.78	0.3512	
	Pre-boiler				1.43	5209.14	0.3509	
T _{water,in} (°C)			14.60		1.32	4886.18	0.3505	
T _{water,out} (°C)			13.34					
m _{water} (kg/s)			2.12					
T _{ref,in} (°C)			-2.36					
P _{ref,in} (kPa)			436.47					
P _{ref,out} (kPa)			431.31					

Point ID	R-134a, P/D 1.167, 15 5 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	6.02	5.30	4.95	4.80	14.89	16690.15	0.7372	15.28
T ₁ (°C)	5.86	5.25	4.92	4.79	13.65	16951.31	0.7349	
T ₂ (°C)	5.74	5.17	4.89	4.77	12.34	17637.22	0.7326	
T ₃ (°C)	5.59	5.09	4.86	4.76	11.03	17815.77	0.7305	
T ₄ (°C)	5.47	5.04	4.83	4.75	9.80	17964.80	0.7288	
T ₅ (°C)	5.36	4.99	4.81	4.74	7.06	11725.90	0.6533	
T _{out} (°C)	5.29	4.94	4.80	4.73	6.66	12337.15	0.6527	
m _{water} (kg/s)			0.23		6.24	13184.73	0.6523	
P _{water,in} (kPa)	566.74	N/A	N/A	290.00	5.82	13378.28	0.6518	
P _{water,out} (kPa)	472.51	N/A	N/A	182.44	5.42	13919.32	0.6516	
P _{sat} (kPa)	342.88	343.92	342.78	343.94	3.63	12744.48	0.5973	
P _{bundle,in} (kPa)			343.58		3.27	12354.17	0.5974	
P _{bundle,out} (kPa)			342.40		2.89	12000.84	0.5976	
m _{ref} (kg/s)			0.15		2.50	11089.48	0.5978	
	Path B	Path C	Path D	Path E	2.14	9947.48	0.5981	
T _{water,in} (°C)	5.95	5.96	5.93	6.01	1.75	5955.41	0.5601	
T _{water,out} (°C)	4.93	5.09	5.08	5.04	1.63	5820.97	0.5598	
m _{water} (kg/s)	0.30	0.34	0.34	0.31	1.51	5604.48	0.5594	
	Pre-boiler				1.39	5363.53	0.5590	
T _{water,in} (°C)			12.28		1.28	5025.12	0.5587	
T _{water,out} (°C)			9.01					
m _{water} (kg/s)			1.24					
T _{ref,in} (°C)			-2.26					
P _{ref,in} (kPa)			375.41					
P _{ref,out} (kPa)			370.30					

Point ID	R-134a, P/D 1.167, 15 5 0.70							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.83	5.13	4.77	4.61	14.11	15145.29	0.8942	15.31
T ₁ (°C)	5.68	5.08	4.74	4.60	13.06	15741.39	0.8925	
T ₂ (°C)	5.55	5.00	4.71	4.58	11.95	16290.29	0.8908	
T ₃ (°C)	5.42	4.92	4.67	4.57	10.83	16703.71	0.8894	
T ₄ (°C)	5.31	4.86	4.64	4.55	9.79	17184.91	0.8883	
T ₅ (°C)	5.20	4.81	4.62	4.54	7.42	12075.70	0.8116	
T _{out} (°C)	5.12	4.76	4.61	4.53	6.98	12667.26	0.8109	
m _{water} (kg/s)			0.23		6.51	13501.42	0.8103	
P _{water,in} (kPa)	566.62	N/A	N/A	289.73	6.04	13757.81	0.8099	
P _{water,out} (kPa)	471.86	N/A	N/A	181.76	5.59	14107.14	0.8096	
P _{sat} (kPa)	340.56	341.61	340.53	341.69	3.90	13506.86	0.7534	
P _{bundle,in} (kPa)			341.18		3.49	13058.79	0.7534	
P _{bundle,out} (kPa)			340.16		3.06	12636.02	0.7535	
m _{ref} (kg/s)			0.15		2.64	11599.20	0.7536	
	Path B	Path C	Path D	Path E	2.23	10256.81	0.7538	
T _{water,in} (°C)	5.78	5.78	5.75	5.83	1.86	6319.52	0.7152	
T _{water,out} (°C)	4.74	4.89	4.88	4.84	1.73	6148.31	0.7147	
m _{water} (kg/s)	0.30	0.34	0.34	0.31	1.59	5875.97	0.7143	
	Pre-boiler				1.45	5589.36	0.7139	
T _{water,in} (°C)			15.02		1.32	5181.32	0.7135	
T _{water,out} (°C)			12.21					
m _{water} (kg/s)			1.82					
T _{ref,in} (°C)			-2.05					
P _{ref,in} (kPa)			415.81					
P _{ref,out} (kPa)			410.21					

Point ID	R-134a, P/D 1.167, 15 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	8.38	6.77	5.80	5.32	34.18	13245.22	0.5995	15.04
T ₁ (°C)	8.05	6.63	5.71	5.28	31.79	13627.13	0.5961	
T ₂ (°C)	7.74	6.44	5.61	5.24	29.24	13726.51	0.5932	
T ₃ (°C)	7.47	6.22	5.51	5.21	26.70	13728.01	0.5911	
T ₄ (°C)	7.22	6.07	5.42	5.17	24.30	13977.50	0.5899	
T ₅ (°C)	6.96	5.91	5.36	5.14	20.57	12966.11	0.3764	
T _{out} (°C)	6.77	5.79	5.31	5.11	19.59	13832.89	0.3759	
m _{water} (kg/s)			0.25		18.54	15038.62	0.3757	
P _{water,in} (kPa)	647.56	N/A	N/A	322.81	17.50	15839.99	0.3760	
P _{water,out} (kPa)	536.88	N/A	N/A	195.96	16.52	16976.79	0.3767	
P _{sat} (kPa)	343.82	344.77	343.68	344.82	11.56	14316.97	0.2173	
P _{bundle,in} (kPa)			344.57		10.50	14294.93	0.2175	
P _{bundle,out} (kPa)			343.25		9.36	14157.80	0.2180	
m _{ref} (kg/s)			0.14		8.23	13523.39	0.2186	
	Path B	Path C	Path D	Path E	7.17	12591.99	0.2194	
T _{water,in} (°C)	8.33	8.33	8.31	8.38	4.35	6688.95	0.1115	
T _{water,out} (°C)	5.65	5.90	5.79	5.77	4.22	6870.55	0.1111	
m _{water} (kg/s)	0.33	0.36	0.34	0.34	4.07	7016.42	0.1106	
	Pre-boiler				3.93	7146.03	0.1102	
T _{water,in} (°C)			10.50		3.80	7244.88	0.1097	
T _{water,out} (°C)			7.16					
m _{water} (kg/s)			0.29					
T _{ref,in} (°C)			-2.16					
P _{ref,in} (kPa)			377.40					
P _{ref,out} (kPa)			371.70					

Point ID	R-134a, P/D 1.167, 15 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.51	6.18	5.25	4.76	29.11	12057.62	0.8102	15.73
T ₁ (°C)	7.25	6.05	5.16	4.72	27.59	12470.95	0.8097	
T ₂ (°C)	7.01	5.86	5.06	4.67	25.98	12860.15	0.8098	
T ₃ (°C)	6.78	5.66	4.95	4.63	24.38	13276.76	0.8106	
T ₄ (°C)	6.56	5.50	4.87	4.59	22.86	13922.06	0.8119	
T ₅ (°C)	6.33	5.36	4.80	4.55	20.73	13768.21	0.6192	
T _{out} (°C)	6.17	5.24	4.76	4.52	19.77	14681.92	0.6185	
m _{water} (kg/s)			0.27		18.76	16071.30	0.6182	
P _{water,in} (kPa)	710.05	N/A	N/A	349.88	17.74	17092.08	0.6182	
P _{water,out} (kPa)	587.08	N/A	N/A	208.95	16.78	18316.21	0.6186	
P _{sat} (kPa)	337.91	338.95	337.85	339.12	12.56	17183.63	0.4711	
P _{bundle,in} (kPa)			338.58		11.37	17242.75	0.4714	
P _{bundle,out} (kPa)			338.71		10.12	17285.28	0.4718	
m _{ref} (kg/s)			0.15		8.86	16747.81	0.4723	
	Path B	Path C	Path D	Path E	7.68	15522.50	0.4730	
T _{water,in} (°C)	7.43	7.42	7.46	7.48	5.70	10321.81	0.3730	
T _{water,out} (°C)	5.09	5.22	5.10	5.23	5.35	10415.10	0.3719	
m _{water} (kg/s)	0.36	0.38	0.34	0.39	4.98	10461.79	0.3708	
	Pre-boiler				4.61	10354.44	0.3697	
T _{water,in} (°C)			8.88		4.26	10075.45	0.3686	
T _{water,out} (°C)			6.37					
m _{water} (kg/s)			1.23					
T _{ref,in} (°C)			-8.82					
P _{ref,in} (kPa)			352.01					
P _{ref,out} (kPa)			346.84					

Point ID	R-134a, P/D 1.167, 15 20 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	9.76	7.59	6.09	5.31	40.03	10406.80	0.7368	14.74
T ₁ (°C)	9.35	7.36	5.94	5.26	38.36	10953.16	0.7391	
T ₂ (°C)	8.96	7.06	5.77	5.19	36.59	11455.60	0.7427	
T ₃ (°C)	8.61	6.72	5.61	5.13	34.82	12128.13	0.7477	
T ₄ (°C)	8.24	6.48	5.47	5.08	33.16	13023.61	0.7536	
T ₅ (°C)	7.87	6.26	5.37	5.05	30.13	13823.11	0.4645	
T _{out} (°C)	7.59	6.08	5.31	5.01	28.25	14655.40	0.4619	
m _{water} (kg/s)			0.24		26.25	15947.03	0.4599	
P _{water,in} (kPa)	578.24	N/A	N/A	294.96	24.25	16551.93	0.4586	
P _{water,out} (kPa)	482.75	N/A	N/A	184.45	22.37	17265.04	0.4581	
P _{sat} (kPa)	341.84	342.84	341.75	342.93	17.40	17275.27	0.2498	
P _{bundle,in} (kPa)			342.53		15.62	17496.55	0.2500	
P _{bundle,out} (kPa)			341.36		13.72	17492.78	0.2506	
m _{ref} (kg/s)			0.14		11.82	16855.95	0.2514	
	Path B	Path C	Path D	Path E	10.03	15482.01	0.2525	
T _{water,in} (°C)	9.69	9.71	9.76	9.77	6.58	9204.74	0.1155	
T _{water,out} (°C)	5.78	5.89	5.85	5.89	6.00	8996.89	0.1136	
m _{water} (kg/s)	0.30	0.30	0.29	0.30	5.38	8662.81	0.1116	
	Pre-boiler				4.76	8019.30	0.1096	
T _{water,in} (°C)			7.48		4.17	7244.11	0.1077	
T _{water,out} (°C)			6.67					
m _{water} (kg/s)			1.23					
T _{ref,in} (°C)			-4.26					
P _{ref,in} (kPa)			368.08					
P _{ref,out} (kPa)			362.79					

Point ID	R-134a, P/D 1.167, 20 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	6.08	5.37	5.05	4.89	14.71	14940.97	0.2241	20.71
T ₁ (°C)	5.94	5.33	5.02	4.88	13.53	15502.91	0.2224	
T ₂ (°C)	5.80	5.26	4.99	4.86	12.27	15653.47	0.2208	
T ₃ (°C)	5.67	5.19	4.95	4.85	11.00	15738.31	0.2192	
T ₄ (°C)	5.55	5.13	4.93	4.83	9.82	15753.73	0.2179	
T ₅ (°C)	5.44	5.08	4.90	4.82	6.61	9575.51	0.1621	
T _{out} (°C)	5.36	5.04	4.89	4.81	6.30	9980.43	0.1618	
m _{water} (kg/s)			0.23		5.98	10546.52	0.1616	
P _{water,in} (kPa)	569.02	N/A	N/A	292.03	5.66	10851.04	0.1615	
P _{water,out} (kPa)	473.95	N/A	N/A	183.75	5.35	11205.92	0.1614	
P _{sat} (kPa)	343.23	344.20	342.96	344.04	3.56	9674.21	0.1216	
P _{bundle,in} (kPa)			344.00		3.28	9507.49	0.1219	
P _{bundle,out} (kPa)			342.47		2.98	9389.41	0.1223	
m _{ref} (kg/s)			0.20		2.69	8958.05	0.1226	
	Path B	Path C	Path D	Path E	2.41	8483.44	0.1230	
T _{water,in} (°C)	6.03	6.03	6.02	6.09	1.77	4913.88	0.0953	
T _{water,out} (°C)	5.02	5.18	5.11	5.10	1.70	4903.38	0.0951	
m _{water} (kg/s)	0.31	0.34	0.32	0.31	1.62	4846.79	0.0949	
	Pre-boiler				1.54	4795.59	0.0947	
T _{water,in} (°C)			8.18		1.47	4687.46	0.0945	
T _{water,out} (°C)			6.65					
m _{water} (kg/s)			0.78					
T _{ref,in} (°C)			-1.09					
P _{ref,in} (kPa)			366.45					
P _{ref,out} (kPa)			360.61					

Point ID	R-134a, P/D 1.167, 20 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.80	5.09	4.76	4.61	14.62	16198.25	0.4908	20.10
T ₁ (°C)	5.65	5.04	4.73	4.60	13.43	16793.30	0.4893	
T ₂ (°C)	5.52	4.97	4.70	4.58	12.17	17248.25	0.4878	
T ₃ (°C)	5.39	4.89	4.67	4.57	10.91	17503.18	0.4864	
T ₄ (°C)	5.27	4.84	4.64	4.56	9.73	17750.42	0.4853	
T ₅ (°C)	5.16	4.79	4.62	4.55	6.95	11493.43	0.4286	
T _{out} (°C)	5.08	4.75	4.61	4.54	6.53	11960.21	0.4282	
m _{water} (kg/s)			0.23		6.09	12644.26	0.4277	
P _{water,in} (kPa)	568.01	N/A	N/A	290.93	5.64	12769.08	0.4274	
P _{water,out} (kPa)	474.08	N/A	N/A	183.92	5.22	12954.26	0.4272	
P _{sat} (kPa)	340.62	341.60	340.45	341.55	3.51	11847.86	0.3875	
P _{bundle,in} (kPa)			341.25		3.18	11509.52	0.3877	
P _{bundle,out} (kPa)			339.99		2.83	11199.74	0.3879	
m _{ref} (kg/s)			0.19		2.47	10431.72	0.3882	
	Path B	Path C	Path D	Path E	2.14	9454.61	0.3885	
T _{water,in} (°C)	5.74	5.75	5.73	5.80	1.65	5436.83	0.3617	
T _{water,out} (°C)	4.73	4.89	4.82	4.84	1.55	5316.68	0.3614	
m _{water} (kg/s)	0.30	0.34	0.32	0.31	1.44	5127.33	0.3612	
	Pre-boiler				1.33	4922.77	0.3609	
T _{water,in} (°C)			14.90		1.23	4628.63	0.3607	
T _{water,out} (°C)			12.55					
m _{water} (kg/s)			1.54					
T _{ref,in} (°C)			-2.55					
P _{ref,in} (kPa)			429.67					
P _{ref,out} (kPa)			423.73					

Point ID	R-134a, P/D 1.167, 20 5 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.73	5.02	4.67	4.52	14.52	16098.38	0.6897	20.05
T ₁ (°C)	5.58	4.97	4.64	4.51	13.37	16631.88	0.6881	
T ₂ (°C)	5.45	4.90	4.61	4.49	12.15	17229.38	0.6866	
T ₃ (°C)	5.31	4.81	4.57	4.48	10.93	17560.00	0.6852	
T ₄ (°C)	5.20	4.76	4.55	4.46	9.78	17904.97	0.6841	
T ₅ (°C)	5.09	4.71	4.53	4.46	7.22	12069.60	0.6261	
T _{out} (°C)	5.01	4.66	4.52	4.45	6.79	12664.88	0.6256	
m _{water} (kg/s)			0.23		6.34	13528.95	0.6252	
P _{water,in} (kPa)	567.29	N/A	N/A	290.06	5.89	13768.81	0.6249	
P _{water,out} (kPa)	472.77	N/A	N/A	182.69	5.46	14157.50	0.6248	
P _{sat} (kPa)	339.57	340.68	339.54	340.68	3.75	13632.32	0.5831	
P _{bundle,in} (kPa)			340.26		3.35	13110.23	0.5831	
P _{bundle,out} (kPa)			339.16		2.93	12597.65	0.5831	
m _{ref} (kg/s)			0.19		2.50	11452.18	0.5833	
	Path B	Path C	Path D	Path E	2.10	10011.34	0.5835	
T _{water,in} (°C)	5.67	5.68	5.65	5.73	1.72	5830.54	0.5551	
T _{water,out} (°C)	4.65	4.80	4.79	4.75	1.60	5666.03	0.5548	
m _{water} (kg/s)	0.30	0.34	0.34	0.31	1.48	5415.30	0.5545	
	Pre-boiler				1.35	5153.35	0.5542	
T _{water,in} (°C)			13.87		1.24	4783.75	0.5539	
T _{water,out} (°C)			10.02					
m _{water} (kg/s)			1.39					
T _{ref,in} (°C)			-2.47					
P _{ref,in} (kPa)			391.20					
P _{ref,out} (kPa)			384.43					

Point ID	R-134a, P/D 1.167, 20 5 0.70							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.91	5.24	4.88	4.72	13.43	14436.24	0.8374	19.93
T ₁ (°C)	5.78	5.19	4.85	4.70	12.49	15110.91	0.8365	
T ₂ (°C)	5.65	5.12	4.82	4.69	11.48	15565.25	0.8356	
T ₃ (°C)	5.53	5.03	4.78	4.67	10.48	16053.27	0.8349	
T ₄ (°C)	5.42	4.97	4.75	4.66	9.53	16643.43	0.8344	
T ₅ (°C)	5.31	4.92	4.73	4.65	7.50	12306.01	0.7768	
T _{out} (°C)	5.24	4.88	4.72	4.64	7.03	12854.07	0.7762	
m _{water} (kg/s)			0.23		6.53	13700.39	0.7757	
P _{water,in} (kPa)	567.21	N/A	N/A	291.15	6.04	13908.71	0.7754	
P _{water,out} (kPa)	471.98	N/A	N/A	182.93	5.57	14130.83	0.7751	
P _{sat} (kPa)	341.99	343.05	341.95	343.12	3.98	14313.75	0.7335	
P _{bundle,in} (kPa)			342.44		3.56	13854.53	0.7335	
P _{bundle,out} (kPa)			341.61		3.11	13396.50	0.7336	
m _{ref} (kg/s)			0.19		2.66	12265.27	0.7338	
	Path B	Path C	Path D	Path E	2.23	10759.18	0.7340	
T _{water,in} (°C)	5.86	5.89	5.93	5.92	1.84	6433.57	0.7058	
T _{water,out} (°C)	4.84	4.99	5.03	4.94	1.71	6254.76	0.7055	
m _{water} (kg/s)	0.30	0.34	0.34	0.31	1.57	5982.93	0.7052	
	Pre-boiler				1.43	5700.10	0.7048	
T _{water,in} (°C)			14.27		1.30	5276.55	0.7045	
T _{water,out} (°C)			11.49					
m _{water} (kg/s)			2.39					
T _{ref,in} (°C)			-2.59					
P _{ref,in} (kPa)			413.55					
P _{ref,out} (kPa)			406.61					

Point ID	R-134a, P/D 1.167, 20 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	8.27	6.62	5.64	5.16	35.05	13602.09	0.4895	20.07
T ₁ (°C)	7.93	6.48	5.55	5.12	32.64	14032.11	0.4873	
T ₂ (°C)	7.62	6.28	5.45	5.08	30.08	14274.42	0.4855	
T ₃ (°C)	7.34	6.06	5.35	5.04	27.52	14417.18	0.4843	
T ₄ (°C)	7.07	5.90	5.26	5.00	25.11	14777.09	0.4837	
T ₅ (°C)	6.80	5.75	5.20	4.97	20.93	13423.16	0.3201	
T _{out} (°C)	6.61	5.63	5.15	4.94	19.86	14278.98	0.3195	
m _{water} (kg/s)			0.25		18.72	15565.12	0.3191	
P _{water,in} (kPa)	648.08	N/A	N/A	322.96	17.58	16394.82	0.3190	
P _{water,out} (kPa)	536.73	N/A	N/A	195.86	16.51	17467.98	0.3193	
P _{sat} (kPa)	342.19	343.15	342.02	343.16	11.55	14765.85	0.1988	
P _{bundle,in} (kPa)			342.87		10.50	14788.76	0.1992	
P _{bundle,out} (kPa)			341.60		9.39	14798.78	0.1997	
m _{ref} (kg/s)			0.19		8.28	14271.97	0.2004	
	Path B	Path C	Path D	Path E	7.23	13369.34	0.2012	
T _{water,in} (°C)	8.20	8.21	8.19	8.26	4.57	7395.93	0.1201	
T _{water,out} (°C)	5.49	5.74	5.64	5.61	4.40	7575.53	0.1197	
m _{water} (kg/s)	0.33	0.36	0.34	0.34	4.21	7705.84	0.1192	
	Pre-boiler				4.03	7845.44	0.1188	
T _{water,in} (°C)			10.40		3.86	7907.51	0.1184	
T _{water,out} (°C)			6.27					
m _{water} (kg/s)			0.34					
T _{ref,in} (°C)			-2.56					
P _{ref,in} (kPa)			365.67					
P _{ref,out} (kPa)			360.07					

Point ID	R-134a, P/D 1.167, 20 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.60	6.25	5.39	4.94	29.80	13177.89	0.7127	
T ₁ (°C)	7.33	6.13	5.31	4.91	28.07	13647.87	0.7117	
T ₂ (°C)	7.08	5.96	5.22	4.86	26.22	14007.77	0.7111	
T ₃ (°C)	6.85	5.77	5.12	4.82	24.37	14400.40	0.7111	
T ₄ (°C)	6.63	5.62	5.04	4.78	22.63	15041.77	0.7116	
T ₅ (°C)	6.40	5.49	4.98	4.75	19.16	13631.15	0.5603	
T _{out} (°C)	6.24	5.38	4.94	4.72	18.28	14531.01	0.5599	
m _{water} (kg/s)			0.27		17.35	15901.66	0.5597	
P _{water,in} (kPa)	709.13	N/A	N/A	349.11	16.42	16908.42	0.5599	
P _{water,out} (kPa)	586.91	N/A	N/A	209.20	15.55	18114.46	0.5604	
P _{sat} (kPa)	340.58	341.57	340.47	341.63	11.52	16810.20	0.4479	19.92
P _{bundle,in} (kPa)			341.14		10.44	16836.51	0.4482	
P _{bundle,out} (kPa)			340.11		9.29	16839.35	0.4487	
m _{ref} (kg/s)			0.19		8.14	16249.70	0.4492	
	Path B	Path C	Path D	Path E	7.05	15048.85	0.4499	
T _{water,in} (°C)	7.53	7.51	7.54	7.57	5.32	10205.17	0.3738	
T _{water,out} (°C)	5.21	5.40	5.35	5.36	5.00	10295.08	0.3730	
m _{water} (kg/s)	0.36	0.38	0.38	0.39	4.66	10348.09	0.3722	
			Pre-boiler		4.32	10244.47	0.3714	
T _{water,in} (°C)			8.65		4.00	9983.53	0.3706	
T _{water,out} (°C)			6.97					
m _{water} (kg/s)			2.36					
T _{ref,in} (°C)			-9.13					
P _{ref,in} (kPa)			356.12					
P _{ref,out} (kPa)			349.96					

Point ID	R-134a, P/D 1.167, 20 27 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.53	8.64	6.63	5.46	57.83	11355.71	0.7507	
T ₁ (°C)	10.90	8.35	6.40	5.38	53.00	11323.63	0.7439	
T ₂ (°C)	10.36	7.96	6.15	5.29	47.87	11120.53	0.7380	
T ₃ (°C)	9.85	7.55	5.90	5.20	42.73	10670.23	0.7334	
T ₄ (°C)	9.42	7.22	5.70	5.12	37.90	10241.97	0.7303	
T ₅ (°C)	8.99	6.89	5.55	5.06	37.45	12045.43	0.4570	
T _{out} (°C)	8.65	6.62	5.46	5.00	36.19	13146.74	0.4586	
m _{water} (kg/s)			0.24		34.86	14646.31	0.4610	
P _{water,in} (kPa)	578.29	N/A	N/A	295.16	33.53	16059.90	0.4641	
P _{water,out} (kPa)	482.29	N/A	N/A	184.75	32.28	18015.91	0.4677	
P _{sat} (kPa)	340.21	341.23	340.26	341.45	26.42	19490.04	0.2592	20.24
P _{bundle,in} (kPa)			341.04		23.52	19852.33	0.2582	
P _{bundle,out} (kPa)			339.95		20.45	19953.22	0.2574	
m _{ref} (kg/s)			0.19		17.37	19068.98	0.2570	
	Path B	Path C	Path D	Path E	14.48	17148.74	0.2569	
T _{water,in} (°C)	11.46	11.48	11.50	11.53	9.52	10687.85	0.1206	
T _{water,out} (°C)	6.13	6.21	6.14	6.26	8.85	10860.55	0.1190	
m _{water} (kg/s)	0.29	0.30	0.29	0.30	8.14	10879.69	0.1173	
			Pre-boiler		7.43	10735.84	0.1156	
T _{water,in} (°C)			7.18		6.76	10418.75	0.1140	
T _{water,out} (°C)			6.61					
m _{water} (kg/s)			2.53					
T _{ref,in} (°C)			-4.54					
P _{ref,in} (kPa)			364.44					
P _{ref,out} (kPa)			358.71					

Point ID	R-134a, P/D 1.167, 25 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.75	5.04	4.71	4.55	14.50	14714.58	0.2032	24.74
T ₁ (°C)	5.60	4.99	4.68	4.54	13.39	15313.28	0.2021	
T ₂ (°C)	5.46	4.92	4.65	4.52	12.21	15547.27	0.2010	
T ₃ (°C)	5.34	4.84	4.62	4.51	11.03	15814.03	0.2001	
T ₄ (°C)	5.22	4.79	4.59	4.49	9.92	16035.22	0.1992	
T ₅ (°C)	5.10	4.74	4.56	4.49	6.75	9915.08	0.1526	
T _{out} (°C)	5.03	4.70	4.55	4.47	6.39	10259.93	0.1522	
m _{water} (kg/s)			0.23		6.00	10761.47	0.1518	
P _{water,in} (kPa)	569.20	N/A	N/A	292.24	5.61	10880.02	0.1515	
P _{water,out} (kPa)	473.76	N/A	N/A	183.76	5.25	11047.30	0.1512	
P _{sat} (kPa)	339.30	340.22	339.01	340.05	3.49	9526.31	0.1182	
P _{bundle,in} (kPa)			340.01		3.24	9418.04	0.1186	
P _{bundle,out} (kPa)			338.49		2.97	9363.77	0.1189	
m _{ref} (kg/s)			0.24		2.70	9085.05	0.1193	
	Path B	Path C	Path D	Path E	2.45	8756.18	0.1197	
T _{water,in} (°C)	5.69	5.68	5.69	5.75	1.80	5098.00	0.0965	
T _{water,out} (°C)	4.68	4.84	4.78	4.77	1.70	5005.10	0.0963	
m _{water} (kg/s)	0.31	0.34	0.32	0.31	1.59	4865.88	0.0961	
	Pre-boiler				1.48	4691.59	0.0958	
T _{water,in} (°C)			9.90		1.38	4445.94	0.0956	
T _{water,out} (°C)			9.36					
m _{water} (kg/s)			2.55					
T _{ref,in} (°C)			-0.80					
P _{ref,in} (kPa)			399.57					
P _{ref,out} (kPa)			393.49					

Point ID	R-134a, P/D 1.167, 25 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.62	4.91	4.57	4.42	14.78	16405.21	0.4574	25.09
T ₁ (°C)	5.48	4.86	4.54	4.41	13.58	17055.61	0.4562	
T ₂ (°C)	5.34	4.79	4.51	4.39	12.30	17527.35	0.4550	
T ₃ (°C)	5.21	4.71	4.47	4.38	11.02	17813.47	0.4540	
T ₄ (°C)	5.09	4.65	4.45	4.36	9.82	18083.89	0.4532	
T ₅ (°C)	4.97	4.60	4.43	4.36	7.10	11914.03	0.4069	
T _{out} (°C)	4.90	4.56	4.42	4.35	6.66	12410.76	0.4064	
m _{water} (kg/s)			0.23		6.20	13163.46	0.4060	
P _{water,in} (kPa)	568.11	N/A	N/A	291.07	5.73	13301.02	0.4057	
P _{water,out} (kPa)	472.53	N/A	N/A	183.73	5.29	13477.85	0.4054	
P _{sat} (kPa)	338.42	339.40	338.30	339.39	3.60	12469.11	0.3728	
P _{bundle,in} (kPa)			339.05		3.24	12101.57	0.3730	
P _{bundle,out} (kPa)			337.86		2.87	11754.16	0.3732	
m _{ref} (kg/s)			0.24		2.50	10897.06	0.3734	
	Path B	Path C	Path D	Path E	2.14	9794.62	0.3737	
T _{water,in} (°C)	5.56	5.57	5.55	5.62	1.70	5774.81	0.3515	
T _{water,out} (°C)	4.54	4.69	4.62	4.65	1.59	5611.52	0.3513	
m _{water} (kg/s)	0.30	0.34	0.32	0.31	1.47	5371.09	0.3510	
	Pre-boiler				1.34	5143.69	0.3508	
T _{water,in} (°C)			18.09		1.23	4761.93	0.3506	
T _{water,out} (°C)			16.39					
m _{water} (kg/s)			2.58					
T _{ref,in} (°C)			-2.43					
P _{ref,in} (kPa)			486.98					
P _{ref,out} (kPa)			480.31					

Point ID	R-134a, P/D 1.167, 25 5 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.87	5.18	4.83	4.68	14.10	15814.88	0.6606	
T ₁ (°C)	5.73	5.13	4.80	4.67	13.01	16545.36	0.6596	
T ₂ (°C)	5.60	5.06	4.77	4.65	11.85	17041.26	0.6587	
T ₃ (°C)	5.47	4.97	4.74	4.64	10.69	17455.12	0.6580	
T ₄ (°C)	5.36	4.92	4.71	4.63	9.60	17882.62	0.6573	
T ₅ (°C)	5.25	4.87	4.69	4.62	7.30	12516.79	0.6100	
T _{out} (°C)	5.17	4.83	4.68	4.61	6.82	13050.12	0.6095	
m _{water} (kg/s)			0.23		6.31	13844.93	0.6091	
P _{water,in} (kPa)	567.32	N/A	N/A	290.65	5.80	13943.49	0.6087	
P _{water,out} (kPa)	472.62	N/A	N/A	182.62	5.32	14048.69	0.6084	
P _{sat} (kPa)	341.70	342.73	341.64	342.82	3.71	13781.92	0.5747	24.72
P _{bundle,in} (kPa)			342.24		3.32	13328.99	0.5748	
P _{bundle,out} (kPa)			341.27		2.91	12874.12	0.5750	
m _{ref} (kg/s)			0.24		2.49	11782.99	0.5752	
	Path B	Path C	Path D	Path E	2.10	10354.27	0.5755	
T _{water,in} (°C)	5.82	5.86	5.88	5.88	1.69	5990.38	0.5527	
T _{water,out} (°C)	4.80	4.95	4.97	4.90	1.57	5834.10	0.5524	
m _{water} (kg/s)	0.30	0.34	0.34	0.31	1.45	5587.64	0.5522	
		Pre-boiler			1.33	5340.45	0.5520	
T _{water,in} (°C)			20.52		1.22	4964.01	0.5518	
T _{water,out} (°C)			17.98					
m _{water} (kg/s)			2.59					
T _{ref,in} (°C)			-2.52					
P _{ref,in} (kPa)			512.09					
P _{ref,out} (kPa)			504.59					

Point ID	R-134a, P/D 1.167, 25 5 0.70							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.90	5.25	4.89	4.73	13.29	14509.65	0.8014	
T ₁ (°C)	5.77	5.19	4.85	4.71	12.34	15160.86	0.8005	
T ₂ (°C)	5.65	5.12	4.82	4.70	11.33	15599.97	0.7998	
T ₃ (°C)	5.53	5.03	4.78	4.68	10.33	16066.35	0.7992	
T ₄ (°C)	5.42	4.98	4.75	4.67	9.38	16616.32	0.7988	
T ₅ (°C)	5.31	4.92	4.73	4.66	7.44	12409.01	0.7535	
T _{out} (°C)	5.24	4.88	4.72	4.65	6.98	12969.03	0.7531	
m _{water} (kg/s)			0.23		6.48	13841.48	0.7528	
P _{water,in} (kPa)	567.17	N/A	N/A	290.69	5.98	14050.37	0.7525	
P _{water,out} (kPa)	472.18	N/A	N/A	181.92	5.52	14281.12	0.7523	
P _{sat} (kPa)	342.15	343.21	342.15	343.31	3.98	14615.52	0.7195	25.04
P _{bundle,in} (kPa)			342.62		3.54	14104.46	0.7195	
P _{bundle,out} (kPa)			341.81		3.08	13580.52	0.7195	
m _{ref} (kg/s)			0.24		2.63	12368.68	0.7195	
	Path B	Path C	Path D	Path E	2.19	10762.24	0.7196	
T _{water,in} (°C)	5.85	5.88	5.92	5.91	1.78	6280.19	0.6973	
T _{water,out} (°C)	4.85	4.99	5.02	4.94	1.67	6164.83	0.6971	
m _{water} (kg/s)	0.30	0.34	0.34	0.31	1.55	5960.57	0.6969	
		Pre-boiler			1.43	5772.03	0.6967	
T _{water,in} (°C)			17.45		1.32	5429.41	0.6964	
T _{water,out} (°C)			14.25					
m _{water} (kg/s)			2.57					
T _{ref,in} (°C)			-2.52					
P _{ref,in} (kPa)			451.90					
P _{ref,out} (kPa)			443.30					

Point ID	R-134a, P/D 1.167, 25 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	8.31	6.69	5.74	5.28	33.77	13340.91	0.4023	25.17
T ₁ (°C)	8.00	6.56	5.66	5.24	31.77	13961.56	0.4016	
T ₂ (°C)	7.69	6.36	5.56	5.20	29.64	14418.57	0.4014	
T ₃ (°C)	7.41	6.14	5.46	5.16	27.52	14947.64	0.4016	
T ₄ (°C)	7.15	5.99	5.38	5.12	25.51	15773.06	0.4023	
T ₅ (°C)	6.87	5.84	5.31	5.09	20.68	13763.83	0.2730	
T _{out} (°C)	6.69	5.73	5.27	5.06	19.50	14545.15	0.2721	
m _{water} (kg/s)			0.25		18.24	15793.49	0.2713	
P _{water,in} (kPa)	648.08	N/A	N/A	322.91	16.99	16455.55	0.2708	
P _{water,out} (kPa)	537.54	N/A	N/A	195.94	15.81	17226.69	0.2705	
P _{sat} (kPa)	343.87	344.85	343.72	344.85	11.05	14523.81	0.1774	
P _{bundle,in} (kPa)			344.54		10.09	14597.99	0.1780	
P _{bundle,out} (kPa)			343.26		9.07	14711.44	0.1786	
m _{ref} (kg/s)			0.24		8.05	14334.78	0.1794	
	Path B	Path C	Path D	Path E	7.08	13587.80	0.1803	
T _{water,in} (°C)	8.26	8.26	8.24	8.31	4.81	8120.09	0.1175	
T _{water,out} (°C)	5.60	5.85	5.75	5.71	4.54	8174.46	0.1170	
m _{water} (kg/s)	0.33	0.36	0.34	0.34	4.26	8202.97	0.1165	
	Pre-boiler				3.98	8113.25	0.1159	
T _{water,in} (°C)			10.24		3.71	7911.72	0.1154	
T _{water,out} (°C)			6.47					
m _{water} (kg/s)			0.45					
T _{ref,in} (°C)			-2.59					
P _{ref,in} (kPa)			368.73					
P _{ref,out} (kPa)			362.73					

Point ID	R-134a, P/D 1.167, 25 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.65	6.25	5.36	4.88	30.75	13091.43	0.6368	24.82
T ₁ (°C)	7.38	6.13	5.27	4.84	29.02	13605.29	0.6362	
T ₂ (°C)	7.12	5.95	5.17	4.80	27.18	13997.40	0.6360	
T ₃ (°C)	6.88	5.75	5.07	4.75	25.34	14449.15	0.6363	
T ₄ (°C)	6.65	5.60	4.98	4.71	23.61	15177.66	0.6371	
T ₅ (°C)	6.41	5.46	4.92	4.68	20.09	13899.09	0.5099	
T _{out} (°C)	6.25	5.35	4.88	4.65	19.16	14836.56	0.5095	
m _{water} (kg/s)			0.27		18.18	16272.29	0.5094	
P _{water,in} (kPa)	710.44	N/A	N/A	350.01	17.19	17342.39	0.5096	
P _{water,out} (kPa)	587.66	N/A	N/A	209.10	16.26	18596.74	0.5101	
P _{sat} (kPa)	339.79	340.83	339.73	340.92	12.22	17700.88	0.4162	
P _{bundle,in} (kPa)			340.31		11.05	17776.08	0.4165	
P _{bundle,out} (kPa)			339.38		9.81	17826.51	0.4169	
m _{ref} (kg/s)			0.24		8.56	17238.23	0.4174	
	Path B	Path C	Path D	Path E	7.39	15938.32	0.4180	
T _{water,in} (°C)	7.58	7.57	7.61	7.63	5.65	10905.51	0.3550	
T _{water,out} (°C)	5.16	5.35	5.30	5.31	5.27	10942.16	0.3543	
m _{water} (kg/s)	0.35	0.38	0.38	0.39	4.87	10927.55	0.3535	
	Pre-boiler				4.47	10756.31	0.3527	
T _{water,in} (°C)			9.04		4.09	10339.11	0.3520	
T _{water,out} (°C)			7.12					
m _{water} (kg/s)			2.53					
T _{ref,in} (°C)			-9.27					
P _{ref,in} (kPa)			358.21					
P _{ref,out} (kPa)			350.68					

Point ID	R-134a, P/D 1.167, 25 15 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.61	6.56	5.77	5.28	24.88	10964.95	0.8409	24.76
T ₁ (°C)	7.42	6.45	5.68	5.23	24.08	11467.98	0.8413	
T ₂ (°C)	7.23	6.30	5.58	5.18	23.22	11901.12	0.8420	
T ₃ (°C)	7.06	6.14	5.48	5.13	22.36	12507.87	0.8432	
T ₄ (°C)	6.88	6.00	5.38	5.09	21.55	13257.73	0.8446	
T ₅ (°C)	6.70	5.87	5.32	5.05	19.53	12894.14	0.7232	
T _{out} (°C)	6.56	5.77	5.27	5.02	18.93	13803.40	0.7235	
m _{water} (kg/s)			0.31		18.29	14904.25	0.7240	
P _{water,in} (kPa)	874.98	N/A	N/A	413.48	17.66	16060.77	0.7248	
P _{water,out} (kPa)	716.59	N/A	N/A	232.41	17.06	17236.67	0.7257	
P _{sat} (kPa)	343.66	344.76	343.71	344.94	14.43	18852.45	0.6305	
P _{bundle,in} (kPa)			344.22		13.11	19019.77	0.6304	
P _{bundle,out} (kPa)			343.42		11.72	18979.51	0.6305	
m _{ref} (kg/s)			0.24		10.32	18536.60	0.6306	
	Path B	Path C	Path D	Path E	9.00	17273.35	0.6308	
T _{water,in} (°C)	7.60	7.58	7.67	7.68	7.05	12387.05	0.5627	
T _{water,out} (°C)	5.63	5.71	5.70	5.65	6.63	12542.87	0.5619	
m _{water} (kg/s)	0.45	0.45	0.44	0.41	6.19	12648.93	0.5611	
	Pre-boiler				5.76	12757.88	0.5602	
T _{water,in} (°C)			15.06		5.34	12473.46	0.5594	
T _{water,out} (°C)			7.13					
m _{water} (kg/s)			0.85					
T _{ref,in} (°C)			-4.74					
P _{ref,in} (kPa)			363.90					
P _{ref,out} (kPa)			355.36					

Point ID	R-134a, P/D 1.167, 25 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.43	8.88	7.07	5.91	56.76	11285.14	0.6831	24.86
T ₁ (°C)	10.89	8.60	6.86	5.82	53.20	11396.78	0.6808	
T ₂ (°C)	10.45	8.27	6.61	5.71	49.42	11457.62	0.6793	
T ₃ (°C)	10.01	7.89	6.37	5.60	45.65	11427.00	0.6788	
T ₄ (°C)	9.61	7.60	6.16	5.51	42.09	11483.85	0.6793	
T ₅ (°C)	9.20	7.30	6.01	5.44	39.27	12307.76	0.4373	
T _{out} (°C)	8.88	7.06	5.90	5.38	37.92	13122.95	0.4378	
m _{water} (kg/s)			0.28		36.48	14323.61	0.4389	
P _{water,in} (kPa)	728.11	N/A	N/A	355.45	35.04	15289.63	0.4405	
P _{water,out} (kPa)	601.50	N/A	N/A	209.50	33.68	16644.83	0.4425	
P _{sat} (kPa)	343.47	344.51	343.43	344.71	29.42	18786.80	0.2588	
P _{bundle,in} (kPa)			344.18		26.65	19201.06	0.2588	
P _{bundle,out} (kPa)			343.13		23.71	19457.21	0.2591	
m _{ref} (kg/s)			0.24		20.77	19207.88	0.2596	
	Path B	Path C	Path D	Path E	18.00	18068.59	0.2602	
T _{water,in} (°C)	11.39	11.36	11.35	11.41	12.84	12716.57	0.1321	
T _{water,out} (°C)	6.44	6.64	6.73	6.58	11.87	12842.86	0.1302	
m _{water} (kg/s)	0.34	0.35	0.37	0.36	10.84	12815.15	0.1282	
	Pre-boiler				9.81	12562.72	0.1262	
T _{water,in} (°C)			7.61		8.83	11983.35	0.1244	
T _{water,out} (°C)			6.78					
m _{water} (kg/s)			2.53					
T _{ref,in} (°C)			-9.05					
P _{ref,in} (kPa)			363.68					
P _{ref,out} (kPa)			357.67					

Point ID	R-134a, P/D 1.167, 25 33 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	13.01	9.46	7.13	5.74	69.41	11352.23	0.7285	
T ₁ (°C)	12.26	9.10	6.87	5.64	64.39	11484.17	0.7250	
T ₂ (°C)	11.63	8.65	6.57	5.51	59.05	11541.40	0.7226	
T ₃ (°C)	11.00	8.16	6.28	5.39	53.71	11455.03	0.7216	
T ₄ (°C)	10.44	7.78	6.03	5.30	48.69	11411.81	0.7219	
T ₅ (°C)	9.89	7.42	5.85	5.22	44.76	12475.76	0.4504	
T _{out} (°C)	9.48	7.12	5.74	5.15	42.64	13313.14	0.4501	
m _{water} (kg/s)			0.24		40.39	14586.67	0.4505	
P _{water,in} (kPa)	577.37	N/A	N/A	295.95	38.13	15549.69	0.4517	
P _{water,out} (kPa)	481.34	N/A	N/A	184.59	36.01	16787.02	0.4535	
P _{sat} (kPa)	341.29	342.33	341.27	342.48	30.94	19311.61	0.2571	25.23
P _{bundle,in} (kPa)			341.94		27.74	19859.65	0.2570	
P _{bundle,out} (kPa)			340.95		24.33	20268.33	0.2572	
m _{ref} (kg/s)			0.24		20.92	19941.90	0.2577	
	Path B	Path C	Path D	Path E	17.72	18449.40	0.2585	
T _{water,in} (°C)	12.94	12.95	12.98	13.02	12.47	12865.16	0.1277	
T _{water,out} (°C)	6.50	6.59	6.51	6.62	11.39	12984.69	0.1256	
m _{water} (kg/s)	0.29	0.30	0.29	0.30	10.24	12945.41	0.1234	
			Pre-boiler		9.10	12494.66	0.1212	
T _{water,in} (°C)			7.94		8.02	11693.08	0.1192	
T _{water,out} (°C)			6.72					
m _{water} (kg/s)			1.52					
T _{ref,in} (°C)			-4.71					
P _{ref,in} (kPa)			366.02					
P _{ref,out} (kPa)			360.59					

Point ID	R-134a, P/D 1.167, 35 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.93	5.21	4.89	4.74	14.83	15989.40	0.1884	
T ₁ (°C)	5.78	5.17	4.87	4.73	13.61	16566.92	0.1875	
T ₂ (°C)	5.64	5.10	4.84	4.72	12.32	16920.17	0.1866	
T ₃ (°C)	5.51	5.03	4.80	4.70	11.03	17119.05	0.1857	
T ₄ (°C)	5.39	4.97	4.78	4.69	9.81	17250.18	0.1850	
T ₅ (°C)	5.28	4.92	4.75	4.68	6.63	10489.67	0.1522	
T _{out} (°C)	5.21	4.89	4.74	4.67	6.26	10860.42	0.1519	
m _{water} (kg/s)			0.23		5.86	11445.75	0.1517	
P _{water,in} (kPa)	568.82	N/A	N/A	291.95	5.47	11568.67	0.1515	
P _{water,out} (kPa)	474.30	N/A	N/A	183.83	5.09	11749.43	0.1513	
P _{sat} (kPa)	341.91	342.75	341.69	342.71	3.44	10272.52	0.1282	35.23
P _{bundle,in} (kPa)			342.64		3.17	10130.65	0.1284	
P _{bundle,out} (kPa)			341.14		2.88	10046.39	0.1286	
m _{ref} (kg/s)			0.34		2.59	9659.65	0.1288	
	Path B	Path C	Path D	Path E	2.32	9158.42	0.1290	
T _{water,in} (°C)	5.87	5.90	5.86	5.93	1.73	5391.21	0.1127	
T _{water,out} (°C)	4.86	5.02	4.97	4.97	1.64	5334.79	0.1125	
m _{water} (kg/s)	0.30	0.34	0.32	0.31	1.54	5229.95	0.1124	
			Pre-boiler		1.45	5130.08	0.1123	
T _{water,in} (°C)			11.86		1.36	4916.76	0.1122	
T _{water,out} (°C)			7.66					
m _{water} (kg/s)			0.57					
T _{ref,in} (°C)			-1.70					
P _{ref,in} (kPa)			385.16					
P _{ref,out} (kPa)			378.06					

Point ID	R-134a, P/D 1.167, 35 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.91	5.22	4.88	4.74	14.23	16446.25	0.4261	35.32
T ₁ (°C)	5.77	5.17	4.86	4.73	13.09	17202.81	0.4252	
T ₂ (°C)	5.63	5.10	4.83	4.71	11.88	17718.90	0.4245	
T ₃ (°C)	5.51	5.02	4.79	4.70	10.67	18129.65	0.4238	
T ₄ (°C)	5.39	4.97	4.77	4.69	9.53	18498.46	0.4232	
T ₅ (°C)	5.29	4.92	4.75	4.68	7.08	12567.07	0.3912	
T _{out} (°C)	5.21	4.88	4.74	4.67	6.62	13110.30	0.3909	
m _{water} (kg/s)			0.23		6.13	13977.23	0.3906	
P _{water,in} (kPa)	566.93	N/A	N/A	289.93	5.64	14119.58	0.3904	
P _{water,out} (kPa)	472.32	N/A	N/A	181.55	5.18	14245.71	0.3903	
P _{sat} (kPa)	342.50	343.52	342.46	343.56	3.53	13571.12	0.3676	
P _{bundle,in} (kPa)			343.12		3.17	13134.52	0.3676	
P _{bundle,out} (kPa)			342.01		2.79	12758.04	0.3677	
m _{ref} (kg/s)			0.34		2.40	11743.69	0.3678	
	Path B	Path C	Path D	Path E	2.04	10428.59	0.3679	
T _{water,in} (°C)	5.85	5.87	5.92	5.93	1.58	5719.95	0.3525	
T _{water,out} (°C)	4.86	5.03	5.04	4.96	1.47	5561.46	0.3523	
m _{water} (kg/s)	0.29	0.34	0.34	0.31	1.36	5317.38	0.3522	
	Pre-boiler				1.24	5067.50	0.3520	
T _{water,in} (°C)			15.33		1.14	4705.55	0.3519	
T _{water,out} (°C)			7.43					
m _{water} (kg/s)			0.80					
T _{ref,in} (°C)			-3.12					
P _{ref,in} (kPa)			368.80					
P _{ref,out} (kPa)			358.08					

Point ID	R-134a, P/D 1.167, 35 5 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.83	5.17	4.82	4.66	13.43	15208.39	0.6311	35.08
T ₁ (°C)	5.70	5.12	4.79	4.65	12.47	16054.92	0.6305	
T ₂ (°C)	5.57	5.04	4.75	4.63	11.45	16624.24	0.6299	
T ₃ (°C)	5.45	4.96	4.72	4.62	10.43	17242.10	0.6295	
T ₄ (°C)	5.34	4.90	4.69	4.61	9.47	17969.53	0.6292	
T ₅ (°C)	5.23	4.85	4.67	4.60	7.36	12839.87	0.5969	
T _{out} (°C)	5.16	4.81	4.66	4.59	6.88	13447.27	0.5966	
m _{water} (kg/s)			0.23		6.37	14357.02	0.5963	
P _{water,in} (kPa)	566.29	N/A	N/A	288.53	5.86	14576.81	0.5961	
P _{water,out} (kPa)	470.69	N/A	N/A	181.81	5.38	14706.67	0.5960	
P _{sat} (kPa)	341.55	342.63	341.58	342.79	3.84	15063.82	0.5729	
P _{bundle,in} (kPa)			342.09		3.42	14566.21	0.5729	
P _{bundle,out} (kPa)			341.26		2.97	14046.65	0.5729	
m _{ref} (kg/s)			0.33		2.53	12824.94	0.5730	
	Path B	Path C	Path D	Path E	2.11	11132.89	0.5731	
T _{water,in} (°C)	5.77	5.80	5.85	5.85	1.68	6161.08	0.5576	
T _{water,out} (°C)	4.79	4.92	4.96	4.88	1.57	5994.31	0.5574	
m _{water} (kg/s)	0.29	0.34	0.34	0.31	1.44	5718.60	0.5573	
	Pre-boiler				1.32	5453.85	0.5571	
T _{water,in} (°C)			15.34		1.20	5048.34	0.5569	
T _{water,out} (°C)			10.88					
m _{water} (kg/s)			2.12					
T _{ref,in} (°C)			-2.84					
P _{ref,in} (kPa)			401.52					
P _{ref,out} (kPa)			388.36					

Point ID	R-134a, P/D 1.167, 35 5 0.70							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.86	5.22	4.85	4.68	12.91	13851.74	0.7771	34.92
T ₁ (°C)	5.74	5.17	4.82	4.67	12.07	14591.68	0.7766	
T ₂ (°C)	5.61	5.09	4.78	4.65	11.18	15145.36	0.7762	
T ₃ (°C)	5.50	5.00	4.74	4.63	10.29	15760.37	0.7760	
T ₄ (°C)	5.39	4.95	4.71	4.62	9.45	16530.52	0.7758	
T ₅ (°C)	5.28	4.89	4.69	4.61	7.54	12374.34	0.7430	
T _{out} (°C)	5.21	4.85	4.68	4.60	7.10	13011.26	0.7428	
m _{water} (kg/s)			0.23		6.62	13948.73	0.7426	
P _{water,in} (kPa)	567.70	N/A	N/A	290.00	6.14	14312.14	0.7424	
P _{water,out} (kPa)	472.28	N/A	N/A	182.46	5.69	14656.35	0.7423	
P _{sat} (kPa)	341.57	342.71	341.65	342.86	4.22	15696.22	0.7186	
P _{bundle,in} (kPa)			342.11		3.76	15264.09	0.7186	
P _{bundle,out} (kPa)			341.38		3.27	14762.71	0.7186	
m _{ref} (kg/s)			0.33		2.78	13580.36	0.7186	
	Path B	Path C	Path D	Path E	2.32	11843.51	0.7187	
T _{water,in} (°C)	5.82	5.84	5.88	5.88	1.94	6945.48	0.7027	
T _{water,out} (°C)	4.80	4.94	4.99	4.90	1.79	6752.05	0.7025	
m _{water} (kg/s)	0.30	0.34	0.34	0.31	1.64	6423.05	0.7023	
	Pre-boiler				1.49	6103.12	0.7020	
T _{water,in} (°C)			17.19		1.34	5613.52	0.7018	
T _{water,out} (°C)			9.04					
m _{water} (kg/s)			1.43					
T _{ref,in} (°C)			-2.80					
P _{ref,in} (kPa)			379.88					
P _{ref,out} (kPa)			363.90					

Point ID	R-134a, P/D 1.167, 35 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.96	6.36	5.48	5.06	33.76	14478.45	0.2944	35.67
T ₁ (°C)	7.64	6.24	5.41	5.03	31.61	15091.07	0.2937	
T ₂ (°C)	7.35	6.06	5.32	4.99	29.32	15708.39	0.2931	
T ₃ (°C)	7.06	5.86	5.23	4.95	27.03	16264.86	0.2930	
T ₄ (°C)	6.80	5.71	5.15	4.91	24.87	17119.69	0.2931	
T ₅ (°C)	6.54	5.57	5.09	4.89	19.17	13895.11	0.2050	
T _{out} (°C)	6.36	5.47	5.06	4.86	18.08	14739.76	0.2044	
m _{water} (kg/s)			0.25		16.92	16005.10	0.2039	
P _{water,in} (kPa)	646.43	N/A	N/A	322.28	15.76	16728.64	0.2036	
P _{water,out} (kPa)	534.94	N/A	N/A	195.47	14.68	17588.52	0.2034	
P _{sat} (kPa)	341.99	342.96	341.84	342.95	10.14	14640.58	0.1411	
P _{bundle,in} (kPa)			342.69		9.25	14697.23	0.1415	
P _{bundle,out} (kPa)			341.41		8.30	14800.28	0.1420	
m _{ref} (kg/s)			0.34		7.35	14397.93	0.1426	
	Path B	Path C	Path D	Path E	6.46	13593.66	0.1432	
T _{water,in} (°C)	7.91	7.92	7.88	7.96	4.52	8291.70	0.1013	
T _{water,out} (°C)	5.36	5.61	5.61	5.48	4.27	8365.37	0.1010	
m _{water} (kg/s)	0.32	0.36	0.37	0.33	4.01	8420.92	0.1006	
	Pre-boiler				3.75	8345.89	0.1003	
T _{water,in} (°C)			10.66		3.50	8160.61	0.0999	
T _{water,out} (°C)			8.09					
m _{water} (kg/s)			0.62					
T _{ref,in} (°C)			3.62					
P _{ref,in} (kPa)			387.00					
P _{ref,out} (kPa)			380.21					

Point ID	R-134a, P/D 1.167, 35 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.63	6.24	5.35	4.87	30.50	13024.65	0.5545	35.87
T ₁ (°C)	7.37	6.11	5.26	4.83	28.88	13600.16	0.5542	
T ₂ (°C)	7.11	5.94	5.16	4.78	27.15	14088.29	0.5542	
T ₃ (°C)	6.87	5.74	5.06	4.74	25.43	14645.82	0.5546	
T ₄ (°C)	6.64	5.59	4.97	4.69	23.80	15502.71	0.5552	
T ₅ (°C)	6.39	5.45	4.91	4.66	20.02	13998.63	0.4672	
T _{out} (°C)	6.23	5.34	4.87	4.63	19.09	14963.19	0.4669	
m _{water} (kg/s)			0.27		18.09	16408.02	0.4669	
P _{water,in} (kPa)	709.23	N/A	N/A	349.00	17.10	17508.73	0.4670	
P _{water,out} (kPa)	588.27	N/A	N/A	208.82	16.16	18749.99	0.4673	
P _{sat} (kPa)	339.80	340.83	339.77	340.92	12.39	18406.17	0.4028	
P _{bundle,in} (kPa)			340.36		11.16	18462.40	0.4029	
P _{bundle,out} (kPa)			339.40		9.85	18418.05	0.4032	
m _{ref} (kg/s)			0.34		8.55	17737.88	0.4036	
	Path B	Path C	Path D	Path E	7.32	16211.43	0.4040	
T _{water,in} (°C)	7.56	7.55	7.58	7.60	5.72	11425.83	0.3612	
T _{water,out} (°C)	5.14	5.32	5.25	5.26	5.33	11487.40	0.3607	
m _{water} (kg/s)	0.35	0.38	0.36	0.37	4.92	11498.82	0.3601	
	Pre-boiler				4.52	11392.48	0.3596	
T _{water,in} (°C)			11.76		4.13	10957.04	0.3590	
T _{water,out} (°C)			9.02					
m _{water} (kg/s)			2.54					
T _{ref,in} (°C)			-10.65					
P _{ref,in} (kPa)			380.98					
P _{ref,out} (kPa)			370.51					

Point ID	R-134a, P/D 1.167, 35 15 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.42	6.34	5.56	5.07	26.38	11952.37	0.7542	34.96
T ₁ (°C)	7.21	6.23	5.47	5.03	25.19	12397.41	0.7540	
T ₂ (°C)	7.01	6.08	5.37	4.98	23.92	12684.52	0.7541	
T ₃ (°C)	6.84	5.92	5.27	4.93	22.65	13104.06	0.7544	
T ₄ (°C)	6.65	5.78	5.18	4.88	21.46	13618.33	0.7550	
T ₅ (°C)	6.48	5.66	5.11	4.85	19.28	13123.78	0.6681	
T _{out} (°C)	6.33	5.55	5.07	4.82	18.66	14030.13	0.6683	
m _{water} (kg/s)			0.31		18.00	15191.77	0.6686	
P _{water,in} (kPa)	874.98	N/A	N/A	413.24	17.34	16307.89	0.6691	
P _{water,out} (kPa)	717.04	N/A	N/A	232.54	16.72	17499.84	0.6698	
P _{sat} (kPa)	341.52	342.66	341.60	342.81	14.22	19472.04	0.6022	
P _{bundle,in} (kPa)			342.11		12.91	19675.00	0.6021	
P _{bundle,out} (kPa)			341.34		11.51	19620.10	0.6022	
m _{ref} (kg/s)			0.33		10.12	19186.58	0.6023	
	Path B	Path C	Path D	Path E	8.80	17833.92	0.6025	
T _{water,in} (°C)	7.41	7.41	7.47	7.49	6.98	12815.00	0.5541	
T _{water,out} (°C)	5.42	5.52	5.51	5.44	6.56	12996.69	0.5535	
m _{water} (kg/s)	0.45	0.45	0.44	0.41	6.12	13097.00	0.5529	
	Pre-boiler				5.67	13216.56	0.5523	
T _{water,in} (°C)			13.97		5.25	12911.28	0.5517	
T _{water,out} (°C)			8.28					
m _{water} (kg/s)			1.51					
T _{ref,in} (°C)			3.39					
P _{ref,in} (kPa)			374.90					
P _{ref,out} (kPa)			361.00					

Point ID	R-134a, P/D 1.167, 35 15 0.70							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	8.45	6.81	5.65	5.01	29.55	10488.20	0.8935	
T ₁ (°C)	8.13	6.63	5.53	4.96	27.59	10777.34	0.8927	
T ₂ (°C)	7.82	6.41	5.39	4.90	25.50	10904.03	0.8923	
T ₃ (°C)	7.53	6.15	5.25	4.84	23.42	11062.25	0.8924	
T ₄ (°C)	7.25	5.97	5.14	4.79	21.45	11163.20	0.8928	
T ₅ (°C)	7.00	5.79	5.06	4.75	20.70	12408.53	0.8077	
T _{out} (°C)	6.81	5.64	5.01	4.72	19.65	13312.26	0.8075	
m _{water} (kg/s)			0.22		18.54	14759.84	0.8075	
P _{water,in} (kPa)	508.88	N/A	N/A	268.34	17.43	15816.70	0.8077	
P _{water,out} (kPa)	427.32	N/A	N/A	174.12	16.38	17145.65	0.8082	
P _{sat} (kPa)	341.46	342.61	341.59	342.89	13.53	19735.84	0.7454	34.98
P _{bundle,in} (kPa)			342.02		12.02	20221.29	0.7453	
P _{bundle,out} (kPa)			341.37		10.41	20393.66	0.7452	
m _{ref} (kg/s)			0.33		8.80	19687.26	0.7453	
	Path B	Path C	Path D	Path E	7.28	17661.79	0.7454	
T _{water,in} (°C)	8.38	8.39	8.44	8.46	5.81	12806.18	0.7050	
T _{water,out} (°C)	5.38	5.43	5.42	5.48	5.28	12895.50	0.7043	
m _{water} (kg/s)	0.28	0.28	0.27	0.28	4.73	12774.73	0.7036	
			Pre-boiler		4.17	12416.37	0.7028	
T _{water,in} (°C)			23.13		3.65	11445.56	0.7021	
T _{water,out} (°C)			8.44					
m _{water} (kg/s)			0.79					
T _{ref,in} (°C)			-2.76					
P _{ref,in} (kPa)			381.98					
P _{ref,out} (kPa)			366.15					

Point ID	R-134a, P/D 1.167, 35 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.01	8.40	6.58	5.46	57.87	11557.81	0.5239	
T ₁ (°C)	10.49	8.12	6.37	5.37	54.41	11834.04	0.5226	
T ₂ (°C)	10.00	7.79	6.13	5.26	50.74	11940.58	0.5220	
T ₃ (°C)	9.57	7.40	5.90	5.16	47.06	12026.04	0.5222	
T ₄ (°C)	9.15	7.10	5.70	5.07	43.60	12175.79	0.5231	
T ₅ (°C)	8.74	6.81	5.55	5.00	39.92	12944.72	0.3470	
T _{out} (°C)	8.40	6.57	5.45	4.94	38.42	13803.75	0.3472	
m _{water} (kg/s)			0.28		36.83	15116.93	0.3479	
P _{water,in} (kPa)	729.58	N/A	N/A	356.02	35.24	16209.97	0.3490	
P _{water,out} (kPa)	602.91	N/A	N/A	210.51	33.74	17576.94	0.3504	
P _{sat} (kPa)	338.62	339.69	338.68	339.71	28.76	19341.59	0.2186	35.27
P _{bundle,in} (kPa)			339.19		25.97	19654.18	0.2186	
P _{bundle,out} (kPa)			338.30		23.00	19819.66	0.2188	
m _{ref} (kg/s)			0.34		20.03	19432.67	0.2192	
	Path B	Path C	Path D	Path E	17.24	18064.51	0.2197	
T _{water,in} (°C)	10.98	10.95	10.99	11.00	12.50	12870.38	0.1294	
T _{water,out} (°C)	5.97	6.09	6.21	6.06	11.58	13049.44	0.1281	
m _{water} (kg/s)	0.34	0.35	0.37	0.35	10.61	13124.64	0.1268	
			Pre-boiler		9.64	12924.12	0.1255	
T _{water,in} (°C)			8.12		8.73	12442.29	0.1242	
T _{water,out} (°C)			6.34					
m _{water} (kg/s)			1.65					
T _{ref,in} (°C)			-7.44					
P _{ref,in} (kPa)			361.19					
P _{ref,out} (kPa)			354.00					

Point ID	R-134a, P/D 1.167, 35 30 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.15	8.69	6.98	5.80	54.74	11102.57	0.7543	35.03
T ₁ (°C)	10.65	8.43	6.76	5.70	51.35	11247.32	0.7530	
T ₂ (°C)	10.21	8.12	6.52	5.58	47.74	11274.93	0.7522	
T ₃ (°C)	9.80	7.76	6.28	5.46	44.13	11259.27	0.7523	
T ₄ (°C)	9.40	7.49	6.07	5.35	40.73	11270.64	0.7530	
T ₅ (°C)	9.02	7.20	5.91	5.27	37.15	11770.38	0.5828	
T _{out} (°C)	8.70	6.97	5.80	5.20	35.96	12524.62	0.5831	
m _{water} (kg/s)			0.28		34.69	13627.44	0.5840	
P _{water,in} (kPa)	728.90	N/A	N/A	356.44	33.43	14540.04	0.5852	
P _{water,out} (kPa)	602.31	N/A	N/A	210.63	32.24	15766.97	0.5867	
P _{sat} (kPa)	342.34	343.37	342.38	343.46	29.39	18782.15	0.4595	
P _{bundle,in} (kPa)			342.76		26.74	19281.17	0.4598	
P _{bundle,out} (kPa)			342.11		23.92	19639.99	0.4602	
m _{ref} (kg/s)			0.33		21.10	19660.08	0.4608	
	Path B	Path C	Path D	Path E	18.44	18753.50	0.4616	
T _{water,in} (°C)	11.11	11.09	11.12	11.13	14.63	15539.18	0.3723	
T _{water,out} (°C)	6.30	6.34	6.49	6.37	13.57	16023.28	0.3708	
m _{water} (kg/s)	0.34	0.35	0.37	0.35	12.44	16456.46	0.3693	
	Pre-boiler				11.32	16794.22	0.3677	
T _{water,in} (°C)			11.72		10.26	16456.84	0.3663	
T _{water,out} (°C)			7.79					
m _{water} (kg/s)			1.66					
T _{ref,in} (°C)			-5.41					
P _{ref,in} (kPa)			368.22					
P _{ref,out} (kPa)			357.38					

Point ID	R-134a, P/D 1.167, 35 45 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	14.68	10.81	8.25	6.51	88.49	11710.73	0.7298	35.16
T ₁ (°C)	13.88	10.41	7.93	6.35	82.69	11817.97	0.7280	
T ₂ (°C)	13.20	9.93	7.58	6.17	76.52	11859.68	0.7272	
T ₃ (°C)	12.53	9.39	7.24	5.99	70.35	11836.36	0.7275	
T ₄ (°C)	11.89	8.98	6.92	5.82	64.55	11779.40	0.7288	
T ₅ (°C)	11.31	8.58	6.69	5.71	57.83	12225.76	0.4668	
T _{out} (°C)	10.83	8.24	6.51	5.60	55.23	12805.68	0.4658	
m _{water} (kg/s)			0.28		52.46	13675.29	0.4653	
P _{water,in} (kPa)	753.52	N/A	N/A	365.72	49.70	14275.60	0.4655	
P _{water,out} (kPa)	621.32	N/A	N/A	212.86	47.10	14970.73	0.4661	
P _{sat} (kPa)	342.28	343.37	342.36	343.60	43.33	17735.14	0.2735	
P _{bundle,in} (kPa)			342.89		39.66	18210.50	0.2745	
P _{bundle,out} (kPa)			342.15		35.75	18546.19	0.2758	
m _{ref} (kg/s)			0.34		31.85	18725.92	0.2774	
	Path B	Path C	Path D	Path E	28.18	18107.53	0.2791	
T _{water,in} (°C)	14.69	14.67	14.67	14.72	22.66	15891.16	0.1415	
T _{water,out} (°C)	7.39	7.45	7.53	7.55	20.85	16280.25	0.1390	
m _{water} (kg/s)	0.35	0.35	0.36	0.36	18.93	16495.44	0.1363	
	Pre-boiler				17.01	16471.26	0.1337	
T _{water,in} (°C)			12.90		15.20	15810.04	0.1312	
T _{water,out} (°C)			5.77					
m _{water} (kg/s)			0.39					
T _{ref,in} (°C)			-6.00					
P _{ref,in} (kPa)			363.55					
P _{ref,out} (kPa)			356.32					

Point ID	R-134a, P/D 1.167, 45 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	6.12	5.40	5.09	4.94	14.79	16038.97	0.1560	45.26
T ₁ (°C)	5.97	5.36	5.06	4.93	13.56	16570.28	0.1553	
T ₂ (°C)	5.83	5.29	5.03	4.91	12.26	16918.25	0.1545	
T ₃ (°C)	5.70	5.22	5.00	4.90	10.95	17058.88	0.1539	
T ₄ (°C)	5.58	5.17	4.97	4.88	9.72	17121.09	0.1533	
T ₅ (°C)	5.47	5.12	4.95	4.87	6.60	10742.50	0.1281	
T _{out} (°C)	5.40	5.08	4.93	4.86	6.23	11155.90	0.1279	
m _{water} (kg/s)			0.23		5.84	11804.84	0.1278	
P _{water,in} (kPa)	569.11	N/A	N/A	291.48	5.45	11968.79	0.1276	
P _{water,out} (kPa)	473.73	N/A	N/A	184.34	5.08	12207.55	0.1275	
P _{sat} (kPa)	344.30	345.17	344.27	345.11	3.43	10300.66	0.1100	
P _{bundle,in} (kPa)			345.02		3.16	10156.47	0.1101	
P _{bundle,out} (kPa)			343.52		2.87	10067.14	0.1103	
m _{ref} (kg/s)			0.43		2.58	9675.05	0.1105	
	Path B	Path C	Path D	Path E	2.31	9164.81	0.1107	
T _{water,in} (°C)	6.06	6.07	6.04	6.12	1.71	5326.90	0.0984	
T _{water,out} (°C)	5.06	5.22	5.16	5.16	1.62	5260.54	0.0983	
m _{water} (kg/s)	0.30	0.34	0.32	0.31	1.52	5145.75	0.0982	
	Pre-boiler				1.43	5028.93	0.0981	
T _{water,in} (°C)			11.81		1.34	4809.31	0.0981	
T _{water,out} (°C)			8.72					
m _{water} (kg/s)			0.87					
T _{ref,in} (°C)			-0.92					
P _{ref,in} (kPa)			399.11					
P _{ref,out} (kPa)			390.99					

Point ID	R-134a, P/D 1.167, 45 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.81	5.12	4.78	4.63	14.24	16497.78	0.4087	45.11
T ₁ (°C)	5.67	5.07	4.75	4.62	13.11	17281.19	0.4081	
T ₂ (°C)	5.54	5.00	4.72	4.61	11.91	17832.89	0.4075	
T ₃ (°C)	5.41	4.92	4.69	4.59	10.70	18273.97	0.4070	
T ₄ (°C)	5.29	4.86	4.66	4.58	9.57	18723.88	0.4066	
T ₅ (°C)	5.19	4.81	4.64	4.57	7.20	12951.63	0.3811	
T _{out} (°C)	5.11	4.77	4.63	4.57	6.72	13541.43	0.3809	
m _{water} (kg/s)			0.23		6.21	14470.86	0.3806	
P _{water,in} (kPa)	566.58	N/A	N/A	289.48	5.70	14591.44	0.3805	
P _{water,out} (kPa)	471.47	N/A	N/A	182.50	5.21	14689.65	0.3803	
P _{sat} (kPa)	341.23	342.26	341.28	342.38	3.60	13986.75	0.3623	
P _{bundle,in} (kPa)			341.88		3.23	13532.89	0.3624	
P _{bundle,out} (kPa)			340.84		2.83	13137.46	0.3625	
m _{ref} (kg/s)			0.43		2.43	12091.66	0.3626	
	Path B	Path C	Path D	Path E	2.05	10671.29	0.3627	
T _{water,in} (°C)	5.75	5.77	5.83	5.82	1.59	5821.93	0.3506	
T _{water,out} (°C)	4.76	4.88	4.93	4.86	1.48	5650.90	0.3505	
m _{water} (kg/s)	0.29	0.34	0.34	0.31	1.37	5384.47	0.3503	
	Pre-boiler				1.25	5126.61	0.3502	
T _{water,in} (°C)			14.90		1.14	4744.09	0.3501	
T _{water,out} (°C)			8.51					
m _{water} (kg/s)			1.26					
T _{ref,in} (°C)			-3.11					
P _{ref,in} (kPa)			377.72					
P _{ref,out} (kPa)			363.30					

Point ID	R-134a, P/D 1.167, 45 5 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.86	5.20	4.85	4.69	13.36	15100.59	0.6091	
T ₁ (°C)	5.74	5.15	4.82	4.68	12.43	16011.38	0.6087	
T ₂ (°C)	5.60	5.07	4.78	4.66	11.44	16625.07	0.6084	
T ₃ (°C)	5.48	4.99	4.75	4.65	10.45	17331.56	0.6081	
T ₄ (°C)	5.37	4.93	4.72	4.63	9.51	18172.56	0.6079	
T ₅ (°C)	5.26	4.88	4.70	4.62	7.37	12970.15	0.5824	
T _{out} (°C)	5.19	4.84	4.69	4.62	6.89	13606.38	0.5821	
m _{water} (kg/s)			0.23		6.38	14552.72	0.5819	
P _{water,in} (kPa)	565.89	N/A	N/A	290.15	5.88	14829.48	0.5817	
P _{water,out} (kPa)	472.36	N/A	N/A	181.67	5.40	15012.01	0.5816	
P _{sat} (kPa)	341.92	343.06	342.01	343.20	3.88	15642.37	0.5634	44.88
P _{bundle,in} (kPa)			342.46		3.45	15161.04	0.5634	
P _{bundle,out} (kPa)			341.68		3.00	14654.90	0.5634	
m _{ref} (kg/s)			0.43		2.55	13419.79	0.5635	
	Path B	Path C	Path D	Path E	2.12	11647.11	0.5635	
T _{water,in} (°C)	5.80	5.83	5.88	5.88	1.78	6688.35	0.5512	
T _{water,out} (°C)	4.81	4.95	4.98	4.91	1.64	6465.50	0.5511	
m _{water} (kg/s)	0.29	0.34	0.34	0.31	1.50	6109.18	0.5509	
			Pre-boiler		1.35	5759.01	0.5508	
T _{water,in} (°C)			17.97		1.21	5247.92	0.5506	
T _{water,out} (°C)			13.34					
m _{water} (kg/s)			2.57					
T _{ref,in} (°C)			-2.32					
P _{ref,in} (kPa)			433.32					
P _{ref,out} (kPa)			415.58					

Point ID	R-134a, P/D 1.167, 45 5 0.70							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.88	5.23	4.87	4.69	12.81	13948.19	0.7638	
T ₁ (°C)	5.76	5.18	4.83	4.68	12.01	14791.06	0.7634	
T ₂ (°C)	5.63	5.10	4.79	4.66	11.15	15424.17	0.7632	
T ₃ (°C)	5.51	5.02	4.75	4.65	10.30	16205.91	0.7630	
T ₄ (°C)	5.40	4.96	4.72	4.63	9.50	17171.75	0.7629	
T ₅ (°C)	5.29	4.90	4.70	4.62	7.58	12851.38	0.7373	
T _{out} (°C)	5.22	4.86	4.69	4.61	7.10	13503.79	0.7371	
m _{water} (kg/s)			0.23		6.60	14454.84	0.7369	
P _{water,in} (kPa)	565.08	N/A	N/A	288.88	6.09	14781.87	0.7368	
P _{water,out} (kPa)	471.43	N/A	N/A	182.18	5.61	15050.51	0.7367	
P _{sat} (kPa)	341.83	342.99	341.97	343.17	4.22	16530.93	0.7182	44.83
P _{bundle,in} (kPa)			342.36		3.75	16125.64	0.7181	
P _{bundle,out} (kPa)			341.69		3.26	15631.42	0.7181	
m _{ref} (kg/s)			0.43		2.76	14372.95	0.7181	
	Path B	Path C	Path D	Path E	2.30	12480.45	0.7181	
T _{water,in} (°C)	5.81	5.84	5.89	5.90	1.93	7196.18	0.7055	
T _{water,out} (°C)	4.81	4.95	4.98	4.91	1.78	7012.19	0.7053	
m _{water} (kg/s)	0.29	0.34	0.34	0.31	1.63	6678.52	0.7052	
			Pre-boiler		1.48	6354.21	0.7050	
T _{water,in} (°C)			21.23		1.33	5847.23	0.7048	
T _{water,out} (°C)			15.55					
m _{water} (kg/s)			2.58					
T _{ref,in} (°C)			0.01					
P _{ref,in} (kPa)			463.87					
P _{ref,out} (kPa)			443.89					

Point ID	R-134a, P/D 1.167, 45 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.83	6.20	5.31	4.87	34.42	14579.10	0.2661	44.54
T ₁ (°C)	7.51	6.08	5.23	4.84	32.21	15190.01	0.2654	
T ₂ (°C)	7.21	5.89	5.14	4.80	29.86	15819.75	0.2650	
T ₃ (°C)	6.92	5.68	5.04	4.75	27.51	16376.18	0.2649	
T ₄ (°C)	6.65	5.54	4.97	4.72	25.30	17239.48	0.2650	
T ₅ (°C)	6.38	5.40	4.91	4.69	19.64	14178.18	0.1928	
T _{out} (°C)	6.20	5.30	4.87	4.66	18.50	15045.28	0.1922	
m _{water} (kg/s)			0.25		17.29	16375.40	0.1918	
P _{water,in} (kPa)	646.92	N/A	N/A	322.19	16.07	17085.47	0.1915	
P _{water,out} (kPa)	535.60	N/A	N/A	195.23	14.93	17953.50	0.1914	
P _{sat} (kPa)	339.80	340.77	339.68	340.77	10.41	15167.91	0.1402	
P _{bundle,in} (kPa)			340.48		9.47	15238.21	0.1406	
P _{bundle,out} (kPa)			339.22		8.48	15325.87	0.1410	
m _{ref} (kg/s)			0.43		7.48	14882.25	0.1414	
	Path B	Path C	Path D	Path E	6.55	13985.74	0.1420	
T _{water,in} (°C)	7.77	7.78	7.75	7.83	4.72	8870.93	0.1077	
T _{water,out} (°C)	5.18	5.43	5.41	5.30	4.44	8924.48	0.1074	
m _{water} (kg/s)	0.32	0.36	0.37	0.33	4.14	8956.27	0.1070	
	Pre-boiler				3.84	8835.38	0.1067	
T _{water,in} (°C)			10.58		3.56	8571.77	0.1064	
T _{water,out} (°C)			8.60					
m _{water} (kg/s)			1.10					
T _{ref,in} (°C)			3.22					
P _{ref,in} (kPa)			391.03					
P _{ref,out} (kPa)			383.22					

Point ID	R-134a, P/D 1.167, 45 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.48	6.11	5.24	4.77	30.14	13288.32	0.5046	44.66
T ₁ (°C)	7.22	5.99	5.15	4.73	28.44	13866.97	0.5042	
T ₂ (°C)	6.96	5.82	5.06	4.69	26.63	14301.84	0.5041	
T ₃ (°C)	6.72	5.62	4.95	4.64	24.82	14790.35	0.5042	
T ₄ (°C)	6.50	5.48	4.87	4.60	23.12	15545.60	0.5046	
T ₅ (°C)	6.26	5.34	4.81	4.57	19.51	14029.45	0.4359	
T _{out} (°C)	6.11	5.23	4.77	4.54	18.60	15010.98	0.4358	
m _{water} (kg/s)			0.27		17.64	16470.28	0.4358	
P _{water,in} (kPa)	710.59	N/A	N/A	348.83	16.68	17613.08	0.4359	
P _{water,out} (kPa)	587.18	N/A	N/A	208.72	15.78	18865.93	0.4363	
P _{sat} (kPa)	338.90	340.03	338.91	340.10	12.25	19165.45	0.3863	
P _{bundle,in} (kPa)			339.43		11.02	19251.60	0.3864	
P _{bundle,out} (kPa)			338.62		9.71	19233.57	0.3865	
m _{ref} (kg/s)			0.43		8.40	18530.73	0.3867	
	Path B	Path C	Path D	Path E	7.16	16881.40	0.3870	
T _{water,in} (°C)	7.42	7.40	7.43	7.46	5.61	11624.16	0.3539	
T _{water,out} (°C)	5.04	5.21	5.14	5.16	5.23	11717.94	0.3535	
m _{water} (kg/s)	0.35	0.38	0.36	0.37	4.83	11718.91	0.3530	
	Pre-boiler				4.42	11621.34	0.3526	
T _{water,in} (°C)			14.14		4.05	11182.83	0.3522	
T _{water,out} (°C)			10.64					
m _{water} (kg/s)			2.55					
T _{ref,in} (°C)			-10.45					
P _{ref,in} (kPa)			400.17					
P _{ref,out} (kPa)			386.12					

Point ID	R-134a, P/D 1.167, 45 15 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.63	6.51	5.71	5.19	27.52	11934.47	0.7223	44.83
T ₁ (°C)	7.42	6.39	5.62	5.14	26.21	12354.19	0.7221	
T ₂ (°C)	7.20	6.24	5.51	5.09	24.82	12597.29	0.7221	
T ₃ (°C)	7.02	6.07	5.40	5.04	23.44	12950.34	0.7224	
T ₄ (°C)	6.83	5.94	5.30	4.98	22.13	13384.98	0.7228	
T ₅ (°C)	6.65	5.81	5.23	4.95	19.76	12817.34	0.6525	
T _{out} (°C)	6.50	5.70	5.19	4.91	19.13	13671.58	0.6526	
m _{water} (kg/s)			0.31		18.46	14757.54	0.6529	
P _{water,in} (kPa)	876.20	N/A	N/A	412.90	17.79	15786.23	0.6533	
P _{water,out} (kPa)	717.29	N/A	N/A	232.62	17.16	16916.53	0.6537	
P _{sat} (kPa)	342.49	343.68	342.62	343.82	14.94	19235.28	0.5994	
P _{bundle,in} (kPa)			343.04		13.61	19546.78	0.5994	
P _{bundle,out} (kPa)			342.37		12.19	19574.19	0.5995	
m _{ref} (kg/s)			0.43		10.78	19334.36	0.5997	
	Path B	Path C	Path D	Path E	9.45	18198.99	0.5999	
T _{water,in} (°C)	7.63	7.63	7.69	7.71	7.60	13468.93	0.5607	
T _{water,out} (°C)	5.53	5.65	5.64	5.56	7.12	13666.30	0.5602	
m _{water} (kg/s)	0.43	0.45	0.44	0.41	6.61	13738.65	0.5597	
	Pre-boiler				6.09	13817.85	0.5591	
T _{water,in} (°C)			15.38		5.61	13438.06	0.5586	
T _{water,out} (°C)			9.94					
m _{water} (kg/s)			2.08					
T _{ref,in} (°C)			2.21					
P _{ref,in} (kPa)			391.88					
P _{ref,out} (kPa)			371.99					

Point ID	R-134a, P/D 1.167, 45 15 0.70							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	8.62	6.96	5.86	5.23	29.80	10752.22	0.8445	44.83
T ₁ (°C)	8.31	6.80	5.73	5.18	27.89	11148.54	0.8441	
T ₂ (°C)	7.99	6.58	5.60	5.11	25.87	11350.83	0.8440	
T ₃ (°C)	7.71	6.33	5.47	5.06	23.85	11628.71	0.8442	
T ₄ (°C)	7.42	6.15	5.36	5.01	21.95	11878.60	0.8447	
T ₅ (°C)	7.16	5.98	5.27	4.97	20.17	12424.09	0.7780	
T _{out} (°C)	6.97	5.85	5.23	4.94	19.06	13236.08	0.7778	
m _{water} (kg/s)			0.22		17.88	14539.86	0.7776	
P _{water,in} (kPa)	509.42	N/A	N/A	268.32	16.70	15366.06	0.7777	
P _{water,out} (kPa)	426.95	N/A	N/A	173.33	15.59	16413.16	0.7779	
P _{sat} (kPa)	344.21	345.36	344.36	345.64	13.15	19299.08	0.7301	
P _{bundle,in} (kPa)			344.76		11.71	19837.47	0.7301	
P _{bundle,out} (kPa)			344.16		10.18	20054.46	0.7301	
m _{ref} (kg/s)			0.43		8.65	19481.76	0.7303	
	Path B	Path C	Path D	Path E	7.21	17699.24	0.7305	
T _{water,in} (°C)	8.57	8.57	8.63	8.65	5.80	13011.23	0.6994	
T _{water,out} (°C)	5.59	5.65	5.64	5.68	5.27	13118.71	0.6989	
m _{water} (kg/s)	0.28	0.28	0.27	0.28	4.71	12964.16	0.6982	
	Pre-boiler				4.14	12542.50	0.6976	
T _{water,in} (°C)			22.16		3.61	11523.29	0.6971	
T _{water,out} (°C)			10.27					
m _{water} (kg/s)			1.20					
T _{ref,in} (°C)			1.15					
P _{ref,in} (kPa)			402.57					
P _{ref,out} (kPa)			380.14					

Point ID	R-134a, P/D 1.167, 45 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.36	8.72	6.89	5.76	58.88	11700.06	0.4132	44.88
T ₁ (°C)	10.83	8.45	6.69	5.68	55.23	11929.23	0.4120	
T ₂ (°C)	10.35	8.11	6.45	5.57	51.35	12017.39	0.4114	
T ₃ (°C)	9.90	7.72	6.22	5.46	47.48	12046.94	0.4114	
T ₄ (°C)	9.48	7.42	6.01	5.38	43.83	12145.75	0.4120	
T ₅ (°C)	9.07	7.13	5.86	5.31	40.12	12899.02	0.2765	
T _{out} (°C)	8.73	6.89	5.76	5.24	38.65	13786.55	0.2768	
m _{water} (kg/s)			0.28		37.09	15119.84	0.2774	
P _{water,in} (kPa)	729.84	N/A	N/A	355.10	35.53	16218.64	0.2783	
P _{water,out} (kPa)	602.57	N/A	N/A	208.92	34.06	17603.56	0.2796	
P _{sat} (kPa)	342.41	343.39	342.35	343.36	29.00	19350.11	0.1796	
P _{bundle,in} (kPa)			342.93		26.19	19738.39	0.1796	
P _{bundle,out} (kPa)			341.96		23.21	19862.43	0.1797	
m _{ref} (kg/s)			0.43		20.22	19599.96	0.1800	
	Path B	Path C	Path D	Path E	17.42	18204.74	0.1803	
T _{water,in} (°C)	11.31	11.29	11.32	11.33	12.65	13150.23	0.1132	
T _{water,out} (°C)	6.19	6.31	6.32	6.24	11.71	13335.19	0.1122	
m _{water} (kg/s)	0.33	0.34	0.33	0.33	10.72	13428.28	0.1111	
	Pre-boiler				9.73	13235.97	0.1100	
T _{water,in} (°C)			9.35		8.79	12709.97	0.1090	
T _{water,out} (°C)			7.63					
m _{water} (kg/s)			2.10					
T _{ref,in} (°C)			-7.57					
P _{ref,in} (kPa)			377.27					
P _{ref,out} (kPa)			368.95					

Point ID	R-134a, P/D 1.167, 45 30 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.55	8.96	7.17	5.94	58.09	11198.83	0.6653	44.59
T ₁ (°C)	11.02	8.69	6.95	5.82	54.38	11324.41	0.6641	
T ₂ (°C)	10.56	8.36	6.69	5.69	50.44	11331.95	0.6634	
T ₃ (°C)	10.12	8.00	6.45	5.57	46.50	11283.51	0.6633	
T ₄ (°C)	9.70	7.71	6.22	5.45	42.79	11248.39	0.6638	
T ₅ (°C)	9.30	7.41	6.05	5.36	38.46	11522.54	0.5267	
T _{out} (°C)	8.97	7.16	5.94	5.29	37.31	12271.67	0.5271	
m _{water} (kg/s)			0.28		36.09	13345.38	0.5278	
P _{water,in} (kPa)	730.08	N/A	N/A	355.87	34.88	14271.17	0.5289	
P _{water,out} (kPa)	602.21	N/A	N/A	209.69	33.73	15512.76	0.5302	
P _{sat} (kPa)	342.91	344.01	343.01	344.13	30.83	18459.98	0.4293	
P _{bundle,in} (kPa)			343.38		28.12	18979.12	0.4297	
P _{bundle,out} (kPa)			342.67		25.24	19384.60	0.4301	
m _{ref} (kg/s)			0.43		22.36	19512.36	0.4307	
	Path B	Path C	Path D	Path E	19.65	18754.02	0.4314	
T _{water,in} (°C)	11.51	11.48	11.52	11.53	15.74	15819.42	0.3615	
T _{water,out} (°C)	6.44	6.41	6.48	6.37	14.59	16339.67	0.3603	
m _{water} (kg/s)	0.34	0.34	0.33	0.33	13.36	16766.97	0.3589	
	Pre-boiler				12.13	17089.51	0.3576	
T _{water,in} (°C)			13.17		10.97	16741.85	0.3564	
T _{water,out} (°C)			9.95					
m _{water} (kg/s)			2.55					
T _{ref,in} (°C)			-5.86					
P _{ref,in} (kPa)			391.05					
P _{ref,out} (kPa)			377.45					

Point ID	R-134a, P/D 1.167, 45 45 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	14.61	10.64	8.15	6.43	92.16	12397.94	0.5941	44.67
T ₁ (°C)	13.79	10.25	7.83	6.28	85.45	12488.45	0.5916	
T ₂ (°C)	13.06	9.79	7.48	6.09	78.33	12422.39	0.5897	
T ₃ (°C)	12.37	9.28	7.15	5.91	71.20	12231.91	0.5887	
T ₄ (°C)	11.74	8.87	6.83	5.75	64.50	12027.30	0.5886	
T ₅ (°C)	11.14	8.48	6.60	5.64	55.51	11880.96	0.3809	
T _{out} (°C)	10.66	8.14	6.43	5.53	53.29	12497.86	0.3806	
m _{water} (kg/s)			0.28		50.92	13378.25	0.3807	
P _{water,in} (kPa)	752.09	N/A	N/A	366.15	48.56	14074.51	0.3813	
P _{water,out} (kPa)	621.33	N/A	N/A	213.06	46.33	14896.72	0.3823	
P _{sat} (kPa)	341.59	342.65	341.60	342.80	43.01	17890.63	0.2316	
P _{bundle,in} (kPa)			342.16		39.34	18378.23	0.2324	
P _{bundle,out} (kPa)			341.30		35.44	18719.01	0.2335	
m _{ref} (kg/s)			0.43		31.53	18889.04	0.2348	
	Path B	Path C	Path D	Path E	27.86	18233.64	0.2362	
T _{water,in} (°C)	14.61	14.60	14.58	14.64	22.26	15846.32	0.1287	
T _{water,out} (°C)	7.27	7.38	7.45	7.38	20.50	16236.46	0.1268	
m _{water} (kg/s)	0.35	0.35	0.36	0.36	18.62	16466.97	0.1247	
	Pre-boiler				16.75	16468.36	0.1227	
T _{water,in} (°C)			12.56		14.98	15824.06	0.1208	
T _{water,out} (°C)			6.07					
m _{water} (kg/s)			0.53					
T _{ref,in} (°C)			-5.52					
P _{ref,in} (kPa)			365.27					
P _{ref,out} (kPa)			356.70					

Point ID	R-134a, P/D 1.167, 45 56 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	19.46	13.04	9.42	7.16	127.56	12327.60	0.7016	45.17
T ₁ (°C)	18.13	12.44	8.99	6.95	117.91	12549.63	0.6986	
T ₂ (°C)	16.97	11.76	8.52	6.71	107.66	12686.18	0.6967	
T ₃ (°C)	15.83	10.99	8.07	6.49	97.41	12713.79	0.6962	
T ₄ (°C)	14.77	10.40	7.67	6.29	87.77	12694.32	0.6970	
T ₅ (°C)	13.81	9.88	7.37	6.16	70.93	12122.45	0.4282	
T _{out} (°C)	13.08	9.41	7.15	6.03	66.85	12683.11	0.4265	
m _{water} (kg/s)			0.24		62.51	13567.13	0.4254	
P _{water,in} (kPa)	579.94	N/A	N/A	298.06	58.17	14075.11	0.4251	
P _{water,out} (kPa)	483.51	N/A	N/A	185.32	54.09	14585.52	0.4255	
P _{sat} (kPa)	347.33	348.45	347.42	348.72	48.65	17460.44	0.2438	
P _{bundle,in} (kPa)			347.99		44.11	18079.46	0.2451	
P _{bundle,out} (kPa)			347.19		39.29	18529.79	0.2468	
m _{ref} (kg/s)			0.43		34.47	18664.10	0.2488	
	Path B	Path C	Path D	Path E	29.93	17945.77	0.2510	
T _{water,in} (°C)	19.40	19.45	19.50	19.52	24.29	16584.19	0.1281	
T _{water,out} (°C)	8.52	8.43	8.35	8.65	22.04	17079.56	0.1257	
m _{water} (kg/s)	0.30	0.30	0.29	0.30	19.65	17385.14	0.1231	
	Pre-boiler				17.25	17189.32	0.1206	
T _{water,in} (°C)			24.04		15.00	16147.16	0.1182	
T _{water,out} (°C)			8.57					
m _{water} (kg/s)			0.13					
T _{ref,in} (°C)			4.79					
P _{ref,in} (kPa)			405.26					
P _{ref,out} (kPa)			397.53					

Point ID	R-134a, P/D 1.167, 55 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.90	5.18	4.86	4.71	14.79	16097.45	0.1392	55.10
T ₁ (°C)	5.75	5.14	4.84	4.70	13.55	16608.91	0.1386	
T ₂ (°C)	5.61	5.07	4.81	4.69	12.24	16947.84	0.1380	
T ₃ (°C)	5.48	4.99	4.77	4.67	10.93	17060.30	0.1374	
T ₄ (°C)	5.36	4.94	4.75	4.66	9.69	17083.12	0.1370	
T ₅ (°C)	5.25	4.89	4.72	4.65	6.66	10615.01	0.1163	
T _{out} (°C)	5.18	4.86	4.71	4.64	6.27	10974.89	0.1161	
m _{water} (kg/s)			0.23		5.86	11548.33	0.1160	
P _{water,in} (kPa)	568.69	N/A	N/A	291.72	5.45	11619.72	0.1158	
P _{water,out} (kPa)	473.92	N/A	N/A	183.43	5.06	11759.81	0.1157	
P _{sat} (kPa)	341.63	342.53	341.41	342.43	3.43	10475.98	0.1013	
P _{bundle,in} (kPa)			342.39		3.16	10335.62	0.1014	
P _{bundle,out} (kPa)			340.86		2.87	10250.57	0.1015	
m _{ref} (kg/s)			0.53		2.58	9858.19	0.1017	
	Path B	Path C	Path D	Path E	2.31	9331.31	0.1018	
T _{water,in} (°C)	5.84	5.85	5.82	5.90	1.72	5426.11	0.0917	
T _{water,out} (°C)	4.84	5.00	4.93	4.94	1.62	5319.97	0.0916	
m _{water} (kg/s)	0.30	0.34	0.32	0.31	1.52	5161.97	0.0915	
	Pre-boiler				1.41	4997.45	0.0914	
T _{water,in} (°C)			11.64		1.31	4723.47	0.0914	
T _{water,out} (°C)			10.12					
m _{water} (kg/s)			1.96					
T _{ref,in} (°C)			-0.22					
P _{ref,in} (kPa)			412.89					
P _{ref,out} (kPa)			403.73					

Point ID	R-134a, P/D 1.167, 55 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.86	5.18	4.83	4.69	14.09	16324.24	0.3968	54.97
T ₁ (°C)	5.73	5.13	4.80	4.67	12.99	17147.92	0.3963	
T ₂ (°C)	5.59	5.05	4.77	4.66	11.82	17739.02	0.3959	
T ₃ (°C)	5.46	4.97	4.74	4.65	10.66	18238.47	0.3955	
T ₄ (°C)	5.35	4.92	4.71	4.63	9.56	18776.02	0.3952	
T ₅ (°C)	5.24	4.87	4.69	4.63	7.23	13052.93	0.3744	
T _{out} (°C)	5.17	4.83	4.68	4.62	6.75	13676.32	0.3742	
m _{water} (kg/s)			0.23		6.24	14632.58	0.3740	
P _{water,in} (kPa)	567.48	N/A	N/A	290.30	5.72	14791.09	0.3739	
P _{water,out} (kPa)	472.19	N/A	N/A	182.03	5.24	14913.35	0.3738	
P _{sat} (kPa)	341.93	342.97	341.97	343.08	3.67	14688.16	0.3590	
P _{bundle,in} (kPa)			342.54		3.27	14208.63	0.3591	
P _{bundle,out} (kPa)			341.55		2.85	13712.68	0.3591	
m _{ref} (kg/s)			0.52		2.43	12527.31	0.3592	
	Path B	Path C	Path D	Path E	2.04	10929.29	0.3592	
T _{water,in} (°C)	5.80	5.82	5.88	5.88	1.62	6065.61	0.3492	
T _{water,out} (°C)	4.81	4.96	4.98	4.91	1.50	5866.67	0.3491	
m _{water} (kg/s)	0.29	0.34	0.34	0.31	1.37	5558.83	0.3490	
	Pre-boiler				1.25	5264.20	0.3489	
T _{water,in} (°C)			14.23		1.13	4834.71	0.3488	
T _{water,out} (°C)			9.97					
m _{water} (kg/s)			2.28					
T _{ref,in} (°C)			-2.88					
P _{ref,in} (kPa)			390.41					
P _{ref,out} (kPa)			371.82					

Point ID	R-134a, P/D 1.167, 55 5 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.83	5.17	4.81	4.65	13.31	14902.44	0.5918	
T ₁ (°C)	5.70	5.12	4.78	4.63	12.41	15831.94	0.5915	
T ₂ (°C)	5.57	5.04	4.74	4.62	11.45	16486.18	0.5913	
T ₃ (°C)	5.45	4.96	4.71	4.60	10.49	17264.86	0.5910	
T ₄ (°C)	5.34	4.90	4.68	4.59	9.59	18207.18	0.5909	
T ₅ (°C)	5.23	4.85	4.66	4.58	7.45	13091.97	0.5701	
T _{out} (°C)	5.16	4.80	4.64	4.57	6.97	13746.79	0.5699	
m _{water} (kg/s)			0.23		6.46	14712.95	0.5697	
P _{water,in} (kPa)	567.20	N/A	N/A	289.38	5.94	15006.68	0.5696	
P _{water,out} (kPa)	471.73	N/A	N/A	182.08	5.46	15208.16	0.5695	
P _{sat} (kPa)	341.40	342.51	341.53	342.71	4.01	16054.31	0.5546	55.25
P _{bundle,in} (kPa)			341.92		3.56	15578.00	0.5546	
P _{bundle,out} (kPa)			341.22		3.09	15040.51	0.5546	
m _{ref} (kg/s)			0.53		2.62	13743.60	0.5547	
	Path B	Path C	Path D	Path E	2.17	11880.87	0.5547	
T _{water,in} (°C)	5.76	5.79	5.85	5.84	1.82	6845.13	0.5447	
T _{water,out} (°C)	4.77	4.90	4.94	4.87	1.69	6663.59	0.5446	
m _{water} (kg/s)	0.29	0.34	0.34	0.31	1.54	6342.29	0.5445	
			Pre-boiler		1.40	6038.41	0.5444	
T _{water,in} (°C)			21.34		1.27	5567.30	0.5443	
T _{water,out} (°C)			15.90					
m _{water} (kg/s)			2.58					
T _{ref,in} (°C)			0.30					
P _{ref,in} (kPa)			471.57					
P _{ref,out} (kPa)			448.76					

Point ID	R-134a, P/D 1.167, 55 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.94	6.36	5.50	5.08	33.43	14700.78	0.2367	
T ₁ (°C)	7.63	6.24	5.43	5.05	31.30	15392.63	0.2362	
T ₂ (°C)	7.34	6.06	5.34	5.01	29.04	16053.06	0.2360	
T ₃ (°C)	7.06	5.86	5.25	4.97	26.77	16670.63	0.2359	
T ₄ (°C)	6.80	5.72	5.17	4.93	24.64	17619.05	0.2361	
T ₅ (°C)	6.53	5.59	5.11	4.91	18.95	14225.17	0.1796	
T _{out} (°C)	6.36	5.49	5.08	4.88	17.82	15060.31	0.1791	
m _{water} (kg/s)			0.25		16.62	16361.72	0.1787	
P _{water,in} (kPa)	646.75	N/A	N/A	321.64	15.42	17019.46	0.1785	
P _{water,out} (kPa)	535.08	N/A	N/A	195.76	14.29	17768.45	0.1783	
P _{sat} (kPa)	342.63	343.59	342.49	343.63	10.05	15288.19	0.1386	55.38
P _{bundle,in} (kPa)			343.22		9.15	15362.63	0.1389	
P _{bundle,out} (kPa)			342.04		8.18	15454.30	0.1392	
m _{ref} (kg/s)			0.53		7.22	15016.12	0.1396	
	Path B	Path C	Path D	Path E	6.31	14099.36	0.1400	
T _{water,in} (°C)	7.89	7.90	7.87	7.95	4.68	9250.57	0.1133	
T _{water,out} (°C)	5.38	5.62	5.60	5.50	4.37	9238.36	0.1130	
m _{water} (kg/s)	0.32	0.36	0.37	0.33	4.04	9173.78	0.1127	
			Pre-boiler		3.71	8943.97	0.1124	
T _{water,in} (°C)			12.22		3.40	8551.70	0.1121	
T _{water,out} (°C)			10.53					
m _{water} (kg/s)			1.67					
T _{ref,in} (°C)			3.74					
P _{ref,in} (kPa)			416.57					
P _{ref,out} (kPa)			406.98					

Point ID	R-134a, P/D 1.167, 55 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.77	6.39	5.52	5.04	30.33	13204.92	0.4961	54.99
T ₁ (°C)	7.51	6.27	5.43	4.99	28.66	13818.49	0.4958	
T ₂ (°C)	7.24	6.09	5.33	4.95	26.89	14268.77	0.4958	
T ₃ (°C)	7.01	5.90	5.22	4.90	25.11	14796.21	0.4959	
T ₄ (°C)	6.78	5.75	5.14	4.86	23.44	15615.61	0.4963	
T ₅ (°C)	6.54	5.62	5.07	4.83	19.62	13944.28	0.4399	
T _{out} (°C)	6.38	5.51	5.03	4.80	18.69	14892.31	0.4398	
m _{water} (kg/s)			0.27		17.70	16276.08	0.4397	
P _{water,in} (kPa)	710.16	N/A	N/A	348.26	16.71	17327.16	0.4398	
P _{water,out} (kPa)	587.06	N/A	N/A	208.39	15.78	18494.37	0.4400	
P _{sat} (kPa)	341.98	343.14	342.01	343.24	12.47	19237.36	0.3991	
P _{bundle,in} (kPa)			342.50		11.22	19369.87	0.3991	
P _{bundle,out} (kPa)			341.77		9.90	19405.12	0.3993	
m _{ref} (kg/s)			0.52		8.57	18771.93	0.3994	
	Path B	Path C	Path D	Path E	7.33	17171.37	0.3997	
T _{water,in} (°C)	7.71	7.69	7.72	7.75	5.81	12069.10	0.3723	
T _{water,out} (°C)	5.31	5.48	5.41	5.39	5.41	12153.61	0.3719	
m _{water} (kg/s)	0.35	0.38	0.36	0.36	4.97	12122.50	0.3715	
	Pre-boiler				4.54	12019.64	0.3712	
T _{water,in} (°C)			17.33		4.13	11507.03	0.3708	
T _{water,out} (°C)			13.07					
m _{water} (kg/s)			2.56					
T _{ref,in} (°C)			-9.91					
P _{ref,in} (kPa)			433.50					
P _{ref,out} (kPa)			416.06					

Point ID	R-134a, P/D 1.167, 55 15 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	8.31	6.72	5.70	5.11	30.77	11654.66	0.6743	54.70
T ₁ (°C)	8.01	6.57	5.58	5.06	28.99	12192.02	0.6740	
T ₂ (°C)	7.70	6.36	5.46	5.00	27.09	12512.00	0.6739	
T ₃ (°C)	7.44	6.15	5.34	4.95	25.20	12923.83	0.6741	
T ₄ (°C)	7.17	5.97	5.23	4.90	23.42	13481.74	0.6745	
T ₅ (°C)	6.91	5.81	5.16	4.87	20.10	12803.94	0.6183	
T _{out} (°C)	6.71	5.69	5.11	4.83	19.11	13758.41	0.6181	
m _{water} (kg/s)			0.24		18.05	14983.77	0.6181	
P _{water,in} (kPa)	580.36	N/A	N/A	295.88	17.00	16009.29	0.6182	
P _{water,out} (kPa)	483.37	N/A	N/A	184.18	16.00	17229.20	0.6185	
P _{sat} (kPa)	342.70	343.83	342.80	343.99	13.32	19500.19	0.5784	
P _{bundle,in} (kPa)			343.19		11.92	19928.96	0.5784	
P _{bundle,out} (kPa)			342.54		10.42	20114.30	0.5785	
m _{ref} (kg/s)			0.52		8.93	19571.60	0.5786	
	Path B	Path C	Path D	Path E	7.53	17903.31	0.5787	
T _{water,in} (°C)	8.24	8.24	8.30	8.32	6.07	13180.86	0.5524	
T _{water,out} (°C)	5.46	5.54	5.52	5.47	5.56	13309.66	0.5520	
m _{water} (kg/s)	0.31	0.30	0.29	0.29	5.03	13244.79	0.5515	
	Pre-boiler				4.49	13043.05	0.5510	
T _{water,in} (°C)			17.09		3.99	12259.77	0.5506	
T _{water,out} (°C)			11.40					
m _{water} (kg/s)			2.32					
T _{ref,in} (°C)			4.88					
P _{ref,in} (kPa)			410.15					
P _{ref,out} (kPa)			383.84					

Point ID	R-134a, P/D 1.167, 55 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.40	8.68	6.84	5.74	60.16	11967.06	0.3625	54.81
T ₁ (°C)	10.86	8.41	6.64	5.66	56.63	12312.78	0.3617	
T ₂ (°C)	10.36	8.06	6.41	5.55	52.88	12493.65	0.3615	
T ₃ (°C)	9.90	7.67	6.18	5.45	49.13	12652.31	0.3618	
T ₄ (°C)	9.47	7.37	5.98	5.36	45.61	12965.00	0.3625	
T ₅ (°C)	9.03	7.08	5.84	5.30	40.70	13363.01	0.2458	
T _{out} (°C)	8.69	6.83	5.74	5.23	39.06	14245.63	0.2458	
m _{water} (kg/s)			0.28		37.32	15614.65	0.2461	
P _{water,in} (kPa)	729.83	N/A	N/A	356.30	35.57	16721.80	0.2467	
P _{water,out} (kPa)	602.79	N/A	N/A	210.16	33.93	18098.19	0.2476	
P _{sat} (kPa)	342.34	343.33	342.37	343.41	28.28	19263.81	0.1614	
P _{bundle,in} (kPa)			342.96		25.51	19545.39	0.1615	
P _{bundle,out} (kPa)			341.95		22.57	19664.47	0.1617	
m _{ref} (kg/s)			0.52		19.62	19205.91	0.1620	
	Path B	Path C	Path D	Path E	16.85	17798.54	0.1624	
T _{water,in} (°C)	11.36	11.34	11.38	11.40	12.42	13038.84	0.1041	
T _{water,out} (°C)	6.27	6.39	6.51	6.36	11.50	13216.08	0.1033	
m _{water} (kg/s)	0.34	0.35	0.37	0.35	10.53	13297.67	0.1024	
	Pre-boiler				9.55	13104.90	0.1016	
T _{water,in} (°C)			9.00		8.64	12586.79	0.1008	
T _{water,out} (°C)			6.96					
m _{water} (kg/s)			2.09					
T _{ref,in} (°C)			-7.65					
P _{ref,in} (kPa)			369.10					
P _{ref,out} (kPa)			359.09					

Point ID	R-134a, P/D 1.167, 55 30 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.40	8.86	7.13	5.95	56.53	11325.52	0.6028	54.82
T ₁ (°C)	10.90	8.59	6.92	5.84	53.15	11545.35	0.6020	
T ₂ (°C)	10.43	8.28	6.68	5.72	49.57	11655.03	0.6016	
T ₃ (°C)	10.00	7.93	6.44	5.60	45.98	11738.69	0.6017	
T ₄ (°C)	9.58	7.64	6.22	5.49	42.61	11897.88	0.6022	
T ₅ (°C)	9.17	7.36	6.07	5.41	37.01	11595.58	0.4910	
T _{out} (°C)	8.87	7.13	5.95	5.33	35.89	12359.28	0.4913	
m _{water} (kg/s)			0.28		34.70	13433.30	0.4918	
P _{water,in} (kPa)	729.48	N/A	N/A	356.23	33.52	14407.64	0.4926	
P _{water,out} (kPa)	601.31	N/A	N/A	209.70	32.40	15662.47	0.4936	
P _{sat} (kPa)	343.93	345.05	343.98	345.27	29.38	18533.39	0.4118	
P _{bundle,in} (kPa)			344.49		26.79	19077.49	0.4121	
P _{bundle,out} (kPa)			343.77		24.04	19500.13	0.4125	
m _{ref} (kg/s)			0.52		21.29	19627.10	0.4130	
	Path B	Path C	Path D	Path E	18.70	18869.81	0.4136	
T _{water,in} (°C)	11.38	11.36	11.36	11.41	14.98	15841.08	0.3562	
T _{water,out} (°C)	6.42	6.59	6.72	6.58	13.87	16348.45	0.3552	
m _{water} (kg/s)	0.34	0.35	0.37	0.36	12.69	16742.56	0.3542	
	Pre-boiler				11.52	17086.67	0.3531	
T _{water,in} (°C)			15.21		10.41	16673.57	0.3521	
T _{water,out} (°C)			10.43					
m _{water} (kg/s)			2.11					
T _{ref,in} (°C)			-6.33					
P _{ref,in} (kPa)			396.39					
P _{ref,out} (kPa)			378.06					

Point ID	R-134a, P/D 1.167, 55 45 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	14.63	10.68	8.21	6.52	91.26	12429.39	0.4915	55.44
T ₁ (°C)	13.82	10.29	7.90	6.37	84.80	12560.07	0.4896	
T ₂ (°C)	13.09	9.84	7.56	6.19	77.94	12536.02	0.4883	
T ₃ (°C)	12.41	9.33	7.22	6.02	71.08	12399.79	0.4877	
T ₄ (°C)	11.79	8.93	6.91	5.86	64.62	12274.39	0.4878	
T ₅ (°C)	11.18	8.54	6.69	5.75	55.06	12001.35	0.3210	
T _{out} (°C)	10.70	8.20	6.52	5.65	52.87	12647.17	0.3208	
m _{water} (kg/s)			0.28		50.55	13562.70	0.3209	
P _{water,in} (kPa)	752.76	N/A	N/A	365.39	48.23	14297.13	0.3215	
P _{water,out} (kPa)	621.75	N/A	N/A	212.72	46.04	15173.09	0.3224	
P _{sat} (kPa)	343.31	344.38	343.34	344.53	42.49	18131.42	0.2018	
P _{bundle,in} (kPa)			343.88		38.81	18622.86	0.2024	
P _{bundle,out} (kPa)			343.03		34.91	18970.78	0.2033	
m _{ref} (kg/s)			0.53		31.00	19115.28	0.2043	
	Path B	Path C	Path D	Path E	27.32	18410.17	0.2054	
T _{water,in} (°C)	14.64	14.62	14.61	14.67	21.72	15860.16	0.1199	
T _{water,out} (°C)	7.36	7.47	7.55	7.46	20.00	16236.39	0.1184	
m _{water} (kg/s)	0.35	0.36	0.36	0.36	18.16	16463.80	0.1168	
	Pre-boiler				16.33	16465.41	0.1152	
T _{water,in} (°C)			9.95		14.61	15812.22	0.1137	
T _{water,out} (°C)			8.01					
m _{water} (kg/s)			2.10					
T _{ref,in} (°C)			-5.51					
P _{ref,in} (kPa)			380.37					
P _{ref,out} (kPa)			370.10					

Point ID	R-134a, P/D 1.33, 15 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.93	5.30	5.02	4.90	14.64	19298.00	0.1971	15.00
T ₁ (°C)	5.80	5.25	5.00	4.89	13.37	19894.26	0.1959	
T ₂ (°C)	5.68	5.19	4.97	4.88	12.01	20730.71	0.1948	
T ₃ (°C)	5.55	5.14	4.94	4.87	10.65	21240.14	0.1937	
T ₄ (°C)	5.43	5.08	4.93	4.86	9.38	20420.85	0.1928	
T ₅ (°C)	5.36	5.04	4.91	4.85	6.54	12908.67	0.1566	
T _{out} (°C)	5.28	5.01	4.89	4.85	6.06	13236.30	0.1561	
m _{water} (kg/s)			0.25		5.55	13149.08	0.1556	
P _{water,in} (kPa)	644.64	N/A	N/A	311.77	5.05	13240.25	0.1551	
P _{water,out} (kPa)	527.14	N/A	N/A	198.52	4.57	12816.04	0.1547	
P _{sat} (kPa)	344.77	345.72	344.40	345.37	3.05	12791.20	0.1296	
P _{bundle,in} (kPa)			345.76		2.84	12826.06	0.1298	
P _{bundle,out} (kPa)			343.53		2.61	13153.21	0.1300	
m _{ref} (kg/s)			0.28		2.38	12695.21	0.1303	
	Path B	Path C	Path D	Path E	2.16	12362.69	0.1306	
T _{water,in} (°C)	5.91	5.89	5.89	5.97	1.42	5492.69	0.1125	
T _{water,out} (°C)	5.12	5.17	5.09	5.19	1.37	5489.82	0.1124	
m _{water} (kg/s)	0.36	0.38	0.34	0.36	1.31	5447.79	0.1123	
	Pre-boiler				1.26	5412.30	0.1122	
T _{water,in} (°C)			7.71		1.21	5329.30	0.1122	
T _{water,out} (°C)			6.99					
m _{water} (kg/s)			2.54					
T _{ref,in} (°C)			0.67					
P _{ref,in} (kPa)			365.07					
P _{ref,out} (kPa)			358.89					

Point ID	R-134a, P/D 1.33, 15 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.62	4.83	4.49	4.38	17.41	21555.64	0.4390	15.14
T ₁ (°C)	5.45	4.77	4.48	4.37	15.80	22340.64	0.4377	
T ₂ (°C)	5.31	4.70	4.45	4.36	14.09	23763.67	0.4363	
T ₃ (°C)	5.14	4.64	4.42	4.35	12.39	24732.43	0.4351	
T ₄ (°C)	5.00	4.57	4.40	4.34	10.78	24123.65	0.4341	
T ₅ (°C)	4.90	4.53	4.39	4.34	7.44	15027.48	0.3947	
T _{out} (°C)	4.81	4.49	4.37	4.33	6.81	15397.22	0.3939	
m _{water} (kg/s)			0.24		6.15	15334.00	0.3931	
P _{water,in} (kPa)	593.35	N/A	N/A	290.71	5.48	15302.92	0.3924	
P _{water,out} (kPa)	486.00	N/A	N/A	188.40	4.85	14698.71	0.3917	
P _{sat} (kPa)	338.53	339.61	338.33	339.40	2.76	11996.46	0.3654	
P _{bundle,in} (kPa)			339.40		2.59	12323.25	0.3658	
P _{bundle,out} (kPa)			337.57		2.42	13086.49	0.3662	
m _{ref} (kg/s)			0.29		2.25	13079.32	0.3666	
	Path B	Path C	Path D	Path E	2.09	13135.34	0.3671	
T _{water,in} (°C)	5.58	5.55	5.55	5.64	1.29	4952.75	0.3490	
T _{water,out} (°C)	4.60	4.62	4.59	4.67	1.22	4847.19	0.3489	
m _{water} (kg/s)	0.29	0.31	0.30	0.30	1.15	4687.46	0.3488	
	Pre-boiler				1.07	4540.58	0.3487	
T _{water,in} (°C)			21.48		1.00	4317.16	0.3486	
T _{water,out} (°C)			6.27					
m _{water} (kg/s)			0.35					
T _{ref,in} (°C)			-4.29					
P _{ref,in} (kPa)			360.41					
P _{ref,out} (kPa)			351.55					

Point ID	R-134a, P/D 1.33, 15 5 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.78	4.98	4.64	4.54	17.62	23356.43	0.6420	15.22
T ₁ (°C)	5.60	4.91	4.63	4.53	15.95	24111.07	0.6406	
T ₂ (°C)	5.46	4.84	4.60	4.52	14.17	26088.06	0.6392	
T ₃ (°C)	5.29	4.78	4.57	4.51	12.40	27330.12	0.6379	
T ₄ (°C)	5.15	4.72	4.56	4.51	10.72	26674.83	0.6368	
T ₅ (°C)	5.05	4.68	4.54	4.50	7.48	16826.63	0.5975	
T _{out} (°C)	4.96	4.64	4.53	4.50	6.81	17344.68	0.5967	
m _{water} (kg/s)			0.24		6.11	17300.88	0.5958	
P _{water,in} (kPa)	592.82	N/A	N/A	290.38	5.41	17232.99	0.5951	
P _{water,out} (kPa)	485.39	N/A	N/A	188.39	4.75	16627.54	0.5944	
P _{sat} (kPa)	340.73	341.87	340.66	341.75	2.61	13352.96	0.5682	
P _{bundle,in} (kPa)			341.52		2.43	13634.06	0.5685	
P _{bundle,out} (kPa)			339.98		2.24	14471.46	0.5689	
m _{ref} (kg/s)			0.29		2.05	14220.94	0.5692	
	Path B	Path C	Path D	Path E	1.87	13998.34	0.5696	
T _{water,in} (°C)	5.71	5.70	5.71	5.80	1.16	4854.45	0.5518	
T _{water,out} (°C)	4.76	4.77	4.74	4.83	1.10	4758.43	0.5517	
m _{water} (kg/s)	0.29	0.31	0.30	0.31	1.04	4610.70	0.5516	
	Pre-boiler				0.97	4476.97	0.5515	
T _{water,in} (°C)			22.28		0.92	4266.01	0.5514	
T _{water,out} (°C)			7.15					
m _{water} (kg/s)			0.54					
T _{ref,in} (°C)			-4.50					
P _{ref,in} (kPa)			367.72					
P _{ref,out} (kPa)			356.45					

Point ID	R-134a, P/D 1.33, 15 5 0.70							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.87	5.08	4.73	4.63	17.08	22321.96	0.7836	15.09
T ₁ (°C)	5.70	5.01	4.71	4.62	15.62	23872.35	0.7825	
T ₂ (°C)	5.55	4.94	4.69	4.61	14.07	26138.40	0.7816	
T ₃ (°C)	5.39	4.88	4.66	4.60	12.52	27571.47	0.7807	
T ₄ (°C)	5.26	4.81	4.65	4.59	11.06	29016.99	0.7801	
T ₅ (°C)	5.15	4.77	4.63	4.59	7.71	17964.56	0.7392	
T _{out} (°C)	5.06	4.73	4.62	4.58	7.00	18501.31	0.7383	
m _{water} (kg/s)			0.24		6.24	18448.46	0.7373	
P _{water,in} (kPa)	592.52	N/A	N/A	290.29	5.48	18493.04	0.7365	
P _{water,out} (kPa)	485.90	N/A	N/A	188.34	4.77	17504.13	0.7358	
P _{sat} (kPa)	341.84	342.99	341.82	342.98	2.67	14726.80	0.7087	
P _{bundle,in} (kPa)			342.55		2.48	15068.13	0.7090	
P _{bundle,out} (kPa)			341.15		2.27	16048.02	0.7094	
m _{ref} (kg/s)			0.28		2.06	15724.88	0.7098	
	Path B	Path C	Path D	Path E	1.87	15388.88	0.7102	
T _{water,in} (°C)	5.82	5.81	5.82	5.90	1.22	5413.85	0.6918	
T _{water,out} (°C)	4.85	4.86	4.82	4.91	1.15	5265.01	0.6917	
m _{water} (kg/s)	0.29	0.31	0.30	0.31	1.07	5049.63	0.6915	
	Pre-boiler				0.99	4861.44	0.6914	
T _{water,in} (°C)			22.01		0.92	4558.12	0.6913	
T _{water,out} (°C)			7.74					
m _{water} (kg/s)			0.69					
T _{ref,in} (°C)			-3.87					
P _{ref,in} (kPa)			371.53					
P _{ref,out} (kPa)			358.82					

Point ID	R-134a, P/D 1.33, 15 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.73	6.09	5.31	4.97	40.33	19616.28	0.3619	15.23
T ₁ (°C)	7.42	5.94	5.24	4.94	37.33	20514.70	0.3606	
T ₂ (°C)	7.11	5.78	5.18	4.91	34.14	21746.58	0.3594	
T ₃ (°C)	6.79	5.64	5.10	4.88	30.96	22872.18	0.3587	
T ₄ (°C)	6.49	5.49	5.05	4.85	27.96	23142.37	0.3583	
T ₅ (°C)	6.28	5.38	5.00	4.82	20.22	17921.40	0.2438	
T _{out} (°C)	6.08	5.30	4.96	4.80	18.51	18395.84	0.2419	
m _{water} (kg/s)			0.28		16.70	18443.06	0.2402	
P _{water,in} (kPa)	778.96	N/A	N/A	362.19	14.89	18621.93	0.2386	
P _{water,out} (kPa)	631.84	N/A	N/A	220.82	13.19	17873.85	0.2373	
P _{sat} (kPa)	341.84	342.89	341.58	342.66	9.03	15452.33	0.1600	
P _{bundle,in} (kPa)			342.77		8.36	15573.50	0.1608	
P _{bundle,out} (kPa)			340.85		7.65	16092.14	0.1618	
m _{ref} (kg/s)			0.29		6.93	15726.66	0.1629	
	Path B	Path C	Path D	Path E	6.26	15345.86	0.1640	
T _{water,in} (°C)	7.72	7.70	7.71	7.78	4.20	8685.04	0.1101	
T _{water,out} (°C)	5.47	5.50	5.47	5.54	4.06	8875.98	0.1098	
m _{water} (kg/s)	0.41	0.42	0.38	0.41	3.90	9083.16	0.1096	
	Pre-boiler				3.74	9261.08	0.1093	
T _{water,in} (°C)			19.64		3.59	9476.45	0.1091	
T _{water,out} (°C)			4.84					
m _{water} (kg/s)			0.15					
T _{ref,in} (°C)			-4.94					
P _{ref,in} (kPa)			362.50					
P _{ref,out} (kPa)			356.40					

Point ID	R-134a, P/D 1.33, 15 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.91	6.12	5.23	4.87	40.53	18858.34	0.5923	15.15
T ₁ (°C)	7.57	5.95	5.17	4.84	37.50	19995.91	0.5911	
T ₂ (°C)	7.22	5.77	5.09	4.80	34.28	21224.91	0.5903	
T ₃ (°C)	6.88	5.61	5.01	4.77	31.06	22415.72	0.5900	
T ₄ (°C)	6.57	5.44	4.95	4.74	28.03	23021.62	0.5901	
T ₅ (°C)	6.33	5.32	4.90	4.71	21.07	19216.64	0.4782	
T _{out} (°C)	6.11	5.23	4.86	4.69	19.24	20058.65	0.4761	
m _{water} (kg/s)			0.26		17.30	20393.32	0.4740	
P _{water,in} (kPa)	684.80	N/A	N/A	325.02	15.36	21071.23	0.4722	
P _{water,out} (kPa)	557.43	N/A	N/A	203.35	13.53	20462.14	0.4708	
P _{sat} (kPa)	341.44	342.52	341.31	342.44	8.96	17353.40	0.3967	
P _{bundle,in} (kPa)			342.27		8.26	17834.69	0.3975	
P _{bundle,out} (kPa)			340.62		7.52	19041.46	0.3985	
m _{ref} (kg/s)			0.29		6.78	18902.45	0.3997	
	Path B	Path C	Path D	Path E	6.08	18658.12	0.4008	
T _{water,in} (°C)	7.85	7.87	7.85	7.96	4.29	10776.28	0.3512	
T _{water,out} (°C)	5.30	5.36	5.29	5.36	3.99	10751.84	0.3508	
m _{water} (kg/s)	0.32	0.33	0.33	0.34	3.68	10659.48	0.3503	
	Pre-boiler				3.37	10487.06	0.3498	
T _{water,in} (°C)			22.46		3.08	10100.82	0.3493	
T _{water,out} (°C)			6.34					
m _{water} (kg/s)			0.33					
T _{ref,in} (°C)			-4.37					
P _{ref,in} (kPa)			363.00					
P _{ref,out} (kPa)			354.48					

Point ID	R-134a, P/D 1.33, 15 15 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.64	5.93	5.05	4.67	38.43	18317.12	0.7990	14.87
T ₁ (°C)	7.31	5.76	4.97	4.63	35.67	19427.73	0.7979	
T ₂ (°C)	6.98	5.58	4.89	4.60	32.74	20624.96	0.7972	
T ₃ (°C)	6.66	5.42	4.80	4.57	29.80	21813.74	0.7970	
T ₄ (°C)	6.36	5.25	4.75	4.54	27.04	22542.39	0.7973	
T ₅ (°C)	6.13	5.13	4.70	4.51	20.89	19561.56	0.6850	
T _{out} (°C)	5.91	5.04	4.66	4.50	19.14	20564.15	0.6832	
m _{water} (kg/s)			0.26		17.28	21127.82	0.6816	
P _{water,in} (kPa)	684.71	N/A	N/A	325.15	15.42	22087.18	0.6802	
P _{water,out} (kPa)	557.62	N/A	N/A	202.51	13.67	21844.83	0.6792	
P _{sat} (kPa)	339.43	340.52	339.38	340.57	9.80	21210.32	0.6044	
P _{bundle,in} (kPa)			340.11		8.81	21260.90	0.6049	
P _{bundle,out} (kPa)			338.75		7.75	21926.61	0.6055	
m _{ref} (kg/s)			0.28		6.69	20549.43	0.6062	
	Path B	Path C	Path D	Path E	5.69	18819.59	0.6069	
T _{water,in} (°C)	7.58	7.60	7.57	7.69	4.26	11587.11	0.5578	
T _{water,out} (°C)	5.14	5.11	5.05	5.15	3.93	11469.41	0.5573	
m _{water} (kg/s)	0.35	0.33	0.33	0.34	3.59	11287.30	0.5567	
	Pre-boiler				3.25	11014.74	0.5562	
T _{water,in} (°C)			22.24		2.93	10412.69	0.5557	
T _{water,out} (°C)			6.95					
m _{water} (kg/s)			0.52					
T _{ref,in} (°C)			-3.91					
P _{ref,in} (kPa)			365.64					
P _{ref,out} (kPa)			354.72					

Point ID	R-134a, P/D 1.33, 15 29 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	10.86	7.73	6.01	5.17	69.68	16336.28	0.8073	15.12
T ₁ (°C)	10.24	7.39	5.83	5.10	64.47	17032.98	0.8053	
T ₂ (°C)	9.64	7.05	5.67	5.03	58.93	17655.90	0.8041	
T ₃ (°C)	9.06	6.74	5.49	4.96	53.39	18023.49	0.8040	
T ₄ (°C)	8.56	6.42	5.37	4.89	48.17	18107.12	0.8048	
T ₅ (°C)	8.13	6.19	5.26	4.83	39.57	18212.05	0.5973	
T _{out} (°C)	7.71	6.00	5.16	4.80	36.40	19089.89	0.5943	
m _{water} (kg/s)			0.26		33.03	19611.21	0.5917	
P _{water,in} (kPa)	684.64	N/A	N/A	325.10	29.67	20441.21	0.5897	
P _{water,out} (kPa)	557.01	N/A	N/A	202.83	26.50	20425.87	0.5883	
P _{sat} (kPa)	340.40	341.53	340.37	341.57	20.31	20669.00	0.4490	
P _{bundle,in} (kPa)			341.21		18.33	20950.94	0.4500	
P _{bundle,out} (kPa)			339.80		16.24	21769.91	0.4513	
m _{ref} (kg/s)			0.29		14.14	20888.92	0.4529	
	Path B	Path C	Path D	Path E	12.17	19673.93	0.4547	
T _{water,in} (°C)	10.79	10.85	10.84	10.93	8.99	14084.48	0.3642	
T _{water,out} (°C)	5.95	5.99	5.92	6.00	8.31	14255.06	0.3631	
m _{water} (kg/s)	0.33	0.33	0.33	0.34	7.59	14392.29	0.3620	
	Pre-boiler				6.87	14386.63	0.3608	
T _{water,in} (°C)			21.87		6.20	14053.24	0.3597	
T _{water,out} (°C)			17.88					
m _{water} (kg/s)			1.36					
T _{ref,in} (°C)			-4.16					
P _{ref,in} (kPa)			524.50					
P _{ref,out} (kPa)			517.30					

Point ID	R-134a, P/D 1.33, 15 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.62	8.18	6.27	5.35	76.27	15949.93	0.6075	15.10
T ₁ (°C)	10.93	7.81	6.08	5.28	70.52	16516.34	0.6049	
T ₂ (°C)	10.28	7.44	5.90	5.21	64.42	17077.91	0.6032	
T ₃ (°C)	9.64	7.09	5.70	5.14	58.31	17382.35	0.6026	
T ₄ (°C)	9.08	6.73	5.56	5.07	52.57	17306.10	0.6031	
T ₅ (°C)	8.63	6.47	5.44	5.01	43.70	17826.99	0.3781	
T _{out} (°C)	8.17	6.26	5.34	4.97	40.34	18627.15	0.3752	
m _{water} (kg/s)			0.26		36.76	19318.61	0.3728	
P _{water,in} (kPa)	684.23	N/A	N/A	325.19	33.19	20275.23	0.3709	
P _{water,out} (kPa)	557.75	N/A	N/A	202.67	29.82	20457.94	0.3697	
P _{sat} (kPa)	341.06	342.08	340.86	341.99	22.22	19653.44	0.2171	
P _{bundle,in} (kPa)			341.92		20.06	19760.60	0.2178	
P _{bundle,out} (kPa)			340.19		17.77	20461.50	0.2189	
m _{ref} (kg/s)			0.28		15.48	19548.36	0.2202	
	Path B	Path C	Path D	Path E	13.32	18288.05	0.2217	
T _{water,in} (°C)	11.60	11.60	11.59	11.67	8.77	11464.33	0.1221	
T _{water,out} (°C)	6.19	6.15	6.22	6.16	8.23	11613.62	0.1212	
m _{water} (kg/s)	0.33	0.32	0.34	0.31	7.66	11785.58	0.1203	
	Pre-boiler				7.08	11849.79	0.1194	
T _{water,in} (°C)			19.61		6.54	11856.24	0.1185	
T _{water,out} (°C)			4.87					
m _{water} (kg/s)			0.15					
T _{ref,in} (°C)			-4.51					
P _{ref,in} (kPa)			361.54					
P _{ref,out} (kPa)			355.35					

Point ID	R-134a, P/D 1.33, 15 39 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	13.62	9.14	6.91	5.76	103.57	18112.60	0.7381	14.98
T ₁ (°C)	12.70	8.70	6.66	5.67	94.02	18625.75	0.7308	
T ₂ (°C)	11.81	8.27	6.44	5.58	83.88	18958.81	0.7244	
T ₃ (°C)	10.96	7.86	6.19	5.49	73.73	18704.20	0.7195	
T ₄ (°C)	10.24	7.46	6.02	5.41	64.18	17800.33	0.7163	
T ₅ (°C)	9.69	7.15	5.88	5.35	50.92	17426.05	0.4300	
T _{out} (°C)	9.13	6.89	5.75	5.30	47.00	18197.82	0.4269	
m _{water} (kg/s)		0.26			42.83	18758.89	0.4244	
P _{water,in} (kPa)	685.55	N/A	N/A	326.05	38.66	19562.56	0.4227	
P _{water,out} (kPa)	558.92	N/A	N/A	203.58	34.73	19654.34	0.4219	
P _{sat} (kPa)	344.12	345.22	344.01	345.22	28.09	21498.94	0.2327	
P _{bundle,in} (kPa)		345.04			25.19	21624.95	0.2337	
P _{bundle,out} (kPa)		343.44			22.12	22238.16	0.2349	
m _{ref} (kg/s)		0.28			19.04	21127.02	0.2365	
	Path B	Path C	Path D	Path E	16.15	19486.10	0.2384	
T _{water,in} (°C)	13.59	13.61	13.59	13.68	10.82	12782.86	0.1137	
T _{water,out} (°C)	6.78	6.81	6.87	6.85	9.99	12801.17	0.1123	
m _{water} (kg/s)	0.32	0.33	0.33	0.33	9.11	12746.82	0.1109	
	Pre-boiler				8.23	12534.39	0.1095	
T _{water,in} (°C)		17.85			7.40	12127.77	0.1081	
T _{water,out} (°C)		5.52						
m _{water} (kg/s)		0.15						
T _{ref,in} (°C)		-2.03						
P _{ref,in} (kPa)		365.13						
P _{ref,out} (kPa)		358.97						

Point ID	R-134a, P/D 1.33, 20 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.59	4.95	4.67	4.55	14.72	19381.13	0.1614	19.93
T ₁ (°C)	5.45	4.90	4.64	4.54	13.46	19930.53	0.1606	
T ₂ (°C)	5.33	4.83	4.62	4.53	12.13	20983.10	0.1598	
T ₃ (°C)	5.20	4.78	4.59	4.52	10.79	21277.45	0.1590	
T ₄ (°C)	5.09	4.73	4.57	4.51	9.54	20944.75	0.1584	
T ₅ (°C)	5.00	4.69	4.56	4.50	6.57	13084.15	0.1309	
T _{out} (°C)	4.93	4.66	4.54	4.49	6.09	13465.72	0.1305	
m _{water} (kg/s)		0.25			5.59	13426.83	0.1301	
P _{water,in} (kPa)	644.53	N/A	N/A	311.61	5.09	13524.41	0.1298	
P _{water,out} (kPa)	526.41	N/A	N/A	198.16	4.61	13182.00	0.1295	
P _{sat} (kPa)	340.57	341.50	340.22	341.15	3.04	12751.50	0.1104	
P _{bundle,in} (kPa)		341.50			2.83	12780.77	0.1106	
P _{bundle,out} (kPa)		339.27			2.60	13117.29	0.1108	
m _{ref} (kg/s)		0.38			2.38	12672.29	0.1110	
	Path B	Path C	Path D	Path E	2.16	12362.58	0.1112	
T _{water,in} (°C)	5.55	5.54	5.55	5.61	1.40	5431.03	0.0976	
T _{water,out} (°C)	4.77	4.81	4.73	4.83	1.35	5434.19	0.0975	
m _{water} (kg/s)	0.36	0.38	0.34	0.36	1.30	5402.29	0.0975	
	Pre-boiler				1.25	5371.08	0.0974	
T _{water,in} (°C)		17.03			1.20	5305.76	0.0973	
T _{water,out} (°C)		5.03						
m _{water} (kg/s)		0.24						
T _{ref,in} (°C)		-5.22						
P _{ref,in} (kPa)		362.77						
P _{ref,out} (kPa)		355.54						

Point ID	R-134a, P/D 1.33, 20 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.78	4.99	4.65	4.55	17.50	22764.09	0.4128	20.06
T ₁ (°C)	5.61	4.93	4.64	4.54	15.85	23551.74	0.4118	
T ₂ (°C)	5.46	4.86	4.61	4.53	14.10	25323.46	0.4107	
T ₃ (°C)	5.30	4.80	4.59	4.52	12.34	26447.84	0.4098	
T ₄ (°C)	5.16	4.73	4.57	4.51	10.69	25780.95	0.4090	
T ₅ (°C)	5.06	4.69	4.55	4.51	7.40	15986.77	0.3797	
T _{out} (°C)	4.97	4.65	4.54	4.50	6.77	16426.35	0.3790	
m _{water} (kg/s)			0.24		6.09	16430.03	0.3784	
P _{water,in} (kPa)	592.84	N/A	N/A	291.10	5.42	16437.62	0.3779	
P _{water,out} (kPa)	485.95	N/A	N/A	188.08	4.78	15846.85	0.3774	
P _{sat} (kPa)	340.77	341.87	340.61	341.71	2.66	12950.47	0.3580	
P _{bundle,in} (kPa)			341.61		2.50	13312.25	0.3583	
P _{bundle,out} (kPa)			339.86		2.32	14226.88	0.3586	
m _{ref} (kg/s)			0.38		2.14	14197.67	0.3590	
	Path B	Path C	Path D	Path E	1.98	14195.60	0.3593	
T _{water,in} (°C)	5.73	5.71	5.71	5.80	1.21	5025.73	0.3464	
T _{water,out} (°C)	4.77	4.79	4.75	4.83	1.15	4891.87	0.3463	
m _{water} (kg/s)	0.29	0.31	0.30	0.30	1.07	4704.76	0.3462	
	Pre-boiler				1.00	4526.59	0.3461	
T _{water,in} (°C)			21.26		0.93	4268.74	0.3460	
T _{water,out} (°C)			7.25					
m _{water} (kg/s)			0.51					
T _{ref,in} (°C)			-4.48					
P _{ref,in} (kPa)			371.07					
P _{ref,out} (kPa)			359.02					

Point ID	R-134a, P/D 1.33, 20 5 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.65	4.85	4.51	4.41	17.79	24381.99	0.6203	20.04
T ₁ (°C)	5.47	4.78	4.49	4.40	16.08	25128.79	0.6192	
T ₂ (°C)	5.33	4.71	4.47	4.39	14.27	27454.18	0.6181	
T ₃ (°C)	5.16	4.65	4.44	4.38	12.45	28868.33	0.6171	
T ₄ (°C)	5.02	4.59	4.43	4.37	10.75	28231.33	0.6163	
T ₅ (°C)	4.92	4.54	4.41	4.37	7.47	17416.30	0.5864	
T _{out} (°C)	4.83	4.51	4.40	4.37	6.79	17930.94	0.5857	
m _{water} (kg/s)			0.24		6.08	17908.78	0.5851	
P _{water,in} (kPa)	592.57	N/A	N/A	291.01	5.36	17706.55	0.5846	
P _{water,out} (kPa)	486.17	N/A	N/A	187.99	4.68	17071.06	0.5841	
P _{sat} (kPa)	339.28	340.44	339.27	340.43	2.66	14591.53	0.5645	
P _{bundle,in} (kPa)			340.01		2.46	14842.48	0.5648	
P _{bundle,out} (kPa)			338.67		2.24	15661.83	0.5651	
m _{ref} (kg/s)			0.38		2.03	15196.59	0.5654	
	Path B	Path C	Path D	Path E	1.83	14692.05	0.5657	
T _{water,in} (°C)	5.58	5.57	5.58	5.67	1.14	4928.28	0.5528	
T _{water,out} (°C)	4.63	4.63	4.60	4.70	1.07	4792.07	0.5527	
m _{water} (kg/s)	0.29	0.31	0.30	0.31	1.00	4589.36	0.5526	
	Pre-boiler				0.93	4409.72	0.5525	
T _{water,in} (°C)			21.82		0.87	4147.34	0.5524	
T _{water,out} (°C)			8.42					
m _{water} (kg/s)			0.80					
T _{ref,in} (°C)			-4.42					
P _{ref,in} (kPa)			380.01					
P _{ref,out} (kPa)			363.63					

Point ID	R-134a, P/D 1.33, 20 5 0.70							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	6.22	5.45	5.11	5.00	16.10	21089.22	0.7651	19.84
T ₁ (°C)	6.06	5.38	5.09	5.00	14.88	22959.77	0.7646	
T ₂ (°C)	5.91	5.31	5.07	4.99	13.58	25587.02	0.7642	
T ₃ (°C)	5.75	5.25	5.04	4.98	12.29	26241.44	0.7639	
T ₄ (°C)	5.66	5.18	5.02	4.97	11.07	30261.17	0.7638	
T ₅ (°C)	5.52	5.14	5.01	4.97	7.66	18215.44	0.7334	
T _{out} (°C)	5.43	5.11	4.99	4.96	6.93	18699.45	0.7327	
m _{water} (kg/s)			0.24		6.15	18574.76	0.7320	
P _{water,in} (kPa)	591.88	N/A	N/A	290.25	5.38	18503.43	0.7314	
P _{water,out} (kPa)	484.78	N/A	N/A	187.87	4.65	17335.86	0.7309	
P _{sat} (kPa)	346.49	347.63	346.54	347.76	2.68	14735.45	0.7115	
P _{bundle,in} (kPa)			347.16		2.48	15015.22	0.7118	
P _{bundle,out} (kPa)			345.95		2.26	15834.72	0.7121	
m _{ref} (kg/s)			0.37		2.04	15366.89	0.7124	
	Path B	Path C	Path D	Path E	1.83	14850.42	0.7127	
T _{water,in} (°C)	6.17	6.16	6.17	6.26	1.14	5038.45	0.7000	
T _{water,out} (°C)	5.23	5.23	5.20	5.28	1.07	4891.31	0.6999	
m _{water} (kg/s)	0.29	0.31	0.30	0.31	1.00	4666.25	0.6998	
	Pre-boiler				0.93	4472.40	0.6997	
T _{water,in} (°C)			21.28		0.86	4184.68	0.6997	
T _{water,out} (°C)			9.71					
m _{water} (kg/s)			1.14					
T _{ref,in} (°C)			-3.84					
P _{ref,in} (kPa)			391.81					
P _{ref,out} (kPa)			373.18					

Point ID	R-134a, P/D 1.33, 20 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.60	5.96	5.18	4.84	40.52	20019.93	0.2897	20.24
T ₁ (°C)	7.29	5.81	5.12	4.82	37.45	21003.49	0.2886	
T ₂ (°C)	6.97	5.65	5.06	4.79	34.19	22250.02	0.2876	
T ₃ (°C)	6.65	5.51	4.98	4.76	30.93	23419.01	0.2870	
T ₄ (°C)	6.36	5.36	4.93	4.73	27.87	23645.54	0.2867	
T ₅ (°C)	6.14	5.26	4.88	4.70	20.04	18208.21	0.2007	
T _{out} (°C)	5.94	5.17	4.84	4.68	18.34	18703.88	0.1993	
m _{water} (kg/s)			0.28		16.53	18767.13	0.1979	
P _{water,in} (kPa)	778.70	N/A	N/A	361.75	14.73	18989.42	0.1967	
P _{water,out} (kPa)	631.57	N/A	N/A	220.13	13.03	18198.84	0.1958	
P _{sat} (kPa)	340.65	341.62	340.35	341.39	8.87	15609.55	0.1378	
P _{bundle,in} (kPa)			341.53		8.21	15737.43	0.1385	
P _{bundle,out} (kPa)			339.59		7.51	16301.02	0.1392	
m _{ref} (kg/s)			0.38		6.81	15937.55	0.1400	
	Path B	Path C	Path D	Path E	6.15	15567.51	0.1409	
T _{water,in} (°C)	7.59	7.57	7.58	7.66	4.15	8941.41	0.1004	
T _{water,out} (°C)	5.35	5.39	5.34	5.42	3.99	9120.46	0.1002	
m _{water} (kg/s)	0.41	0.42	0.38	0.41	3.82	9307.86	0.1000	
	Pre-boiler				3.66	9460.21	0.0998	
T _{water,in} (°C)			19.49		3.50	9638.40	0.0996	
T _{water,out} (°C)			4.70					
m _{water} (kg/s)			0.19					
T _{ref,in} (°C)			-5.17					
P _{ref,in} (kPa)			363.03					
P _{ref,out} (kPa)			355.83					

Point ID	R-134a, P/D 1.33, 20 15 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.90	6.22	5.36	4.98	37.73	18356.72	0.7198	20.06
T ₁ (°C)	7.58	6.05	5.27	4.95	35.04	19518.28	0.7191	
T ₂ (°C)	7.25	5.87	5.20	4.91	32.19	20776.46	0.7187	
T ₃ (°C)	6.94	5.72	5.11	4.88	29.33	22018.46	0.7187	
T ₄ (°C)	6.65	5.55	5.06	4.85	26.65	22839.18	0.7191	
T ₅ (°C)	6.42	5.44	5.01	4.83	20.55	19742.37	0.6374	
T _{out} (°C)	6.20	5.34	4.97	4.81	18.82	20792.33	0.6361	
m _{water} (kg/s)			0.26		16.99	21374.02	0.6350	
P _{water,in} (kPa)	684.95	N/A	N/A	324.68	15.16	22338.31	0.6340	
P _{water,out} (kPa)	557.59	N/A	N/A	202.82	13.43	22146.15	0.6333	
P _{sat} (kPa)	343.48	344.57	343.45	344.66	9.71	21967.74	0.5799	
P _{bundle,in} (kPa)			344.13		8.71	22044.20	0.5803	
P _{bundle,out} (kPa)			342.82		7.64	22715.55	0.5808	
m _{ref} (kg/s)			0.38		6.58	21278.64	0.5814	
	Path B	Path C	Path D	Path E	5.58	19394.90	0.5820	
T _{water,in} (°C)	7.85	7.86	7.84	7.95	4.15	11824.20	0.5479	
T _{water,out} (°C)	5.44	5.42	5.35	5.46	3.83	11659.45	0.5475	
m _{water} (kg/s)	0.35	0.33	0.33	0.34	3.48	11392.65	0.5471	
	Pre-boiler				3.13	11050.94	0.5466	
T _{water,in} (°C)			21.84		2.80	10345.54	0.5462	
T _{water,out} (°C)			8.66					
m _{water} (kg/s)			0.80					
T _{ref,in} (°C)			-3.91					
P _{ref,in} (kPa)			383.48					
P _{ref,out} (kPa)			367.37					

Point ID	R-134a, P/D 1.33, 20 15 0.70							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.84	6.25	5.35	4.89	35.78	15789.46	0.8769	19.91
T ₁ (°C)	7.56	6.08	5.25	4.84	33.61	16713.55	0.8766	
T ₂ (°C)	7.25	5.90	5.16	4.80	31.30	17664.51	0.8765	
T ₃ (°C)	6.95	5.74	5.06	4.76	28.98	18627.62	0.8768	
T ₄ (°C)	6.68	5.57	4.99	4.72	26.81	19345.32	0.8774	
T ₅ (°C)	6.46	5.45	4.93	4.70	21.25	17300.93	0.7947	
T _{out} (°C)	6.24	5.34	4.88	4.67	19.74	18184.28	0.7938	
m _{water} (kg/s)			0.27		18.14	18797.92	0.7931	
P _{water,in} (kPa)	715.04	N/A	N/A	336.35	16.54	19806.36	0.7925	
P _{water,out} (kPa)	581.08	N/A	N/A	208.01	15.03	20125.93	0.7921	
P _{sat} (kPa)	341.32	342.52	341.54	342.72	12.02	22277.35	0.7365	
P _{bundle,in} (kPa)			341.96		10.79	22448.34	0.7367	
P _{bundle,out} (kPa)			340.97		9.48	22914.80	0.7370	
m _{ref} (kg/s)			0.38		8.16	21481.88	0.7373	
	Path B	Path C	Path D	Path E	6.93	19642.51	0.7377	
T _{water,in} (°C)	7.80	7.82	7.82	7.91	5.41	13428.00	0.7013	
T _{water,out} (°C)	5.30	5.40	5.22	5.33	4.98	13324.35	0.7008	
m _{water} (kg/s)	0.34	0.34	0.33	0.33	4.52	13139.37	0.7002	
	Pre-boiler				4.07	12843.45	0.6997	
T _{water,in} (°C)			22.18		3.64	12128.07	0.6991	
T _{water,out} (°C)			10.86					
m _{water} (kg/s)			1.14					
T _{ref,in} (°C)			-1.99					
P _{ref,in} (kPa)			407.59					
P _{ref,out} (kPa)			389.40					

Point ID	R-134a, P/D 1.33, 20 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.80	8.38	6.51	5.63	75.99	16308.62	0.4677	20.22
T ₁ (°C)	11.11	8.02	6.32	5.56	70.22	16918.74	0.4658	
T ₂ (°C)	10.47	7.65	6.16	5.49	64.09	17537.39	0.4646	
T ₃ (°C)	9.83	7.31	5.96	5.42	57.96	17885.83	0.4642	
T ₄ (°C)	9.27	6.96	5.83	5.36	52.19	17834.85	0.4646	
T ₅ (°C)	8.83	6.70	5.72	5.30	43.09	18256.23	0.2985	
T _{out} (°C)	8.37	6.50	5.62	5.26	39.69	19079.05	0.2963	
m _{water} (kg/s)			0.26		36.07	19779.19	0.2943	
P _{water,in} (kPa)	684.17	N/A	N/A	325.34	32.45	20731.46	0.2928	
P _{water,out} (kPa)	558.55	N/A	N/A	202.46	29.05	20842.03	0.2918	
P _{sat} (kPa)	344.85	345.94	344.69	345.85	21.33	19674.62	0.1802	
P _{bundle,in} (kPa)			345.74		19.25	19774.93	0.1808	
P _{bundle,out} (kPa)			344.08		17.04	20487.99	0.1817	
m _{ref} (kg/s)			0.38		14.83	19544.16	0.1827	
	Path B	Path C	Path D	Path E	12.75	18266.92	0.1838	
T _{water,in} (°C)	11.78	11.78	11.77	11.85	8.52	11533.97	0.1115	
T _{water,out} (°C)	6.45	6.42	6.48	6.42	8.00	11700.87	0.1109	
m _{water} (kg/s)	0.33	0.32	0.34	0.31	7.44	11884.19	0.1102	
	Pre-boiler				6.89	11962.05	0.1096	
T _{water,in} (°C)			19.47		6.36	11985.22	0.1089	
T _{water,out} (°C)			5.16					
m _{water} (kg/s)			0.20					
T _{ref,in} (°C)			-4.59					
P _{ref,in} (kPa)			367.36					
P _{ref,out} (kPa)			359.90					

Point ID	R-134a, P/D 1.33, 20 30 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.25	7.97	6.18	5.28	72.81	16245.71	0.7226	19.86
T ₁ (°C)	10.60	7.63	5.99	5.20	67.41	16920.84	0.7211	
T ₂ (°C)	9.97	7.27	5.82	5.12	61.68	17555.96	0.7203	
T ₃ (°C)	9.37	6.94	5.62	5.04	55.95	17963.95	0.7202	
T ₄ (°C)	8.83	6.62	5.49	4.96	50.55	18067.74	0.7210	
T ₅ (°C)	8.39	6.37	5.37	4.91	41.07	17867.13	0.5534	
T _{out} (°C)	7.96	6.17	5.27	4.87	37.86	18766.54	0.5512	
m _{water} (kg/s)			0.26		34.44	19334.66	0.5493	
P _{water,in} (kPa)	686.23	N/A	N/A	325.52	31.02	20159.78	0.5478	
P _{water,out} (kPa)	559.90	N/A	N/A	203.23	27.80	20240.46	0.5469	
P _{sat} (kPa)	341.28	342.34	341.25	342.45	22.05	21430.04	0.4347	
P _{bundle,in} (kPa)			341.96		19.87	21804.84	0.4354	
P _{bundle,out} (kPa)			340.69		17.56	22696.84	0.4364	
m _{ref} (kg/s)			0.37		15.25	21798.22	0.4375	
	Path B	Path C	Path D	Path E	13.07	20465.05	0.4387	
T _{water,in} (°C)	11.18	11.23	11.22	11.31	9.92	15611.67	0.3647	
T _{water,out} (°C)	6.15	6.12	6.03	6.14	9.13	15826.23	0.3638	
m _{water} (kg/s)	0.35	0.33	0.33	0.34	8.30	16053.21	0.3627	
	Pre-boiler				7.46	16109.22	0.3617	
T _{water,in} (°C)			25.22		6.67	15679.76	0.3607	
T _{water,out} (°C)			7.14					
m _{water} (kg/s)			0.39					
T _{ref,in} (°C)			-2.89					
P _{ref,in} (kPa)			371.76					
P _{ref,out} (kPa)			359.55					

Point ID	R-134a, P/D 1.33, 20 42 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	14.12	9.25	6.88	5.65	113.66	18673.19	0.6116	20.06
T ₁ (°C)	13.10	8.78	6.61	5.55	102.77	19169.39	0.6050	
T ₂ (°C)	12.14	8.32	6.38	5.46	91.21	19459.84	0.5991	
T ₃ (°C)	11.20	7.90	6.11	5.36	79.64	19066.56	0.5944	
T ₄ (°C)	10.43	7.46	5.93	5.27	68.76	17956.67	0.5911	
T ₅ (°C)	9.84	7.14	5.77	5.20	53.85	17369.15	0.3604	
T _{out} (°C)	9.24	6.86	5.64	5.15	49.73	18155.86	0.3581	
m _{water} (kg/s)			0.26		45.36	18734.56	0.3562	
P _{water,in} (kPa)	685.71	N/A	N/A	326.22	40.99	19565.92	0.3550	
P _{water,out} (kPa)	558.57	N/A	N/A	202.72	36.88	19708.18	0.3545	
P _{sat} (kPa)	342.12	343.25	342.06	343.24	30.08	21866.81	0.2030	
P _{bundle,in} (kPa)			343.04		26.96	22024.83	0.2038	
P _{bundle,out} (kPa)			341.43		23.64	22681.43	0.2049	
m _{ref} (kg/s)			0.38		20.32	21545.24	0.2062	
	Path B	Path C	Path D	Path E	17.20	19838.32	0.2077	
T _{water,in} (°C)	14.11	14.12	14.10	14.19	11.77	13469.17	0.1081	
T _{water,out} (°C)	6.76	6.78	6.83	6.83	10.85	13519.57	0.1069	
m _{water} (kg/s)	0.32	0.33	0.33	0.33	9.87	13500.43	0.1058	
	Pre-boiler				8.90	13322.33	0.1046	
T _{water,in} (°C)			16.38		7.98	12886.03	0.1035	
T _{water,out} (°C)			5.55					
m _{water} (kg/s)			0.22					
T _{ref,in} (°C)			-1.95					
P _{ref,in} (kPa)			364.74					
P _{ref,out} (kPa)			357.32					

Point ID	R-134a, P/D 1.33, 20 53 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	16.17	10.42	7.54	5.94	135.96	17814.75	0.7368	20.03
T ₁ (°C)	14.93	9.85	7.21	5.81	123.36	18148.26	0.7301	
T ₂ (°C)	13.83	9.28	6.90	5.67	109.97	18313.49	0.7244	
T ₃ (°C)	12.75	8.78	6.57	5.54	96.58	17923.75	0.7201	
T ₄ (°C)	11.85	8.27	6.33	5.41	83.98	17007.84	0.7174	
T ₅ (°C)	11.14	7.88	6.12	5.31	66.61	16727.95	0.4326	
T _{out} (°C)	10.41	7.53	5.93	5.25	61.50	17406.53	0.4292	
m _{water} (kg/s)			0.27		56.07	17741.77	0.4265	
P _{water,in} (kPa)	714.68	N/A	N/A	336.03	50.64	18262.44	0.4245	
P _{water,out} (kPa)	580.53	N/A	N/A	209.50	45.53	18179.37	0.4233	
P _{sat} (kPa)	341.44	342.55	341.41	342.66	39.07	21277.19	0.2360	
P _{bundle,in} (kPa)			342.25		35.37	21767.48	0.2375	
P _{bundle,out} (kPa)			340.95		31.43	22693.53	0.2394	
m _{ref} (kg/s)			0.38		27.50	22172.00	0.2416	
	Path B	Path C	Path D	Path E	23.79	21202.86	0.2440	
T _{water,in} (°C)	16.09	16.20	16.18	16.26	17.11	16183.48	0.1179	
T _{water,out} (°C)	7.37	7.25	7.20	7.37	15.63	16223.67	0.1161	
m _{water} (kg/s)	0.35	0.33	0.33	0.33	14.06	16252.68	0.1142	
	Pre-boiler				12.49	16001.65	0.1123	
T _{water,in} (°C)			23.59		11.01	15315.22	0.1105	
T _{water,out} (°C)			5.78					
m _{water} (kg/s)			0.10					
T _{ref,in} (°C)			3.33					
P _{ref,in} (kPa)			364.05					
P _{ref,out} (kPa)			356.89					

Point ID	R-134a, P/D 1.33, 25 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.73	5.09	4.81	4.70	14.89	19844.94	0.1514	24.95
T ₁ (°C)	5.60	5.04	4.79	4.69	13.59	20422.84	0.1507	
T ₂ (°C)	5.48	4.98	4.76	4.68	12.21	21451.98	0.1500	
T ₃ (°C)	5.34	4.93	4.74	4.67	10.82	21972.22	0.1493	
T ₄ (°C)	5.23	4.87	4.72	4.66	9.52	21263.37	0.1488	
T ₅ (°C)	5.15	4.83	4.70	4.65	6.58	13228.42	0.1268	
T _{out} (°C)	5.07	4.80	4.69	4.64	6.09	13594.90	0.1265	
m _{water} (kg/s)			0.25		5.58	13524.85	0.1262	
P _{water,in} (kPa)	645.30	N/A	N/A	311.41	5.06	13606.47	0.1259	
P _{water,out} (kPa)	526.99	N/A	N/A	198.16	4.58	13197.63	0.1257	
P _{sat} (kPa)	342.37	343.29	341.98	342.95	3.00	12897.62	0.1106	
P _{bundle,in} (kPa)			343.26		2.79	12903.49	0.1107	
P _{bundle,out} (kPa)			341.19		2.56	13217.81	0.1108	
m _{ref} (kg/s)			0.47		2.33	12712.73	0.1110	
	Path B	Path C	Path D	Path E	2.11	12333.65	0.1112	
T _{water,in} (°C)	5.70	5.68	5.69	5.76	1.37	5400.79	0.1004	
T _{water,out} (°C)	4.92	4.96	4.88	4.98	1.32	5365.44	0.1004	
m _{water} (kg/s)	0.36	0.38	0.34	0.36	1.26	5292.85	0.1003	
	Pre-boiler				1.20	5219.20	0.1003	
T _{water,in} (°C)			16.65		1.15	5105.50	0.1002	
T _{water,out} (°C)			7.01					
m _{water} (kg/s)			0.38					
T _{ref,in} (°C)			-5.24					
P _{ref,in} (kPa)			391.59					
P _{ref,out} (kPa)			383.21					

Point ID	R-134a, P/D 1.33, 25 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.89	5.10	4.76	4.66	17.69	23658.96	0.4007	25.11
T ₁ (°C)	5.71	5.03	4.74	4.65	15.99	24456.00	0.3998	
T ₂ (°C)	5.57	4.96	4.72	4.64	14.19	26474.06	0.3989	
T ₃ (°C)	5.40	4.90	4.69	4.63	12.38	27676.50	0.3981	
T ₄ (°C)	5.26	4.84	4.67	4.62	10.69	26934.53	0.3974	
T ₅ (°C)	5.16	4.79	4.66	4.62	7.42	16680.49	0.3740	
T _{out} (°C)	5.08	4.76	4.65	4.61	6.77	17180.48	0.3735	
m _{water} (kg/s)			0.24		6.09	17249.69	0.3730	
P _{water,in} (kPa)	593.84	N/A	N/A	291.09	5.40	17300.77	0.3726	
P _{water,out} (kPa)	486.61	N/A	N/A	188.06	4.76	16732.60	0.3722	
P _{sat} (kPa)	342.16	343.32	342.08	343.19	2.60	13549.28	0.3568	
P _{bundle,in} (kPa)			342.95		2.42	13846.58	0.3570	
P _{bundle,out} (kPa)			341.35		2.23	14720.68	0.3572	
m _{ref} (kg/s)			0.47		2.05	14515.41	0.3575	
	Path B	Path C	Path D	Path E	1.87	14298.09	0.3578	
T _{water,in} (°C)	5.84	5.81	5.82	5.91	1.18	4963.77	0.3476	
T _{water,out} (°C)	4.88	4.89	4.86	4.94	1.11	4819.82	0.3476	
m _{water} (kg/s)	0.29	0.31	0.30	0.30	1.04	4618.85	0.3475	
	Pre-boiler				0.96	4433.81	0.3474	
T _{water,in} (°C)			20.86		0.89	4161.07	0.3473	
T _{water,out} (°C)			8.48					
m _{water} (kg/s)			0.73					
T _{ref,in} (°C)			-4.56					
P _{ref,in} (kPa)			383.77					
P _{ref,out} (kPa)			367.63					

Point ID	R-134a, P/D 1.33, 25 5 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	6.11	5.32	4.99	4.89	17.33	23819.20	0.5839	24.90
T ₁ (°C)	5.93	5.25	4.97	4.88	15.71	24873.93	0.5831	
T ₂ (°C)	5.79	5.18	4.95	4.87	13.99	27108.97	0.5824	
T ₃ (°C)	5.63	5.12	4.92	4.86	12.27	28666.42	0.5818	
T ₄ (°C)	5.49	5.07	4.90	4.85	10.65	28482.63	0.5813	
T ₅ (°C)	5.39	5.02	4.89	4.85	7.52	17921.84	0.5577	
T _{out} (°C)	5.30	4.99	4.88	4.85	6.81	18396.79	0.5572	
m _{water} (kg/s)			0.24		6.07	18313.53	0.5567	
P _{water,in} (kPa)	591.72	N/A	N/A	290.50	5.32	18064.64	0.5562	
P _{water,out} (kPa)	485.05	N/A	N/A	187.39	4.61	17180.94	0.5558	
P _{sat} (kPa)	345.13	346.27	345.15	346.34	2.59	14205.21	0.5409	
P _{bundle,in} (kPa)			345.81		2.40	14454.82	0.5411	
P _{bundle,out} (kPa)			344.49		2.19	15182.50	0.5414	
m _{ref} (kg/s)			0.47		1.98	14693.78	0.5417	
	Path B	Path C	Path D	Path E	1.78	14196.69	0.5420	
T _{water,in} (°C)	6.05	6.04	6.05	6.14	1.12	4882.15	0.5326	
T _{water,out} (°C)	5.11	5.12	5.08	5.17	1.06	4761.67	0.5326	
m _{water} (kg/s)	0.29	0.31	0.30	0.31	0.99	4564.41	0.5325	
	Pre-boiler				0.93	4406.59	0.5324	
T _{water,in} (°C)			21.19		0.86	4151.45	0.5324	
T _{water,out} (°C)			10.38					
m _{water} (kg/s)			1.22					
T _{ref,in} (°C)			-3.31					
P _{ref,in} (kPa)			401.56					
P _{ref,out} (kPa)			379.40					

Point ID	R-134a, P/D 1.33, 25 5 0.70							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	6.18	5.43	5.09	4.99	16.06	21591.26	0.7444	24.64
T ₁ (°C)	6.03	5.36	5.07	4.98	14.72	23400.84	0.7440	
T ₂ (°C)	5.88	5.29	5.05	4.97	13.30	25318.75	0.7435	
T ₃ (°C)	5.73	5.23	5.02	4.97	11.88	27367.33	0.7431	
T ₄ (°C)	5.60	5.17	5.01	4.96	10.54	28268.35	0.7429	
T ₅ (°C)	5.50	5.13	4.99	4.95	7.67	18554.36	0.7196	
T _{out} (°C)	5.42	5.09	4.98	4.95	6.93	19062.07	0.7191	
m _{water} (kg/s)			0.24		6.14	18914.46	0.7185	
P _{water,in} (kPa)	592.08	N/A	N/A	291.08	5.36	18965.18	0.7180	
P _{water,out} (kPa)	485.16	N/A	N/A	187.79	4.62	17558.90	0.7176	
P _{sat} (kPa)	346.39	347.63	346.50	347.73	2.70	15910.32	0.7026	
P _{bundle,in} (kPa)			347.07		2.48	16160.75	0.7028	
P _{bundle,out} (kPa)			345.92		2.24	16917.49	0.7030	
m _{ref} (kg/s)			0.46		2.00	16166.56	0.7033	
	Path B	Path C	Path D	Path E	1.78	15393.57	0.7035	
T _{water,in} (°C)	6.12	6.14	6.12	6.23	1.15	5082.81	0.6940	
T _{water,out} (°C)	5.21	5.26	5.17	5.26	1.07	4909.34	0.6939	
m _{water} (kg/s)	0.29	0.31	0.30	0.31	0.99	4644.80	0.6938	
	Pre-boiler				0.91	4404.40	0.6938	
T _{water,in} (°C)			20.69		0.84	4078.62	0.6937	
T _{water,out} (°C)			11.27					
m _{water} (kg/s)			1.60					
T _{ref,in} (°C)			3.94					
P _{ref,in} (kPa)			411.04					
P _{ref,out} (kPa)			385.28					

Point ID	R-134a, P/D 1.33, 25 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.87	6.25	5.49	5.16	40.29	20372.82	0.2461	25.19
T ₁ (°C)	7.56	6.10	5.43	5.14	37.16	21371.44	0.2451	
T ₂ (°C)	7.25	5.95	5.37	5.11	33.82	22596.30	0.2443	
T ₃ (°C)	6.93	5.81	5.29	5.07	30.49	23716.72	0.2437	
T ₄ (°C)	6.64	5.66	5.24	5.05	27.36	23809.36	0.2433	
T ₅ (°C)	6.43	5.56	5.19	5.02	19.57	18135.67	0.1751	
T _{out} (°C)	6.23	5.48	5.15	5.00	17.90	18617.71	0.1740	
m _{water} (kg/s)			0.28		16.13	18656.88	0.1729	
P _{water,in} (kPa)	778.58	N/A	N/A	361.09	14.36	18859.00	0.1720	
P _{water,out} (kPa)	630.66	N/A	N/A	219.56	12.69	18022.97	0.1712	
P _{sat} (kPa)	344.60	345.59	344.32	345.39	8.71	15672.39	0.1254	
P _{bundle,in} (kPa)			345.51		8.06	15801.55	0.1259	
P _{bundle,out} (kPa)			343.56		7.37	16383.51	0.1265	
m _{ref} (kg/s)			0.48		6.68	16012.57	0.1272	
	Path B	Path C	Path D	Path E	6.03	15634.34	0.1278	
T _{water,in} (°C)	7.87	7.86	7.86	7.94	4.10	9020.64	0.0957	
T _{water,out} (°C)	5.66	5.70	5.65	5.73	3.94	9188.12	0.0956	
m _{water} (kg/s)	0.40	0.42	0.38	0.41	3.77	9365.92	0.0954	
	Pre-boiler				3.59	9501.70	0.0952	
T _{water,in} (°C)			19.36		3.43	9655.68	0.0951	
T _{water,out} (°C)			5.06					
m _{water} (kg/s)			0.25					
T _{ref,in} (°C)			-5.21					
P _{ref,in} (kPa)			369.53					
P _{ref,out} (kPa)			361.00					

Point ID	R-134a, P/D 1.33, 25 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.88	6.14	5.26	4.89	39.46	19007.05	0.4862	25.09
T ₁ (°C)	7.55	5.97	5.18	4.86	36.59	20263.03	0.4855	
T ₂ (°C)	7.21	5.78	5.11	4.83	33.53	21632.48	0.4851	
T ₃ (°C)	6.88	5.62	5.02	4.80	30.48	23006.74	0.4850	
T ₄ (°C)	6.58	5.46	4.97	4.77	27.61	23887.94	0.4851	
T ₅ (°C)	6.34	5.34	4.92	4.75	20.85	20141.73	0.4185	
T _{out} (°C)	6.12	5.25	4.88	4.73	19.06	21189.46	0.4175	
m _{water} (kg/s)			0.26		17.16	21748.36	0.4165	
P _{water,in} (kPa)	684.55	N/A	N/A	324.63	15.26	22734.62	0.4156	
P _{water,out} (kPa)	557.52	N/A	N/A	202.86	13.48	22393.51	0.4150	
P _{sat} (kPa)	342.37	343.51	342.35	343.52	9.47	21345.91	0.3718	
P _{bundle,in} (kPa)			343.08		8.51	21375.87	0.3721	
P _{bundle,out} (kPa)			341.67		7.49	22115.13	0.3726	
m _{ref} (kg/s)			0.47		6.47	20791.83	0.3731	
	Path B	Path C	Path D	Path E	5.51	19074.47	0.3736	
T _{water,in} (°C)	7.83	7.85	7.82	7.94	4.08	11335.78	0.3459	
T _{water,out} (°C)	5.32	5.35	5.28	5.38	3.77	11169.69	0.3456	
m _{water} (kg/s)	0.32	0.33	0.33	0.34	3.43	10911.04	0.3453	
	Pre-boiler				3.09	10557.78	0.3450	
T _{water,in} (°C)			22.08		2.78	9890.45	0.3447	
T _{water,out} (°C)			8.24					
m _{water} (kg/s)			0.65					
T _{ref,in} (°C)			-4.47					
P _{ref,in} (kPa)			384.18					
P _{ref,out} (kPa)			368.03					

Point ID	R-134a, P/D 1.33, 25 15 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	8.03	6.36	5.50	5.12	37.47	18436.51	0.6871	24.76
T ₁ (°C)	7.71	6.19	5.42	5.09	34.82	19643.64	0.6865	
T ₂ (°C)	7.39	6.01	5.34	5.06	32.00	20961.10	0.6863	
T ₃ (°C)	7.07	5.86	5.26	5.03	29.18	22257.74	0.6863	
T ₄ (°C)	6.78	5.70	5.20	5.00	26.53	23146.06	0.6866	
T ₅ (°C)	6.55	5.58	5.16	4.98	20.30	19788.53	0.6209	
T _{out} (°C)	6.34	5.49	5.11	4.96	18.60	20836.62	0.6199	
m _{water} (kg/s)			0.26		16.79	21417.07	0.6190	
P _{water,in} (kPa)	684.17	N/A	N/A	324.42	14.97	22373.35	0.6183	
P _{water,out} (kPa)	557.42	N/A	N/A	202.72	13.27	22199.41	0.6178	
P _{sat} (kPa)	345.38	346.52	345.43	346.67	9.74	22664.75	0.5755	
P _{bundle,in} (kPa)			346.01		8.72	22832.31	0.5758	
P _{bundle,out} (kPa)			344.82		7.64	23481.10	0.5762	
m _{ref} (kg/s)			0.47		6.55	21984.48	0.5766	
	Path B	Path C	Path D	Path E	5.53	19956.61	0.5772	
T _{water,in} (°C)	7.98	7.99	7.97	8.09	4.11	11938.15	0.5504	
T _{water,out} (°C)	5.59	5.58	5.49	5.60	3.79	11785.76	0.5501	
m _{water} (kg/s)	0.35	0.33	0.33	0.34	3.44	11516.18	0.5497	
	Pre-boiler				3.10	11175.52	0.5494	
T _{water,in} (°C)			21.42		2.78	10469.04	0.5491	
T _{water,out} (°C)			10.25					
m _{water} (kg/s)			1.14					
T _{ref,in} (°C)			-1.29					
P _{ref,in} (kPa)			401.06					
P _{ref,out} (kPa)			379.05					

Point ID	R-134a, P/D 1.33, 25 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.48	7.98	6.07	5.17	77.91	16459.28	0.4071	25.11
T ₁ (°C)	10.78	7.61	5.88	5.10	71.92	17062.79	0.4055	
T ₂ (°C)	10.12	7.24	5.71	5.03	65.55	17669.27	0.4044	
T ₃ (°C)	9.46	6.88	5.51	4.95	59.18	17982.99	0.4041	
T ₄ (°C)	8.89	6.53	5.38	4.88	53.19	17887.14	0.4043	
T ₅ (°C)	8.44	6.27	5.26	4.83	43.88	18327.82	0.2678	
T _{out} (°C)	7.97	6.06	5.16	4.78	40.41	19157.64	0.2660	
m _{water} (kg/s)			0.26		36.72	19864.45	0.2643	
P _{water,in} (kPa)	685.10	N/A	N/A	326.18	33.03	20805.97	0.2631	
P _{water,out} (kPa)	559.06	N/A	N/A	203.26	29.56	20915.18	0.2622	
P _{sat} (kPa)	339.18	340.29	339.05	340.19	21.89	20024.44	0.1705	
P _{bundle,in} (kPa)			340.05		19.76	20155.95	0.1711	
P _{bundle,out} (kPa)			338.54		17.49	20942.82	0.1719	
m _{ref} (kg/s)			0.47		15.23	20019.01	0.1728	
	Path B	Path C	Path D	Path E	13.10	18738.95	0.1737	
T _{water,in} (°C)	11.46	11.46	11.45	11.53	8.95	12173.75	0.1144	
T _{water,out} (°C)	6.01	5.96	6.04	5.99	8.37	12330.57	0.1138	
m _{water} (kg/s)	0.33	0.32	0.34	0.31	7.75	12508.56	0.1132	
	Pre-boiler				7.12	12547.90	0.1126	
T _{water,in} (°C)			19.31		6.54	12487.18	0.1121	
T _{water,out} (°C)			5.05					
m _{water} (kg/s)			0.26					
T _{ref,in} (°C)			-4.59					
P _{ref,in} (kPa)			364.68					
P _{ref,out} (kPa)			355.32					

Point ID	R-134a, P/D 1.33, 25 30 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.39	8.11	6.35	5.46	72.77	16510.36	0.6359	24.99
T ₁ (°C)	10.74	7.77	6.16	5.38	67.34	17221.55	0.6348	
T ₂ (°C)	10.11	7.41	5.99	5.30	61.58	17904.35	0.6343	
T ₃ (°C)	9.51	7.10	5.79	5.22	55.81	18315.49	0.6344	
T ₄ (°C)	8.98	6.77	5.66	5.15	50.38	18477.10	0.6351	
T ₅ (°C)	8.53	6.53	5.55	5.09	40.76	18195.66	0.5024	
T _{out} (°C)	8.10	6.33	5.45	5.06	37.50	19130.36	0.5006	
m _{water} (kg/s)			0.26		34.03	19667.81	0.4990	
P _{water,in} (kPa)	685.74	N/A	N/A	325.60	30.56	20461.10	0.4978	
P _{water,out} (kPa)	558.80	N/A	N/A	203.84	27.30	20479.63	0.4970	
P _{sat} (kPa)	343.95	345.04	343.94	345.17	21.77	22018.09	0.4094	
P _{bundle,in} (kPa)			344.61		19.59	22445.85	0.4100	
P _{bundle,out} (kPa)			343.35		17.28	23406.13	0.4108	
m _{ref} (kg/s)			0.47		14.97	22456.96	0.4118	
	Path B	Path C	Path D	Path E	12.79	21024.13	0.4129	
T _{water,in} (°C)	11.32	11.38	11.37	11.46	9.78	16208.31	0.3558	
T _{water,out} (°C)	6.32	6.27	6.19	6.32	8.96	16346.44	0.3550	
m _{water} (kg/s)	0.35	0.33	0.33	0.34	8.09	16487.98	0.3542	
	Pre-boiler				7.21	16435.20	0.3533	
T _{water,in} (°C)			25.25		6.39	15753.07	0.3525	
T _{water,out} (°C)			8.33					
m _{water} (kg/s)			0.49					
T _{ref,in} (°C)			0.14					
P _{ref,in} (kPa)			385.51					
P _{ref,out} (kPa)			369.27					

Point ID	R-134a, P/D 1.33, 25 45 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	14.77	9.56	7.08	5.79	122.70	19171.87	0.5364	24.84
T ₁ (°C)	13.67	9.07	6.80	5.68	110.52	19634.23	0.5301	
T ₂ (°C)	12.63	8.59	6.56	5.58	97.59	19870.30	0.5244	
T ₃ (°C)	11.63	8.15	6.27	5.48	84.65	19325.23	0.5197	
T ₄ (°C)	10.81	7.70	6.08	5.38	72.47	17998.83	0.5162	
T ₅ (°C)	10.19	7.36	5.92	5.30	56.21	17244.90	0.3184	
T _{out} (°C)	9.55	7.06	5.77	5.25	51.93	18018.68	0.3165	
m _{water} (kg/s)			0.26		47.39	18582.76	0.3150	
P _{water,in} (kPa)	685.72	N/A	N/A	326.20	42.84	19387.94	0.3140	
P _{water,out} (kPa)	558.22	N/A	N/A	202.84	38.56	19529.61	0.3136	
P _{sat} (kPa)	343.05	344.19	342.99	344.19	31.70	21921.27	0.1842	
P _{bundle,in} (kPa)			343.94		28.43	22120.12	0.1849	
P _{bundle,out} (kPa)			342.42		24.95	22831.77	0.1859	
m _{ref} (kg/s)			0.47		21.47	21749.42	0.1871	
	Path B	Path C	Path D	Path E	18.19	20090.65	0.1885	
T _{water,in} (°C)	14.75	14.77	14.76	14.85	12.67	14105.49	0.1032	
T _{water,out} (°C)	6.96	6.97	7.02	7.04	11.66	14176.15	0.1022	
m _{water} (kg/s)	0.32	0.33	0.33	0.33	10.58	14185.44	0.1011	
	Pre-boiler				9.51	14008.07	0.1001	
T _{water,in} (°C)			14.89		8.50	13540.19	0.0991	
T _{water,out} (°C)			5.96					
m _{water} (kg/s)			0.32					
T _{ref,in} (°C)			-1.30					
P _{ref,in} (kPa)			368.06					
P _{ref,out} (kPa)			359.28					

Point ID	R-134a, P/D 1.33, 35 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.66	5.02	4.74	4.63	15.04	20656.70	0.1387	35.08
T ₁ (°C)	5.53	4.97	4.71	4.62	13.72	21384.48	0.1382	
T ₂ (°C)	5.41	4.90	4.69	4.61	12.32	22606.60	0.1377	
T ₃ (°C)	5.27	4.85	4.66	4.60	10.91	23460.42	0.1372	
T ₄ (°C)	5.15	4.80	4.65	4.59	9.59	22717.29	0.1368	
T ₅ (°C)	5.07	4.76	4.63	4.58	6.64	13997.95	0.1210	
T _{out} (°C)	5.00	4.73	4.62	4.58	6.13	14409.09	0.1207	
m _{water} (kg/s)			0.25		5.58	14299.50	0.1205	
P _{water,in} (kPa)	644.42	N/A	N/A	311.60	5.04	14371.04	0.1202	
P _{water,out} (kPa)	526.59	N/A	N/A	198.51	4.53	13858.25	0.1200	
P _{sat} (kPa)	341.73	342.70	341.36	342.36	2.94	13907.77	0.1091	
P _{bundle,in} (kPa)			342.60		2.72	13905.42	0.1092	
P _{bundle,out} (kPa)			340.58		2.48	14276.72	0.1093	
m _{ref} (kg/s)			0.66		2.25	13675.84	0.1094	
	Path B	Path C	Path D	Path E	2.03	13188.73	0.1095	
T _{water,in} (°C)	5.63	5.62	5.62	5.69	1.32	5480.52	0.1017	
T _{water,out} (°C)	4.85	4.88	4.80	4.91	1.26	5415.73	0.1017	
m _{water} (kg/s)	0.36	0.38	0.34	0.36	1.20	5305.33	0.1016	
	Pre-boiler				1.14	5201.00	0.1016	
T _{water,in} (°C)			15.70		1.08	5038.79	0.1016	
T _{water,out} (°C)			8.71					
m _{water} (kg/s)			0.74					
T _{ref,in} (°C)			-5.28					
P _{ref,in} (kPa)			412.92					
P _{ref,out} (kPa)			401.98					

Point ID	R-134a, P/D 1.33, 35 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.76	4.98	4.64	4.54	17.34	23788.32	0.3842	34.95
T ₁ (°C)	5.60	4.91	4.62	4.53	15.73	25196.45	0.3836	
T ₂ (°C)	5.44	4.84	4.60	4.52	14.01	27281.74	0.3830	
T ₃ (°C)	5.29	4.78	4.57	4.51	12.30	29066.84	0.3826	
T ₄ (°C)	5.15	4.72	4.56	4.50	10.69	28869.64	0.3821	
T ₅ (°C)	5.05	4.67	4.54	4.50	7.52	18294.11	0.3650	
T _{out} (°C)	4.96	4.64	4.53	4.50	6.81	18808.73	0.3647	
m _{water} (kg/s)			0.24		6.06	18733.69	0.3643	
P _{water,in} (kPa)	593.02	N/A	N/A	291.36	5.31	18719.75	0.3640	
P _{water,out} (kPa)	486.64	N/A	N/A	188.66	4.61	17651.26	0.3637	
P _{sat} (kPa)	340.95	342.04	340.94	342.06	2.61	15032.10	0.3524	
P _{bundle,in} (kPa)			341.72		2.41	15305.04	0.3525	
P _{bundle,out} (kPa)			340.22		2.20	16139.37	0.3526	
m _{ref} (kg/s)			0.66		1.98	15620.59	0.3528	
	Path B	Path C	Path D	Path E	1.78	15115.16	0.3529	
T _{water,in} (°C)	5.70	5.70	5.71	5.79	1.13	5200.50	0.3452	
T _{water,out} (°C)	4.75	4.76	4.74	4.82	1.07	5096.81	0.3452	
m _{water} (kg/s)	0.29	0.31	0.30	0.31	1.01	4923.37	0.3451	
	Pre-boiler				0.94	4792.99	0.3451	
T _{water,in} (°C)			20.30		0.88	4543.94	0.3450	
T _{water,out} (°C)			10.91					
m _{water} (kg/s)			1.31					
T _{ref,in} (°C)			-3.98					
P _{ref,in} (kPa)			409.93					
P _{ref,out} (kPa)			384.87					

Point ID	R-134a, P/D 1.33, 35 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.67	6.04	5.28	4.94	40.34	20536.41	0.2013	35.23
T ₁ (°C)	7.35	5.90	5.21	4.92	37.19	21561.01	0.2006	
T ₂ (°C)	7.04	5.74	5.15	4.89	33.85	22813.90	0.2001	
T ₃ (°C)	6.72	5.60	5.07	4.86	30.50	23963.37	0.1997	
T ₄ (°C)	6.43	5.45	5.02	4.83	27.35	24054.58	0.1995	
T ₅ (°C)	6.22	5.35	4.98	4.80	19.75	18593.07	0.1505	
T _{out} (°C)	6.02	5.27	4.94	4.78	18.09	19168.19	0.1497	
m _{water} (kg/s)			0.28		16.31	19305.14	0.1490	
P _{water,in} (kPa)	779.23	N/A	N/A	360.55	14.54	19652.92	0.1483	
P _{water,out} (kPa)	630.38	N/A	N/A	219.50	12.88	18892.52	0.1478	
P _{sat} (kPa)	342.15	343.25	341.95	343.02	8.79	16558.20	0.1151	
P _{bundle,in} (kPa)			343.06		8.11	16674.70	0.1154	
P _{bundle,out} (kPa)			341.15		7.38	17330.32	0.1159	
m _{ref} (kg/s)			0.66		6.66	16882.38	0.1164	
	Path B	Path C	Path D	Path E	5.97	16395.36	0.1169	
T _{water,in} (°C)	7.66	7.65	7.65	7.73	4.21	9600.76	0.0943	
T _{water,out} (°C)	5.44	5.46	5.42	5.50	4.01	9708.43	0.0942	
m _{water} (kg/s)	0.40	0.42	0.38	0.41	3.79	9801.34	0.0941	
	Pre-boiler				3.58	9841.65	0.0939	
T _{water,in} (°C)			19.02		3.37	9841.26	0.0938	
T _{water,out} (°C)			5.59					
m _{water} (kg/s)			0.36					
T _{ref,in} (°C)			-5.27					
P _{ref,in} (kPa)			374.68					
P _{ref,out} (kPa)			362.29					

Point ID	R-134a, P/D 1.33, 35 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	8.11	6.42	5.57	5.21	38.12	19104.89	0.4434	34.88
T ₁ (°C)	7.79	6.25	5.49	5.19	35.34	20401.36	0.4430	
T ₂ (°C)	7.46	6.08	5.43	5.16	32.39	21809.66	0.4428	
T ₃ (°C)	7.14	5.92	5.34	5.13	29.44	23213.77	0.4428	
T ₄ (°C)	6.85	5.77	5.29	5.10	26.67	24132.28	0.4429	
T ₅ (°C)	6.61	5.65	5.25	5.08	20.06	20179.76	0.3962	
T _{out} (°C)	6.40	5.56	5.21	5.06	18.34	21239.54	0.3955	
m _{water} (kg/s)			0.26		16.52	21839.04	0.3948	
P _{water,in} (kPa)	683.64	N/A	N/A	324.41	14.71	22828.21	0.3943	
P _{water,out} (kPa)	557.39	N/A	N/A	203.03	12.99	22547.73	0.3938	
P _{sat} (kPa)	346.64	347.81	346.67	347.88	9.23	22184.52	0.3639	
P _{bundle,in} (kPa)			347.36		8.28	22266.26	0.3642	
P _{bundle,out} (kPa)			346.07		7.26	22928.96	0.3645	
m _{ref} (kg/s)			0.66		6.25	21494.56	0.3649	
	Path B	Path C	Path D	Path E	5.29	19603.45	0.3653	
T _{water,in} (°C)	8.06	8.07	8.05	8.16	3.88	11321.81	0.3464	
T _{water,out} (°C)	5.68	5.67	5.59	5.69	3.57	11117.99	0.3462	
m _{water} (kg/s)	0.35	0.33	0.33	0.34	3.24	10800.34	0.3459	
	Pre-boiler				2.91	10391.94	0.3457	
T _{water,in} (°C)			21.42		2.60	9668.26	0.3455	
T _{water,out} (°C)			10.96					
m _{water} (kg/s)			1.17					
T _{ref,in} (°C)			-3.19					
P _{ref,in} (kPa)			414.64					
P _{ref,out} (kPa)			389.76					

Point ID	R-134a, P/D 1.33, 35 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.66	8.20	6.34	5.47	76.98	16671.40	0.3085	35.14
T ₁ (°C)	10.96	7.84	6.16	5.40	71.09	17317.63	0.3075	
T ₂ (°C)	10.31	7.47	6.00	5.33	64.84	17996.92	0.3069	
T ₃ (°C)	9.67	7.13	5.80	5.25	58.58	18389.77	0.3068	
T ₄ (°C)	9.10	6.78	5.67	5.19	52.69	18366.53	0.3072	
T ₅ (°C)	8.65	6.53	5.56	5.13	43.08	18614.29	0.2104	
T _{out} (°C)	8.19	6.33	5.46	5.09	39.61	19455.74	0.2090	
m _{water} (kg/s)			0.26		35.92	20159.44	0.2078	
P _{water,in} (kPa)	685.65	N/A	N/A	325.67	32.23	21084.51	0.2069	
P _{water,out} (kPa)	558.22	N/A	N/A	202.65	28.76	21134.70	0.2063	
P _{sat} (kPa)	343.21	344.33	343.10	344.25	21.10	19966.38	0.1421	
P _{bundle,in} (kPa)			344.08		19.04	20082.37	0.1426	
P _{bundle,out} (kPa)			342.43		16.85	20867.08	0.1432	
m _{ref} (kg/s)			0.66		14.66	19919.67	0.1439	
	Path B	Path C	Path D	Path E	12.60	18620.95	0.1447	
T _{water,in} (°C)	11.64	11.63	11.63	11.71	9.00	12798.23	0.1037	
T _{water,out} (°C)	6.14	6.24	6.32	6.27	8.37	12933.07	0.1033	
m _{water} (kg/s)	0.33	0.32	0.34	0.31	7.70	13071.29	0.1028	
	Pre-boiler				7.03	13060.02	0.1023	
T _{water,in} (°C)			18.95		6.40	12900.56	0.1019	
T _{water,out} (°C)			5.82					
m _{water} (kg/s)			0.38					
T _{ref,in} (°C)			-4.56					
P _{ref,in} (kPa)			375.92					
P _{ref,out} (kPa)			363.64					

Point ID	R-134a, P/D 1.33, 35 45 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	14.70	9.41	6.91	5.62	124.69	19453.84	0.4072	34.94
T ₁ (°C)	13.58	8.92	6.63	5.52	112.24	19936.87	0.4027	
T ₂ (°C)	12.52	8.43	6.39	5.41	99.02	20197.87	0.3985	
T ₃ (°C)	11.50	7.98	6.11	5.30	85.79	19646.73	0.3952	
T ₄ (°C)	10.67	7.53	5.92	5.21	73.34	18293.81	0.3927	
T ₅ (°C)	10.04	7.18	5.75	5.13	56.83	17545.82	0.2507	
T _{out} (°C)	9.40	6.89	5.61	5.07	52.45	18345.35	0.2492	
m _{water} (kg/s)			0.26		47.79	18943.52	0.2480	
P _{water,in} (kPa)	684.51	N/A	N/A	326.09	43.14	19759.70	0.2472	
P _{water,out} (kPa)	559.92	N/A	N/A	202.68	38.76	19904.77	0.2469	
P _{sat} (kPa)	341.17	342.33	341.16	342.34	31.51	21955.60	0.1543	
P _{bundle,in} (kPa)			342.05		28.24	22152.98	0.1548	
P _{bundle,out} (kPa)			340.50		24.76	22846.18	0.1556	
m _{ref} (kg/s)			0.66		21.29	21717.41	0.1565	
	Path B	Path C	Path D	Path E	18.02	20016.28	0.1576	
T _{water,in} (°C)	14.68	14.70	14.68	14.77	13.05	14801.11	0.0970	
T _{water,out} (°C)	6.80	6.81	6.86	6.89	11.99	14901.68	0.0963	
m _{water} (kg/s)	0.32	0.33	0.33	0.33	10.86	14948.14	0.0955	
	Pre-boiler				9.73	14798.94	0.0947	
T _{water,in} (°C)			12.58		8.66	14303.35	0.0939	
T _{water,out} (°C)			6.79					
m _{water} (kg/s)			0.59					
T _{ref,in} (°C)			0.93					
P _{ref,in} (kPa)			373.16					
P _{ref,out} (kPa)			361.03					

Point ID	R-134a, P/D 1.33, 45 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.71	5.05	4.77	4.67	15.26	21608.94	0.1281	44.93
T ₁ (°C)	5.57	5.00	4.75	4.66	13.89	22522.86	0.1277	
T ₂ (°C)	5.45	4.94	4.73	4.66	12.44	23904.36	0.1273	
T ₃ (°C)	5.31	4.89	4.71	4.65	11.00	24928.81	0.1269	
T ₄ (°C)	5.19	4.83	4.69	4.64	9.63	24176.60	0.1266	
T ₅ (°C)	5.11	4.80	4.68	4.63	6.70	14826.27	0.1142	
T _{out} (°C)	5.04	4.77	4.66	4.63	6.15	15225.38	0.1140	
m _{water} (kg/s)			0.25		5.57	15047.58	0.1138	
P _{water,in} (kPa)	644.99	N/A	N/A	311.59	4.99	15067.93	0.1136	
P _{water,out} (kPa)	527.10	N/A	N/A	198.50	4.44	14362.20	0.1134	
P _{sat} (kPa)	342.34	343.38	342.04	343.07	2.81	14273.54	0.1050	
P _{bundle,in} (kPa)			343.25		2.59	14182.95	0.1051	
P _{bundle,out} (kPa)			341.22		2.35	14519.42	0.1052	
m _{ref} (kg/s)			0.85		2.12	13788.98	0.1053	
	Path B	Path C	Path D	Path E	1.90	13163.52	0.1054	
T _{water,in} (°C)	5.67	5.67	5.68	5.75	1.26	5312.70	0.0995	
T _{water,out} (°C)	4.90	4.92	4.85	4.96	1.20	5230.13	0.0995	
m _{water} (kg/s)	0.36	0.38	0.34	0.36	1.14	5099.68	0.0995	
	Pre-boiler				1.08	4994.20	0.0994	
T _{water,in} (°C)			15.36		1.02	4799.79	0.0994	
T _{water,out} (°C)			12.83					
m _{water} (kg/s)			2.57					
T _{ref,in} (°C)			-5.22					
P _{ref,in} (kPa)			454.46					
P _{ref,out} (kPa)			440.92					

Point ID	R-134a, P/D 1.33, 45 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	6.12	5.34	5.01	4.91	17.04	23829.26	0.3737	44.63
T ₁ (°C)	5.95	5.27	5.00	4.91	15.46	25222.37	0.3733	
T ₂ (°C)	5.80	5.21	4.98	4.90	13.77	27356.76	0.3729	
T ₃ (°C)	5.65	5.15	4.95	4.89	12.09	29181.34	0.3725	
T ₄ (°C)	5.51	5.09	4.93	4.88	10.51	29030.20	0.3723	
T ₅ (°C)	5.41	5.05	4.92	4.88	7.39	18070.19	0.3593	
T _{out} (°C)	5.33	5.01	4.91	4.87	6.68	18462.88	0.3589	
m _{water} (kg/s)			0.24		5.92	18274.58	0.3586	
P _{water,in} (kPa)	592.83	N/A	N/A	290.76	5.17	18033.96	0.3583	
P _{water,out} (kPa)	485.86	N/A	N/A	188.25	4.46	16852.41	0.3581	
P _{sat} (kPa)	345.53	346.69	345.58	346.79	2.55	14366.38	0.3498	
P _{bundle,in} (kPa)			346.27		2.36	14697.48	0.3500	
P _{bundle,out} (kPa)			344.90		2.17	15560.74	0.3501	
m _{ref} (kg/s)			0.84		1.98	15241.51	0.3503	
	Path B	Path C	Path D	Path E	1.80	14974.16	0.3504	
T _{water,in} (°C)	6.06	6.06	6.07	6.15	1.15	5127.54	0.3451	
T _{water,out} (°C)	5.13	5.14	5.11	5.20	1.07	4931.07	0.3450	
m _{water} (kg/s)	0.29	0.31	0.30	0.31	0.98	4647.78	0.3450	
	Pre-boiler				0.90	4374.56	0.3449	
T _{water,in} (°C)			19.76		0.82	4025.25	0.3449	
T _{water,out} (°C)			13.95					
m _{water} (kg/s)			2.58					
T _{ref,in} (°C)			-1.51					
P _{ref,in} (kPa)			444.38					
P _{ref,out} (kPa)			410.21					

Point ID	R-134a, P/D 1.33, 45 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.48	5.85	5.08	4.74	40.43	20655.85	0.1892	45.13
T ₁ (°C)	7.16	5.70	5.01	4.71	37.24	21681.32	0.1887	
T ₂ (°C)	6.85	5.54	4.95	4.68	33.84	22903.22	0.1882	
T ₃ (°C)	6.53	5.40	4.87	4.65	30.45	23992.21	0.1879	
T ₄ (°C)	6.24	5.25	4.82	4.62	27.25	23995.34	0.1877	
T ₅ (°C)	6.03	5.15	4.77	4.59	19.83	18812.05	0.1492	
T _{out} (°C)	5.83	5.07	4.73	4.58	18.20	19476.39	0.1486	
m _{water} (kg/s)			0.28		16.47	19739.51	0.1481	
P _{water,in} (kPa)	778.29	N/A	N/A	360.99	14.74	20279.42	0.1476	
P _{water,out} (kPa)	629.86	N/A	N/A	219.82	13.11	19709.46	0.1472	
P _{sat} (kPa)	339.90	340.90	339.68	340.74	9.07	17599.38	0.1213	
P _{bundle,in} (kPa)			340.76		8.33	17670.22	0.1216	
P _{bundle,out} (kPa)			338.94		7.53	18370.37	0.1220	
m _{ref} (kg/s)			0.85		6.74	17764.43	0.1223	
	Path B	Path C	Path D	Path E	5.99	17064.42	0.1227	
T _{water,in} (°C)	7.47	7.45	7.46	7.54	4.37	10576.21	0.1049	
T _{water,out} (°C)	5.23	5.25	5.20	5.30	4.11	10596.64	0.1048	
m _{water} (kg/s)	0.40	0.41	0.38	0.41	3.84	10595.30	0.1047	
	Pre-boiler				3.57	10539.20	0.1045	
T _{water,in} (°C)			18.58		3.32	10334.90	0.1044	
T _{water,out} (°C)			6.34					
m _{water} (kg/s)			0.53					
T _{ref,in} (°C)			-5.11					
P _{ref,in} (kPa)			383.68					
P _{ref,out} (kPa)			366.79					

Point ID	R-134a, P/D 1.33, 45 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	10.83	7.55	5.86	5.08	74.11	17919.27	0.2468	45.02
T ₁ (°C)	10.18	7.21	5.68	5.02	68.20	18746.84	0.2458	
T ₂ (°C)	9.55	6.88	5.54	4.95	61.93	19558.11	0.2450	
T ₃ (°C)	8.92	6.56	5.37	4.89	55.65	20058.26	0.2447	
T ₄ (°C)	8.38	6.25	5.26	4.83	49.75	20001.62	0.2447	
T ₅ (°C)	7.96	6.02	5.16	4.78	39.63	19574.53	0.1741	
T _{out} (°C)	7.53	5.84	5.07	4.74	36.31	20513.82	0.1730	
m _{water} (kg/s)			0.26		32.79	21229.84	0.1721	
P _{water,in} (kPa)	686.59	N/A	N/A	326.54	29.26	22214.68	0.1714	
P _{water,out} (kPa)	560.27	N/A	N/A	203.91	25.94	22083.72	0.1710	
P _{sat} (kPa)	340.00	341.13	339.92	341.08	19.24	21556.04	0.1246	
P _{bundle,in} (kPa)			340.86		17.21	21452.47	0.1248	
P _{bundle,out} (kPa)			339.19		15.04	21846.80	0.1252	
m _{ref} (kg/s)			0.85		12.87	20385.78	0.1256	
	Path B	Path C	Path D	Path E	10.84	18480.49	0.1261	
T _{water,in} (°C)	10.80	10.80	10.79	10.88	8.13	13349.59	0.0966	
T _{water,out} (°C)	5.82	5.84	5.91	5.88	7.53	13453.41	0.0962	
m _{water} (kg/s)	0.32	0.33	0.33	0.33	6.89	13538.34	0.0959	
	Pre-boiler				6.26	13451.41	0.0956	
T _{water,in} (°C)			18.66		5.66	13155.88	0.0952	
T _{water,out} (°C)			6.30					
m _{water} (kg/s)			0.48					
T _{ref,in} (°C)			-4.35					
P _{ref,in} (kPa)			382.24					
P _{ref,out} (kPa)			365.98					

Point ID	R-134a, P/D 1.33, 55 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.62	4.96	4.68	4.59	15.41	22602.97	0.1252	54.82
T ₁ (°C)	5.48	4.91	4.66	4.58	14.00	23650.68	0.1248	
T ₂ (°C)	5.35	4.85	4.64	4.57	12.50	25186.70	0.1245	
T ₃ (°C)	5.22	4.80	4.62	4.56	11.00	26309.03	0.1242	
T ₄ (°C)	5.10	4.74	4.60	4.55	9.59	25395.75	0.1239	
T ₅ (°C)	5.02	4.71	4.59	4.55	6.67	15484.73	0.1138	
T _{out} (°C)	4.94	4.68	4.58	4.54	6.11	15857.92	0.1136	
m _{water} (kg/s)			0.25		5.52	15676.39	0.1134	
P _{water,in} (kPa)	645.88	N/A	N/A	312.44	4.92	15698.45	0.1132	
P _{water,out} (kPa)	527.71	N/A	N/A	199.20	4.36	14857.13	0.1131	
P _{sat} (kPa)	341.40	342.51	341.19	342.23	2.73	14889.01	0.1062	
P _{bundle,in} (kPa)			342.30		2.51	14735.19	0.1063	
P _{bundle,out} (kPa)			340.38		2.27	15079.99	0.1063	
m _{ref} (kg/s)			1.03		2.03	14247.23	0.1064	
	Path B	Path C	Path D	Path E	1.81	13500.74	0.1065	
T _{water,in} (°C)	5.58	5.57	5.59	5.65	1.23	5290.60	0.1017	
T _{water,out} (°C)	4.81	4.83	4.76	4.87	1.17	5171.63	0.1017	
m _{water} (kg/s)	0.36	0.38	0.34	0.36	1.10	4997.89	0.1017	
	Pre-boiler				1.03	4855.88	0.1016	
T _{water,in} (°C)			18.00		0.97	4608.65	0.1016	
T _{water,out} (°C)			14.90					
m _{water} (kg/s)			2.58					
T _{ref,in} (°C)			-5.10					
P _{ref,in} (kPa)			491.74					
P _{ref,out} (kPa)			476.14					

Point ID	R-134a, P/D 1.33, 55 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.47	5.83	5.06	4.72	40.65	20990.85	0.1725	55.19
T ₁ (°C)	7.15	5.68	4.99	4.69	37.41	22067.58	0.1720	
T ₂ (°C)	6.83	5.53	4.93	4.66	33.96	23340.18	0.1716	
T ₃ (°C)	6.51	5.38	4.85	4.63	30.52	24456.74	0.1714	
T ₄ (°C)	6.23	5.23	4.80	4.60	27.28	24439.24	0.1712	
T ₅ (°C)	6.02	5.13	4.75	4.58	19.91	19278.02	0.1396	
T _{out} (°C)	5.82	5.05	4.71	4.56	18.27	19982.14	0.1391	
m _{water} (kg/s)			0.28		16.53	20307.26	0.1387	
P _{water,in} (kPa)	777.22	N/A	N/A	361.54	14.79	20948.58	0.1383	
P _{water,out} (kPa)	630.80	N/A	N/A	219.70	13.16	20421.34	0.1380	
P _{sat} (kPa)	339.92	340.94	339.66	340.76	9.09	18559.81	0.1169	
P _{bundle,in} (kPa)			340.71		8.30	18594.54	0.1171	
P _{bundle,out} (kPa)			338.98		7.47	19293.41	0.1174	
m _{ref} (kg/s)			1.04		6.63	18523.10	0.1177	
	Path B	Path C	Path D	Path E	5.85	17586.31	0.1180	
T _{water,in} (°C)	7.46	7.44	7.45	7.53	4.23	10639.72	0.1036	
T _{water,out} (°C)	5.22	5.23	5.17	5.28	3.98	10658.16	0.1035	
m _{water} (kg/s)	0.40	0.41	0.38	0.41	3.72	10641.09	0.1034	
	Pre-boiler				3.45	10568.17	0.1033	
T _{water,in} (°C)			17.96		3.20	10344.95	0.1032	
T _{water,out} (°C)			7.45					
m _{water} (kg/s)			0.76					
T _{ref,in} (°C)			-4.64					
P _{ref,in} (kPa)			397.15					
P _{ref,out} (kPa)			375.21					

Point ID	R-134a, P/D 1.33, 55 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.69	8.12	6.32	5.49	81.21	18371.67	0.2312	55.00
T ₁ (°C)	10.97	7.77	6.13	5.42	74.40	19160.13	0.2302	
T ₂ (°C)	10.28	7.41	5.98	5.35	67.16	19898.10	0.2294	
T ₃ (°C)	9.60	7.07	5.80	5.28	59.93	20225.44	0.2289	
T ₄ (°C)	9.02	6.74	5.68	5.21	53.11	19936.62	0.2287	
T ₅ (°C)	8.56	6.50	5.57	5.16	42.12	19515.00	0.1664	
T _{out} (°C)	8.11	6.30	5.48	5.12	38.60	20486.54	0.1655	
m _{water} (kg/s)			0.26		34.87	21211.65	0.1647	
P _{water,in} (kPa)	686.55	N/A	N/A	326.03	31.14	22198.17	0.1641	
P _{water,out} (kPa)	558.64	N/A	N/A	203.65	27.63	22141.75	0.1637	
P _{sat} (kPa)	344.53	345.64	344.44	345.59	20.60	21820.88	0.1231	
P _{bundle,in} (kPa)			345.35		18.42	21801.11	0.1234	
P _{bundle,out} (kPa)			343.73		16.10	22265.58	0.1238	
m _{ref} (kg/s)			1.04		13.77	20839.30	0.1242	
	Path B	Path C	Path D	Path E	11.59	18878.23	0.1247	
T _{water,in} (°C)	11.67	11.67	11.65	11.74	8.77	14076.17	0.0990	
T _{water,out} (°C)	6.29	6.30	6.36	6.34	8.08	14156.54	0.0987	
m _{water} (kg/s)	0.32	0.33	0.33	0.33	7.35	14190.61	0.0984	
	Pre-boiler				6.62	14060.36	0.0980	
T _{water,in} (°C)			18.20		5.93	13597.94	0.0977	
T _{water,out} (°C)			7.61					
m _{water} (kg/s)			0.68					
T _{ref,in} (°C)			-3.32					
P _{ref,in} (kPa)			398.25					
P _{ref,out} (kPa)			377.77					

Point ID	R-134a, P/D 1.5, 10 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.70	5.10	4.82	4.68	14.20	16679.66	0.1820	9.93
T ₁ (°C)	5.59	5.03	4.79	4.67	13.19	18069.59	0.1815	
T ₂ (°C)	5.45	4.98	4.77	4.66	12.11	18423.28	0.1811	
T ₃ (°C)	5.35	4.92	4.74	4.65	11.03	19198.63	0.1807	
T ₄ (°C)	5.24	4.88	4.71	4.63	10.02	19761.97	0.1805	
T ₅ (°C)	5.14	4.84	4.69	4.63	6.82	11519.19	0.1431	
T _{out} (°C)	5.07	4.81	4.67	4.62	6.24	11195.74	0.1423	
m _{water} (kg/s)			0.26		5.63	11070.66	0.1416	
P _{water,in} (kPa)	684.09	N/A	N/A	328.80	5.01	10242.97	0.1409	
P _{water,out} (kPa)	562.29	N/A	N/A	203.59	4.44	9548.41	0.1404	
P _{sat} (kPa)	341.26	342.25	340.81	342.15	3.50	11061.18	0.1158	
P _{bundle,in} (kPa)			342.28		3.32	11252.80	0.1161	
P _{bundle,out} (kPa)			339.79		3.14	11425.40	0.1165	
m _{ref} (kg/s)			0.28		2.95	11689.67	0.1169	
	Path B	Path C	Path D	Path E	2.77	11865.76	0.1173	
T _{water,in} (°C)	5.78	5.67	5.68	5.72	1.69	5171.60	0.0988	
T _{water,out} (°C)	4.84	4.98	4.82	4.86	1.63	5185.15	0.0987	
m _{water} (kg/s)	0.32	0.38	0.33	0.33	1.56	5125.77	0.0986	
	Pre-boiler				1.49	5093.19	0.0985	
T _{water,in} (°C)			9.27		1.43	4910.63	0.0984	
T _{water,out} (°C)			6.20					
m _{water} (kg/s)			0.53					
T _{ref,in} (°C)			0.44					
P _{ref,in} (kPa)			362.60					
P _{ref,out} (kPa)			356.58					

Point ID	R-134a, P/D 1.5, 10 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.69	5.04	4.77	4.64	15.40	19416.54	0.4475	9.98
T ₁ (°C)	5.56	4.98	4.74	4.64	14.20	21118.26	0.4468	
T ₂ (°C)	5.41	4.92	4.71	4.62	12.93	21628.61	0.4462	
T ₃ (°C)	5.31	4.86	4.69	4.62	11.66	22664.57	0.4457	
T ₄ (°C)	5.19	4.82	4.67	4.61	10.46	23296.50	0.4453	
T ₅ (°C)	5.09	4.79	4.65	4.60	7.18	14583.14	0.4058	
T _{out} (°C)	5.01	4.75	4.63	4.59	6.47	14077.20	0.4050	
m _{water} (kg/s)			0.26		5.71	13811.88	0.4041	
P _{water,in} (kPa)	699.32	N/A	N/A	334.24	4.96	12456.26	0.4033	
P _{water,out} (kPa)	575.49	N/A	N/A	206.07	4.25	11209.91	0.4026	
P _{sat} (kPa)	341.45	342.50	341.19	342.12	3.29	13420.59	0.3769	
P _{bundle,in} (kPa)			342.35		3.06	13523.02	0.3771	
P _{bundle,out} (kPa)			340.24		2.82	13328.69	0.3774	
m _{ref} (kg/s)			0.29		2.57	13214.49	0.3777	
	Path B	Path C	Path D	Path E	2.34	12871.78	0.3780	
T _{water,in} (°C)	5.75	5.64	5.65	5.72	1.41	4999.23	0.3590	
T _{water,out} (°C)	4.82	4.92	4.76	4.85	1.35	4964.65	0.3589	
m _{water} (kg/s)	0.33	0.39	0.33	0.34	1.28	4844.59	0.3588	
	Pre-boiler				1.21	4757.37	0.3587	
T _{water,in} (°C)			21.85		1.15	4505.11	0.3586	
T _{water,out} (°C)			6.50					
m _{water} (kg/s)			0.37					
T _{ref,in} (°C)			-6.47					
P _{ref,in} (kPa)			363.55					
P _{ref,out} (kPa)			354.85					

Point ID	R-134a, P/D 1.5, 10 5 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.81	5.14	4.85	4.72	16.14	20605.76	0.6441	10.06
T ₁ (°C)	5.69	5.07	4.82	4.72	14.89	22630.17	0.6434	
T ₂ (°C)	5.53	5.01	4.79	4.71	13.57	23494.63	0.6427	
T ₃ (°C)	5.42	4.95	4.77	4.70	12.25	25103.56	0.6422	
T ₄ (°C)	5.29	4.91	4.75	4.69	11.01	26224.21	0.6418	
T ₅ (°C)	5.19	4.87	4.73	4.69	7.64	16568.78	0.6025	
T _{out} (°C)	5.11	4.83	4.71	4.67	6.86	16077.28	0.6016	
m _{water} (kg/s)			0.26		6.03	15841.57	0.6007	
P _{water,in} (kPa)	699.13	N/A	N/A	333.71	5.19	14300.53	0.5998	
P _{water,out} (kPa)	574.89	N/A	N/A	205.59	4.41	12792.98	0.5990	
P _{sat} (kPa)	342.53	343.63	342.39	343.37	3.42	15806.14	0.5741	
P _{bundle,in} (kPa)			343.62		3.14	15876.00	0.5742	
P _{bundle,out} (kPa)			341.52		2.84	15507.57	0.5744	
m _{ref} (kg/s)			0.29		2.54	15093.06	0.5747	
	Path B	Path C	Path D	Path E	2.26	14326.35	0.5749	
T _{water,in} (°C)	5.87	5.78	5.78	5.86	1.40	5376.60	0.5568	
T _{water,out} (°C)	4.92	5.00	4.84	4.94	1.34	5346.59	0.5567	
m _{water} (kg/s)	0.33	0.39	0.33	0.34	1.27	5224.53	0.5566	
	Pre-boiler				1.20	5144.41	0.5565	
T _{water,in} (°C)			21.35		1.14	4863.59	0.5564	
T _{water,out} (°C)			7.45					
m _{water} (kg/s)			0.59					
T _{ref,in} (°C)			-3.82					
P _{ref,in} (kPa)			369.71					
P _{ref,out} (kPa)			358.53					

Point ID	R-134a, P/D 1.5, 10 5 0.70							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.63	4.97	4.68	4.56	15.95	20712.94	0.8001	9.92
T ₁ (°C)	5.51	4.89	4.65	4.55	14.79	22908.61	0.7996	
T ₂ (°C)	5.35	4.84	4.62	4.54	13.57	24068.80	0.7991	
T ₃ (°C)	5.24	4.77	4.60	4.53	12.34	26160.65	0.7988	
T ₄ (°C)	5.12	4.74	4.58	4.52	11.19	27788.02	0.7985	
T ₅ (°C)	5.02	4.70	4.56	4.52	7.77	17439.40	0.7564	
T _{out} (°C)	4.94	4.66	4.55	4.51	6.94	16837.55	0.7553	
m _{water} (kg/s)			0.27		6.06	16477.43	0.7543	
P _{water,in} (kPa)	718.03	N/A	N/A	340.91	5.18	14663.17	0.7534	
P _{water,out} (kPa)	589.36	N/A	N/A	208.69	4.35	12927.14	0.7525	
P _{sat} (kPa)	340.63	341.72	340.55	341.54	3.43	16085.86	0.7252	
P _{bundle,in} (kPa)			341.30		3.14	16172.09	0.7253	
P _{bundle,out} (kPa)			339.74		2.84	15734.62	0.7255	
m _{ref} (kg/s)			0.28		2.53	15300.11	0.7257	
	Path B	Path C	Path D	Path E	2.24	14134.54	0.7260	
T _{water,in} (°C)	5.69	5.60	5.60	5.68	1.40	5460.36	0.7056	
T _{water,out} (°C)	4.75	4.84	4.67	4.77	1.35	5455.34	0.7055	
m _{water} (kg/s)	0.33	0.40	0.34	0.34	1.29	5357.01	0.7054	
	Pre-boiler				1.23	5302.83	0.7053	
T _{water,in} (°C)			21.66		1.17	5044.92	0.7052	
T _{water,out} (°C)			7.47					
m _{water} (kg/s)			0.67					
T _{ref,in} (°C)			2.21					
P _{ref,in} (kPa)			370.98					
P _{ref,out} (kPa)			357.94					

Point ID	R-134a, P/D 1.5, 10 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	8.10	6.22	5.44	5.11	44.30	20786.13	0.3441	10.14
T ₁ (°C)	7.75	6.04	5.38	5.08	40.66	22621.91	0.3425	
T ₂ (°C)	7.33	5.88	5.32	5.05	36.79	23427.47	0.3411	
T ₃ (°C)	7.01	5.73	5.25	5.02	32.92	24566.16	0.3402	
T ₄ (°C)	6.69	5.61	5.19	4.99	29.28	25319.26	0.3397	
T ₅ (°C)	6.41	5.51	5.14	4.97	20.01	18751.76	0.2272	
T _{out} (°C)	6.20	5.43	5.10	4.94	17.74	18321.38	0.2243	
m _{water} (kg/s)			0.27		15.33	17499.78	0.2214	
P _{water,in} (kPa)	717.37	N/A	N/A	340.77	12.92	15894.95	0.2187	
P _{water,out} (kPa)	590.27	N/A	N/A	207.91	10.66	13748.23	0.2164	
P _{sat} (kPa)	343.46	344.50	343.17	344.13	8.05	13443.56	0.1467	
P _{bundle,in} (kPa)			344.49		7.55	13857.51	0.1477	
P _{bundle,out} (kPa)			342.18		7.03	14332.12	0.1490	
m _{ref} (kg/s)			0.29		6.51	14642.58	0.1503	
	Path B	Path C	Path D	Path E	6.01	14732.25	0.1516	
T _{water,in} (°C)	8.19	8.09	8.09	8.17	3.95	8117.06	0.1015	
T _{water,out} (°C)	5.59	5.71	5.55	5.61	3.76	8193.87	0.1012	
m _{water} (kg/s)	0.33	0.35	0.34	0.34	3.55	8216.22	0.1008	
	Pre-boiler				3.34	8201.75	0.1005	
T _{water,in} (°C)			12.93		3.15	8015.60	0.1002	
T _{water,out} (°C)			5.38					
m _{water} (kg/s)			0.31					
T _{ref,in} (°C)			-7.29					
P _{ref,in} (kPa)			364.83					
P _{ref,out} (kPa)			358.59					

Point ID	R-134a, P/D 1.5, 10 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.70	5.95	5.13	4.75	40.10	18554.39	0.5959	
T ₁ (°C)	7.39	5.76	5.05	4.72	37.33	20227.78	0.5955	
T ₂ (°C)	7.00	5.60	4.98	4.68	34.37	21152.43	0.5954	
T ₃ (°C)	6.71	5.44	4.90	4.65	31.42	22627.64	0.5958	
T ₄ (°C)	6.40	5.32	4.84	4.62	28.64	24018.18	0.5966	
T ₅ (°C)	6.14	5.20	4.79	4.60	20.26	18685.39	0.4828	
T _{out} (°C)	5.92	5.11	4.74	4.58	18.22	18689.41	0.4803	
m _{water} (kg/s)			0.27		16.06	18447.57	0.4778	
P _{water,in} (kPa)	718.30	N/A	N/A	340.03	13.89	17119.36	0.4756	
P _{water,out} (kPa)	590.34	N/A	N/A	208.23	11.85	16002.98	0.4737	
P _{sat} (kPa)	339.80	340.78	339.58	340.59	9.24	16625.61	0.4024	9.94
P _{bundle,in} (kPa)			340.59		8.50	17076.88	0.4034	
P _{bundle,out} (kPa)			338.75		7.73	17540.90	0.4046	
m _{ref} (kg/s)			0.28		6.95	17531.63	0.4059	
	Path B	Path C	Path D	Path E	6.21	16727.20	0.4071	
T _{water,in} (°C)	7.81	7.70	7.69	7.76	4.26	9932.61	0.3581	
T _{water,out} (°C)	5.19	5.27	5.14	5.25	3.96	9858.38	0.3576	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	3.63	9659.23	0.3571	
	Pre-boiler				3.31	9330.18	0.3565	
T _{water,in} (°C)			11.34		3.01	8723.44	0.3561	
T _{water,out} (°C)			7.08					
m _{water} (kg/s)			1.33					
T _{ref,in} (°C)			-6.97					
P _{ref,in} (kPa)			361.43					
P _{ref,out} (kPa)			353.16					

Point ID	R-134a, P/D 1.5, 10 15 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.57	5.90	5.10	4.73	37.58	18245.73	0.7903	
T ₁ (°C)	7.27	5.72	5.03	4.70	35.15	19947.05	0.7899	
T ₂ (°C)	6.91	5.56	4.95	4.67	32.58	21054.54	0.7900	
T ₃ (°C)	6.63	5.41	4.87	4.64	30.00	22797.67	0.7905	
T ₄ (°C)	6.34	5.30	4.81	4.61	27.57	24554.21	0.7915	
T ₅ (°C)	6.09	5.18	4.77	4.59	19.71	19372.09	0.6816	
T _{out} (°C)	5.88	5.09	4.72	4.57	17.76	19536.74	0.6794	
m _{water} (kg/s)			0.27		15.70	19469.74	0.6773	
P _{water,in} (kPa)	716.23	N/A	N/A	339.21	13.63	18225.11	0.6754	
P _{water,out} (kPa)	588.58	N/A	N/A	206.94	11.68	17265.74	0.6739	
P _{sat} (kPa)	340.09	341.15	339.98	340.99	9.41	19396.43	0.6045	9.92
P _{bundle,in} (kPa)			340.79		8.57	19969.81	0.6050	
P _{bundle,out} (kPa)			339.22		7.68	20536.01	0.6056	
m _{ref} (kg/s)			0.28		6.78	20286.25	0.6064	
	Path B	Path C	Path D	Path E	5.94	18879.07	0.6072	
T _{water,in} (°C)	7.66	7.56	7.56	7.62	4.07	10665.02	0.5586	
T _{water,out} (°C)	5.16	5.22	5.09	5.21	3.77	10598.53	0.5581	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	3.45	10391.39	0.5576	
	Pre-boiler				3.13	10062.54	0.5571	
T _{water,in} (°C)			18.67		2.83	9343.38	0.5566	
T _{water,out} (°C)			7.09					
m _{water} (kg/s)			0.65					
T _{ref,in} (°C)			2.06					
P _{ref,in} (kPa)			367.08					
P _{ref,out} (kPa)			355.81					

Point ID	R-134a, P/D 1.5, 10 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.13	7.69	5.92	5.15	76.84	17247.72	0.5855	10.01
T ₁ (°C)	10.50	7.28	5.77	5.10	71.58	18578.05	0.5853	
T ₂ (°C)	9.77	6.93	5.61	5.04	65.99	19353.54	0.5861	
T ₃ (°C)	9.20	6.60	5.45	4.98	60.40	20409.86	0.5879	
T ₄ (°C)	8.62	6.32	5.33	4.92	55.14	21448.81	0.5905	
T ₅ (°C)	8.11	6.09	5.23	4.88	43.81	21660.61	0.3667	
T _{out} (°C)	7.67	5.90	5.14	4.84	39.10	21926.91	0.3612	
m _{water} (kg/s)			0.27		34.09	21673.55	0.3560	
P _{water,in} (kPa)	717.82	N/A	N/A	339.52	29.09	20477.49	0.3513	
P _{water,out} (kPa)	589.84	N/A	N/A	206.71	24.38	18754.45	0.3474	
P _{sat} (kPa)	340.05	341.13	339.88	340.88	18.75	18806.19	0.2040	
P _{bundle,in} (kPa)			341.07		17.03	19266.71	0.2052	
P _{bundle,out} (kPa)			339.02		15.20	19720.37	0.2068	
m _{ref} (kg/s)			0.29		13.37	19322.09	0.2086	
	Path B	Path C	Path D	Path E	11.64	18132.24	0.2104	
T _{water,in} (°C)	11.24	11.15	11.15	11.21	7.26	10321.86	0.1133	
T _{water,out} (°C)	6.04	6.16	5.98	6.08	6.80	10372.75	0.1126	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	6.31	10389.53	0.1118	
		Pre-boiler			5.82	10249.56	0.1110	
T _{water,in} (°C)			7.75		5.36	9938.16	0.1102	
T _{water,out} (°C)			6.17					
m _{water} (kg/s)			0.83					
T _{ref,in} (°C)			4.70					
P _{ref,in} (kPa)			361.33					
P _{ref,out} (kPa)			355.17					

Point ID	R-134a, P/D 1.5, 10 30 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.24	7.93	6.20	5.38	73.75	16779.69	0.8131	10.14
T ₁ (°C)	10.62	7.54	6.04	5.31	68.71	18010.14	0.8129	
T ₂ (°C)	9.93	7.20	5.87	5.24	63.36	18666.73	0.8137	
T ₃ (°C)	9.38	6.87	5.70	5.17	58.01	19563.06	0.8155	
T ₄ (°C)	8.83	6.61	5.57	5.11	52.97	20468.53	0.8181	
T ₅ (°C)	8.34	6.37	5.47	5.07	42.22	20441.63	0.6020	
T _{out} (°C)	7.91	6.19	5.37	5.02	37.89	20713.63	0.5971	
m _{water} (kg/s)			0.27		33.29	20592.29	0.5924	
P _{water,in} (kPa)	716.24	N/A	N/A	340.77	28.69	19627.91	0.5883	
P _{water,out} (kPa)	589.39	N/A	N/A	207.61	24.36	18270.84	0.5850	
P _{sat} (kPa)	343.09	344.12	342.96	344.04	19.99	20093.25	0.4463	
P _{bundle,in} (kPa)			343.86		18.16	20828.77	0.4475	
P _{bundle,out} (kPa)			342.30		16.22	21571.78	0.4490	
m _{ref} (kg/s)			0.29		14.28	21416.36	0.4508	
	Path B	Path C	Path D	Path E	12.46	20374.49	0.4527	
T _{water,in} (°C)	11.34	11.25	11.25	11.32	8.55	13401.91	0.3581	
T _{water,out} (°C)	6.26	6.33	6.17	6.29	7.89	13510.95	0.3571	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	7.20	13560.35	0.3560	
		Pre-boiler			6.50	13337.33	0.3549	
T _{water,in} (°C)			17.95		5.85	12695.33	0.3538	
T _{water,out} (°C)			6.96					
m _{water} (kg/s)			0.49					
T _{ref,in} (°C)			-4.16					
P _{ref,in} (kPa)			364.93					
P _{ref,out} (kPa)			356.39					

Point ID	R-134a, P/D 1.5, 10 40 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	13.30	8.89	6.57	5.44	98.74	16570.17	0.7170	10.18
T ₁ (°C)	12.47	8.37	6.35	5.36	91.65	17653.91	0.7159	
T ₂ (°C)	11.55	7.92	6.11	5.27	84.11	18189.72	0.7160	
T ₃ (°C)	10.82	7.49	5.88	5.18	76.58	18838.28	0.7175	
T ₄ (°C)	10.09	7.13	5.70	5.11	69.49	19428.66	0.7201	
T ₅ (°C)	9.44	6.82	5.57	5.05	55.73	19879.20	0.4333	
T _{out} (°C)	8.88	6.56	5.44	5.00	50.19	20214.07	0.4275	
m _{water} (kg/s)			0.27		44.30	20150.26	0.4220	
P _{water,in} (kPa)	716.47	N/A	N/A	340.91	38.41	19427.00	0.4173	
P _{water,out} (kPa)	589.50	N/A	N/A	208.01	32.87	18263.70	0.4135	
P _{sat} (kPa)	340.67	341.65	340.49	341.60	27.58	20790.06	0.2294	
P _{bundle,in} (kPa)			341.54		24.91	21479.95	0.2309	
P _{bundle,out} (kPa)			339.78		22.08	22071.63	0.2327	
m _{ref} (kg/s)			0.29		19.24	21609.65	0.2348	
	Path B	Path C	Path D	Path E	16.57	20223.73	0.2371	
T _{water,in} (°C)	13.42	13.34	13.33	13.40	10.70	12826.95	0.1127	
T _{water,out} (°C)	6.61	6.73	6.51	6.63	9.84	12781.18	0.1114	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	8.92	12663.16	0.1099	
	Pre-boiler				8.01	12238.06	0.1085	
T _{water,in} (°C)			13.79		7.15	11551.35	0.1071	
T _{water,out} (°C)			5.43					
m _{water} (kg/s)			0.25					
T _{ref,in} (°C)			-4.56					
P _{ref,in} (kPa)			361.77					
P _{ref,out} (kPa)			355.78					

Point ID	R-134a, P/D 1.5, 15 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.58	4.96	4.69	4.55	14.47	16731.34	0.1658	14.94
T ₁ (°C)	5.47	4.90	4.65	4.54	13.45	18099.02	0.1654	
T ₂ (°C)	5.33	4.85	4.63	4.53	12.37	18552.52	0.1651	
T ₃ (°C)	5.22	4.78	4.60	4.52	11.28	19367.18	0.1649	
T ₄ (°C)	5.11	4.75	4.58	4.50	10.26	20015.94	0.1647	
T ₅ (°C)	5.01	4.71	4.56	4.50	7.00	12656.34	0.1391	
T _{out} (°C)	4.94	4.67	4.54	4.49	6.37	12266.17	0.1385	
m _{water} (kg/s)			0.26		5.69	12107.16	0.1380	
P _{water,in} (kPa)	682.37	N/A	N/A	328.34	5.02	11113.65	0.1375	
P _{water,out} (kPa)	562.16	N/A	N/A	202.29	4.39	10208.84	0.1370	
P _{sat} (kPa)	339.93	340.90	339.58	340.41	3.46	11919.41	0.1200	
P _{bundle,in} (kPa)			340.90		3.26	12021.96	0.1201	
P _{bundle,out} (kPa)			338.51		3.05	12173.65	0.1203	
m _{ref} (kg/s)			0.43		2.84	12305.37	0.1206	
	Path B	Path C	Path D	Path E	2.64	12340.53	0.1208	
T _{water,in} (°C)	5.65	5.55	5.55	5.61	1.56	5065.15	0.1078	
T _{water,out} (°C)	4.71	4.85	4.68	4.73	1.49	5049.86	0.1077	
m _{water} (kg/s)	0.32	0.38	0.33	0.33	1.42	4957.70	0.1076	
	Pre-boiler				1.35	4894.16	0.1075	
T _{water,in} (°C)			8.55		1.29	4675.49	0.1075	
T _{water,out} (°C)			6.68					
m _{water} (kg/s)			2.04					
T _{ref,in} (°C)			-8.26					
P _{ref,in} (kPa)			363.56					
P _{ref,out} (kPa)			355.53					

Point ID	R-134a, P/D 1.5, 15 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.68	5.03	4.76	4.64	15.67	20463.68	0.4131	15.02
T ₁ (°C)	5.56	4.96	4.73	4.63	14.44	22428.90	0.4127	
T ₂ (°C)	5.41	4.91	4.70	4.62	13.13	23139.89	0.4122	
T ₃ (°C)	5.30	4.85	4.68	4.61	11.82	24500.21	0.4119	
T ₄ (°C)	5.18	4.81	4.66	4.60	10.59	25416.90	0.4116	
T ₅ (°C)	5.08	4.77	4.64	4.60	7.23	15585.59	0.3851	
T _{out} (°C)	5.00	4.74	4.63	4.59	6.49	15026.63	0.3845	
m _{water} (kg/s)			0.26		5.70	14726.13	0.3839	
P _{water,in} (kPa)	700.63	N/A	N/A	334.36	4.92	13205.43	0.3834	
P _{water,out} (kPa)	575.85	N/A	N/A	206.32	4.18	11765.65	0.3829	
P _{sat} (kPa)	341.54	342.60	341.36	342.33	3.25	14244.06	0.3658	
P _{bundle,in} (kPa)			342.37		3.00	14274.05	0.3660	
P _{bundle,out} (kPa)			340.45		2.74	13969.67	0.3662	
m _{ref} (kg/s)			0.43		2.48	13720.48	0.3664	
	Path B	Path C	Path D	Path E	2.23	13161.67	0.3666	
T _{water,in} (°C)	5.75	5.64	5.65	5.72	1.34	4963.25	0.3541	
T _{water,out} (°C)	4.82	4.91	4.75	4.84	1.28	4899.92	0.3540	
m _{water} (kg/s)	0.33	0.39	0.33	0.34	1.21	4752.00	0.3539	
	Pre-boiler				1.14	4635.71	0.3539	
T _{water,in} (°C)			20.60		1.08	4346.39	0.3538	
T _{water,out} (°C)			7.96					
m _{water} (kg/s)			0.68					
T _{ref,in} (°C)			-6.89					
P _{ref,in} (kPa)			378.29					
P _{ref,out} (kPa)			364.03					

Point ID	R-134a, P/D 1.5, 15 5 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.95	5.28	4.99	4.87	16.47	21018.47	0.6096	14.92
T ₁ (°C)	5.83	5.21	4.96	4.86	15.26	23154.13	0.6092	
T ₂ (°C)	5.67	5.16	4.94	4.85	13.97	24230.76	0.6089	
T ₃ (°C)	5.56	5.09	4.92	4.84	12.69	26174.44	0.6088	
T ₄ (°C)	5.44	5.05	4.89	4.83	11.47	27513.15	0.6087	
T ₅ (°C)	5.34	5.01	4.88	4.83	7.90	17084.68	0.5801	
T _{out} (°C)	5.26	4.98	4.86	4.82	7.08	16431.77	0.5795	
m _{water} (kg/s)			0.27		6.21	16196.68	0.5788	
P _{water,in} (kPa)	742.37	N/A	N/A	350.33	5.34	14519.84	0.5782	
P _{water,out} (kPa)	609.55	N/A	N/A	212.65	4.52	12886.96	0.5777	
P _{sat} (kPa)	344.42	345.49	344.33	345.37	3.56	15637.22	0.5599	
P _{bundle,in} (kPa)			345.08		3.27	15677.88	0.5601	
P _{bundle,out} (kPa)			343.52		2.96	15247.34	0.5603	
m _{ref} (kg/s)			0.43		2.65	14871.51	0.5606	
	Path B	Path C	Path D	Path E	2.36	13902.92	0.5608	
T _{water,in} (°C)	6.04	5.92	5.93	6.00	1.44	5338.82	0.5483	
T _{water,out} (°C)	5.05	5.15	4.99	5.09	1.38	5326.11	0.5482	
m _{water} (kg/s)	0.34	0.40	0.34	0.35	1.31	5206.05	0.5481	
	Pre-boiler				1.25	5125.65	0.5481	
T _{water,in} (°C)			19.00		1.19	4856.59	0.5480	
T _{water,out} (°C)			9.88					
m _{water} (kg/s)			1.36					
T _{ref,in} (°C)			-6.69					
P _{ref,in} (kPa)			392.84					
P _{ref,out} (kPa)			373.72					

Point ID	R-134a, P/D 1.5, 15 5 0.70							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	6.07	5.43	5.16	5.05	15.36	21249.28	0.7440	14.97
T ₁ (°C)	5.96	5.36	5.13	5.04	14.26	23641.54	0.7433	
T ₂ (°C)	5.81	5.31	5.11	5.03	13.08	24980.13	0.7427	
T ₃ (°C)	5.70	5.25	5.09	5.02	11.90	27378.50	0.7509	
T ₄ (°C)	5.58	5.22	5.07	5.01	10.79	29286.61	0.7509	
T ₅ (°C)	5.49	5.18	5.06	5.01	7.40	17746.86	0.7249	
T _{out} (°C)	5.41	5.15	5.04	5.00	6.59	17019.01	0.7243	
m _{water} (kg/s)			0.27		5.72	16602.01	0.7152	
P _{water,in} (kPa)	718.55	N/A	N/A	340.84	4.86	14557.29	0.7151	
P _{water,out} (kPa)	589.11	N/A	N/A	209.22	4.04	12668.69	0.7150	
P _{sat} (kPa)	346.74	347.89	346.75	347.81	3.25	16383.75	0.6995	
P _{bundle,in} (kPa)			347.36		2.98	16538.02	0.6992	
P _{bundle,out} (kPa)			346.02		2.70	16165.55	0.6990	
m _{ref} (kg/s)			0.43		2.42	15863.89	0.7076	
	Path B	Path C	Path D	Path E	2.16	14768.11	0.7078	
T _{water,in} (°C)	6.14	6.05	6.05	6.13	1.31	5265.71	0.6966	
T _{water,out} (°C)	5.24	5.33	5.16	5.26	1.25	5228.97	0.6965	
m _{water} (kg/s)	0.33	0.40	0.34	0.34	1.18	5080.64	0.6965	
	Pre-boiler				1.12	4977.93	0.6964	
T _{water,in} (°C)			19.95		1.06	4684.66	0.6963	
T _{water,out} (°C)			10.52					
m _{water} (kg/s)			1.50					
T _{ref,in} (°C)			2.76					
P _{ref,in} (kPa)			403.27					
P _{ref,out} (kPa)			380.33					

Point ID	R-134a, P/D 1.5, 15 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.74	5.86	5.08	4.74	44.35	21058.60	0.2644	15.09
T ₁ (°C)	7.39	5.68	5.02	4.71	40.63	22915.35	0.2633	
T ₂ (°C)	6.96	5.52	4.95	4.68	36.69	23663.44	0.2623	
T ₃ (°C)	6.64	5.37	4.88	4.65	32.74	24715.22	0.2616	
T ₄ (°C)	6.32	5.25	4.82	4.62	29.02	25332.01	0.2612	
T ₅ (°C)	6.05	5.15	4.78	4.60	19.88	18898.37	0.1860	
T _{out} (°C)	5.84	5.07	4.73	4.58	17.66	18519.72	0.1840	
m _{water} (kg/s)			0.27		15.30	17770.58	0.1821	
P _{water,in} (kPa)	717.20	N/A	N/A	339.87	12.94	16231.96	0.1804	
P _{water,out} (kPa)	589.32	N/A	N/A	208.21	10.72	14130.13	0.1789	
P _{sat} (kPa)	339.44	340.39	339.12	340.01	8.22	14171.47	0.1324	
P _{bundle,in} (kPa)			340.33		7.68	14595.74	0.1331	
P _{bundle,out} (kPa)			338.15		7.11	15058.30	0.1339	
m _{ref} (kg/s)			0.43		6.53	15296.66	0.1348	
	Path B	Path C	Path D	Path E	5.99	15280.08	0.1358	
T _{water,in} (°C)	7.81	7.73	7.73	7.81	3.93	8507.21	0.1027	
T _{water,out} (°C)	5.23	5.34	5.17	5.25	3.72	8546.33	0.1025	
m _{water} (kg/s)	0.33	0.35	0.34	0.34	3.49	8508.37	0.1022	
	Pre-boiler				3.26	8431.83	0.1020	
T _{water,in} (°C)			13.42		3.04	8155.75	0.1017	
T _{water,out} (°C)			5.13					
m _{water} (kg/s)			0.44					
T _{ref,in} (°C)			-8.14					
P _{ref,in} (kPa)			363.55					
P _{ref,out} (kPa)			355.31					

Point ID	R-134a, P/D 1.5, 15 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.79	6.07	5.25	4.88	39.20	18723.67	0.5079	14.96
T ₁ (°C)	7.47	5.88	5.18	4.85	36.52	20447.91	0.5076	
T ₂ (°C)	7.10	5.72	5.11	4.82	33.67	21472.60	0.5076	
T ₃ (°C)	6.81	5.56	5.03	4.79	30.81	23097.02	0.5079	
T ₄ (°C)	6.51	5.45	4.97	4.76	28.13	24635.81	0.5084	
T ₅ (°C)	6.25	5.33	4.93	4.74	20.01	19301.52	0.4337	
T _{out} (°C)	6.04	5.24	4.87	4.72	18.00	19413.44	0.4321	
m _{water} (kg/s)		0.27			15.87	19246.98	0.4306	
P _{water,in} (kPa)	717.26	N/A	N/A	340.36	13.74	17951.41	0.4293	
P _{water,out} (kPa)	589.43	N/A	N/A	207.84	11.73	16871.90	0.4281	
P _{sat} (kPa)	341.85	342.89	341.72	342.76	9.26	18190.86	0.3814	
P _{bundle,in} (kPa)		342.61			8.47	18672.22	0.3819	
P _{bundle,out} (kPa)		340.92			7.63	19208.02	0.3826	
m _{ref} (kg/s)		0.43			6.79	19049.74	0.3833	
	Path B	Path C	Path D	Path E	5.99	17889.43	0.3840	
T _{water,in} (°C)	7.89	7.78	7.78	7.84	4.11	10315.13	0.3518	
T _{water,out} (°C)	5.31	5.38	5.25	5.37	3.80	10219.46	0.3515	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	3.48	9983.00	0.3512	
	Pre-boiler				3.15	9623.62	0.3508	
T _{water,in} (°C)		15.98			2.85	8913.37	0.3505	
T _{water,out} (°C)		8.30						
m _{water} (kg/s)		1.08						
T _{ref,in} (°C)		-5.56						
P _{ref,in} (kPa)		378.09						
P _{ref,out} (kPa)		363.99						

Point ID	R-134a, P/D 1.5, 15 15 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	8.18	6.47	5.63	5.24	38.51	18035.71	0.6959	15.00
T ₁ (°C)	7.87	6.28	5.55	5.21	36.05	19719.73	0.6959	
T ₂ (°C)	7.51	6.11	5.47	5.18	33.45	20849.11	0.6962	
T ₃ (°C)	7.22	5.95	5.39	5.15	30.84	22563.17	0.6968	
T ₄ (°C)	6.92	5.84	5.33	5.12	28.39	24357.76	0.6977	
T ₅ (°C)	6.66	5.71	5.29	5.10	20.51	19597.96	0.6229	
T _{out} (°C)	6.44	5.62	5.23	5.08	18.47	19768.58	0.6214	
m _{water} (kg/s)		0.27			16.30	19712.37	0.6199	
P _{water,in} (kPa)	716.77	N/A	N/A	339.47	14.13	18449.77	0.6187	
P _{water,out} (kPa)	588.68	N/A	N/A	206.92	12.08	17424.32	0.6177	
P _{sat} (kPa)	346.42	347.53	346.39	347.46	9.92	20225.40	0.5718	
P _{bundle,in} (kPa)		347.01			8.98	20739.80	0.5723	
P _{bundle,out} (kPa)		345.64			7.99	21182.73	0.5728	
m _{ref} (kg/s)		0.43			6.99	20713.56	0.5735	
	Path B	Path C	Path D	Path E	6.05	18914.29	0.5742	
T _{water,in} (°C)	8.27	8.17	8.17	8.24	4.13	10656.41	0.5436	
T _{water,out} (°C)	5.69	5.74	5.60	5.73	3.80	10517.93	0.5432	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	3.45	10207.78	0.5428	
	Pre-boiler				3.10	9744.55	0.5425	
T _{water,in} (°C)		17.86			2.77	8910.15	0.5421	
T _{water,out} (°C)		9.74						
m _{water} (kg/s)		1.34						
T _{ref,in} (°C)		3.89						
P _{ref,in} (kPa)		395.25						
P _{ref,out} (kPa)		375.54						

Point ID	R-134a, P/D 1.5, 15 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.26	7.75	5.98	5.21	78.90	17736.61	0.4304	15.12
T ₁ (°C)	10.61	7.34	5.83	5.16	73.30	19126.04	0.4301	
T ₂ (°C)	9.86	6.99	5.67	5.10	67.35	19903.97	0.4304	
T ₃ (°C)	9.28	6.66	5.51	5.03	61.40	20937.05	0.4314	
T ₄ (°C)	8.69	6.39	5.39	4.98	55.81	21926.90	0.4330	
T ₅ (°C)	8.18	6.15	5.30	4.94	43.63	21686.29	0.2826	
T _{out} (°C)	7.73	5.97	5.21	4.90	38.96	21967.23	0.2790	
m _{water} (kg/s)			0.27		33.99	21730.61	0.2755	
P _{water,in} (kPa)	716.38	N/A	N/A	340.27	29.02	20558.26	0.2724	
P _{water,out} (kPa)	589.10	N/A	N/A	207.45	24.34	18859.44	0.2699	
P _{sat} (kPa)	341.04	342.06	340.83	341.84	18.69	18903.74	0.1745	
P _{bundle,in} (kPa)			341.89		16.98	19361.21	0.1755	
P _{bundle,out} (kPa)			339.98		15.15	19836.36	0.1767	
m _{ref} (kg/s)			0.43		13.33	19460.99	0.1780	
	Path B	Path C	Path D	Path E	11.62	18285.28	0.1794	
T _{water,in} (°C)	11.37	11.29	11.28	11.35	7.52	11025.47	0.1155	
T _{water,out} (°C)	6.12	6.22	6.05	6.15	7.02	11101.51	0.1150	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	6.50	11138.27	0.1144	
	Pre-boiler				5.97	11003.66	0.1139	
T _{water,in} (°C)			15.26		5.47	10647.00	0.1133	
T _{water,out} (°C)			6.34					
m _{water} (kg/s)			0.23					
T _{ref,in} (°C)			4.90					
P _{ref,in} (kPa)			365.59					
P _{ref,out} (kPa)			356.91					

Point ID	R-134a, P/D 1.5, 15 30 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.27	7.96	6.26	5.45	74.11	17221.31	0.6465	15.15
T ₁ (°C)	10.65	7.58	6.10	5.38	68.97	18522.16	0.6464	
T ₂ (°C)	9.96	7.24	5.94	5.31	63.52	19239.29	0.6469	
T ₃ (°C)	9.41	6.93	5.77	5.24	58.06	20230.87	0.6481	
T ₄ (°C)	8.85	6.66	5.64	5.18	52.93	21189.52	0.6499	
T ₅ (°C)	8.36	6.44	5.54	5.14	41.26	20539.32	0.5057	
T _{out} (°C)	7.94	6.25	5.44	5.10	37.06	20845.25	0.5026	
m _{water} (kg/s)			0.27		32.61	20775.10	0.4996	
P _{water,in} (kPa)	716.58	N/A	N/A	340.51	28.15	19869.11	0.4970	
P _{water,out} (kPa)	590.41	N/A	N/A	207.64	23.95	18585.64	0.4949	
P _{sat} (kPa)	344.47	345.52	344.41	345.50	19.84	20861.15	0.4043	
P _{bundle,in} (kPa)			345.18		18.02	21694.02	0.4053	
P _{bundle,out} (kPa)			343.67		16.08	22635.02	0.4065	
m _{ref} (kg/s)			0.43		14.14	22566.23	0.4078	
	Path B	Path C	Path D	Path E	12.31	21499.08	0.4092	
T _{water,in} (°C)	11.38	11.29	11.29	11.36	8.65	14544.88	0.3487	
T _{water,out} (°C)	6.32	6.38	6.22	6.35	7.94	14645.41	0.3479	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	7.18	14666.76	0.3471	
	Pre-boiler				6.42	14374.06	0.3463	
T _{water,in} (°C)			15.87		5.71	13489.93	0.3455	
T _{water,out} (°C)			8.70					
m _{water} (kg/s)			1.10					
T _{ref,in} (°C)			-2.99					
P _{ref,in} (kPa)			380.54					
P _{ref,out} (kPa)			366.63					

Point ID	R-134a, P/D 1.5, 15 45 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	14.51	9.56	7.05	5.81	112.27	17302.70	0.5630	15.08
T ₁ (°C)	13.56	9.00	6.80	5.72	103.54	18401.71	0.5611	
T ₂ (°C)	12.51	8.51	6.55	5.62	94.27	18860.07	0.5601	
T ₃ (°C)	11.68	8.06	6.30	5.52	85.00	19327.05	0.5601	
T ₄ (°C)	10.88	7.66	6.10	5.44	76.27	19683.63	0.5611	
T ₅ (°C)	10.17	7.33	5.95	5.38	59.90	19706.67	0.3467	
T _{out} (°C)	9.55	7.04	5.81	5.32	54.04	20076.95	0.3426	
m _{water} (kg/s)			0.27		47.82	20080.16	0.3389	
P _{water,in} (kPa)	716.81	N/A	N/A	340.26	41.59	19476.06	0.3357	
P _{water,out} (kPa)	589.30	N/A	N/A	207.74	35.74	18433.20	0.3332	
P _{sat} (kPa)	344.40	345.37	344.21	345.36	30.31	21448.25	0.1970	
P _{bundle,in} (kPa)			345.23		27.34	22205.27	0.1980	
P _{bundle,out} (kPa)			343.46		24.18	22897.98	0.1994	
m _{ref} (kg/s)			0.43		21.03	22444.23	0.2009	
	Path B	Path C	Path D	Path E	18.06	21024.21	0.2027	
T _{water,in} (°C)	14.63	14.55	14.54	14.61	11.92	13938.67	0.1108	
T _{water,out} (°C)	7.10	7.22	7.00	7.12	10.92	13929.13	0.1097	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	9.87	13852.40	0.1086	
	Pre-boiler				8.81	13407.89	0.1075	
T _{water,in} (°C)			12.05		7.82	12634.29	0.1064	
T _{water,out} (°C)			6.22					
m _{water} (kg/s)			0.53					
T _{ref,in} (°C)			-3.67					
P _{ref,in} (kPa)			368.30					
P _{ref,out} (kPa)			360.26					

Point ID	R-134a, P/D 1.5, 20 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.64	5.03	4.76	4.63	14.00	16893.61	0.1454	20.14
T ₁ (°C)	5.53	4.97	4.73	4.63	13.03	18341.30	0.1452	
T ₂ (°C)	5.39	4.92	4.71	4.61	12.00	18944.63	0.1451	
T ₃ (°C)	5.29	4.85	4.69	4.60	10.97	19937.52	0.1450	
T ₄ (°C)	5.18	4.81	4.66	4.59	10.00	20791.66	0.1450	
T ₅ (°C)	5.08	4.78	4.64	4.59	7.05	13592.65	0.1265	
T _{out} (°C)	5.01	4.75	4.62	4.58	6.32	12956.69	0.1261	
m _{water} (kg/s)			0.26		5.56	12561.52	0.1256	
P _{water,in} (kPa)	671.45	N/A	N/A	323.54	4.79	11468.26	0.1252	
P _{water,out} (kPa)	552.54	N/A	N/A	200.25	4.07	9949.71	0.1248	
P _{sat} (kPa)	341.12	342.10	340.79	341.66	3.31	12185.87	0.1127	
P _{bundle,in} (kPa)			342.10		3.10	12233.46	0.1128	
P _{bundle,out} (kPa)			339.74		2.88	12303.82	0.1130	
m _{ref} (kg/s)			0.58		2.66	12357.06	0.1132	
	Path B	Path C	Path D	Path E	2.46	12280.96	0.1134	
T _{water,in} (°C)	5.70	5.61	5.62	5.67	1.46	4969.93	0.1043	
T _{water,out} (°C)	4.80	4.91	4.75	4.81	1.40	4929.06	0.1042	
m _{water} (kg/s)	0.32	0.38	0.32	0.33	1.33	4816.20	0.1042	
	Pre-boiler				1.26	4731.11	0.1041	
T _{water,in} (°C)			18.91		1.19	4480.65	0.1041	
T _{water,out} (°C)			5.30					
m _{water} (kg/s)			0.37					
T _{ref,in} (°C)			-8.10					
P _{ref,in} (kPa)			370.46					
P _{ref,out} (kPa)			359.73					

Point ID	R-134a, P/D 1.5, 20 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.60	4.95	4.68	4.57	15.62	21349.05	0.3963	19.88
T ₁ (°C)	5.48	4.88	4.65	4.56	14.37	23523.55	0.3959	
T ₂ (°C)	5.32	4.83	4.63	4.55	13.04	24336.48	0.3956	
T ₃ (°C)	5.21	4.77	4.61	4.54	11.71	25919.78	0.3953	
T ₄ (°C)	5.09	4.73	4.59	4.53	10.46	26902.65	0.3951	
T ₅ (°C)	5.00	4.70	4.57	4.53	7.14	16269.44	0.3754	
T _{out} (°C)	4.92	4.66	4.56	4.52	6.39	15647.50	0.3750	
m _{water} (kg/s)			0.26		5.60	15390.96	0.3746	
P _{water,in} (kPa)	698.71	N/A	N/A	333.89	4.81	13740.10	0.3742	
P _{water,out} (kPa)	575.09	N/A	N/A	206.24	4.07	12157.07	0.3738	
P _{sat} (kPa)	340.88	341.99	340.73	341.71	3.19	15542.63	0.3615	
P _{bundle,in} (kPa)			341.60		2.93	15540.79	0.3616	
P _{bundle,out} (kPa)			339.85		2.66	15143.48	0.3617	
m _{ref} (kg/s)			0.57		2.38	14808.05	0.3618	
	Path B	Path C	Path D	Path E	2.13	14057.89	0.3620	
T _{water,in} (°C)	5.66	5.56	5.56	5.63	1.28	4978.51	0.3531	
T _{water,out} (°C)	4.74	4.83	4.67	4.76	1.22	4943.34	0.3531	
m _{water} (kg/s)	0.32	0.39	0.33	0.34	1.16	4819.32	0.3530	
	Pre-boiler				1.10	4736.82	0.3530	
T _{water,in} (°C)			19.02		1.05	4464.50	0.3529	
T _{water,out} (°C)			9.90					
m _{water} (kg/s)			1.19					
T _{ref,in} (°C)			-4.30					
P _{ref,in} (kPa)			396.65					
P _{ref,out} (kPa)			375.93					

Point ID	R-134a, P/D 1.5, 20 5 0.55							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	6.05	5.40	5.13	5.02	15.55	21437.06	0.5836	20.00
T ₁ (°C)	5.93	5.33	5.10	5.01	14.40	23786.46	0.5835	
T ₂ (°C)	5.78	5.29	5.08	5.00	13.18	25090.54	0.5833	
T ₃ (°C)	5.67	5.22	5.06	5.00	11.96	27368.66	0.5832	
T ₄ (°C)	5.55	5.19	5.04	4.99	10.82	29063.05	0.5832	
T ₅ (°C)	5.46	5.15	5.03	4.99	7.37	17357.95	0.5635	
T _{out} (°C)	5.38	5.12	5.01	4.98	6.57	16584.05	0.5630	
m _{water} (kg/s)			0.27		5.73	16268.95	0.5626	
P _{water,in} (kPa)	717.01	N/A	N/A	340.93	4.88	14367.12	0.5621	
P _{water,out} (kPa)	588.78	N/A	N/A	208.75	4.09	12572.76	0.5618	
P _{sat} (kPa)	346.47	347.56	346.45	347.55	3.22	15430.42	0.5500	
P _{bundle,in} (kPa)			347.09		2.96	15454.56	0.5502	
P _{bundle,out} (kPa)			345.65		2.67	14943.97	0.5504	
m _{ref} (kg/s)			0.57		2.39	14488.94	0.5506	
	Path B	Path C	Path D	Path E	2.12	13437.69	0.5508	
T _{water,in} (°C)	6.13	6.02	6.03	6.10	1.26	4869.61	0.5430	
T _{water,out} (°C)	5.20	5.30	5.13	5.23	1.21	4868.52	0.5430	
m _{water} (kg/s)	0.33	0.40	0.34	0.34	1.16	4762.60	0.5429	
	Pre-boiler				1.11	4706.77	0.5429	
T _{water,in} (°C)			19.01		1.06	4479.40	0.5428	
T _{water,out} (°C)			12.16					
m _{water} (kg/s)			2.24					
T _{ref,in} (°C)			-0.27					
P _{ref,in} (kPa)			423.15					
P _{ref,out} (kPa)			394.00					

Point ID	R-134a, P/D 1.5, 20 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.65	5.85	5.09	4.74	42.08	20347.48	0.2238	19.83
T ₁ (°C)	7.31	5.67	5.02	4.72	38.70	22129.60	0.2230	
T ₂ (°C)	6.91	5.52	4.95	4.68	35.11	22927.78	0.2222	
T ₃ (°C)	6.61	5.37	4.88	4.65	31.52	24109.23	0.2217	
T ₄ (°C)	6.30	5.27	4.82	4.62	28.15	24871.61	0.2214	
T ₅ (°C)	6.04	5.16	4.78	4.61	18.99	18045.23	0.1657	
T _{out} (°C)	5.83	5.07	4.73	4.58	17.04	17930.54	0.1645	
m _{water} (kg/s)			0.27		14.97	17520.89	0.1634	
P _{water,in} (kPa)	722.49	N/A	N/A	344.03	12.90	16021.52	0.1624	
P _{water,out} (kPa)	595.97	N/A	N/A	211.70	10.95	14821.93	0.1615	
P _{sat} (kPa)	339.69	340.64	339.37	340.29	8.34	14872.72	0.1266	
P _{bundle,in} (kPa)			340.51		7.74	15211.22	0.1271	
P _{bundle,out} (kPa)			338.43		7.09	15609.32	0.1276	
m _{ref} (kg/s)			0.57		6.45	15672.64	0.1282	
	Path B	Path C	Path D	Path E	5.84	15201.29	0.1288	
T _{water,in} (°C)	7.74	7.63	7.63	7.69	3.96	8852.60	0.1042	
T _{water,out} (°C)	5.18	5.29	5.16	5.23	3.71	8819.43	0.1040	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	3.45	8708.66	0.1038	
		Pre-boiler			3.19	8529.79	0.1035	
T _{water,in} (°C)			15.27		2.95	8116.44	0.1033	
T _{water,out} (°C)			5.57					
m _{water} (kg/s)			0.49					
T _{ref,in} (°C)			-7.41					
P _{ref,in} (kPa)			368.67					
P _{ref,out} (kPa)			358.05					

Point ID	R-134a, P/D 1.5, 20 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.83	6.15	5.35	4.98	38.31	18732.83	0.4665	19.92
T ₁ (°C)	7.53	5.96	5.28	4.96	35.73	20503.90	0.4663	
T ₂ (°C)	7.16	5.81	5.20	4.92	32.99	21618.34	0.4663	
T ₃ (°C)	6.88	5.65	5.12	4.89	30.25	23346.12	0.4666	
T ₄ (°C)	6.58	5.54	5.06	4.87	27.67	25026.17	0.4670	
T ₅ (°C)	6.33	5.42	5.02	4.85	19.63	19496.06	0.4121	
T _{out} (°C)	6.12	5.34	4.97	4.83	17.67	19622.36	0.4110	
m _{water} (kg/s)			0.27		15.58	19510.23	0.4100	
P _{water,in} (kPa)	717.26	N/A	N/A	340.16	13.50	18228.22	0.4091	
P _{water,out} (kPa)	589.57	N/A	N/A	207.17	11.53	17160.45	0.4084	
P _{sat} (kPa)	343.34	344.42	343.29	344.34	9.34	19390.75	0.3747	
P _{bundle,in} (kPa)			344.02		8.47	19790.29	0.3751	
P _{bundle,out} (kPa)			342.54		7.54	20173.80	0.3755	
m _{ref} (kg/s)			0.57		6.62	19679.32	0.3760	
	Path B	Path C	Path D	Path E	5.75	17976.93	0.3765	
T _{water,in} (°C)	7.93	7.82	7.82	7.89	3.92	10119.47	0.3540	
T _{water,out} (°C)	5.41	5.47	5.34	5.46	3.62	9988.36	0.3537	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	3.30	9706.41	0.3535	
		Pre-boiler			2.98	9296.34	0.3532	
T _{water,in} (°C)			16.72		2.68	8546.06	0.3530	
T _{water,out} (°C)			10.10					
m _{water} (kg/s)			1.45					
T _{ref,in} (°C)			2.93					
P _{ref,in} (kPa)			399.54					
P _{ref,out} (kPa)			378.24					

Point ID	R-134a, P/D 1.5, 20 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.18	7.67	5.94	5.20	79.18	18197.50	0.3392	20.07
T ₁ (°C)	10.53	7.28	5.80	5.14	73.44	19653.90	0.3388	
T ₂ (°C)	9.78	6.93	5.64	5.08	67.33	20457.36	0.3389	
T ₃ (°C)	9.20	6.61	5.49	5.02	61.22	21522.60	0.3395	
T ₄ (°C)	8.61	6.34	5.37	4.96	55.47	22525.62	0.3405	
T ₅ (°C)	8.10	6.11	5.28	4.92	42.81	21906.65	0.2281	
T _{out} (°C)	7.66	5.93	5.19	4.88	38.19	22178.66	0.2254	
m _{water} (kg/s)			0.27		33.27	21919.22	0.2228	
P _{water,in} (kPa)	716.88	N/A	N/A	340.37	28.36	20690.45	0.2206	
P _{water,out} (kPa)	589.40	N/A	N/A	207.93	23.73	18919.20	0.2187	
P _{sat} (kPa)	341.09	342.11	340.91	341.90	18.28	19070.22	0.1481	
P _{bundle,in} (kPa)			341.93		16.60	19536.93	0.1488	
P _{bundle,out} (kPa)			340.07		14.82	20045.67	0.1497	
m _{ref} (kg/s)			0.57		13.04	19675.55	0.1506	
	Path B	Path C	Path D	Path E	11.36	18511.02	0.1517	
T _{water,in} (°C)	11.28	11.20	11.19	11.26	7.48	11351.95	0.1043	
T _{water,out} (°C)	6.09	6.18	6.02	6.12	6.97	11428.92	0.1039	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	6.43	11460.98	0.1035	
	Pre-boiler				5.90	11317.05	0.1031	
T _{water,in} (°C)			9.58		5.39	10909.71	0.1027	
T _{water,out} (°C)			7.16					
m _{water} (kg/s)			1.24					
T _{ref,in} (°C)			2.26					
P _{ref,in} (kPa)			370.45					
P _{ref,out} (kPa)			359.51					

Point ID	R-134a, P/D 1.5, 20 45 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	14.52	9.54	7.04	5.82	113.36	17558.67	0.4348	20.37
T ₁ (°C)	13.57	8.98	6.79	5.72	104.41	18684.50	0.4332	
T ₂ (°C)	12.50	8.50	6.54	5.62	94.90	19136.84	0.4323	
T ₃ (°C)	11.67	8.04	6.29	5.52	85.39	19588.47	0.4322	
T ₄ (°C)	10.86	7.65	6.10	5.44	76.43	19911.83	0.4328	
T ₅ (°C)	10.15	7.31	5.95	5.38	59.75	19826.21	0.2737	
T _{out} (°C)	9.53	7.03	5.81	5.32	53.90	20210.27	0.2707	
m _{water} (kg/s)			0.27		47.68	20228.80	0.2679	
P _{water,in} (kPa)	715.87	N/A	N/A	340.64	41.46	19627.02	0.2656	
P _{water,out} (kPa)	589.20	N/A	N/A	207.59	35.61	18582.84	0.2638	
P _{sat} (kPa)	344.53	345.52	344.38	345.53	30.00	21410.79	0.1630	
P _{bundle,in} (kPa)			345.36		27.05	22139.24	0.1639	
P _{bundle,out} (kPa)			343.68		23.92	22801.55	0.1649	
m _{ref} (kg/s)			0.58		20.78	22304.05	0.1661	
	Path B	Path C	Path D	Path E	17.83	20856.17	0.1674	
T _{water,in} (°C)	14.64	14.57	14.55	14.62	11.94	14041.16	0.1000	
T _{water,out} (°C)	7.10	7.21	7.00	7.12	10.96	14070.46	0.0992	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	9.91	14045.09	0.0984	
	Pre-boiler				8.86	13658.47	0.0975	
T _{water,in} (°C)			9.95		7.88	12914.28	0.0968	
T _{water,out} (°C)			7.27					
m _{water} (kg/s)			1.38					
T _{ref,in} (°C)			-2.05					
P _{ref,in} (kPa)			373.33					
P _{ref,out} (kPa)			362.73					

Point ID	R-134a, P/D 1.5, 25 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.74	5.11	4.84	4.70	15.03	18489.59	0.1391	24.87
T ₁ (°C)	5.63	5.05	4.81	4.70	13.88	20000.23	0.1388	
T ₂ (°C)	5.48	5.00	4.78	4.69	12.66	20409.91	0.1386	
T ₃ (°C)	5.37	4.93	4.76	4.68	11.44	21240.70	0.1384	
T ₄ (°C)	5.26	4.90	4.73	4.67	10.29	21728.14	0.1383	
T ₅ (°C)	5.16	4.86	4.71	4.66	7.09	13706.52	0.1226	
T _{out} (°C)	5.09	4.82	4.70	4.65	6.43	13285.35	0.1223	
m _{water} (kg/s)			0.26		5.73	13071.66	0.1219	
P _{water,in} (kPa)	699.53	N/A	N/A	334.24	5.02	11967.58	0.1216	
P _{water,out} (kPa)	574.75	N/A	N/A	205.78	4.36	10942.71	0.1214	
P _{sat} (kPa)	342.05	343.03	341.76	342.72	3.39	12692.24	0.1110	
P _{bundle,in} (kPa)			342.99		3.18	12890.31	0.1111	
P _{bundle,out} (kPa)			340.71		2.97	12938.84	0.1113	
m _{ref} (kg/s)			0.71		2.75	13117.82	0.1114	
	Path B	Path C	Path D	Path E	2.55	13080.14	0.1115	
T _{water,in} (°C)	5.82	5.71	5.71	5.78	1.48	5143.18	0.1038	
T _{water,out} (°C)	4.87	4.99	4.83	4.91	1.42	5119.30	0.1037	
m _{water} (kg/s)	0.33	0.39	0.33	0.34	1.35	5017.64	0.1037	
	Pre-boiler				1.29	4946.55	0.1036	
T _{water,in} (°C)			21.66		1.22	4703.95	0.1036	
T _{water,out} (°C)			5.64					
m _{water} (kg/s)			0.38					
T _{ref,in} (°C)			-7.58					
P _{ref,in} (kPa)			378.71					
P _{ref,out} (kPa)			364.75					

Point ID	R-134a, P/D 1.5, 25 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.85	5.21	4.94	4.83	15.61	21624.59	0.3821	25.00
T ₁ (°C)	5.73	5.14	4.91	4.82	14.34	23859.45	0.3818	
T ₂ (°C)	5.58	5.09	4.89	4.81	13.00	24675.92	0.3815	
T ₃ (°C)	5.47	5.03	4.87	4.81	11.66	26281.45	0.3813	
T ₄ (°C)	5.35	4.99	4.85	4.80	10.39	27159.24	0.3812	
T ₅ (°C)	5.26	4.96	4.83	4.80	7.11	16465.73	0.3657	
T _{out} (°C)	5.18	4.92	4.82	4.79	6.35	15739.31	0.3654	
m _{water} (kg/s)			0.26		5.55	15450.63	0.3650	
P _{water,in} (kPa)	700.46	N/A	N/A	334.15	4.75	13682.09	0.3647	
P _{water,out} (kPa)	576.09	N/A	N/A	205.95	3.99	12011.91	0.3645	
P _{sat} (kPa)	344.04	345.23	343.99	345.01	3.17	15421.95	0.3550	
P _{bundle,in} (kPa)			344.88		2.90	15320.06	0.3551	
P _{bundle,out} (kPa)			343.15		2.61	14745.91	0.3552	
m _{ref} (kg/s)			0.71		2.32	14184.60	0.3553	
	Path B	Path C	Path D	Path E	2.05	13240.97	0.3554	
T _{water,in} (°C)	5.92	5.81	5.82	5.89	1.21	4542.58	0.3488	
T _{water,out} (°C)	5.01	5.09	4.93	5.02	1.16	4528.52	0.3488	
m _{water} (kg/s)	0.32	0.39	0.33	0.34	1.11	4421.95	0.3488	
	Pre-boiler				1.06	4360.51	0.3487	
T _{water,in} (°C)			17.95		1.01	4138.62	0.3487	
T _{water,out} (°C)			12.32					
m _{water} (kg/s)			2.35					
T _{ref,in} (°C)			-2.58					
P _{ref,in} (kPa)			422.62					
P _{ref,out} (kPa)			394.37					

Point ID	R-134a, P/D 1.5, 25 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.64	5.86	5.09	4.75	41.61	20176.75	0.2019	24.90
T ₁ (°C)	7.31	5.68	5.03	4.72	38.34	21985.28	0.2013	
T ₂ (°C)	6.92	5.53	4.96	4.68	34.87	22842.99	0.2009	
T ₃ (°C)	6.61	5.38	4.89	4.65	31.39	24127.88	0.2006	
T ₄ (°C)	6.30	5.28	4.83	4.62	28.13	25062.74	0.2006	
T ₅ (°C)	6.04	5.16	4.78	4.60	19.08	18230.98	0.1561	
T _{out} (°C)	5.83	5.08	4.74	4.58	17.12	18137.72	0.1551	
m _{water} (kg/s)			0.27		15.03	17726.97	0.1541	
P _{water,in} (kPa)	718.10	N/A	N/A	340.53	12.95	16252.14	0.1533	
P _{water,out} (kPa)	590.47	N/A	N/A	207.88	10.99	15013.80	0.1526	
P _{sat} (kPa)	339.76	340.76	339.50	340.46	8.48	15410.97	0.1250	
P _{bundle,in} (kPa)			340.58		7.87	15794.74	0.1254	
P _{bundle,out} (kPa)			338.53		7.21	16299.73	0.1259	
m _{ref} (kg/s)			0.71		6.56	16432.97	0.1264	
	Path B	Path C	Path D	Path E	5.94	16031.82	0.1269	
T _{water,in} (°C)	7.73	7.63	7.63	7.68	4.08	9331.12	0.1077	
T _{water,out} (°C)	5.18	5.27	5.14	5.22	3.82	9315.20	0.1075	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	3.55	9214.36	0.1073	
	Pre-boiler				3.27	9029.32	0.1071	
T _{water,in} (°C)			20.84		3.01	8580.55	0.1070	
T _{water,out} (°C)			5.74					
m _{water} (kg/s)			0.39					
T _{ref,in} (°C)			-6.61					
P _{ref,in} (kPa)			376.67					
P _{ref,out} (kPa)			362.77					

Point ID	R-134a, P/D 1.5, 25 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.93	6.30	5.53	5.17	37.24	19013.91	0.4332	25.01
T ₁ (°C)	7.64	6.11	5.45	5.14	34.72	20858.83	0.4330	
T ₂ (°C)	7.28	5.97	5.38	5.11	32.04	22059.28	0.4331	
T ₃ (°C)	7.00	5.82	5.30	5.08	29.36	23890.01	0.4333	
T ₄ (°C)	6.71	5.71	5.25	5.06	26.84	25645.35	0.4337	
T ₅ (°C)	6.47	5.60	5.21	5.04	18.94	19859.07	0.3915	
T _{out} (°C)	6.27	5.51	5.16	5.02	17.06	19986.42	0.3907	
m _{water} (kg/s)			0.27		15.05	20009.57	0.3899	
P _{water,in} (kPa)	716.83	N/A	N/A	339.68	13.05	18691.21	0.3892	
P _{water,out} (kPa)	589.60	N/A	N/A	207.11	11.16	17691.21	0.3887	
P _{sat} (kPa)	345.86	347.01	345.89	346.93	9.10	20600.47	0.3632	
P _{bundle,in} (kPa)			346.57		8.24	21161.17	0.3635	
P _{bundle,out} (kPa)			345.14		7.33	21692.83	0.3639	
m _{ref} (kg/s)			0.71		6.41	21218.50	0.3643	
	Path B	Path C	Path D	Path E	5.56	19304.82	0.3647	
T _{water,in} (°C)	8.03	7.92	7.92	7.99	3.72	10314.01	0.3481	
T _{water,out} (°C)	5.59	5.65	5.51	5.63	3.43	10171.76	0.3479	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	3.13	9856.25	0.3477	
	Pre-boiler				2.82	9420.06	0.3475	
T _{water,in} (°C)			16.65		2.53	8623.23	0.3473	
T _{water,out} (°C)			12.11					
m _{water} (kg/s)			2.58					
T _{ref,in} (°C)			3.81					
P _{ref,in} (kPa)			424.39					
P _{ref,out} (kPa)			395.62					

Point ID	R-134a, P/D 1.5, 25 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.23	7.76	6.06	5.30	78.47	18276.03	0.3050	25.10
T ₁ (°C)	10.58	7.37	5.91	5.24	72.73	19733.46	0.3046	
T ₂ (°C)	9.84	7.03	5.76	5.18	66.63	20530.19	0.3046	
T ₃ (°C)	9.26	6.71	5.60	5.12	60.54	21587.45	0.3051	
T ₄ (°C)	8.68	6.45	5.48	5.06	54.80	22569.84	0.3059	
T ₅ (°C)	8.18	6.22	5.38	5.02	42.00	21699.23	0.2166	
T _{out} (°C)	7.74	6.04	5.29	4.98	37.50	21960.78	0.2145	
m _{water} (kg/s)			0.27		32.72	21726.46	0.2126	
P _{water,in} (kPa)	717.26	N/A	N/A	340.06	27.93	20541.54	0.2108	
P _{water,out} (kPa)	589.97	N/A	N/A	207.58	23.43	18845.65	0.2094	
P _{sat} (kPa)	342.65	343.69	342.50	343.49	18.49	19758.85	0.1536	
P _{bundle,in} (kPa)			343.46		16.79	20332.30	0.1541	
P _{bundle,out} (kPa)			341.67		14.98	21009.43	0.1548	
m _{ref} (kg/s)			0.72		13.17	20726.07	0.1556	
	Path B	Path C	Path D	Path E	11.47	19561.78	0.1564	
T _{water,in} (°C)	11.34	11.25	11.24	11.31	7.75	12392.47	0.1190	
T _{water,out} (°C)	6.19	6.27	6.10	6.22	7.19	12469.53	0.1186	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	6.59	12495.95	0.1182	
	Pre-boiler				5.99	12322.52	0.1178	
T _{water,in} (°C)			13.48		5.42	11777.81	0.1175	
T _{water,out} (°C)			7.63					
m _{water} (kg/s)			0.82					
T _{ref,in} (°C)			0.23					
P _{ref,in} (kPa)			381.12					
P _{ref,out} (kPa)			366.14					

Point ID	R-134a, P/D 1.5, 35 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.54	4.92	4.66	4.54	14.46	18975.94	0.1305	34.83
T ₁ (°C)	5.43	4.86	4.63	4.53	13.33	20634.32	0.1303	
T ₂ (°C)	5.28	4.81	4.60	4.52	12.14	21183.78	0.1302	
T ₃ (°C)	5.17	4.74	4.58	4.51	10.94	22211.34	0.1300	
T ₄ (°C)	5.06	4.71	4.56	4.50	9.82	22818.07	0.1299	
T ₅ (°C)	4.97	4.67	4.54	4.50	6.80	14197.24	0.1193	
T _{out} (°C)	4.90	4.64	4.53	4.49	6.13	13679.72	0.1190	
m _{water} (kg/s)			0.26		5.41	13434.96	0.1188	
P _{water,in} (kPa)	670.96	N/A	N/A	323.11	4.69	12098.59	0.1186	
P _{water,out} (kPa)	553.25	N/A	N/A	200.77	4.02	10862.94	0.1184	
P _{sat} (kPa)	340.25	341.26	340.02	341.01	3.12	12860.61	0.1115	
P _{bundle,in} (kPa)			341.14		2.90	12886.48	0.1115	
P _{bundle,out} (kPa)			339.02		2.67	12721.18	0.1116	
m _{ref} (kg/s)			1.00		2.44	12655.81	0.1117	
	Path B	Path C	Path D	Path E	2.22	12315.11	0.1118	
T _{water,in} (°C)	5.62	5.50	5.51	5.57	1.28	4577.14	0.1067	
T _{water,out} (°C)	4.70	4.80	4.64	4.73	1.22	4521.30	0.1067	
m _{water} (kg/s)	0.32	0.38	0.32	0.33	1.16	4386.67	0.1067	
	Pre-boiler				1.09	4280.56	0.1067	
T _{water,in} (°C)			20.70		1.03	4023.05	0.1066	
T _{water,out} (°C)			6.98					
m _{water} (kg/s)			0.62					
T _{ref,in} (°C)			-7.16					
P _{ref,in} (kPa)			395.87					
P _{ref,out} (kPa)			374.77					

Point ID	R-134a, P/D 1.5, 35 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.74	5.99	5.22	4.88	41.27	20365.37	0.1677	35.17
T ₁ (°C)	7.42	5.81	5.16	4.85	37.99	22190.92	0.1673	
T ₂ (°C)	7.03	5.66	5.09	4.82	34.51	23071.36	0.1669	
T ₃ (°C)	6.73	5.51	5.02	4.79	31.03	24350.40	0.1667	
T ₄ (°C)	6.42	5.41	4.96	4.76	27.75	25273.89	0.1667	
T ₅ (°C)	6.16	5.29	4.91	4.74	18.84	18404.28	0.1355	
T _{out} (°C)	5.96	5.21	4.87	4.72	16.92	18364.72	0.1349	
m _{water} (kg/s)			0.27		14.89	18027.84	0.1342	
P _{water,in} (kPa)	717.34	N/A	N/A	340.14	12.85	16592.32	0.1337	
P _{water,out} (kPa)	590.92	N/A	N/A	207.46	10.93	15418.11	0.1332	
P _{sat} (kPa)	341.61	342.61	341.35	342.29	8.58	16426.68	0.1141	
P _{bundle,in} (kPa)			342.39		7.92	16802.85	0.1144	
P _{bundle,out} (kPa)			340.39		7.21	17322.56	0.1147	
m _{ref} (kg/s)			1.01		6.50	17362.07	0.1150	
	Path B	Path C	Path D	Path E	5.83	16750.88	0.1153	
T _{water,in} (°C)	7.83	7.73	7.73	7.79	4.00	9616.39	0.1021	
T _{water,out} (°C)	5.30	5.39	5.25	5.34	3.74	9606.80	0.1020	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	3.46	9499.96	0.1019	
	Pre-boiler				3.18	9308.42	0.1018	
T _{water,in} (°C)			19.03		2.92	8812.01	0.1017	
T _{water,out} (°C)			7.18					
m _{water} (kg/s)			0.68					
T _{ref,in} (°C)			-6.06					
P _{ref,in} (kPa)			396.02					
P _{ref,out} (kPa)			375.24					

Point ID	R-134a, P/D 1.5, 35 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	11.24	7.86	6.20	5.45	75.84	17944.01	0.2402	34.93
T ₁ (°C)	10.61	7.48	6.06	5.40	70.51	19397.71	0.2401	
T ₂ (°C)	9.90	7.15	5.90	5.33	64.86	20255.43	0.2403	
T ₃ (°C)	9.34	6.84	5.75	5.27	59.20	21429.92	0.2407	
T ₄ (°C)	8.77	6.59	5.62	5.21	53.87	22564.17	0.2414	
T ₅ (°C)	8.27	6.37	5.53	5.17	40.93	21292.42	0.1785	
T _{out} (°C)	7.85	6.19	5.45	5.13	36.57	21527.38	0.1770	
m _{water} (kg/s)			0.27		31.93	21274.68	0.1756	
P _{water,in} (kPa)	716.62	N/A	N/A	340.35	27.30	20105.40	0.1744	
P _{water,out} (kPa)	589.13	N/A	N/A	207.09	22.94	18457.63	0.1735	
P _{sat} (kPa)	344.73	345.75	344.58	345.61	18.48	19829.68	0.1344	
P _{bundle,in} (kPa)			345.50		16.74	20379.78	0.1348	
P _{bundle,out} (kPa)			343.72		14.90	20970.10	0.1353	
m _{ref} (kg/s)			1.00		13.05	20577.30	0.1359	
	Path B	Path C	Path D	Path E	11.31	19254.51	0.1365	
T _{water,in} (°C)	11.34	11.25	11.25	11.32	7.77	12509.96	0.1106	
T _{water,out} (°C)	6.31	6.38	6.21	6.33	7.17	12534.67	0.1103	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	6.54	12493.09	0.1100	
	Pre-boiler				5.91	12218.31	0.1097	
T _{water,in} (°C)			15.54		5.31	11546.02	0.1094	
T _{water,out} (°C)			9.17					
m _{water} (kg/s)			1.25					
T _{ref,in} (°C)			-4.72					
P _{ref,in} (kPa)			400.52					
P _{ref,out} (kPa)			379.61					

Point ID	R-134a, P/D 1.5, 45 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.56	4.96	4.71	4.60	13.78	19423.52	0.1171	44.92
T ₁ (°C)	5.44	4.89	4.68	4.59	12.67	21179.70	0.1169	
T ₂ (°C)	5.30	4.85	4.66	4.58	11.50	21776.97	0.1168	
T ₃ (°C)	5.20	4.79	4.64	4.57	10.32	22875.40	0.1167	
T ₄ (°C)	5.09	4.76	4.62	4.56	9.22	23495.20	0.1166	
T ₅ (°C)	5.00	4.72	4.60	4.56	6.27	14307.86	0.1089	
T _{out} (°C)	4.93	4.69	4.59	4.55	5.64	13748.11	0.1087	
m _{water} (kg/s)			0.25		4.96	13532.76	0.1085	
P _{water,in} (kPa)	644.32	N/A	N/A	313.31	4.29	12134.60	0.1084	
P _{water,out} (kPa)	531.02	N/A	N/A	196.06	3.66	10857.20	0.1082	
P _{sat} (kPa)	341.28	342.32	341.05	341.94	2.81	13322.45	0.1033	
P _{bundle,in} (kPa)			342.14		2.61	13349.41	0.1034	
P _{bundle,out} (kPa)			339.97		2.39	13141.67	0.1034	
m _{ref} (kg/s)			1.28		2.18	13086.22	0.1035	
	Path B	Path C	Path D	Path E	1.98	12687.67	0.1035	
T _{water,in} (°C)	5.63	5.52	5.53	5.59	1.15	4488.49	0.0999	
T _{water,out} (°C)	4.76	4.86	4.70	4.79	1.11	4474.85	0.0999	
m _{water} (kg/s)	0.31	0.37	0.31	0.32	1.06	4389.38	0.0999	
	Pre-boiler				1.01	4346.60	0.0998	
T _{water,in} (°C)			19.59		0.97	4129.34	0.0998	
T _{water,out} (°C)			8.77					
m _{water} (kg/s)			0.96					
T _{ref,in} (°C)			-6.36					
P _{ref,in} (kPa)			416.43					
P _{ref,out} (kPa)			388.69					

Point ID	R-134a, P/D 1.5, 45 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	7.77	6.02	5.26	4.91	41.12	20572.57	0.1496	45.02
T ₁ (°C)	7.44	5.84	5.19	4.89	37.82	22426.92	0.1493	
T ₂ (°C)	7.05	5.69	5.12	4.86	34.32	23322.66	0.1490	
T ₃ (°C)	6.75	5.55	5.05	4.82	30.82	24595.39	0.1488	
T ₄ (°C)	6.45	5.45	4.99	4.80	27.52	25502.14	0.1487	
T ₅ (°C)	6.19	5.33	4.95	4.78	18.59	18442.46	0.1245	
T _{out} (°C)	5.99	5.25	4.90	4.76	16.73	18440.66	0.1240	
m _{water} (kg/s)			0.27		14.74	18136.03	0.1235	
P _{water,in} (kPa)	716.84	N/A	N/A	340.22	12.76	16795.08	0.1232	
P _{water,out} (kPa)	590.02	N/A	N/A	207.70	10.90	15693.87	0.1228	
P _{sat} (kPa)	342.24	343.31	342.06	343.01	8.72	17380.65	0.1081	
P _{bundle,in} (kPa)			343.04		8.00	17715.39	0.1082	
P _{bundle,out} (kPa)			341.07		7.23	18181.16	0.1085	
m _{ref} (kg/s)			1.29		6.46	18070.06	0.1087	
	Path B	Path C	Path D	Path E	5.73	17163.08	0.1090	
T _{water,in} (°C)	7.85	7.76	7.76	7.81	3.90	9572.72	0.0989	
T _{water,out} (°C)	5.34	5.42	5.28	5.37	3.64	9516.82	0.0988	
m _{water} (kg/s)	0.33	0.34	0.34	0.34	3.36	9363.12	0.0987	
	Pre-boiler				3.08	9115.89	0.0986	
T _{water,in} (°C)			16.01		2.81	8557.46	0.0985	
T _{water,out} (°C)			9.82					
m _{water} (kg/s)			1.62					
T _{ref,in} (°C)			-5.72					
P _{ref,in} (kPa)			417.43					
P _{ref,out} (kPa)			389.39					

Point ID	R-134a, P/D 1.5, 55 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	5.80	5.21	4.97	4.86	13.67	19995.49	0.1110	
T ₁ (°C)	5.69	5.15	4.94	4.86	12.54	21827.68	0.1109	
T ₂ (°C)	5.55	5.10	4.92	4.85	11.34	22385.06	0.1108	
T ₃ (°C)	5.45	5.05	4.90	4.84	10.14	23503.96	0.1107	
T ₄ (°C)	5.34	5.02	4.88	4.83	9.01	23968.59	0.1106	
T ₅ (°C)	5.25	4.98	4.87	4.83	6.09	14360.10	0.1045	
T _{out} (°C)	5.18	4.95	4.85	4.82	5.47	13730.90	0.1044	
m _{water} (kg/s)			0.25		4.81	13475.90	0.1042	
P _{water,in} (kPa)	644.56	N/A	N/A	313.20	4.15	12016.49	0.1041	
P _{water,out} (kPa)	531.13	N/A	N/A	195.92	3.52	10696.21	0.1040	
P _{sat} (kPa)	344.50	345.56	344.31	345.25	2.73	13333.09	0.1002	54.81
P _{bundle,in} (kPa)		345.45			2.53	13291.05	0.1002	
P _{bundle,out} (kPa)		343.33			2.31	12957.64	0.1003	
m _{ref} (kg/s)		1.57			2.09	12764.37	0.1003	
	Path B	Path C	Path D	Path E	1.88	12200.89	0.1004	
T _{water,in} (°C)	5.88	5.77	5.78	5.84	1.07	4190.93	0.0976	
T _{water,out} (°C)	5.03	5.12	4.96	5.05	1.03	4168.77	0.0976	
m _{water} (kg/s)	0.31	0.37	0.31	0.32	0.99	4071.50	0.0976	
	Pre-boiler				0.94	4013.40	0.0976	
T _{water,in} (°C)		17.43			0.90	3800.83	0.0976	
T _{water,out} (°C)		11.84						
m _{water} (kg/s)		2.18						
T _{ref,in} (°C)		-5.55						
P _{ref,in} (kPa)		444.38						
P _{ref,out} (kPa)		408.53						

Point ID	R-123, P/D 1.167, 15 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.48	15.74	14.97	14.67	40.81	17606.78	0.5342	14.96
T ₁ (°C)	17.14	15.59	14.91	14.67	37.91	18504.45	0.5285	
T ₂ (°C)	16.81	15.42	14.86	14.66	34.82	19592.51	0.5226	
T ₃ (°C)	16.48	15.24	14.80	14.66	31.73	20591.16	0.5171	
T ₄ (°C)	16.19	15.15	14.76	14.65	28.82	21556.58	0.5134	
T ₅ (°C)	15.93	15.04	14.73	14.65	20.08	18417.96	0.2689	
T _{out} (°C)	15.72	14.96	14.70	14.64	17.93	18535.28	0.2679	
m _{water} (kg/s)			0.28		15.65	18743.21	0.2677	
P _{water,in} (kPa)	752.97	N/A	N/A	343.85	13.37	17072.83	0.2675	
P _{water,out} (kPa)	614.27	N/A	N/A	200.79	11.22	15612.81	0.2675	
P _{sat} (kPa)	60.39	60.33	59.90	59.76	7.18	14784.07	0.1154	
P _{bundle,in} (kPa)			60.64		6.44	14404.71	0.1128	
P _{bundle,out} (kPa)			62.35		5.65	13964.70	0.1099	
m _{ref} (kg/s)			0.14		4.86	12712.39	0.1071	
	Path B	Path C	Path D	Path E	4.12	11188.26	0.1044	
T _{water,in} (°C)	17.53	17.51	17.58	17.53	0.00	0.00	0.0897	
T _{water,out} (°C)	15.07	15.22	15.13	15.09	0.00	0.00	0.0897	
m _{water} (kg/s)	0.34	0.33	0.34	0.35	0.00	0.00	0.0897	
	Pre-boiler				0.00	0.00	0.0897	
T _{water,in} (°C)			21.26		0.00	0.00	0.0897	
T _{water,out} (°C)			20.57					
m _{water} (kg/s)			1.57					
T _{ref,in} (°C)			-1.29					
P _{ref,in} (kPa)			78.67					
P _{ref,out} (kPa)			73.12					

Point ID	R-123, P/D 1.167, 15 15 0.30							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.88	16.18	15.39	15.06	39.73	17012.45	0.7715	15.96
T ₁ (°C)	17.55	16.04	15.32	15.06	36.96	17866.25	0.7698	
T ₂ (°C)	17.23	15.86	15.26	15.04	34.01	18817.25	0.7689	
T ₃ (°C)	16.91	15.68	15.20	15.03	31.06	19734.26	0.7690	
T ₄ (°C)	16.62	15.58	15.15	15.01	28.29	20673.89	0.7699	
T ₅ (°C)	16.36	15.47	15.12	15.01	20.38	17997.14	0.5455	
T _{out} (°C)	16.16	15.39	15.08	15.00	18.28	18316.75	0.5411	
m _{water} (kg/s)			0.28		16.06	18656.45	0.5369	
P _{water,in} (kPa)	750.63	N/A	N/A	342.77	13.83	17212.51	0.5333	
P _{water,out} (kPa)	610.86	N/A	N/A	196.69	11.73	15958.04	0.5304	
P _{sat} (kPa)	61.28	61.29	60.90	60.79	8.39	17236.57	0.3934	
P _{bundle,in} (kPa)			61.43		7.44	16796.74	0.3943	
P _{bundle,out} (kPa)			63.43		6.43	16043.55	0.3954	
m _{ref} (kg/s)			0.15		5.42	14523.51	0.3968	
	Path B	Path C	Path D	Path E	4.48	12379.85	0.3983	
T _{water,in} (°C)	17.93	17.92	17.99	17.94	1.90	5403.31	0.3114	
T _{water,out} (°C)	15.46	15.58	15.52	15.49	1.80	5305.49	0.3110	
m _{water} (kg/s)	0.33	0.32	0.34	0.35	1.69	5152.48	0.3107	
	Pre-boiler				1.58	4979.89	0.3103	
T _{water,in} (°C)			28.38		1.48	4656.64	0.3100	
T _{water,out} (°C)			20.33					
m _{water} (kg/s)			0.34					
T _{ref,in} (°C)			-6.33					
P _{ref,in} (kPa)			77.47					
P _{ref,out} (kPa)			71.19					

Point ID	R-123, P/D 1.167, 20 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.72	15.85	15.02	14.71	43.44	17724.34	0.5239	19.96
T ₁ (°C)	17.35	15.69	14.96	14.70	40.36	18652.65	0.5220	
T ₂ (°C)	17.00	15.51	14.90	14.69	37.09	19796.76	0.5210	
T ₃ (°C)	16.65	15.32	14.84	14.68	33.81	20849.02	0.5208	
T ₄ (°C)	16.34	15.22	14.80	14.67	30.73	21900.91	0.5215	
T ₅ (°C)	16.06	15.10	14.76	14.67	21.60	19068.55	0.3240	
T _{out} (°C)	15.84	15.02	14.73	14.66	19.28	19238.51	0.3198	
m _{water} (kg/s)			0.28		16.83	19582.80	0.3158	
P _{water,in} (kPa)	752.60	N/A	N/A	343.94	14.37	17928.03	0.3123	
P _{water,out} (kPa)	613.97	N/A	N/A	201.97	12.05	16442.13	0.3096	
P _{sat} (kPa)	60.46	60.41	59.97	59.82	7.86	16081.64	0.1870	
P _{bundle,in} (kPa)			60.64		7.02	15728.01	0.1878	
P _{bundle,out} (kPa)			62.41		6.13	15297.18	0.1888	
m _{ref} (kg/s)			0.19		5.23	13886.31	0.1900	
	Path B	Path C	Path D	Path E	4.39	12125.95	0.1914	
T _{water,in} (°C)	17.76	17.75	17.82	17.77	0.00	0.00	0.1092	
T _{water,out} (°C)	15.13	15.27	15.19	15.15	0.00	0.00	0.1092	
m _{water} (kg/s)	0.34	0.33	0.34	0.35	0.00	0.00	0.1092	
	Pre-boiler				0.00	0.00	0.1092	
T _{water,in} (°C)			21.04		0.00	0.00	0.1092	
T _{water,out} (°C)			20.39					
m _{water} (kg/s)			2.44					
T _{ref,in} (°C)			-1.35					
P _{ref,in} (kPa)			77.63					
P _{ref,out} (kPa)			71.50					

Point ID	R-123, P/D 1.167, 20 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	18.00	16.14	15.30	14.94	43.18	17313.69	0.7501	20.49
T ₁ (°C)	17.62	15.99	15.23	14.93	40.14	18134.02	0.7485	
T ₂ (°C)	17.29	15.80	15.16	14.91	36.91	19219.03	0.7477	
T ₃ (°C)	16.93	15.60	15.09	14.89	33.68	20113.30	0.7478	
T ₄ (°C)	16.63	15.50	15.04	14.87	30.64	21125.01	0.7487	
T ₅ (°C)	16.35	15.38	15.01	14.86	22.04	18587.33	0.5557	
T _{out} (°C)	16.12	15.29	14.97	14.85	19.67	18925.86	0.5518	
m _{water} (kg/s)			0.28		17.16	19246.12	0.5482	
P _{water,in} (kPa)	750.18	N/A	N/A	341.82	14.64	17535.24	0.5451	
P _{water,out} (kPa)	611.46	N/A	N/A	197.41	12.28	15999.07	0.5426	
P _{sat} (kPa)	60.90	60.95	60.56	60.42	9.15	17910.09	0.4248	
P _{bundle,in} (kPa)			61.04		8.06	17437.09	0.4253	
P _{bundle,out} (kPa)			63.11		6.90	16763.13	0.4260	
m _{ref} (kg/s)			0.20		5.73	14740.84	0.4269	
	Path B	Path C	Path D	Path E	4.64	12318.76	0.4279	
T _{water,in} (°C)	18.05	18.05	18.11	18.06	2.55	7121.03	0.3518	
T _{water,out} (°C)	15.37	15.47	15.41	15.40	2.43	7128.01	0.3515	
m _{water} (kg/s)	0.34	0.32	0.34	0.35	2.30	7101.48	0.3511	
	Pre-boiler				2.18	7091.17	0.3508	
T _{water,in} (°C)			29.99		2.05	6774.58	0.3505	
T _{water,out} (°C)			28.55					
m _{water} (kg/s)			2.64					
T _{ref,in} (°C)			-6.37					
P _{ref,in} (kPa)			85.41					
P _{ref,out} (kPa)			77.42					

Point ID	R-123, P/D 1.167, 25 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.48	15.68	14.88	14.58	42.05	17830.47	0.3720	25.07
T ₁ (°C)	17.13	15.52	14.82	14.58	39.06	18773.02	0.3684	
T ₂ (°C)	16.79	15.36	14.77	14.57	35.88	19929.47	0.3648	
T ₃ (°C)	16.45	15.17	14.71	14.56	32.70	21002.93	0.3618	
T ₄ (°C)	16.15	15.07	14.67	14.55	29.70	22071.46	0.3595	
T ₅ (°C)	15.88	14.96	14.64	14.55	20.81	19176.35	0.2085	
T _{out} (°C)	15.67	14.88	14.60	14.54	18.57	19345.14	0.2083	
m _{water} (kg/s)		0.28			16.19	19679.99	0.2083	
P _{water,in} (kPa)	752.05	N/A	N/A	342.18	13.81	17973.18	0.2085	
P _{water,out} (kPa)	614.53	N/A	N/A	199.99	11.57	16471.51	0.2089	
P _{sat} (kPa)	60.22	60.17	59.72	59.57	7.48	16392.50	0.1170	
P _{bundle,in} (kPa)		60.41			6.68	16059.81	0.1153	
P _{bundle,out} (kPa)		62.13			5.83	15651.43	0.1134	
m _{ref} (kg/s)		0.24			4.98	14235.70	0.1116	
	Path B	Path C	Path D	Path E	4.19	12448.27	0.1099	
T _{water,in} (°C)	17.53	17.52	17.59	17.54	0.00	0.00	0.1010	
T _{water,out} (°C)	14.99	15.14	15.06	15.02	0.00	0.00	0.1010	
m _{water} (kg/s)	0.34	0.33	0.34	0.35	0.00	0.00	0.1010	
	Pre-boiler				0.00	0.00	0.1010	
T _{water,in} (°C)		21.55			0.00	0.00	0.1010	
T _{water,out} (°C)		20.76						
m _{water} (kg/s)		2.44						
T _{ref,in} (°C)		-1.53						
P _{ref,in} (kPa)		78.87						
P _{ref,out} (kPa)		72.46						

Point ID	R-123, P/D 1.167, 25 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.66	15.99	15.24	14.94	39.05	17308.19	0.6039	25.23
T ₁ (°C)	17.32	15.85	15.18	14.93	36.32	18142.71	0.6003	
T ₂ (°C)	17.02	15.68	15.12	14.91	33.42	19246.55	0.5970	
T ₃ (°C)	16.70	15.51	15.06	14.90	30.52	20221.85	0.5942	
T ₄ (°C)	16.42	15.41	15.02	14.89	27.79	21250.85	0.5918	
T ₅ (°C)	16.16	15.31	14.99	14.88	19.56	18310.26	0.4509	
T _{out} (°C)	15.97	15.24	14.96	14.87	17.46	18586.03	0.4507	
m _{water} (kg/s)		0.28			15.23	18848.19	0.4507	
P _{water,in} (kPa)	749.83	N/A	N/A	340.66	13.00	17109.06	0.4508	
P _{water,out} (kPa)	611.66	N/A	N/A	195.81	10.90	15591.58	0.4512	
P _{sat} (kPa)	61.01	61.06	60.63	60.46	7.82	17369.47	0.3638	
P _{bundle,in} (kPa)		61.15			6.89	16833.05	0.3619	
P _{bundle,out} (kPa)		63.12			5.90	16131.07	0.3598	
m _{ref} (kg/s)		0.24			4.92	14163.73	0.3577	
	Path B	Path C	Path D	Path E	3.99	11795.12	0.3557	
T _{water,in} (°C)	17.70	17.69	17.76	17.71	0.00	0.00	0.3472	
T _{water,out} (°C)	15.33	15.44	15.37	15.35	0.00	0.00	0.3472	
m _{water} (kg/s)	0.34	0.32	0.34	0.35	0.00	0.00	0.3472	
	Pre-boiler				0.00	0.00	0.3472	
T _{water,in} (°C)		28.59			0.00	0.00	0.3472	
T _{water,out} (°C)		26.78						
m _{water} (kg/s)		2.63						
T _{ref,in} (°C)		-6.91						
P _{ref,in} (kPa)		93.74						
P _{ref,out} (kPa)		83.11						

Point ID	R-123, P/D 1.167, 25 22 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	19.32	16.87	15.65	15.13	55.62	16139.31	0.7959	25.07
T ₁ (°C)	18.86	16.64	15.54	15.09	52.29	17112.57	0.7970	
T ₂ (°C)	18.41	16.37	15.44	15.05	48.75	18318.94	0.7991	
T ₃ (°C)	17.95	16.10	15.34	15.02	45.21	19522.42	0.8021	
T ₄ (°C)	17.54	15.93	15.26	14.98	41.88	20998.76	0.8058	
T ₅ (°C)	17.15	15.77	15.20	14.97	31.62	19692.92	0.5905	
T _{out} (°C)	16.85	15.65	15.14	14.94	28.21	20115.80	0.5852	
m _{water} (kg/s)			0.28		24.58	20572.98	0.5800	
P _{water,in} (kPa)	750.32	N/A	N/A	342.97	20.96	19114.64	0.5754	
P _{water,out} (kPa)	612.31	N/A	N/A	197.51	17.54	17487.47	0.5715	
P _{sat} (kPa)	60.99	61.06	60.69	60.58	12.95	18342.08	0.4384	
P _{bundle,in} (kPa)			61.10		11.67	18457.00	0.4398	
P _{bundle,out} (kPa)			63.27		10.32	18507.62	0.4416	
m _{ref} (kg/s)			0.24		8.97	17711.52	0.4436	
	Path B	Path C	Path D	Path E	7.69	16298.26	0.4456	
T _{water,in} (°C)	19.37	19.37	19.43	19.38	5.00	11363.24	0.3595	
T _{water,out} (°C)	15.74	15.79	15.75	15.76	4.56	11166.98	0.3586	
m _{water} (kg/s)	0.33	0.32	0.34	0.35	4.09	10786.63	0.3576	
	Pre-boiler				3.62	10241.66	0.3566	
T _{water,in} (°C)			38.67		3.18	9187.15	0.3556	
T _{water,out} (°C)			24.83					
m _{water} (kg/s)			0.34					
T _{ref,in} (°C)			-6.71					
P _{ref,in} (kPa)			93.96					
P _{ref,out} (kPa)			83.30					

Point ID	R-123, P/D 1.167, 25 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	21.26	17.90	16.15	15.38	74.00	15336.80	0.7216	24.99
T ₁ (°C)	20.64	17.56	16.00	15.34	70.34	16330.44	0.7254	
T ₂ (°C)	20.06	17.19	15.85	15.28	66.45	17808.28	0.7308	
T ₃ (°C)	19.41	16.80	15.69	15.23	62.56	19305.99	0.7378	
T ₄ (°C)	18.85	16.55	15.58	15.18	58.90	21218.62	0.7457	
T ₅ (°C)	18.32	16.33	15.49	15.15	45.08	20692.33	0.4397	
T _{out} (°C)	17.89	16.15	15.40	15.12	40.20	21136.50	0.4321	
m _{water} (kg/s)			0.28		35.02	21771.29	0.4249	
P _{water,in} (kPa)	751.60	N/A	N/A	344.62	29.84	20532.43	0.4186	
P _{water,out} (kPa)	613.60	N/A	N/A	199.29	24.96	18912.62	0.4132	
P _{sat} (kPa)	61.27	61.32	60.94	60.83	18.97	20014.21	0.2247	
P _{bundle,in} (kPa)			61.35		17.15	20611.30	0.2265	
P _{bundle,out} (kPa)			63.51		15.21	21398.76	0.2288	
m _{ref} (kg/s)			0.24		13.28	20957.91	0.2314	
	Path B	Path C	Path D	Path E	11.46	19890.64	0.2341	
T _{water,in} (°C)	21.34	21.33	21.38	21.34	6.75	12691.72	0.1105	
T _{water,out} (°C)	16.28	16.28	16.24	16.32	6.16	12587.59	0.1093	
m _{water} (kg/s)	0.34	0.33	0.34	0.35	5.54	12360.77	0.1079	
	Pre-boiler				4.91	11885.93	0.1066	
T _{water,in} (°C)			21.96		4.32	10860.92	0.1053	
T _{water,out} (°C)			21.07					
m _{water} (kg/s)			2.61					
T _{ref,in} (°C)			-9.23					
P _{ref,in} (kPa)			79.68					
P _{ref,out} (kPa)			73.46					

Point ID	R-123, P/D 1.167, 35 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.72	15.80	14.95	14.63	44.48	17694.67	0.3077	35.14
T ₁ (°C)	17.34	15.63	14.89	14.62	41.36	18645.42	0.3051	
T ₂ (°C)	16.99	15.45	14.82	14.61	38.06	19827.35	0.3027	
T ₃ (°C)	16.62	15.26	14.76	14.60	34.75	20937.07	0.3006	
T ₄ (°C)	16.30	15.15	14.72	14.59	31.64	22079.93	0.2991	
T ₅ (°C)	16.02	15.03	14.68	14.59	22.27	19673.69	0.1839	
T _{out} (°C)	15.79	14.95	14.65	14.58	19.86	19891.16	0.1836	
m _{water} (kg/s)			0.28		17.29	20303.98	0.1834	
P _{water,in} (kPa)	752.69	N/A	N/A	343.67	14.73	18560.19	0.1833	
P _{water,out} (kPa)	613.69	N/A	N/A	200.81	12.31	17020.34	0.1834	
P _{sat} (kPa)	60.27	60.26	59.80	59.60	8.09	17340.04	0.1127	
P _{bundle,in} (kPa)			60.44		7.23	17107.66	0.1114	
P _{bundle,out} (kPa)			62.19		6.32	16842.14	0.1100	
m _{ref} (kg/s)			0.34		5.40	15438.81	0.1086	
	Path B	Path C	Path D	Path E	4.54	13575.15	0.1073	
T _{water,in} (°C)	17.77	17.76	17.82	17.78	0.00	0.00	0.1004	
T _{water,out} (°C)	15.06	15.20	15.13	15.09	0.00	0.00	0.1004	
m _{water} (kg/s)	0.34	0.33	0.34	0.35	0.00	0.00	0.1004	
	Pre-boiler				0.00	0.00	0.1004	
T _{water,in} (°C)			23.27		0.00	0.00	0.1004	
T _{water,out} (°C)			22.36					
m _{water} (kg/s)			2.62					
T _{ref,in} (°C)			2.30					
P _{ref,in} (kPa)			83.93					
P _{ref,out} (kPa)			76.31					

Point ID	R-123, P/D 1.167, 35 17 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	18.47	16.44	15.52	15.12	47.10	17060.33	0.6055	35.19
T ₁ (°C)	18.08	16.27	15.44	15.11	43.91	17942.74	0.6050	
T ₂ (°C)	17.70	16.06	15.36	15.08	40.53	19110.69	0.6049	
T ₃ (°C)	17.31	15.84	15.28	15.06	37.14	20162.70	0.6054	
T ₄ (°C)	16.97	15.73	15.23	15.03	33.96	21354.43	0.6065	
T ₅ (°C)	16.66	15.60	15.19	15.02	24.28	18979.87	0.4822	
T _{out} (°C)	16.42	15.51	15.15	15.00	21.63	19291.92	0.4794	
m _{water} (kg/s)			0.28		18.82	19609.81	0.4769	
P _{water,in} (kPa)	748.79	N/A	N/A	340.02	16.02	17907.12	0.4747	
P _{water,out} (kPa)	610.44	N/A	N/A	193.02	13.37	16277.85	0.4729	
P _{sat} (kPa)	61.29	61.35	60.91	60.71	9.77	17904.75	0.3972	
P _{bundle,in} (kPa)			61.42		8.68	17686.29	0.3977	
P _{bundle,out} (kPa)			63.40		7.53	17358.13	0.3984	
m _{ref} (kg/s)			0.34		6.38	15706.43	0.3991	
	Path B	Path C	Path D	Path E	5.29	13634.84	0.4000	
T _{water,in} (°C)	18.53	18.52	18.58	18.54	3.20	8720.13	0.3509	
T _{water,out} (°C)	15.58	15.69	15.63	15.61	3.01	8689.17	0.3506	
m _{water} (kg/s)	0.34	0.32	0.34	0.35	2.80	8595.50	0.3503	
	Pre-boiler				2.59	8500.53	0.3500	
T _{water,in} (°C)			34.62		2.39	7979.96	0.3497	
T _{water,out} (°C)			32.12					
m _{water} (kg/s)			2.65					
T _{ref,in} (°C)			-7.05					
P _{ref,in} (kPa)			113.38					
P _{ref,out} (kPa)			99.03					

Point ID	R-123, P/D 1.167, 35 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	20.92	17.35	15.63	14.86	81.48	16857.37	0.5672	34.77
T ₁ (°C)	20.23	17.01	15.48	14.82	76.16	17798.34	0.5675	
T ₂ (°C)	19.58	16.65	15.33	14.77	70.51	19012.79	0.5689	
T ₃ (°C)	18.90	16.26	15.17	14.71	64.86	20166.83	0.5715	
T ₄ (°C)	18.31	16.02	15.06	14.67	59.54	21503.26	0.5750	
T ₅ (°C)	17.77	15.80	14.97	14.65	44.40	20534.66	0.3476	
T _{out} (°C)	17.33	15.62	14.88	14.62	39.61	20951.37	0.3423	
m _{water} (kg/s)			0.28		34.52	21570.83	0.3372	
P _{water,in} (kPa)	750.27	N/A	N/A	344.31	29.43	20299.76	0.3327	
P _{water,out} (kPa)	613.88	N/A	N/A	198.09	24.64	18682.88	0.3290	
P _{sat} (kPa)	60.04	60.09	59.67	59.47	18.68	20008.22	0.1895	
P _{bundle,in} (kPa)			60.14		16.90	20631.43	0.1911	
P _{bundle,out} (kPa)			62.18		15.02	21464.28	0.1930	
m _{ref} (kg/s)			0.33		13.13	21070.05	0.1951	
	Path B	Path C	Path D	Path E	11.35	20055.13	0.1974	
T _{water,in} (°C)	20.99	20.98	21.04	20.99	6.56	12454.47	0.1056	
T _{water,out} (°C)	15.69	15.80	15.76	15.72	5.96	12237.00	0.1047	
m _{water} (kg/s)	0.34	0.33	0.34	0.35	5.31	11859.24	0.1037	
	Pre-boiler				4.67	11226.02	0.1027	
T _{water,in} (°C)			23.07		4.06	10069.92	0.1018	
T _{water,out} (°C)			22.07					
m _{water} (kg/s)			2.62					
T _{ref,in} (°C)			-1.89					
P _{ref,in} (kPa)			83.16					
P _{ref,out} (kPa)			75.59					

Point ID	R-123, P/D 1.167, 35 30 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	21.01	18.25	16.29	15.38	55.09	10536.81	0.7754	34.96
T ₁ (°C)	20.56	17.88	16.10	15.32	54.55	11410.66	0.7826	
T ₂ (°C)	20.10	17.46	15.93	15.24	53.97	12733.75	0.7912	
T ₃ (°C)	19.55	17.02	15.74	15.17	53.39	13784.06	0.8007	
T ₄ (°C)	19.17	16.74	15.60	15.11	52.85	15459.56	0.8107	
T ₅ (°C)	18.71	16.49	15.50	15.07	50.23	19962.98	0.6111	
T _{out} (°C)	18.23	16.29	15.40	15.02	44.95	20405.33	0.6053	
m _{water} (kg/s)			0.28		39.33	21089.17	0.5996	
P _{water,in} (kPa)	748.34	N/A	N/A	340.09	33.72	19978.65	0.5944	
P _{water,out} (kPa)	610.29	N/A	N/A	194.80	28.44	18572.92	0.5901	
P _{sat} (kPa)	60.99	61.09	60.66	60.48	22.52	20999.23	0.4550	
P _{bundle,in} (kPa)			61.09		20.24	21485.27	0.4555	
P _{bundle,out} (kPa)			63.18		17.81	22155.01	0.4562	
m _{ref} (kg/s)			0.33		15.39	21706.11	0.4571	
	Path B	Path C	Path D	Path E	13.11	20230.81	0.4582	
T _{water,in} (°C)	21.07	21.07	21.14	21.09	9.09	15599.64	0.3689	
T _{water,out} (°C)	16.22	16.14	16.13	16.30	8.32	15886.67	0.3677	
m _{water} (kg/s)	0.33	0.32	0.34	0.35	7.50	15960.85	0.3665	
	Pre-boiler				6.68	15911.26	0.3652	
T _{water,in} (°C)			34.73		5.90	15012.91	0.3640	
T _{water,out} (°C)			32.22					
m _{water} (kg/s)			2.65					
T _{ref,in} (°C)			-6.21					
P _{ref,in} (kPa)			113.46					
P _{ref,out} (kPa)			99.20					

Point ID	R-123, P/D 1.167, 35 45 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	24.30	23.36	18.98	16.40	18.66	1919.99	0.6916	34.78
T ₁ (°C)	24.09	22.48	18.51	16.17	18.18	1898.89	0.7050	
T ₂ (°C)	23.93	21.65	18.02	15.94	17.66	1867.41	0.7204	
T ₃ (°C)	23.81	20.71	17.48	15.71	17.15	1833.76	0.7370	
T ₄ (°C)	23.69	20.07	17.07	15.51	16.66	1812.89	0.7537	
T ₅ (°C)	23.53	19.48	16.72	15.36	106.55	16366.09	0.5735	
T _{out} (°C)	23.36	18.99	16.42	15.25	96.55	16494.93	0.5608	
m _{water} (kg/s)			0.28		85.93	16830.68	0.5479	
P _{water,in} (kPa)	747.71	N/A	N/A	342.69	75.31	16210.58	0.5356	
P _{water,out} (kPa)	611.74	N/A	N/A	196.74	65.31	15440.81	0.5248	
P _{sat} (kPa)	60.29	60.36	59.92	59.78	60.68	19663.28	0.3003	
P _{bundle,in} (kPa)			60.38		55.96	20848.79	0.3007	
P _{bundle,out} (kPa)			62.48		50.96	22741.62	0.3014	
m _{ref} (kg/s)			0.33		45.95	23934.24	0.3023	
	Path B	Path C	Path D	Path E	41.24	24900.90	0.3035	
T _{water,in} (°C)	24.39	24.40	24.44	24.40	29.22	21741.54	0.1402	
T _{water,out} (°C)	17.41	16.90	17.12	17.63	26.31	22614.06	0.1357	
m _{water} (kg/s)	0.34	0.32	0.34	0.35	23.21	23362.35	0.1309	
	Pre-boiler				20.12	23616.21	0.1261	
T _{water,in} (°C)			29.13		17.20	22531.92	0.1217	
T _{water,out} (°C)			22.11					
m _{water} (kg/s)			0.41					
T _{ref,in} (°C)			-5.69					
P _{ref,in} (kPa)			82.79					
P _{ref,out} (kPa)			76.00					

Point ID	R-123, P/D 1.167, 45 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.23	15.51	14.76	14.49	40.23	17801.13	0.2502	44.74
T ₁ (°C)	16.89	15.36	14.71	14.49	37.39	18748.17	0.2483	
T ₂ (°C)	16.57	15.20	14.66	14.48	34.38	19935.97	0.2466	
T ₃ (°C)	16.25	15.03	14.60	14.48	31.36	21037.64	0.2451	
T ₄ (°C)	15.96	14.93	14.57	14.47	28.53	22144.98	0.2439	
T ₅ (°C)	15.70	14.83	14.54	14.47	19.79	19550.28	0.1627	
T _{out} (°C)	15.50	14.76	14.51	14.46	17.59	19740.11	0.1623	
m _{water} (kg/s)			0.28		15.27	19980.93	0.1620	
P _{water,in} (kPa)	750.79	N/A	N/A	341.45	12.94	18072.08	0.1619	
P _{water,out} (kPa)	612.62	N/A	N/A	197.48	10.75	16384.87	0.1618	
P _{sat} (kPa)	60.02	60.00	59.55	59.32	6.68	15682.89	0.1116	
P _{bundle,in} (kPa)			60.16		5.96	15238.30	0.1107	
P _{bundle,out} (kPa)			61.93		5.20	14729.12	0.1098	
m _{ref} (kg/s)			0.43		4.43	13283.92	0.1089	
	Path B	Path C	Path D	Path E	3.71	11508.95	0.1080	
T _{water,in} (°C)	17.27	17.26	17.33	17.28	0.00	0.00	0.1036	
T _{water,out} (°C)	14.87	15.00	14.93	14.89	0.00	0.00	0.1036	
m _{water} (kg/s)	0.34	0.33	0.34	0.35	0.00	0.00	0.1036	
	Pre-boiler				0.00	0.00	0.1036	
T _{water,in} (°C)			25.82		0.00	0.00	0.1036	
T _{water,out} (°C)			24.00					
m _{water} (kg/s)			1.72					
T _{ref,in} (°C)			1.92					
P _{ref,in} (kPa)			90.67					
P _{ref,out} (kPa)			81.39					

Point ID	R-123, P/D 1.167, 45 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	18.09	16.29	15.47	15.13	41.90	16907.86	0.5260	44.69
T ₁ (°C)	17.74	16.14	15.40	15.11	39.06	17828.75	0.5255	
T ₂ (°C)	17.40	15.95	15.33	15.09	36.05	18850.66	0.5254	
T ₃ (°C)	17.07	15.77	15.27	15.07	33.03	19821.68	0.5257	
T ₄ (°C)	16.76	15.66	15.22	15.05	30.19	20964.40	0.5263	
T ₅ (°C)	16.49	15.55	15.19	15.05	21.40	18346.45	0.4397	
T _{out} (°C)	16.27	15.47	15.15	15.03	19.13	18698.33	0.4379	
m _{water} (kg/s)			0.28		16.72	18975.48	0.4361	
P _{water,in} (kPa)	750.86	N/A	N/A	342.86	14.31	17368.12	0.4346	
P _{water,out} (kPa)	612.22	N/A	N/A	196.62	12.03	15938.16	0.4333	
P _{sat} (kPa)	61.36	61.44	61.00	60.80	8.59	17597.29	0.3801	
P _{bundle,in} (kPa)			61.49		7.66	17335.21	0.3804	
P _{bundle,out} (kPa)			63.51		6.66	16763.68	0.3808	
m _{ref} (kg/s)			0.43		5.66	15389.32	0.3814	
	Path B	Path C	Path D	Path E	4.72	13329.50	0.3820	
T _{water,in} (°C)	18.13	18.13	18.20	18.15	2.75	7848.34	0.3470	
T _{water,out} (°C)	15.52	15.64	15.58	15.56	2.54	7640.60	0.3468	
m _{water} (kg/s)	0.33	0.32	0.34	0.35	2.32	7304.36	0.3465	
	Pre-boiler				2.10	6928.89	0.3462	
T _{water,in} (°C)			40.04		1.89	6248.20	0.3460	
T _{water,out} (°C)			36.91					
m _{water} (kg/s)			2.66					
T _{ref,in} (°C)			-6.59					
P _{ref,in} (kPa)			129.63					
P _{ref,out} (kPa)			115.93					

Point ID	R-123, P/D 1.167, 45 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	21.28	17.79	16.11	15.37	79.72	16926.65	0.4483	44.88
T ₁ (°C)	20.59	17.46	15.97	15.33	74.47	17845.85	0.4485	
T ₂ (°C)	19.96	17.11	15.83	15.28	68.90	19076.06	0.4495	
T ₃ (°C)	19.30	16.73	15.67	15.24	63.33	20224.01	0.4514	
T ₄ (°C)	18.72	16.49	15.56	15.20	58.08	21570.34	0.4540	
T ₅ (°C)	18.19	16.28	15.47	15.17	43.06	20524.32	0.2822	
T _{out} (°C)	17.77	16.11	15.39	15.15	38.43	20964.93	0.2783	
m _{water} (kg/s)			0.28		33.51	21612.14	0.2745	
P _{water,in} (kPa)	750.66	N/A	N/A	343.10	28.59	20362.87	0.2713	
P _{water,out} (kPa)	612.67	N/A	N/A	199.66	23.96	18795.91	0.2686	
P _{sat} (kPa)	61.37	61.42	60.98	60.74	18.19	20527.71	0.1641	
P _{bundle,in} (kPa)			61.48		16.46	21243.87	0.1652	
P _{bundle,out} (kPa)			63.43		14.61	22224.15	0.1665	
m _{ref} (kg/s)			0.43		12.77	21947.04	0.1681	
	Path B	Path C	Path D	Path E	11.04	20950.23	0.1698	
T _{water,in} (°C)	21.35	21.35	21.40	21.36	6.10	12154.00	0.1010	
T _{water,out} (°C)	16.19	16.30	16.26	16.22	5.52	11888.74	0.1003	
m _{water} (kg/s)	0.34	0.33	0.34	0.35	4.90	11427.98	0.0996	
	Pre-boiler				4.28	10712.71	0.0989	
T _{water,in} (°C)			25.82		3.70	9494.79	0.0982	
T _{water,out} (°C)			23.85					
m _{water} (kg/s)			1.72					
T _{ref,in} (°C)			-1.75					
P _{ref,in} (kPa)			90.06					
P _{ref,out} (kPa)			81.46					

Point ID	R-123, P/D 1.167, 45 30 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	20.64	17.48	15.80	15.04	69.24	14643.46	0.6775	44.96
T ₁ (°C)	20.03	17.16	15.64	14.98	65.80	15468.58	0.6797	
T ₂ (°C)	19.50	16.80	15.50	14.92	62.14	16723.91	0.6828	
T ₃ (°C)	18.89	16.42	15.34	14.86	58.49	17834.34	0.6867	
T ₄ (°C)	18.39	16.18	15.23	14.81	55.05	19401.47	0.6912	
T ₅ (°C)	17.89	15.96	15.14	14.78	43.58	20026.44	0.5302	
T _{out} (°C)	17.47	15.79	15.05	14.75	38.87	20418.90	0.5259	
m _{water} (kg/s)			0.28		33.86	20916.07	0.5219	
P _{water,in} (kPa)	750.68	N/A	N/A	344.02	28.85	19557.52	0.5183	
P _{water,out} (kPa)	613.86	N/A	N/A	199.02	24.13	17914.81	0.5153	
P _{sat} (kPa)	60.36	60.45	60.03	59.78	18.62	19719.17	0.4147	
P _{bundle,in} (kPa)			60.46		16.82	20127.28	0.4157	
P _{bundle,out} (kPa)			62.54		14.90	20658.60	0.4170	
m _{ref} (kg/s)			0.43		12.98	20166.07	0.4185	
	Path B	Path C	Path D	Path E	11.17	18964.15	0.4200	
T _{water,in} (°C)	20.69	20.69	20.76	20.72	7.70	14281.65	0.3542	
T _{water,out} (°C)	15.75	15.83	15.83	15.82	6.94	14138.83	0.3533	
m _{water} (kg/s)	0.33	0.32	0.34	0.35	6.13	13623.61	0.3523	
	Pre-boiler				5.32	12869.58	0.3513	
T _{water,in} (°C)			39.94		4.55	11419.49	0.3504	
T _{water,out} (°C)			36.86					
m _{water} (kg/s)			2.66					
T _{ref,in} (°C)			-4.99					
P _{ref,in} (kPa)			129.57					
P _{ref,out} (kPa)			115.74					

Point ID	R-123, P/D 1.167, 45 35 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	22.87	22.36	19.05	16.72	9.61	1196.65	0.7293	44.81
T ₁ (°C)	22.78	21.65	18.57	16.52	9.68	1218.14	0.7368	
T ₂ (°C)	22.70	21.02	18.15	16.31	9.75	1238.69	0.7456	
T ₃ (°C)	22.62	20.37	17.67	16.11	9.83	1259.15	0.7552	
T ₄ (°C)	22.55	19.92	17.31	15.93	9.89	1280.16	0.7649	
T ₅ (°C)	22.48	19.46	17.01	15.80	79.10	14126.25	0.6512	
T _{out} (°C)	22.37	19.03	16.74	15.70	72.12	14165.56	0.6455	
m _{water} (kg/s)			0.28		64.69	14144.52	0.6397	
P _{water,in} (kPa)	754.21	N/A	N/A	347.54	57.27	13464.84	0.6344	
P _{water,out} (kPa)	616.69	N/A	N/A	204.47	50.28	12855.84	0.6299	
P _{sat} (kPa)	61.58	61.68	61.27	61.07	55.91	20723.12	0.4951	
P _{bundle,in} (kPa)			61.70		50.91	21459.48	0.4941	
P _{bundle,out} (kPa)			63.88		45.59	22862.49	0.4933	
m _{ref} (kg/s)			0.43		40.28	23315.02	0.4926	
	Path B	Path C	Path D	Path E	35.28	23195.14	0.4922	
T _{water,in} (°C)	22.94	22.95	23.00	22.94	25.95	21072.23	0.3899	
T _{water,out} (°C)	17.04	16.75	17.08	17.32	23.37	21896.07	0.3868	
m _{water} (kg/s)	0.33	0.32	0.34	0.35	20.64	22405.57	0.3835	
	Pre-boiler				17.90	22536.82	0.3803	
T _{water,in} (°C)			40.88		15.33	21441.00	0.3772	
T _{water,out} (°C)			37.68					
m _{water} (kg/s)			2.66					
T _{ref,in} (°C)			-5.69					
P _{ref,in} (kPa)			129.60					
P _{ref,out} (kPa)			118.40					

Point ID	R-123, P/D 1.167, 45 40 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	29.88	29.78	29.64	28.04	1.92	128.34	0.8076	44.45
T ₁ (°C)	29.85	29.77	29.16	26.80	1.92	128.36	0.8113	
T ₂ (°C)	29.85	29.71	28.64	25.60	1.92	128.45	0.8153	
T ₃ (°C)	29.84	29.68	28.49	24.54	1.92	128.51	0.8195	
T ₄ (°C)	29.83	29.66	28.44	23.44	1.92	128.65	0.8237	
T ₅ (°C)	29.82	29.62	28.32	22.49	4.44	300.69	0.6956	
T _{out} (°C)	29.79	29.60	28.07	21.82	4.25	288.44	0.6940	
m _{water} (kg/s)		0.28			4.04	274.92	0.6926	
P _{water,in} (kPa)	752.39	N/A	N/A	344.79	3.83	261.19	0.6911	
P _{water,out} (kPa)	614.52	N/A	N/A	200.18	3.64	248.45	0.6899	
P _{sat} (kPa)	62.17	62.29	61.91	61.74	46.30	3459.60	0.5924	
P _{bundle,in} (kPa)		62.24			37.38	2875.57	0.5922	
P _{bundle,out} (kPa)		64.52			27.90	2147.49	0.5920	
m _{ref} (kg/s)		0.42			18.42	1407.46	0.5918	
	Path B	Path C	Path D	Path E	9.50	725.26	0.5917	
T _{water,in} (°C)	30.02	30.06	30.07	30.03	145.46	15444.27	0.5410	
T _{water,out} (°C)	24.99	21.86	23.46	25.07	134.77	16059.93	0.5281	
m _{water} (kg/s)	0.33	0.32	0.34	0.35	123.40	16415.23	0.5143	
	Pre-boiler				112.04	16981.47	0.5006	
T _{water,in} (°C)		40.93			101.35	17408.61	0.4877	
T _{water,out} (°C)		37.79						
m _{water} (kg/s)		2.67						
T _{ref,in} (°C)		-3.46						
P _{ref,in} (kPa)		129.82						
P _{ref,out} (kPa)		118.82						

Point ID	R-123, P/D 1.167, 45 45 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	24.76	20.14	17.19	15.74	92.66	11497.60	0.6181	44.68
T ₁ (°C)	23.91	19.57	16.91	15.63	91.54	12363.82	0.6274	
T ₂ (°C)	23.24	18.95	16.63	15.51	90.35	13800.36	0.6385	
T ₃ (°C)	22.36	18.31	16.33	15.39	89.16	15329.56	0.6511	
T ₄ (°C)	21.61	17.87	16.11	15.29	88.03	17463.17	0.6641	
T ₅ (°C)	20.82	17.49	15.92	15.23	74.61	19507.22	0.4027	
T _{out} (°C)	20.12	17.19	15.75	15.17	66.86	19938.81	0.3957	
m _{water} (kg/s)		0.28			58.63	20521.95	0.3890	
P _{water,in} (kPa)	750.47	N/A	N/A	345.40	50.39	19594.62	0.3830	
P _{water,out} (kPa)	613.46	N/A	N/A	199.32	42.64	18292.81	0.3780	
P _{sat} (kPa)	60.95	61.04	60.58	60.34	34.86	20757.41	0.2117	
P _{bundle,in} (kPa)		61.01			31.81	21807.85	0.2135	
P _{bundle,out} (kPa)		63.08			28.58	23433.58	0.2157	
m _{ref} (kg/s)		0.43			25.35	23993.85	0.2182	
	Path B	Path C	Path D	Path E	22.30	24055.74	0.2208	
T _{water,in} (°C)	24.87	24.87	24.91	24.87	14.87	18558.62	0.1104	
T _{water,out} (°C)	16.91	16.91	16.92	16.97	13.34	18763.59	0.1086	
m _{water} (kg/s)	0.34	0.33	0.34	0.35	11.73	18711.49	0.1067	
	Pre-boiler				10.11	18136.29	0.1047	
T _{water,in} (°C)		33.26			8.59	16450.22	0.1029	
T _{water,out} (°C)		21.43						
m _{water} (kg/s)		0.31						
T _{ref,in} (°C)		-4.67						
P _{ref,in} (kPa)		90.66						
P _{ref,out} (kPa)		81.62						

Point ID	R-123, P/D 1.167, 55 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.51	15.73	14.95	14.68	41.52	17837.71	0.2104	55.05
T ₁ (°C)	17.16	15.58	14.90	14.67	38.63	18823.62	0.2089	
T ₂ (°C)	16.83	15.41	14.85	14.67	35.57	20078.79	0.2076	
T ₃ (°C)	16.49	15.23	14.79	14.66	32.51	21267.16	0.2065	
T ₄ (°C)	16.19	15.13	14.76	14.65	29.63	22514.85	0.2056	
T ₅ (°C)	15.93	15.03	14.73	14.65	20.52	20062.08	0.1375	
T _{out} (°C)	15.72	14.95	14.70	14.64	18.23	20312.08	0.1372	
m _{water} (kg/s)			0.28		15.81	20613.25	0.1370	
P _{water,in} (kPa)	752.05	N/A	N/A	344.16	13.38	18677.97	0.1368	
P _{water,out} (kPa)	614.13	N/A	N/A	200.95	11.09	16938.96	0.1368	
P _{sat} (kPa)	60.49	60.46	60.01	59.75	6.87	16250.36	0.0953	
P _{bundle,in} (kPa)			60.64		6.13	15863.79	0.0946	
P _{bundle,out} (kPa)			62.38		5.35	15438.83	0.0938	
m _{ref} (kg/s)			0.53		4.56	13967.84	0.0930	
	Path B	Path C	Path D	Path E	3.83	12140.02	0.0923	
T _{water,in} (°C)	17.56	17.55	17.62	17.57	0.00	0.00	0.0886	
T _{water,out} (°C)	15.07	15.20	15.13	15.09	0.00	0.00	0.0886	
m _{water} (kg/s)	0.34	0.33	0.34	0.35	0.00	0.00	0.0886	
	Pre-boiler				0.00	0.00	0.0886	
T _{water,in} (°C)			26.58		0.00	0.00	0.0886	
T _{water,out} (°C)			25.22					
m _{water} (kg/s)			2.63					
T _{ref,in} (°C)			1.70					
P _{ref,in} (kPa)			95.41					
P _{ref,out} (kPa)			85.67					

Point ID	R-123, P/D 1.167, 55 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	20.92	17.45	15.81	15.09	79.56	17191.04	0.3788	54.77
T ₁ (°C)	20.24	17.13	15.67	15.04	74.21	18173.62	0.3788	
T ₂ (°C)	19.60	16.78	15.53	15.00	68.54	19376.89	0.3795	
T ₃ (°C)	18.96	16.42	15.38	14.96	62.86	20519.06	0.3809	
T ₄ (°C)	18.38	16.19	15.27	14.92	57.52	21848.93	0.3829	
T ₅ (°C)	17.85	15.97	15.19	14.90	42.12	20614.38	0.2432	
T _{out} (°C)	17.43	15.81	15.11	14.88	37.63	21144.60	0.2402	
m _{water} (kg/s)			0.28		32.87	21799.85	0.2373	
P _{water,in} (kPa)	751.99	N/A	N/A	344.52	28.10	20559.63	0.2348	
P _{water,out} (kPa)	613.88	N/A	N/A	199.56	23.61	19124.71	0.2328	
P _{sat} (kPa)	60.80	60.82	60.36	60.11	17.81	21064.93	0.1489	
P _{bundle,in} (kPa)			60.89		16.04	21712.75	0.1499	
P _{bundle,out} (kPa)			62.77		14.15	22632.89	0.1510	
m _{ref} (kg/s)			0.52		12.27	22083.61	0.1523	
	Path B	Path C	Path D	Path E	10.49	20679.25	0.1537	
T _{water,in} (°C)	20.99	20.99	21.05	21.00	5.73	12366.18	0.0999	
T _{water,out} (°C)	15.87	16.02	15.95	15.90	5.17	11905.62	0.0993	
m _{water} (kg/s)	0.34	0.34	0.34	0.35	4.57	11376.73	0.0987	
	Pre-boiler				3.97	10599.71	0.0982	
T _{water,in} (°C)			28.51		3.41	9284.78	0.0976	
T _{water,out} (°C)			24.82					
m _{water} (kg/s)			1.29					
T _{ref,in} (°C)			-7.16					
P _{ref,in} (kPa)			96.45					
P _{ref,out} (kPa)			86.46					

Point ID	R-123, P/D 1.167, 55 38 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	22.87	18.50	16.34	15.35	98.53	16263.09	0.4670	
T ₁ (°C)	22.02	18.08	16.15	15.28	92.42	17134.65	0.4679	
T ₂ (°C)	21.25	17.63	15.96	15.20	85.93	18370.60	0.4697	
T ₃ (°C)	20.42	17.16	15.75	15.13	79.44	19515.43	0.4725	
T ₄ (°C)	19.70	16.84	15.60	15.07	73.33	20930.97	0.4760	
T ₅ (°C)	19.02	16.56	15.48	15.04	55.02	20279.71	0.2963	
T _{out} (°C)	18.49	16.34	15.36	15.00	49.23	20770.66	0.2921	
m _{water} (kg/s)			0.28		43.08	21461.22	0.2882	
P _{water,in} (kPa)	748.71	N/A	N/A	341.02	36.92	20430.02	0.2849	
P _{water,out} (kPa)	614.13	N/A	N/A	199.02	31.13	19033.79	0.2822	
P _{sat} (kPa)	60.88	60.93	60.47	60.20	24.30	21073.84	0.1725	54.84
P _{bundle,in} (kPa)			60.95		22.07	22011.99	0.1738	
P _{bundle,out} (kPa)			62.90		19.70	23405.58	0.1754	
m _{ref} (kg/s)			0.52		17.33	23587.38	0.1773	
	Path B	Path C	Path D	Path E	15.10	23107.93	0.1792	
T _{water,in} (°C)	22.95	22.96	23.01	22.96	9.18	15600.22	0.1073	
T _{water,out} (°C)	16.32	16.43	16.43	16.38	8.27	15486.96	0.1064	
m _{water} (kg/s)	0.34	0.33	0.34	0.35	7.29	15151.25	0.1055	
	Pre-boiler				6.32	14438.78	0.1045	
T _{water,in} (°C)			27.75		5.41	12883.40	0.1036	
T _{water,out} (°C)			25.98					
m _{water} (kg/s)			2.63					
T _{ref,in} (°C)			-5.51					
P _{ref,in} (kPa)			97.55					
P _{ref,out} (kPa)			87.51					

Point ID	R-123, P/D 1.33, 15 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.97	15.90	15.11	14.87	49.43	20005.92	0.3469	
T ₁ (°C)	17.58	15.74	15.08	14.87	44.83	21183.81	0.3412	
T ₂ (°C)	17.14	15.56	15.03	14.87	39.95	22386.08	0.3357	
T ₃ (°C)	16.72	15.41	14.98	14.87	35.06	22366.23	0.3307	
T ₄ (°C)	16.41	15.31	14.94	14.87	30.47	22184.90	0.3264	
T ₅ (°C)	16.13	15.19	14.93	14.87	19.42	18880.22	0.1935	
T _{out} (°C)	15.89	15.12	14.90	14.86	17.33	19509.40	0.1933	
m _{water} (kg/s)			0.27		15.12	19327.45	0.1932	
P _{water,in} (kPa)	736.28	N/A	N/A	337.93	12.90	17764.75	0.1934	
P _{water,out} (kPa)	601.83	N/A	N/A	190.48	10.81	16734.18	0.1937	
P _{sat} (kPa)	61.22	60.84	60.45	60.07	5.51	11530.51	0.1149	15.07
P _{bundle,in} (kPa)			60.73		5.01	11437.78	0.1140	
P _{bundle,out} (kPa)			60.33		4.47	11240.08	0.1130	
m _{ref} (kg/s)			0.28		3.94	10513.90	0.1121	
	Path B	Path C	Path D	Path E	3.43	9350.68	0.1112	
T _{water,in} (°C)	18.01	17.99	18.07	18.01	0.00	0.00	0.1050	
T _{water,out} (°C)	15.26	15.34	15.31	15.26	0.00	0.00	0.1050	
m _{water} (kg/s)	0.32	0.31	0.32	0.32	0.00	0.00	0.1050	
	Pre-boiler				0.00	0.00	0.1050	
T _{water,in} (°C)			27.77		0.00	0.00	0.1050	
T _{water,out} (°C)			20.14					
m _{water} (kg/s)			0.36					
T _{ref,in} (°C)			-7.37					
P _{ref,in} (kPa)			83.09					
P _{ref,out} (kPa)			78.93					

Point ID	R-123, P/D 1.33, 15 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.69	15.77	15.04	14.79	45.79	19972.12	0.5864	14.66
T ₁ (°C)	17.33	15.63	15.01	14.80	41.47	21114.16	0.5807	
T ₂ (°C)	16.92	15.47	14.96	14.79	36.88	22198.74	0.5750	
T ₃ (°C)	16.53	15.33	14.90	14.79	32.29	22068.51	0.5698	
T ₄ (°C)	16.24	15.24	14.87	14.78	27.97	21731.02	0.5654	
T ₅ (°C)	15.98	15.12	14.85	14.79	17.91	18300.19	0.4379	
T _{out} (°C)	15.77	15.05	14.82	14.78	16.03	18896.20	0.4379	
m _{water} (kg/s)			0.27		14.03	18753.07	0.4382	
P _{water,in} (kPa)	736.37	N/A	N/A	338.02	12.04	17263.16	0.4387	
P _{water,out} (kPa)	602.74	N/A	N/A	190.90	10.16	16362.39	0.4393	
P _{sat} (kPa)	61.00	60.70	60.38	60.05	5.91	12899.30	0.3633	
P _{bundle,in} (kPa)			60.36		5.34	12871.49	0.3623	
P _{bundle,out} (kPa)			60.34		4.73	12665.03	0.3611	
m _{ref} (kg/s)			0.28		4.12	11717.28	0.3600	
	Path B	Path C	Path D	Path E	3.55	10391.07	0.3590	
T _{water,in} (°C)	17.73	17.71	17.79	17.71	0.00	0.00	0.3524	
T _{water,out} (°C)	15.16	15.22	15.18	15.16	0.00	0.00	0.3524	
m _{water} (kg/s)	0.32	0.31	0.32	0.32	0.00	0.00	0.3524	
	Pre-boiler				0.00	0.00	0.3524	
T _{water,in} (°C)			31.17		0.00	0.00	0.3524	
T _{water,out} (°C)			28.66					
m _{water} (kg/s)			2.18					
T _{ref,in} (°C)			-6.74					
P _{ref,in} (kPa)			101.70					
P _{ref,out} (kPa)			92.64					

Point ID	R-123, P/D 1.33, 15 25 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	20.74	17.53	16.17	15.63	74.77	19041.29	0.7942	15.02
T ₁ (°C)	20.16	17.26	16.08	15.61	68.39	20266.86	0.7906	
T ₂ (°C)	19.49	16.96	15.97	15.58	61.60	21674.88	0.7880	
T ₃ (°C)	18.84	16.70	15.86	15.55	54.81	22217.50	0.7867	
T ₄ (°C)	18.34	16.51	15.78	15.52	48.43	22509.95	0.7867	
T ₅ (°C)	17.91	16.31	15.72	15.51	33.30	20404.85	0.5675	
T _{out} (°C)	17.53	16.18	15.66	15.49	29.76	21259.61	0.5631	
m _{water} (kg/s)			0.27		26.01	21498.31	0.5591	
P _{water,in} (kPa)	736.72	N/A	N/A	338.33	22.25	20247.21	0.5558	
P _{water,out} (kPa)	602.28	N/A	N/A	191.62	18.72	19469.33	0.5534	
P _{sat} (kPa)	62.58	62.34	62.07	61.80	12.75	17400.89	0.4249	
P _{bundle,in} (kPa)			61.89		11.55	17948.83	0.4265	
P _{bundle,out} (kPa)			62.16		10.28	18498.16	0.4285	
m _{ref} (kg/s)			0.28		9.01	18029.03	0.4307	
	Path B	Path C	Path D	Path E	7.81	16867.03	0.4331	
T _{water,in} (°C)	20.80	20.80	20.87	20.79	3.81	11277.48	0.3519	
T _{water,out} (°C)	16.25	16.29	16.25	16.28	3.50	11193.45	0.3514	
m _{water} (kg/s)	0.32	0.31	0.32	0.32	3.17	10976.78	0.3508	
	Pre-boiler				2.84	10668.71	0.3502	
T _{water,in} (°C)			31.34		2.53	9621.38	0.3496	
T _{water,out} (°C)			29.26					
m _{water} (kg/s)			2.64					
T _{ref,in} (°C)			-5.87					
P _{ref,in} (kPa)			103.53					
P _{ref,out} (kPa)			94.50					

Point ID	R-123, P/D 1.33, 15 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	21.55	17.66	15.96	15.27	90.05	18676.67	0.6607	14.88
T ₁ (°C)	20.83	17.30	15.84	15.24	82.48	19817.36	0.6568	
T ₂ (°C)	20.04	16.94	15.70	15.20	74.44	21136.22	0.6542	
T ₃ (°C)	19.25	16.62	15.55	15.16	66.40	21700.17	0.6533	
T ₄ (°C)	18.65	16.39	15.45	15.13	58.84	22024.46	0.6539	
T ₅ (°C)	18.12	16.13	15.37	15.12	41.21	20460.15	0.3832	
T _{out} (°C)	17.65	15.97	15.29	15.09	36.89	21311.56	0.3779	
m _{water} (kg/s)			0.27		32.30	21588.33	0.3730	
P _{water,in} (kPa)	739.93	N/A	N/A	341.31	27.71	20419.98	0.3690	
P _{water,out} (kPa)	604.83	N/A	N/A	193.42	23.39	19852.54	0.3661	
P _{sat} (kPa)	61.48	61.17	60.87	60.61	16.34	18249.06	0.2070	
P _{bundle,in} (kPa)			60.85		14.80	18907.17	0.2091	
P _{bundle,out} (kPa)			60.95		13.16	19627.10	0.2116	
m _{ref} (kg/s)			0.28		11.52	19434.45	0.2145	
	Path B	Path C	Path D	Path E	9.98	18317.42	0.2175	
T _{water,in} (°C)	21.60	21.60	21.67	21.60	4.68	11949.99	0.1175	
T _{water,out} (°C)	16.02	16.09	16.04	16.03	4.27	11850.28	0.1168	
m _{water} (kg/s)	0.32	0.32	0.32	0.32	3.83	11590.49	0.1160	
	Pre-boiler				3.39	11127.46	0.1152	
T _{water,in} (°C)			22.84		2.98	9960.47	0.1144	
T _{water,out} (°C)			21.60					
m _{water} (kg/s)			2.16					
T _{ref,in} (°C)			-6.48					
P _{ref,in} (kPa)			82.80					
P _{ref,out} (kPa)			78.82					

Point ID	R-123, P/D 1.33, 20 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.81	15.78	15.01	14.78	48.40	20118.99	0.2803	19.96
T ₁ (°C)	17.42	15.62	14.98	14.78	43.89	21309.35	0.2761	
T ₂ (°C)	16.99	15.45	14.93	14.78	39.10	22505.06	0.2721	
T ₃ (°C)	16.58	15.30	14.88	14.78	34.30	22529.74	0.2683	
T ₄ (°C)	16.28	15.21	14.85	14.78	29.79	22319.75	0.2651	
T ₅ (°C)	16.00	15.09	14.83	14.78	18.99	19168.56	0.1672	
T _{out} (°C)	15.77	15.02	14.80	14.78	16.95	19817.68	0.1671	
m _{water} (kg/s)			0.27		14.79	19682.65	0.1671	
P _{water,in} (kPa)	736.01	N/A	N/A	338.61	12.62	18125.19	0.1673	
P _{water,out} (kPa)	601.67	N/A	N/A	190.33	10.58	17115.22	0.1676	
P _{sat} (kPa)	61.03	60.64	60.27	59.89	5.30	11575.41	0.1099	
P _{bundle,in} (kPa)			60.50		4.83	11523.15	0.1092	
P _{bundle,out} (kPa)			60.13		4.32	11373.42	0.1085	
m _{ref} (kg/s)			0.38		3.82	10658.16	0.1078	
	Path B	Path C	Path D	Path E	3.34	9555.20	0.1072	
T _{water,in} (°C)	17.85	17.83	17.91	17.85	0.00	0.00	0.1027	
T _{water,out} (°C)	15.16	15.23	15.20	15.16	0.00	0.00	0.1027	
m _{water} (kg/s)	0.32	0.31	0.32	0.32	0.00	0.00	0.1027	
	Pre-boiler				0.00	0.00	0.1027	
T _{water,in} (°C)			29.96		0.00	0.00	0.1027	
T _{water,out} (°C)			21.56					
m _{water} (kg/s)			0.43					
T _{ref,in} (°C)			-7.48					
P _{ref,in} (kPa)			89.29					
P _{ref,out} (kPa)			83.60					

Point ID	R-123, P/D 1.33, 20 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.83	15.85	15.09	14.82	47.02	19736.18	0.5264	19.81
T ₁ (°C)	17.46	15.70	15.05	14.82	42.74	20969.53	0.5224	
T ₂ (°C)	17.03	15.52	14.99	14.81	38.20	22072.77	0.5185	
T ₃ (°C)	16.64	15.38	14.94	14.80	33.65	22086.57	0.5149	
T ₄ (°C)	16.35	15.29	14.90	14.79	29.37	22193.08	0.5120	
T ₅ (°C)	16.07	15.17	14.88	14.80	18.74	18564.91	0.4131	
T _{out} (°C)	15.84	15.10	14.85	14.78	16.75	19242.36	0.4131	
m _{water} (kg/s)			0.27		14.63	19093.32	0.4132	
P _{water,in} (kPa)	738.40	N/A	N/A	340.24	12.51	17532.62	0.4135	
P _{water,out} (kPa)	602.89	N/A	N/A	193.34	10.51	16502.17	0.4139	
P _{sat} (kPa)	60.98	60.72	60.44	60.09	6.19	12707.24	0.3555	
P _{bundle,in} (kPa)			60.34		5.64	12781.26	0.3547	
P _{bundle,out} (kPa)			60.39		5.06	12688.09	0.3539	
m _{ref} (kg/s)			0.37		4.47	11991.36	0.3531	
	Path B	Path C	Path D	Path E	3.92	10925.83	0.3524	
T _{water,in} (°C)	17.86	17.84	17.92	17.85	0.00	0.00	0.3470	
T _{water,out} (°C)	15.17	15.23	15.20	15.18	0.00	0.00	0.3470	
m _{water} (kg/s)	0.31	0.32	0.32	0.33	0.00	0.00	0.3470	
	Pre-boiler				0.00	0.00	0.3470	
T _{water,in} (°C)			37.75		0.00	0.00	0.3470	
T _{water,out} (°C)			33.57					
m _{water} (kg/s)			1.74					
T _{ref,in} (°C)			-6.23					
P _{ref,in} (kPa)			121.99					
P _{ref,out} (kPa)			109.24					

Point ID	R-123, P/D 1.33, 20 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	20.80	17.11	15.50	14.86	85.46	18734.21	0.5014	19.89
T ₁ (°C)	20.12	16.77	15.40	14.83	78.27	19888.43	0.4986	
T ₂ (°C)	19.37	16.43	15.26	14.80	70.63	21225.57	0.4967	
T ₃ (°C)	18.62	16.12	15.13	14.77	63.00	21797.08	0.4959	
T ₄ (°C)	18.04	15.91	15.03	14.74	55.81	22107.99	0.4961	
T ₅ (°C)	17.55	15.67	14.95	14.72	39.01	20587.44	0.3041	
T _{out} (°C)	17.10	15.51	14.88	14.70	34.90	21447.40	0.3003	
m _{water} (kg/s)			0.27		30.54	21721.49	0.2968	
P _{water,in} (kPa)	738.66	N/A	N/A	341.14	26.17	20503.30	0.2938	
P _{water,out} (kPa)	604.90	N/A	N/A	193.34	22.06	19884.17	0.2916	
P _{sat} (kPa)	60.58	60.25	59.97	59.67	15.28	18082.61	0.1780	
P _{bundle,in} (kPa)			59.91		13.84	18704.78	0.1794	
P _{bundle,out} (kPa)			59.98		12.31	19399.41	0.1812	
m _{ref} (kg/s)			0.38		10.79	19176.35	0.1831	
	Path B	Path C	Path D	Path E	9.35	18047.27	0.1852	
T _{water,in} (°C)	20.84	20.84	20.91	20.84	4.21	11570.58	0.1131	
T _{water,out} (°C)	15.57	15.64	15.59	15.58	3.82	11365.13	0.1126	
m _{water} (kg/s)	0.32	0.32	0.32	0.32	3.41	10986.31	0.1120	
	Pre-boiler				3.00	10405.34	0.1114	
T _{water,in} (°C)			26.10		2.62	9168.20	0.1109	
T _{water,out} (°C)			22.56					
m _{water} (kg/s)			0.99					
T _{ref,in} (°C)			-6.11					
P _{ref,in} (kPa)			88.47					
P _{ref,out} (kPa)			82.84					

Point ID	R-123, P/D 1.33, 20 33 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	21.81	17.77	15.91	15.13	91.54	17388.12	0.7791	19.99
T ₁ (°C)	21.12	17.38	15.78	15.08	84.84	18604.53	0.7780	
T ₂ (°C)	20.29	16.98	15.61	15.03	77.71	20093.81	0.7781	
T ₃ (°C)	19.47	16.63	15.45	14.97	70.59	21049.28	0.7794	
T ₄ (°C)	18.83	16.38	15.33	14.92	63.88	21993.18	0.7817	
T ₅ (°C)	18.26	16.10	15.24	14.90	44.91	20380.29	0.5661	
T _{out} (°C)	17.76	15.92	15.15	14.87	40.26	21287.16	0.5616	
m _{water} (kg/s)		0.27			35.32	21610.34	0.5575	
P _{water,in} (kPa)	740.29	N/A	N/A	343.22	30.37	20666.72	0.5540	
P _{water,out} (kPa)	606.00	N/A	N/A	195.24	25.72	20131.06	0.5514	
P _{sat} (kPa)	60.88	60.68	60.45	60.17	18.53	18772.13	0.4240	
P _{bundle,in} (kPa)		60.18			16.80	19618.23	0.4257	
P _{bundle,out} (kPa)		60.55			14.96	20481.12	0.4277	
m _{ref} (kg/s)		0.38			13.12	20357.76	0.4300	
	Path B	Path C	Path D	Path E	11.39	19432.72	0.4325	
T _{water,in} (°C)	21.87	21.86	21.93	21.86	6.91	15786.87	0.3520	
T _{water,out} (°C)	15.94	15.94	15.90	15.97	6.21	15754.18	0.3511	
m _{water} (kg/s)	0.31	0.32	0.32	0.33	5.46	15442.57	0.3501	
	Pre-boiler				4.71	14843.07	0.3490	
T _{water,in} (°C)		48.23			4.01	12948.11	0.3481	
T _{water,out} (°C)		31.21						
m _{water} (kg/s)		0.42						
T _{ref,in} (°C)		-5.64						
P _{ref,in} (kPa)		123.48						
P _{ref,out} (kPa)		110.32						

Point ID	R-123, P/D 1.33, 20 36 0.37							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	22.85	19.47	16.90	15.72	72.00	11053.88	0.8082	19.92
T ₁ (°C)	22.33	18.93	16.69	15.64	68.74	11645.72	0.8129	
T ₂ (°C)	21.67	18.40	16.45	15.54	65.28	12337.19	0.8191	
T ₃ (°C)	20.99	17.92	16.21	15.45	61.81	12838.90	0.8263	
T ₄ (°C)	20.46	17.55	16.02	15.37	58.55	13535.13	0.8343	
T ₅ (°C)	19.91	17.16	15.88	15.33	61.22	19554.30	0.6266	
T _{out} (°C)	19.47	16.91	15.75	15.29	55.17	20362.59	0.6203	
m _{water} (kg/s)		0.27			48.74	20780.91	0.6143	
P _{water,in} (kPa)	740.38	N/A	N/A	343.93	42.31	20129.95	0.6089	
P _{water,out} (kPa)	606.33	N/A	N/A	195.09	36.25	19947.64	0.6043	
P _{sat} (kPa)	61.67	61.51	61.28	61.03	27.58	19722.65	0.4595	
P _{bundle,in} (kPa)		60.96			25.10	20854.52	0.4608	
P _{bundle,out} (kPa)		61.45			22.47	22218.76	0.4626	
m _{ref} (kg/s)		0.38			19.85	22707.97	0.4645	
	Path B	Path C	Path D	Path E	17.37	22354.24	0.4667	
T _{water,in} (°C)	22.93	22.93	22.99	22.93	11.48	19534.62	0.3736	
T _{water,out} (°C)	16.90	16.50	16.46	16.86	10.19	19814.49	0.3718	
m _{water} (kg/s)	0.31	0.32	0.32	0.33	8.82	19605.75	0.3699	
	Pre-boiler				7.45	18736.13	0.3681	
T _{water,in} (°C)		47.48			6.17	16183.05	0.3663	
T _{water,out} (°C)		31.96						
m _{water} (kg/s)		0.48						
T _{ref,in} (°C)		-5.59						
P _{ref,in} (kPa)		125.33						
P _{ref,out} (kPa)		112.11						

Point ID	R-123, P/D 1.33, 20 45 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	24.49	19.06	16.47	15.32	122.13	16667.48	0.6780	20.27
T ₁ (°C)	23.59	18.52	16.26	15.26	113.47	17770.95	0.6771	
T ₂ (°C)	22.50	17.98	16.03	15.17	104.27	19305.81	0.6778	
T ₃ (°C)	21.35	17.49	15.79	15.09	95.07	20216.76	0.6802	
T ₄ (°C)	20.50	17.12	15.61	15.02	86.42	21080.00	0.6840	
T ₅ (°C)	19.75	16.73	15.47	14.99	62.30	20209.72	0.3943	
T _{out} (°C)	19.06	16.47	15.35	14.95	56.01	21110.98	0.3884	
m _{water} (kg/s)			0.27		49.32	21592.87	0.3831	
P _{water,in} (kPa)	739.48	N/A	N/A	341.41	42.63	20861.54	0.3786	
P _{water,out} (kPa)	605.68	N/A	N/A	194.54	36.33	20572.38	0.3752	
P _{sat} (kPa)	60.86	60.60	60.33	60.03	26.97	20012.37	0.2025	
P _{bundle,in} (kPa)			60.24		24.49	21118.65	0.2046	
P _{bundle,out} (kPa)			60.41		21.86	22426.72	0.2072	
m _{ref} (kg/s)			0.38		19.22	22830.91	0.2101	
	Path B	Path C	Path D	Path E	16.74	22273.49	0.2133	
T _{water,in} (°C)	24.57	24.58	24.63	24.57	9.73	17251.51	0.1031	
T _{water,out} (°C)	16.40	16.44	16.40	16.49	8.75	17475.89	0.1018	
m _{water} (kg/s)	0.31	0.31	0.32	0.33	7.71	17508.32	0.1004	
	Pre-boiler				6.67	17054.85	0.0990	
T _{water,in} (°C)			23.74		5.68	15252.31	0.0977	
T _{water,out} (°C)			22.50					
m _{water} (kg/s)			2.63					
T _{ref,in} (°C)			-5.71					
P _{ref,in} (kPa)			87.06					
P _{ref,out} (kPa)			81.76					

Point ID	R-123, P/D 1.33, 20 50 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	25.97	20.42	17.43	16.07	116.80	13840.03	0.7158	20.35
T ₁ (°C)	25.17	19.80	17.20	15.99	112.27	15038.72	0.7215	
T ₂ (°C)	24.12	19.18	16.92	15.88	107.46	16841.54	0.7293	
T ₃ (°C)	22.96	18.61	16.63	15.78	102.66	18606.77	0.7390	
T ₄ (°C)	22.01	18.19	16.41	15.69	98.13	20633.67	0.7498	
T ₅ (°C)	21.18	17.73	16.24	15.64	71.48	19802.04	0.4351	
T _{out} (°C)	20.43	17.44	16.09	15.59	64.32	20655.25	0.4281	
m _{water} (kg/s)			0.27		56.71	21107.44	0.4217	
P _{water,in} (kPa)	738.23	N/A	N/A	342.05	49.10	20425.08	0.4163	
P _{water,out} (kPa)	604.97	N/A	N/A	193.62	41.94	20183.14	0.4121	
P _{sat} (kPa)	62.32	62.09	61.84	61.55	32.01	20107.60	0.2245	
P _{bundle,in} (kPa)			61.68		29.18	21331.88	0.2268	
P _{bundle,out} (kPa)			61.92		26.17	22910.05	0.2296	
m _{ref} (kg/s)			0.38		23.16	23732.51	0.2328	
	Path B	Path C	Path D	Path E	20.33	23601.71	0.2362	
T _{water,in} (°C)	26.06	26.07	26.12	26.06	12.27	18586.35	0.1159	
T _{water,out} (°C)	17.39	17.23	17.19	17.40	11.00	18974.38	0.1142	
m _{water} (kg/s)	0.31	0.31	0.32	0.33	9.64	19116.06	0.1124	
	Pre-boiler				8.29	18671.97	0.1106	
T _{water,in} (°C)			25.19		7.02	16740.92	0.1089	
T _{water,out} (°C)			22.99					
m _{water} (kg/s)			1.58					
T _{ref,in} (°C)			-5.57					
P _{ref,in} (kPa)			89.35					
P _{ref,out} (kPa)			83.78					

Point ID	R-123, P/D 1.33, 25 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	15.72	14.92	14.70	14.70	19.41	17845.92	0.1442	25.11
T ₁ (°C)	15.56	14.89	14.72	14.71	17.56	18584.96	0.1432	
T ₂ (°C)	15.38	14.83	14.72	14.72	15.60	18927.15	0.1422	
T ₃ (°C)	15.22	14.79	14.72	14.72	13.64	17921.19	0.1412	
T ₄ (°C)	15.12	14.77	14.72	14.73	11.79	17513.05	0.1403	
T ₅ (°C)	15.00	14.74	14.73	14.74	5.36	10849.02	0.1134	
T _{out} (°C)	14.91	14.71	14.73	14.74	4.91	11123.08	0.1129	
m _{water} (kg/s)			0.27		4.43	10846.94	0.1124	
P _{water,in} (kPa)	740.61	N/A	N/A	340.82	3.95	9928.29	0.1119	
P _{water,out} (kPa)	605.30	N/A	N/A	193.46	3.50	9439.82	0.1114	
P _{sat} (kPa)	61.28	60.78	60.35	59.87	0.00	0.00	0.1076	
P _{bundle,in} (kPa)			60.87		0.00	0.00	0.1076	
P _{bundle,out} (kPa)			60.09		0.00	0.00	0.1076	
m _{ref} (kg/s)			0.47		0.00	0.00	0.1076	
	Path B	Path C	Path D	Path E	0.00	0.00	0.1076	
T _{water,in} (°C)	15.74	15.73	15.81	15.74	0.00	0.00	0.1076	
T _{water,out} (°C)	14.83	14.90	14.89	14.83	0.00	0.00	0.1076	
m _{water} (kg/s)	0.31	0.32	0.32	0.33	0.00	0.00	0.1076	
	Pre-boiler				0.00	0.00	0.1076	
T _{water,in} (°C)			29.35		0.00	0.00	0.1076	
T _{water,out} (°C)			26.11					
m _{water} (kg/s)			1.44					
T _{ref,in} (°C)			-7.98					
P _{ref,in} (kPa)			95.38					
P _{ref,out} (kPa)			89.26					

Point ID	R-123, P/D 1.33, 25 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.82	15.80	15.04	14.81	48.20	20178.18	0.2326	25.15
T ₁ (°C)	17.44	15.65	15.01	14.82	43.69	21373.82	0.2292	
T ₂ (°C)	17.01	15.48	14.97	14.82	38.91	22565.45	0.2260	
T ₃ (°C)	16.60	15.33	14.92	14.82	34.12	22589.94	0.2231	
T ₄ (°C)	16.30	15.24	14.89	14.81	29.61	22365.94	0.2205	
T ₅ (°C)	16.03	15.12	14.87	14.82	18.79	19231.73	0.1435	
T _{out} (°C)	15.80	15.05	14.84	14.81	16.76	19802.72	0.1435	
m _{water} (kg/s)			0.27		14.61	19641.36	0.1435	
P _{water,in} (kPa)	736.06	N/A	N/A	338.21	12.45	18054.33	0.1437	
P _{water,out} (kPa)	602.40	N/A	N/A	190.23	10.42	17010.33	0.1439	
P _{sat} (kPa)	61.15	60.78	60.39	59.99	5.23	11756.87	0.0990	
P _{bundle,in} (kPa)			60.62		4.77	11722.06	0.0985	
P _{bundle,out} (kPa)			60.20		4.27	11599.47	0.0979	
m _{ref} (kg/s)			0.47		3.77	10883.18	0.0974	
	Path B	Path C	Path D	Path E	3.30	9759.10	0.0969	
T _{water,in} (°C)	17.86	17.85	17.93	17.86	0.00	0.00	0.0933	
T _{water,out} (°C)	15.19	15.26	15.23	15.20	0.00	0.00	0.0933	
m _{water} (kg/s)	0.32	0.31	0.32	0.32	0.00	0.00	0.0933	
	Pre-boiler				0.00	0.00	0.0933	
T _{water,in} (°C)			26.43		0.00	0.00	0.0933	
T _{water,out} (°C)			24.14					
m _{water} (kg/s)			1.87					
T _{ref,in} (°C)			-7.25					
P _{ref,in} (kPa)			94.04					
P _{ref,out} (kPa)			87.49					

Point ID	R-123, P/D 1.33, 25 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	18.78	16.63	15.79	15.48	50.93	19822.23	0.5069	24.96
T ₁ (°C)	18.37	16.46	15.75	15.48	46.34	21098.85	0.5036	
T ₂ (°C)	17.92	16.27	15.68	15.46	41.46	22351.07	0.5004	
T ₃ (°C)	17.48	16.11	15.62	15.45	36.58	22464.46	0.4975	
T ₄ (°C)	17.17	16.01	15.57	15.44	31.98	22723.57	0.4951	
T ₅ (°C)	16.86	15.88	15.54	15.44	20.54	18884.94	0.4091	
T _{out} (°C)	16.62	15.80	15.51	15.43	18.34	19553.75	0.4091	
m _{water} (kg/s)			0.27		16.01	19399.91	0.4093	
P _{water,in} (kPa)	738.33	N/A	N/A	339.31	13.68	17902.82	0.4095	
P _{water,out} (kPa)	603.68	N/A	N/A	191.58	11.48	16924.57	0.4099	
P _{sat} (kPa)	62.58	62.34	62.04	61.75	7.22	14159.46	0.3597	
P _{bundle,in} (kPa)			61.88		6.59	14464.11	0.3590	
P _{bundle,out} (kPa)			62.07		5.91	14601.97	0.3582	
m _{ref} (kg/s)			0.47		5.23	14009.71	0.3575	
	Path B	Path C	Path D	Path E	4.59	12960.58	0.3568	
T _{water,in} (°C)	18.81	18.80	18.88	18.80	0.00	0.00	0.3518	
T _{water,out} (°C)	15.86	15.92	15.89	15.88	0.00	0.00	0.3518	
m _{water} (kg/s)	0.31	0.31	0.32	0.33	0.00	0.00	0.3518	
	Pre-boiler				0.00	0.00	0.3518	
T _{water,in} (°C)			42.97		0.00	0.00	0.3518	
T _{water,out} (°C)			39.50					
m _{water} (kg/s)			2.68					
T _{ref,in} (°C)			-6.01					
P _{ref,in} (kPa)			130.72					
P _{ref,out} (kPa)			129.95					

Point ID	R-123, P/D 1.33, 25 25 0.30							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	20.32	17.23	15.94	15.43	72.41	19387.80	0.5651	25.12
T ₁ (°C)	19.75	16.97	15.85	15.41	66.05	20604.18	0.5629	
T ₂ (°C)	19.10	16.68	15.75	15.38	59.29	22024.22	0.5613	
T ₃ (°C)	18.47	16.43	15.65	15.35	52.54	22310.79	0.5605	
T ₄ (°C)	18.01	16.26	15.57	15.32	46.18	22576.79	0.5604	
T ₅ (°C)	17.58	16.07	15.51	15.32	31.75	20619.11	0.4350	
T _{out} (°C)	17.22	15.95	15.45	15.30	28.34	21512.69	0.4323	
m _{water} (kg/s)			0.27		24.71	21687.33	0.4298	
P _{water,in} (kPa)	739.81	N/A	N/A	343.27	21.08	20357.76	0.4277	
P _{water,out} (kPa)	605.32	N/A	N/A	193.21	17.67	19482.02	0.4262	
P _{sat} (kPa)	62.14	61.90	61.65	61.34	11.88	17041.51	0.3526	
P _{bundle,in} (kPa)			61.45		10.81	17672.19	0.3537	
P _{bundle,out} (kPa)			61.66		9.68	18224.74	0.3551	
m _{ref} (kg/s)			0.47		8.54	17944.28	0.3566	
	Path B	Path C	Path D	Path E	7.47	17028.22	0.3582	
T _{water,in} (°C)	20.36	20.35	20.43	20.36	3.66	11565.48	0.3119	
T _{water,out} (°C)	15.99	16.04	16.01	16.02	3.32	11327.32	0.3116	
m _{water} (kg/s)	0.31	0.31	0.32	0.33	2.96	10898.02	0.3112	
	Pre-boiler				2.60	10351.91	0.3108	
T _{water,in} (°C)			44.11		2.27	9026.76	0.3104	
T _{water,out} (°C)			35.75					
m _{water} (kg/s)			1.01					
T _{ref,in} (°C)			-5.83					
P _{ref,in} (kPa)			130.67					
P _{ref,out} (kPa)			123.02					

Point ID	R-123, P/D 1.33, 25 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	21.29	17.58	15.97	15.32	85.74	18658.51	0.4022	25.30
T ₁ (°C)	20.61	17.25	15.86	15.30	78.54	19796.55	0.4001	
T ₂ (°C)	19.85	16.90	15.73	15.26	70.89	21127.41	0.3985	
T ₃ (°C)	19.10	16.59	15.59	15.23	63.24	21708.00	0.3979	
T ₄ (°C)	18.52	16.38	15.49	15.20	56.05	22010.21	0.3981	
T ₅ (°C)	18.03	16.13	15.41	15.19	39.21	20613.14	0.2463	
T _{out} (°C)	17.58	15.98	15.35	15.17	35.09	21495.83	0.2433	
m _{water} (kg/s)			0.27		30.72	21792.32	0.2405	
P _{water,in} (kPa)	737.71	N/A	N/A	340.80	26.34	20623.77	0.2383	
P _{water,out} (kPa)	603.96	N/A	N/A	193.06	22.23	20055.26	0.2365	
P _{sat} (kPa)	61.74	61.40	61.11	60.79	15.44	18336.18	0.1466	
P _{bundle,in} (kPa)			61.07		13.96	18939.43	0.1477	
P _{bundle,out} (kPa)			61.10		12.38	19613.73	0.1491	
m _{ref} (kg/s)			0.48		10.80	19324.51	0.1506	
	Path B	Path C	Path D	Path E	9.32	18077.58	0.1522	
T _{water,in} (°C)	21.34	21.33	21.40	21.33	4.15	11477.41	0.0954	
T _{water,out} (°C)	16.04	16.11	16.05	16.05	3.79	11353.94	0.0950	
m _{water} (kg/s)	0.32	0.32	0.32	0.32	3.41	11066.33	0.0946	
	Pre-boiler				3.03	10631.26	0.0941	
T _{water,in} (°C)			27.31		2.66	9497.08	0.0938	
T _{water,out} (°C)			24.08					
m _{water} (kg/s)			1.29					
T _{ref,in} (°C)			-6.07					
P _{ref,in} (kPa)			94.40					
P _{ref,out} (kPa)			88.00					

Point ID	R-123, P/D 1.33, 25 45 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	24.44	19.06	16.57	15.47	123.42	17558.63	0.5708	25.06
T ₁ (°C)	23.48	18.54	16.37	15.41	113.45	18563.88	0.5685	
T ₂ (°C)	22.39	18.02	16.15	15.33	102.85	19863.27	0.5674	
T ₃ (°C)	21.27	17.54	15.92	15.25	92.26	20373.41	0.5677	
T ₄ (°C)	20.44	17.19	15.74	15.19	82.28	20713.98	0.5691	
T ₅ (°C)	19.71	16.82	15.61	15.15	59.83	20104.25	0.3420	
T _{out} (°C)	19.06	16.58	15.49	15.11	53.77	20930.62	0.3375	
m _{water} (kg/s)			0.27		47.34	21437.03	0.3333	
P _{water,in} (kPa)	739.55	N/A	N/A	342.40	40.90	20660.09	0.3299	
P _{water,out} (kPa)	606.43	N/A	N/A	194.68	34.84	20319.52	0.3273	
P _{sat} (kPa)	61.28	61.03	60.75	60.44	25.97	19882.97	0.1920	
P _{bundle,in} (kPa)			60.61		23.59	20951.79	0.1939	
P _{bundle,out} (kPa)			60.80		21.07	22252.36	0.1961	
m _{ref} (kg/s)			0.47		18.54	22687.28	0.1985	
	Path B	Path C	Path D	Path E	16.16	22154.30	0.2012	
T _{water,in} (°C)	24.52	24.52	24.58	24.51	9.22	16651.34	0.1157	
T _{water,out} (°C)	16.51	16.58	16.54	16.60	8.28	16780.02	0.1146	
m _{water} (kg/s)	0.31	0.31	0.32	0.33	7.28	16688.99	0.1136	
	Pre-boiler				6.29	16114.24	0.1125	
T _{water,in} (°C)			28.48		5.35	14291.71	0.1115	
T _{water,out} (°C)			24.09					
m _{water} (kg/s)			0.99					
T _{ref,in} (°C)			-5.64					
P _{ref,in} (kPa)			95.44					
P _{ref,out} (kPa)			88.58					

Point ID	R-123, P/D 1.33, 35 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	15.52	14.70	14.47	14.46	19.94	18031.76	0.1291	35.23
T ₁ (°C)	15.36	14.67	14.49	14.47	18.02	18760.82	0.1284	
T ₂ (°C)	15.18	14.61	14.48	14.48	15.97	19065.10	0.1276	
T ₃ (°C)	15.01	14.57	14.48	14.49	13.93	18022.42	0.1268	
T ₄ (°C)	14.91	14.55	14.49	14.49	12.01	17552.23	0.1261	
T ₅ (°C)	14.78	14.51	14.50	14.51	5.60	11228.50	0.1059	
T _{out} (°C)	14.69	14.48	14.49	14.50	5.12	11449.92	0.1055	
m _{water} (kg/s)		0.27			4.60	11159.84	0.1051	
P _{water,in} (kPa)	741.42	N/A	N/A	342.86	4.09	10181.31	0.1047	
P _{water,out} (kPa)	606.80	N/A	N/A	196.20	3.61	9655.14	0.1044	
P _{sat} (kPa)	60.67	60.19	59.80	59.32	0.00	0.00	0.1016	
P _{bundle,in} (kPa)		60.15			0.00	0.00	0.1016	
P _{bundle,out} (kPa)		59.51			0.00	0.00	0.1016	
m _{ref} (kg/s)		0.66			0.00	0.00	0.1016	
	Path B	Path C	Path D	Path E	0.00	0.00	0.1016	
T _{water,in} (°C)	15.54	15.51	15.59	15.53	0.00	0.00	0.1016	
T _{water,out} (°C)	14.60	14.66	14.65	14.60	0.00	0.00	0.1016	
m _{water} (kg/s)	0.31	0.32	0.32	0.33	0.00	0.00	0.1016	
	Pre-boiler				0.00	0.00	0.1016	
T _{water,in} (°C)		31.13			0.00	0.00	0.1016	
T _{water,out} (°C)		28.75						
m _{water} (kg/s)		2.65						
T _{ref,in} (°C)		-7.68						
P _{ref,in} (kPa)		107.64						
P _{ref,out} (kPa)		99.93						

Point ID	R-123, P/D 1.33, 35 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.71	15.75	15.01	14.79	46.81	20264.77	0.1917	35.26
T ₁ (°C)	17.34	15.60	14.99	14.80	42.42	21469.21	0.1894	
T ₂ (°C)	16.92	15.43	14.94	14.80	37.75	22659.16	0.1871	
T ₃ (°C)	16.52	15.29	14.89	14.80	33.09	22671.67	0.1850	
T ₄ (°C)	16.23	15.20	14.86	14.79	28.70	22448.27	0.1833	
T ₅ (°C)	15.96	15.09	14.85	14.80	18.20	19271.81	0.1293	
T _{out} (°C)	15.74	15.02	14.82	14.79	16.22	19917.87	0.1291	
m _{water} (kg/s)		0.27			14.12	19738.94	0.1291	
P _{water,in} (kPa)	737.44	N/A	N/A	338.87	12.03	18102.68	0.1291	
P _{water,out} (kPa)	602.36	N/A	N/A	191.04	10.05	17021.15	0.1291	
P _{sat} (kPa)	61.11	60.74	60.37	59.98	5.04	11644.62	0.0968	
P _{bundle,in} (kPa)		60.52			4.61	11682.80	0.0964	
P _{bundle,out} (kPa)		60.18			4.16	11655.18	0.0961	
m _{ref} (kg/s)		0.67			3.70	11031.49	0.0957	
	Path B	Path C	Path D	Path E	3.28	10027.10	0.0954	
T _{water,in} (°C)	17.75	17.73	17.81	17.74	0.00	0.00	0.0929	
T _{water,out} (°C)	15.16	15.22	15.20	15.16	0.00	0.00	0.0929	
m _{water} (kg/s)	0.32	0.31	0.32	0.32	0.00	0.00	0.0929	
	Pre-boiler				0.00	0.00	0.0929	
T _{water,in} (°C)		29.89			0.00	0.00	0.0929	
T _{water,out} (°C)		27.63						
m _{water} (kg/s)		2.64						
T _{ref,in} (°C)		-6.83						
P _{ref,in} (kPa)		107.69						
P _{ref,out} (kPa)		99.32						

Point ID	R-123, P/D 1.33, 35 30 0.08							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	22.41	18.68	17.05	16.39	86.52	18587.62	0.3093	35.03
T ₁ (°C)	21.73	18.34	16.94	16.37	79.24	19702.66	0.3079	
T ₂ (°C)	20.97	17.99	16.80	16.33	71.51	21014.82	0.3069	
T ₃ (°C)	20.21	17.68	16.67	16.29	63.77	21598.24	0.3066	
T ₄ (°C)	19.62	17.46	16.56	16.26	56.49	21873.68	0.3070	
T ₅ (°C)	19.13	17.21	16.49	16.25	39.70	20720.63	0.1960	
T _{out} (°C)	18.68	17.06	16.42	16.23	35.52	21638.12	0.1937	
m _{water} (kg/s)			0.27		31.07	21958.07	0.1917	
P _{water,in} (kPa)	737.82	N/A	N/A	340.62	26.63	20820.49	0.1899	
P _{water,out} (kPa)	604.11	N/A	N/A	192.77	22.45	20279.67	0.1886	
P _{sat} (kPa)	64.47	64.14	63.83	63.49	15.54	18650.01	0.1234	
P _{bundle,in} (kPa)			63.77		14.11	19410.91	0.1243	
P _{bundle,out} (kPa)			63.81		12.58	20331.24	0.1254	
m _{ref} (kg/s)			0.66		11.05	20335.92	0.1266	
	Path B	Path C	Path D	Path E	9.61	19404.19	0.1279	
T _{water,in} (°C)	22.47	22.47	22.55	22.47	4.43	12831.34	0.0869	
T _{water,out} (°C)	17.11	17.18	17.12	17.12	3.99	12564.80	0.0865	
m _{water} (kg/s)	0.32	0.32	0.32	0.32	3.52	12071.75	0.0862	
	Pre-boiler				3.05	11338.38	0.0858	
T _{water,in} (°C)			29.78		2.61	9793.29	0.0855	
T _{water,out} (°C)			27.63					
m _{water} (kg/s)			2.65					
T _{ref,in} (°C)			-5.86					
P _{ref,in} (kPa)			107.54					
P _{ref,out} (kPa)			99.73					

Point ID	R-123, P/D 1.33, 45 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	15.86	15.06	14.83	14.82	19.57	18025.42	0.1180	45.20
T ₁ (°C)	15.71	15.03	14.85	14.83	17.70	18788.32	0.1173	
T ₂ (°C)	15.53	14.97	14.84	14.84	15.71	19116.36	0.1167	
T ₃ (°C)	15.37	14.93	14.84	14.84	13.72	18073.91	0.1161	
T ₄ (°C)	15.27	14.91	14.85	14.85	11.84	17715.96	0.1155	
T ₅ (°C)	15.14	14.87	14.85	14.86	5.54	11394.42	0.0996	
T _{out} (°C)	15.05	14.84	14.85	14.86	5.07	11707.53	0.0993	
m _{water} (kg/s)			0.27		4.56	11437.33	0.0990	
P _{water,in} (kPa)	741.02	N/A	N/A	341.69	4.06	10463.34	0.0987	
P _{water,out} (kPa)	606.10	N/A	N/A	194.51	3.59	9954.31	0.0985	
P _{sat} (kPa)	61.53	61.08	60.70	60.22	0.00	0.00	0.0963	
P _{bundle,in} (kPa)			60.96		0.00	0.00	0.0963	
P _{bundle,out} (kPa)			60.41		0.00	0.00	0.0963	
m _{ref} (kg/s)			0.85		0.00	0.00	0.0963	
	Path B	Path C	Path D	Path E	0.00	0.00	0.0963	
T _{water,in} (°C)	15.89	15.87	15.95	15.88	0.00	0.00	0.0963	
T _{water,out} (°C)	14.95	15.02	15.01	14.95	0.00	0.00	0.0963	
m _{water} (kg/s)	0.31	0.32	0.32	0.33	0.00	0.00	0.0963	
	Pre-boiler				0.00	0.00	0.0963	
T _{water,in} (°C)			33.07		0.00	0.00	0.0963	
T _{water,out} (°C)			30.11					
m _{water} (kg/s)			2.65					
T _{ref,in} (°C)			-7.20					
P _{ref,in} (kPa)			119.36					
P _{ref,out} (kPa)			110.89					

Point ID	R-123, P/D 1.33, 55 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	16.15	15.37	15.15	15.13	19.22	17870.99	0.1095	54.02
T ₁ (°C)	16.00	15.34	15.16	15.14	17.38	18601.42	0.1090	
T ₂ (°C)	15.82	15.28	15.16	15.15	15.43	18902.50	0.1085	
T ₃ (°C)	15.67	15.24	15.16	15.16	13.47	17886.20	0.1080	
T ₄ (°C)	15.57	15.22	15.16	15.16	11.64	17491.52	0.1076	
T ₅ (°C)	15.44	15.18	15.17	15.17	5.34	11077.94	0.0949	
T _{out} (°C)	15.36	15.16	15.16	15.17	4.90	11398.91	0.0947	
m _{water} (kg/s)		0.27			4.43	11156.98	0.0945	
P _{water,in} (kPa)	739.94	N/A	N/A	339.87	3.96	10245.29	0.0942	
P _{water,out} (kPa)	604.91	N/A	N/A	192.45	3.52	9806.12	0.0940	
P _{sat} (kPa)	62.29	61.85	61.49	61.00	0.00	0.00	0.0922	
P _{bundle,in} (kPa)		61.72			0.00	0.00	0.0922	
P _{bundle,out} (kPa)		61.21			0.00	0.00	0.0922	
m _{ref} (kg/s)		1.02			0.00	0.00	0.0922	
	Path B	Path C	Path D	Path E	0.00	0.00	0.0922	
T _{water,in} (°C)	16.18	16.16	16.24	16.18	0.00	0.00	0.0922	
T _{water,out} (°C)	15.26	15.33	15.32	15.26	0.00	0.00	0.0922	
m _{water} (kg/s)	0.31	0.32	0.32	0.33	0.00	0.00	0.0922	
	Pre-boiler				0.00	0.00	0.0922	
T _{water,in} (°C)		39.08			0.00	0.00	0.0922	
T _{water,out} (°C)		26.17						
m _{water} (kg/s)		0.71						
T _{ref,in} (°C)		-6.84						
P _{ref,in} (kPa)		125.31						
P _{ref,out} (kPa)		120.78						

Point ID	R-123, P/D 1.5, 10 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	15.88	15.03	14.78	14.78	20.31	19700.15	0.4145	9.96
T ₁ (°C)	15.72	15.00	14.78	14.79	18.29	21030.12	0.4126	
T ₂ (°C)	15.52	14.94	14.79	14.80	16.14	21545.96	0.4108	
T ₃ (°C)	15.36	14.88	14.80	14.80	13.99	21150.72	0.4089	
T ₄ (°C)	15.22	14.85	14.80	14.81	11.97	20616.84	0.4072	
T ₅ (°C)	15.10	14.83	14.81	14.83	5.89	12426.66	0.3612	
T _{out} (°C)	15.02	14.80	14.80	14.83	5.28	12415.77	0.3601	
m _{water} (kg/s)		0.26			4.64	12027.38	0.3589	
P _{water,in} (kPa)	692.42	N/A	N/A	336.56	4.00	10964.63	0.3578	
P _{water,out} (kPa)	568.95	N/A	N/A	191.76	3.39	9571.16	0.3567	
P _{sat} (kPa)	61.53	60.73	60.61	60.31	0.00	0.00	0.3506	
P _{bundle,in} (kPa)		60.86			0.00	0.00	0.3506	
P _{bundle,out} (kPa)		60.28			0.00	0.00	0.3506	
m _{ref} (kg/s)		0.28			0.00	0.00	0.3506	
	Path B	Path C	Path D	Path E	0.00	0.00	0.3506	
T _{water,in} (°C)	15.87	15.85	15.88	15.87	0.00	0.00	0.3506	
T _{water,out} (°C)	14.92	14.97	14.97	14.94	0.00	0.00	0.3506	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	0.00	0.00	0.3506	
	Pre-boiler				0.00	0.00	0.3506	
T _{water,in} (°C)		39.03			0.00	0.00	0.3506	
T _{water,out} (°C)		27.90						
m _{water} (kg/s)		0.51						
T _{ref,in} (°C)		-7.90						
P _{ref,in} (kPa)		104.43						
P _{ref,out} (kPa)		94.92						

Point ID	R-123, P/D 1.5, 10 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	18.08	15.92	15.13	14.89	52.09	20847.00	0.3513	10.10
T ₁ (°C)	17.70	15.78	15.10	14.90	47.42	22702.19	0.3456	
T ₂ (°C)	17.20	15.59	15.03	14.90	42.46	23942.46	0.3400	
T ₃ (°C)	16.79	15.42	14.99	14.90	37.50	24723.49	0.3349	
T ₄ (°C)	16.45	15.29	14.96	14.90	32.83	25485.76	0.3305	
T ₅ (°C)	16.13	15.20	14.95	14.91	20.50	18958.39	0.1965	
T _{out} (°C)	15.91	15.13	14.92	14.91	18.26	19464.88	0.1961	
m _{water} (kg/s)		0.27			15.88	19528.15	0.1958	
P _{water,in} (kPa)	749.80	N/A	N/A	355.86	13.50	18475.55	0.1957	
P _{water,out} (kPa)	613.31	N/A	N/A	195.40	11.26	16456.94	0.1957	
P _{sat} (kPa)	61.31	60.56	60.37	60.18	5.84	9587.12	0.1170	
P _{bundle,in} (kPa)		60.78			5.20	9466.78	0.1158	
P _{bundle,out} (kPa)		60.15			4.52	8647.64	0.1146	
m _{ref} (kg/s)		0.29			3.84	7569.95	0.1134	
	Path B	Path C	Path D	Path E	3.19	6380.48	0.1123	
T _{water,in} (°C)	18.11	18.09	18.11	18.09	0.00	0.00	0.1066	
T _{water,out} (°C)	15.28	15.34	15.31	15.28	0.00	0.00	0.1066	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	0.00	0.00	0.1066	
	Pre-boiler				0.00	0.00	0.1066	
T _{water,in} (°C)		32.91			0.00	0.00	0.1066	
T _{water,out} (°C)		20.55						
m _{water} (kg/s)		0.22						
T _{ref,in} (°C)		-7.70						
P _{ref,in} (kPa)		83.77						
P _{ref,out} (kPa)		79.56						

Point ID	R-123, P/D 1.5, 10 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	18.01	15.87	15.07	14.85	49.49	20956.15	0.5842	9.95
T ₁ (°C)	17.62	15.73	15.03	14.85	44.81	22845.66	0.5785	
T ₂ (°C)	17.13	15.55	14.99	14.85	39.83	24205.65	0.5729	
T ₃ (°C)	16.72	15.39	14.95	14.85	34.86	24663.60	0.5679	
T ₄ (°C)	16.39	15.26	14.92	14.85	30.18	25260.04	0.5635	
T ₅ (°C)	16.08	15.17	14.90	14.86	19.03	18783.96	0.4325	
T _{out} (°C)	15.86	15.09	14.87	14.85	16.95	19438.54	0.4321	
m _{water} (kg/s)		0.26			14.74	19595.13	0.4318	
P _{water,in} (kPa)	691.72	N/A	N/A	335.76	12.52	18660.42	0.4317	
P _{water,out} (kPa)	568.66	N/A	N/A	190.11	10.44	16665.15	0.4318	
P _{sat} (kPa)	61.19	60.53	60.45	60.35	4.77	8362.10	0.3541	
P _{bundle,in} (kPa)		60.55			4.35	8077.92	0.3533	
P _{bundle,out} (kPa)		60.34			3.90	7721.40	0.3525	
m _{ref} (kg/s)		0.28			3.46	7161.40	0.3517	
	Path B	Path C	Path D	Path E	3.04	6387.60	0.3510	
T _{water,in} (°C)	18.00	17.98	18.00	17.99	0.00	0.00	0.3455	
T _{water,out} (°C)	15.23	15.26	15.24	15.22	0.00	0.00	0.3455	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	0.00	0.00	0.3455	
	Pre-boiler				0.00	0.00	0.3455	
T _{water,in} (°C)		40.62			0.00	0.00	0.3455	
T _{water,out} (°C)		27.72						
m _{water} (kg/s)		0.43						
T _{ref,in} (°C)		-7.40						
P _{ref,in} (kPa)		104.18						
P _{ref,out} (kPa)		94.76						

Point ID	R-123, P/D 1.5, 10 27 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	20.49	16.96	15.46	14.92	78.78	18892.02	0.8178	
T ₁ (°C)	19.91	16.68	15.36	14.90	72.52	20787.71	0.8150	
T ₂ (°C)	19.11	16.35	15.25	14.88	65.87	22485.71	0.8132	
T ₃ (°C)	18.43	16.04	15.15	14.85	59.22	23781.49	0.8127	
T ₄ (°C)	17.86	15.80	15.06	14.83	52.96	25551.63	0.8134	
T ₅ (°C)	17.33	15.63	15.01	14.82	35.44	20603.12	0.5820	
T _{out} (°C)	16.95	15.48	14.95	14.80	31.62	21619.40	0.5772	
m _{water} (kg/s)			0.26		27.56	22298.43	0.5728	
P _{water,in} (kPa)	691.80	N/A	N/A	336.29	23.50	21846.86	0.5690	
P _{water,out} (kPa)	568.80	N/A	N/A	190.51	19.68	20015.30	0.5661	9.88
P _{sat} (kPa)	60.87	60.29	60.28	60.26	12.25	14445.70	0.4321	
P _{bundle,in} (kPa)			60.17		11.00	14427.98	0.4339	
P _{bundle,out} (kPa)			60.34		9.67	14085.81	0.4361	
m _{ref} (kg/s)			0.28		8.34	13246.03	0.4385	
	Path B	Path C	Path D	Path E	7.09	11767.34	0.4410	
T _{water,in} (°C)	20.50	20.50	20.51	20.51	3.12	9271.79	0.3593	
T _{water,out} (°C)	15.67	15.62	15.57	15.64	2.85	9034.32	0.3588	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	2.57	8611.94	0.3583	
	Pre-boiler				2.28	8179.25	0.3578	
T _{water,in} (°C)			40.75		2.01	7228.85	0.3573	
T _{water,out} (°C)			27.73					
m _{water} (kg/s)			0.43					
T _{ref,in} (°C)			-7.46					
P _{ref,in} (kPa)			104.23					
P _{ref,out} (kPa)			94.77					

Point ID	R-123, P/D 1.5, 10 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	21.13	17.41	15.79	15.20	86.35	18938.90	0.6027	
T ₁ (°C)	20.49	17.12	15.69	15.18	79.62	20671.31	0.5997	
T ₂ (°C)	19.66	16.76	15.56	15.16	72.47	22141.18	0.5978	
T ₃ (°C)	18.96	16.43	15.45	15.13	65.32	22925.76	0.5973	
T ₄ (°C)	18.41	16.16	15.36	15.11	58.58	24772.71	0.5981	
T ₅ (°C)	17.80	15.98	15.30	15.10	40.06	20700.26	0.3523	
T _{out} (°C)	17.40	15.81	15.23	15.08	35.91	21713.38	0.3473	
m _{water} (kg/s)			0.27		31.50	22461.28	0.3426	
P _{water,in} (kPa)	750.63	N/A	N/A	355.27	27.08	22160.32	0.3387	
P _{water,out} (kPa)	614.17	N/A	N/A	196.31	22.93	20597.75	0.3357	10.12
P _{sat} (kPa)	61.47	60.78	60.70	60.60	14.08	14744.11	0.1916	
P _{bundle,in} (kPa)			60.85		12.71	14902.75	0.1934	
P _{bundle,out} (kPa)			60.63		11.26	14638.32	0.1954	
m _{ref} (kg/s)			0.29		9.81	13916.27	0.1978	
	Path B	Path C	Path D	Path E	8.44	12610.63	0.2003	
T _{water,in} (°C)	21.18	21.17	21.19	21.17	3.23	8661.30	0.1119	
T _{water,out} (°C)	15.91	15.93	15.87	15.88	2.98	8438.48	0.1115	
m _{water} (kg/s)	0.31	0.31	0.29	0.31	2.71	8083.04	0.1110	
	Pre-boiler				2.43	7687.33	0.1105	
T _{water,in} (°C)			30.53		2.18	6916.16	0.1101	
T _{water,out} (°C)			20.31					
m _{water} (kg/s)			0.27					
T _{ref,in} (°C)			-7.44					
P _{ref,in} (kPa)			83.78					
P _{ref,out} (kPa)			79.50					

Point ID	R-123, P/D 1.5, 15 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	15.56	14.72	14.48	14.49	21.04	19452.64	0.1436	22.98
T ₁ (°C)	15.41	14.69	14.52	14.50	19.07	20741.59	0.1426	
T ₂ (°C)	15.21	14.63	14.50	14.51	16.99	21244.42	0.1415	
T ₃ (°C)	15.05	14.58	14.51	14.52	14.90	21160.24	0.1405	
T ₄ (°C)	14.91	14.55	14.52	14.52	12.93	20875.49	0.1395	
T ₅ (°C)	14.79	14.53	14.53	14.54	6.14	11608.20	0.1087	
T _{out} (°C)	14.71	14.52	14.52	14.54	5.30	10832.84	0.1078	
m _{water} (kg/s)		0.27			4.40	9708.95	0.1067	
P _{water,in} (kPa)	749.69	N/A	N/A	356.46	3.51	7953.82	0.1057	
P _{water,out} (kPa)	613.61	N/A	N/A	195.38	2.67	6118.06	0.1047	
P _{sat} (kPa)	60.81	60.00	59.73	59.45	0.00	0.00	0.1015	
P _{bundle,in} (kPa)		60.37			0.00	0.00	0.1015	
P _{bundle,out} (kPa)		59.38			0.00	0.00	0.1015	
m _{ref} (kg/s)		0.43			0.00	0.00	0.1015	
	Path B	Path C	Path D	Path E	0.00	0.00	0.1015	
T _{water,in} (°C)	15.58	15.55	15.58	15.57	0.00	0.00	0.1015	
T _{water,out} (°C)	14.63	14.69	14.68	14.66	0.00	0.00	0.1015	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	0.00	0.00	0.1015	
	Pre-boiler				0.00	0.00	0.1015	
T _{water,in} (°C)		27.48			0.00	0.00	0.1015	
T _{water,out} (°C)		25.92						
m _{water} (kg/s)		2.65						
T _{ref,in} (°C)		-7.89						
P _{ref,in} (kPa)		92.12						
P _{ref,out} (kPa)		86.43						

Point ID	R-123, P/D 1.5, 15 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	15.60	14.77	14.51	14.50	19.81	19764.04	0.3902	15.21
T ₁ (°C)	15.44	14.74	14.52	14.51	17.81	21044.13	0.3890	
T ₂ (°C)	15.24	14.68	14.53	14.51	15.68	21433.23	0.3877	
T ₃ (°C)	15.09	14.62	14.53	14.52	13.56	20939.59	0.3865	
T ₄ (°C)	14.96	14.59	14.53	14.52	11.56	20263.01	0.3853	
T ₅ (°C)	14.84	14.57	14.53	14.54	5.94	11745.74	0.3550	
T _{out} (°C)	14.76	14.54	14.52	14.54	5.31	11591.64	0.3542	
m _{water} (kg/s)		0.26			4.64	11094.99	0.3535	
P _{water,in} (kPa)	692.02	N/A	N/A	333.27	3.97	9983.20	0.3527	
P _{water,out} (kPa)	567.64	N/A	N/A	191.27	3.34	8608.23	0.3519	
P _{sat} (kPa)	60.64	59.99	59.89	59.72	0.00	0.00	0.3480	
P _{bundle,in} (kPa)		59.95			0.00	0.00	0.3480	
P _{bundle,out} (kPa)		59.68			0.00	0.00	0.3480	
m _{ref} (kg/s)		0.43			0.00	0.00	0.3480	
	Path B	Path C	Path D	Path E	0.00	0.00	0.3480	
T _{water,in} (°C)	15.58	15.56	15.59	15.58	0.00	0.00	0.3480	
T _{water,out} (°C)	14.63	14.67	14.66	14.63	0.00	0.00	0.3480	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	0.00	0.00	0.3480	
	Pre-boiler				0.00	0.00	0.3480	
T _{water,in} (°C)		50.40			0.00	0.00	0.3480	
T _{water,out} (°C)		34.22						
m _{water} (kg/s)		0.53						
T _{ref,in} (°C)		-7.22						
P _{ref,in} (kPa)		129.74						
P _{ref,out} (kPa)		121.32						

Point ID	R-123, P/D 1.5, 15 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.79	15.62	14.82	14.58	52.39	20904.22	0.2665	14.87
T ₁ (°C)	17.41	15.48	14.80	14.59	47.68	22766.58	0.2626	
T ₂ (°C)	16.91	15.29	14.73	14.59	42.67	24028.02	0.2587	
T ₃ (°C)	16.50	15.12	14.69	14.60	37.67	24774.26	0.2552	
T ₄ (°C)	16.15	14.99	14.66	14.60	32.96	25527.36	0.2522	
T ₅ (°C)	15.83	14.90	14.64	14.61	20.63	19013.99	0.1610	
T _{out} (°C)	15.61	14.82	14.61	14.60	18.35	19481.50	0.1607	
m _{water} (kg/s)			0.27		15.93	19503.28	0.1605	
P _{water,in} (kPa)	749.38	N/A	N/A	355.61	13.50	18366.72	0.1605	
P _{water,out} (kPa)	613.74	N/A	N/A	194.41	11.22	16261.36	0.1605	
P _{sat} (kPa)	60.55	59.82	59.63	59.45	6.01	9838.16	0.1073	
P _{bundle,in} (kPa)			59.99		5.33	9694.88	0.1064	
P _{bundle,out} (kPa)			59.40		4.61	8813.89	0.1056	
m _{ref} (kg/s)			0.42		3.90	7674.08	0.1047	
	Path B	Path C	Path D	Path E	3.22	6415.07	0.1039	
T _{water,in} (°C)	17.81	17.79	17.82	17.82	0.00	0.00	0.1000	
T _{water,out} (°C)	14.98	15.02	15.00	14.98	0.00	0.00	0.1000	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	0.00	0.00	0.1000	
	Pre-boiler				0.00	0.00	0.1000	
T _{water,in} (°C)			27.53		0.00	0.00	0.1000	
T _{water,out} (°C)			23.20					
m _{water} (kg/s)			0.91					
T _{ref,in} (°C)			-7.29					
P _{ref,in} (kPa)			90.76					
P _{ref,out} (kPa)			84.87					

Point ID	R-123, P/D 1.5, 15 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	18.03	15.88	15.08	14.83	49.56	20940.98	0.5061	14.89
T ₁ (°C)	17.64	15.75	15.04	14.84	44.88	22857.06	0.5022	
T ₂ (°C)	17.15	15.56	14.99	14.83	39.90	24201.58	0.4985	
T ₃ (°C)	16.74	15.39	14.95	14.83	34.93	24722.61	0.4950	
T ₄ (°C)	16.40	15.27	14.91	14.82	30.24	25351.22	0.4921	
T ₅ (°C)	16.09	15.18	14.89	14.83	19.21	19102.62	0.4043	
T _{out} (°C)	15.87	15.10	14.86	14.82	17.12	19844.40	0.4042	
m _{water} (kg/s)			0.26		14.89	20090.31	0.4042	
P _{water,in} (kPa)	692.83	N/A	N/A	334.94	12.66	19188.52	0.4043	
P _{water,out} (kPa)	569.51	N/A	N/A	190.50	10.56	17204.58	0.4046	
P _{sat} (kPa)	61.11	60.51	60.49	60.38	5.17	9066.25	0.3534	
P _{bundle,in} (kPa)			60.35		4.72	8833.12	0.3528	
P _{bundle,out} (kPa)			60.39		4.24	8498.71	0.3522	
m _{ref} (kg/s)			0.43		3.77	7952.69	0.3517	
	Path B	Path C	Path D	Path E	3.32	7151.36	0.3511	
T _{water,in} (°C)	18.04	18.02	18.04	18.03	0.00	0.00	0.3471	
T _{water,out} (°C)	15.24	15.26	15.23	15.23	0.00	0.00	0.3471	
m _{water} (kg/s)	0.31	0.31	0.29	0.31	0.00	0.00	0.3471	
	Pre-boiler				0.00	0.00	0.3471	
T _{water,in} (°C)			41.31		0.00	0.00	0.3471	
T _{water,out} (°C)			36.90					
m _{water} (kg/s)			1.91					
T _{ref,in} (°C)			-7.57					
P _{ref,in} (kPa)			129.05					
P _{ref,out} (kPa)			120.21					

Point ID	R-123, P/D 1.5, 15 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	21.10	17.36	15.73	15.14	86.75	18908.77	0.4422	14.90
T ₁ (°C)	20.46	17.07	15.63	15.12	80.00	20641.97	0.4402	
T ₂ (°C)	19.63	16.71	15.50	15.09	72.83	22113.80	0.4390	
T ₃ (°C)	18.92	16.37	15.39	15.07	65.65	22899.29	0.4386	
T ₄ (°C)	18.36	16.11	15.30	15.05	58.90	24741.18	0.4392	
T ₅ (°C)	17.76	15.92	15.24	15.04	40.28	20793.36	0.2707	
T _{out} (°C)	17.35	15.75	15.17	15.02	36.09	21820.22	0.2672	
m _{water} (kg/s)			0.27		31.64	22577.25	0.2639	
P _{water,in} (kPa)	750.13	N/A	N/A	355.91	27.19	22276.54	0.2612	
P _{water,out} (kPa)	613.25	N/A	N/A	196.21	23.01	20689.05	0.2591	
P _{sat} (kPa)	61.33	60.65	60.56	60.43	14.21	14991.64	0.1598	
P _{bundle,in} (kPa)			60.66		12.82	15170.90	0.1610	
P _{bundle,out} (kPa)			60.45		11.34	14900.68	0.1624	
m _{ref} (kg/s)			0.43		9.87	14156.62	0.1640	
	Path B	Path C	Path D	Path E	8.48	12822.02	0.1658	
T _{water,in} (°C)	21.14	21.13	21.15	21.14	3.38	9219.93	0.1044	
T _{water,out} (°C)	15.85	15.88	15.81	15.82	3.09	8938.84	0.1041	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	2.79	8510.38	0.1037	
	Pre-boiler				2.49	8036.80	0.1033	
T _{water,in} (°C)			29.02		2.20	7126.79	0.1030	
T _{water,out} (°C)			22.51					
m _{water} (kg/s)			0.62					
T _{ref,in} (°C)			-7.60					
P _{ref,in} (kPa)			91.11					
P _{ref,out} (kPa)			85.31					

Point ID	R-123, P/D 1.5, 15 30 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	20.83	17.26	15.69	15.09	83.27	19195.35	0.6718	15.10
T ₁ (°C)	20.22	16.98	15.59	15.06	76.65	20957.79	0.6698	
T ₂ (°C)	19.42	16.63	15.46	15.03	69.62	22521.76	0.6685	
T ₃ (°C)	18.73	16.31	15.34	14.99	62.59	23127.45	0.6682	
T ₄ (°C)	18.22	16.06	15.25	14.96	55.97	25016.24	0.6687	
T ₅ (°C)	17.63	15.88	15.19	14.95	38.59	20931.14	0.5094	
T _{out} (°C)	17.25	15.71	15.12	14.93	34.63	22064.41	0.5062	
m _{water} (kg/s)			0.27		30.43	22899.09	0.5033	
P _{water,in} (kPa)	748.19	N/A	N/A	353.59	26.23	22733.80	0.5008	
P _{water,out} (kPa)	611.82	N/A	N/A	195.79	22.27	21273.37	0.4990	
P _{sat} (kPa)	61.12	60.58	60.62	60.57	14.45	15759.88	0.4059	
P _{bundle,in} (kPa)			60.33		13.00	15999.48	0.4070	
P _{bundle,out} (kPa)			60.63		11.47	15696.74	0.4084	
m _{ref} (kg/s)			0.43		9.93	14878.63	0.4099	
	Path B	Path C	Path D	Path E	8.48	13414.41	0.4115	
T _{water,in} (°C)	20.86	20.86	20.88	20.87	4.49	12344.63	0.3547	
T _{water,out} (°C)	15.78	15.77	15.72	15.74	4.03	11993.62	0.3542	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	3.55	11316.42	0.3536	
	Pre-boiler				3.08	10575.37	0.3531	
T _{water,in} (°C)			41.77		2.62	9071.58	0.3525	
T _{water,out} (°C)			37.31					
m _{water} (kg/s)			1.91					
T _{ref,in} (°C)			-7.03					
P _{ref,in} (kPa)			129.78					
P _{ref,out} (kPa)			121.56					

Point ID	R-123, P/D 1.5, 15 42 0.24							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	24.33	18.77	16.26	15.25	118.23	17083.07	0.7293	15.05
T ₁ (°C)	23.42	18.31	16.07	15.19	109.64	18746.35	0.7280	
T ₂ (°C)	22.19	17.76	15.84	15.12	100.52	20320.39	0.7279	
T ₃ (°C)	21.12	17.24	15.65	15.06	91.40	21416.72	0.7293	
T ₄ (°C)	20.28	16.83	15.49	15.01	82.81	23455.58	0.7320	
T ₅ (°C)	19.38	16.53	15.38	14.98	57.80	20496.64	0.4863	
T _{out} (°C)	18.77	16.27	15.27	14.94	51.78	21708.15	0.4815	
m _{water} (kg/s)			0.25		45.39	22712.35	0.4772	
P _{water,in} (kPa)	664.62	N/A	N/A	325.33	39.00	22827.89	0.4736	
P _{water,out} (kPa)	547.27	N/A	N/A	185.17	32.99	21485.08	0.4709	
P _{sat} (kPa)	60.97	60.44	60.47	60.45	23.08	18201.17	0.3264	
P _{bundle,in} (kPa)			60.20		20.62	18892.55	0.3279	
P _{bundle,out} (kPa)			60.52		18.00	18898.01	0.3298	
m _{ref} (kg/s)			0.43		15.39	18189.66	0.3320	
	Path B	Path C	Path D	Path E	12.93	16453.24	0.3344	
T _{water,in} (°C)	24.37	24.38	24.38	24.37	7.38	15254.70	0.2449	
T _{water,out} (°C)	16.45	16.39	16.30	16.39	6.61	15180.88	0.2439	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	5.78	14707.98	0.2429	
	Pre-boiler				4.96	13987.43	0.2420	
T _{water,in} (°C)			36.18		4.18	12239.61	0.2410	
T _{water,out} (°C)			31.37					
m _{water} (kg/s)			1.31					
T _{ref,in} (°C)			-5.58					
P _{ref,in} (kPa)			115.66					
P _{ref,out} (kPa)			104.85					

Point ID	R-123, P/D 1.5, 15 42 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	24.76	21.21	17.98	16.43	74.43	9306.52	0.7998	15.01
T ₁ (°C)	24.39	20.62	17.71	16.31	73.00	10052.91	0.8074	
T ₂ (°C)	23.63	19.93	17.36	16.18	71.49	10949.58	0.8166	
T ₃ (°C)	22.88	19.28	17.07	16.07	69.98	11712.38	0.8270	
T ₄ (°C)	22.30	18.74	16.81	15.97	68.55	12930.99	0.8377	
T ₅ (°C)	21.60	18.35	16.63	15.90	78.15	19135.19	0.6325	
T _{out} (°C)	21.21	17.99	16.45	15.84	70.69	20050.76	0.6261	
m _{water} (kg/s)			0.27		62.75	20804.91	0.6198	
P _{water,in} (kPa)	747.17	N/A	N/A	354.71	54.82	20926.53	0.6141	
P _{water,out} (kPa)	611.61	N/A	N/A	198.15	47.35	20092.05	0.6094	
P _{sat} (kPa)	62.87	62.39	62.47	62.48	37.19	19598.23	0.4617	
P _{bundle,in} (kPa)			62.02		33.65	20780.18	0.4624	
P _{bundle,out} (kPa)			62.58		29.90	21445.33	0.4634	
m _{ref} (kg/s)			0.43		26.14	21568.21	0.4648	
	Path B	Path C	Path D	Path E	22.60	20636.55	0.4662	
T _{water,in} (°C)	24.85	24.87	24.87	24.86	15.12	21072.01	0.3729	
T _{water,out} (°C)	17.75	17.22	17.18	17.72	13.53	21737.23	0.3710	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	11.83	21921.48	0.3689	
	Pre-boiler				10.13	21527.49	0.3669	
T _{water,in} (°C)			41.68		8.53	19707.05	0.3650	
T _{water,out} (°C)			37.63					
m _{water} (kg/s)			2.12					
T _{ref,in} (°C)			-6.55					
P _{ref,in} (kPa)			130.00					
P _{ref,out} (kPa)			122.71					

Point ID	R-123, P/D 1.5, 15 45 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	25.37	19.48	16.80	15.71	128.94	17462.84	0.6284	15.07
T ₁ (°C)	24.36	18.99	16.60	15.64	119.05	18998.20	0.6261	
T ₂ (°C)	23.06	18.40	16.36	15.57	108.55	20329.27	0.6251	
T ₃ (°C)	21.95	17.85	16.15	15.50	98.05	21157.74	0.6258	
T ₄ (°C)	21.06	17.41	15.97	15.45	88.16	22771.75	0.6279	
T ₅ (°C)	20.12	17.09	15.85	15.41	62.65	20410.56	0.3662	
T _{out} (°C)	19.47	16.81	15.73	15.38	56.26	21594.74	0.3611	
m _{water} (kg/s)			0.26		49.46	22611.57	0.3565	
P _{water,in} (kPa)	690.78	N/A	N/A	334.91	42.67	22765.74	0.3528	
P _{water,out} (kPa)	568.13	N/A	N/A	190.58	36.28	21567.30	0.3501	
P _{sat} (kPa)	61.97	61.37	61.37	61.32	25.40	18422.74	0.1953	
P _{bundle,in} (kPa)			61.26		22.77	19200.12	0.1969	
P _{bundle,out} (kPa)			61.37		19.99	19349.20	0.1989	
m _{ref} (kg/s)			0.43		17.20	18847.58	0.2013	
	Path B	Path C	Path D	Path E	14.58	17301.55	0.2038	
T _{water,in} (°C)	25.43	25.43	25.44	25.43	8.13	15756.34	0.1077	
T _{water,out} (°C)	16.95	16.93	16.82	16.87	7.28	15718.45	0.1067	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	6.38	15336.34	0.1056	
	Pre-boiler				5.49	14600.36	0.1046	
T _{water,in} (°C)			35.80		4.64	12880.13	0.1035	
T _{water,out} (°C)			22.56					
m _{water} (kg/s)			0.28					
T _{ref,in} (°C)			-3.57					
P _{ref,in} (kPa)			93.79					
P _{ref,out} (kPa)			87.45					

Point ID	R-123, P/D 1.5, 20 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	15.50	14.64	14.40	14.41	21.45	19931.50	0.1357	30.13
T ₁ (°C)	15.35	14.61	14.44	14.42	19.44	21317.58	0.1349	
T ₂ (°C)	15.14	14.55	14.42	14.43	17.30	21909.85	0.1341	
T ₃ (°C)	14.98	14.50	14.42	14.43	15.16	21894.91	0.1333	
T ₄ (°C)	14.84	14.47	14.43	14.44	13.15	21688.13	0.1326	
T ₅ (°C)	14.72	14.45	14.44	14.46	6.37	12262.14	0.1087	
T _{out} (°C)	14.63	14.44	14.44	14.46	5.50	11473.11	0.1079	
m _{water} (kg/s)			0.27		4.57	10338.16	0.1071	
P _{water,in} (kPa)	750.34	N/A	N/A	355.50	3.64	8491.63	0.1063	
P _{water,out} (kPa)	613.92	N/A	N/A	195.57	2.77	6535.89	0.1055	
P _{sat} (kPa)	60.58	59.79	59.55	59.28	0.00	0.00	0.1030	
P _{bundle,in} (kPa)			60.09		0.00	0.00	0.1030	
P _{bundle,out} (kPa)			59.18		0.00	0.00	0.1030	
m _{ref} (kg/s)			0.57		0.00	0.00	0.1030	
	Path B	Path C	Path D	Path E	0.00	0.00	0.1030	
T _{water,in} (°C)	15.51	15.48	15.52	15.51	0.00	0.00	0.1030	
T _{water,out} (°C)	14.55	14.61	14.60	14.58	0.00	0.00	0.1030	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	0.00	0.00	0.1030	
	Pre-boiler				0.00	0.00	0.1030	
T _{water,in} (°C)			30.28		0.00	0.00	0.1030	
T _{water,out} (°C)			27.80					
m _{water} (kg/s)			2.19					
T _{ref,in} (°C)			-7.79					
P _{ref,in} (kPa)			101.69					
P _{ref,out} (kPa)			94.67					

Point ID	R-123, P/D 1.5, 20 5 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	15.71	14.90	14.65	14.62	19.24	19522.14	0.3764	20.02
T ₁ (°C)	15.56	14.87	14.65	14.63	17.34	20792.50	0.3756	
T ₂ (°C)	15.37	14.81	14.66	14.64	15.32	21215.64	0.3747	
T ₃ (°C)	15.22	14.76	14.65	14.64	13.30	20837.81	0.3739	
T ₄ (°C)	15.09	14.73	14.66	14.65	11.39	20311.58	0.3731	
T ₅ (°C)	14.98	14.70	14.66	14.66	5.79	11501.26	0.3505	
T _{out} (°C)	14.89	14.68	14.65	14.66	5.21	11457.68	0.3500	
m _{water} (kg/s)			0.26		4.59	11020.08	0.3494	
P _{water,in} (kPa)	686.17	N/A	N/A	333.19	3.97	10034.64	0.3489	
P _{water,out} (kPa)	563.66	N/A	N/A	191.32	3.38	8805.79	0.3484	
P _{sat} (kPa)	60.87	60.32	60.25	60.08	0.00	0.00	0.3453	
P _{bundle,in} (kPa)			60.16		0.00	0.00	0.3453	
P _{bundle,out} (kPa)			60.07		0.00	0.00	0.3453	
m _{ref} (kg/s)			0.57		0.00	0.00	0.3453	
	Path B	Path C	Path D	Path E	0.00	0.00	0.3453	
T _{water,in} (°C)	15.70	15.69	15.71	15.70	0.00	0.00	0.3453	
T _{water,out} (°C)	14.76	14.79	14.79	14.76	0.00	0.00	0.3453	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	0.00	0.00	0.3453	
	Pre-boiler				0.00	0.00	0.3453	
T _{water,in} (°C)			62.18		0.00	0.00	0.3453	
T _{water,out} (°C)			38.84					
m _{water} (kg/s)			0.48					
T _{ref,in} (°C)			-6.36					
P _{ref,in} (kPa)			130.72					
P _{ref,out} (kPa)			131.83					

Point ID	R-123, P/D 1.5, 20 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.90	15.66	14.83	14.57	54.00	20888.61	0.2318	19.90
T ₁ (°C)	17.51	15.52	14.81	14.58	49.16	22763.83	0.2288	
T ₂ (°C)	17.00	15.32	14.73	14.58	44.02	24043.11	0.2259	
T ₃ (°C)	16.57	15.14	14.68	14.58	38.88	24819.41	0.2232	
T ₄ (°C)	16.21	15.01	14.65	14.58	34.05	25618.57	0.2209	
T ₅ (°C)	15.88	14.91	14.63	14.59	21.49	19317.44	0.1499	
T _{out} (°C)	15.65	14.83	14.60	14.58	19.11	19848.83	0.1497	
m _{water} (kg/s)			0.27		16.59	19926.66	0.1495	
P _{water,in} (kPa)	749.72	N/A	N/A	353.91	14.07	18819.44	0.1495	
P _{water,out} (kPa)	613.99	N/A	N/A	195.27	11.69	16685.73	0.1495	
P _{sat} (kPa)	60.46	59.77	59.61	59.43	6.49	10422.47	0.1076	
P _{bundle,in} (kPa)			59.86		5.77	10334.46	0.1070	
P _{bundle,out} (kPa)			59.38		5.01	9472.61	0.1063	
m _{ref} (kg/s)			0.57		4.24	8320.45	0.1056	
	Path B	Path C	Path D	Path E	3.53	7012.46	0.1050	
T _{water,in} (°C)	17.92	17.90	17.92	17.91	0.00	0.00	0.1018	
T _{water,out} (°C)	14.98	15.02	14.99	14.98	0.00	0.00	0.1018	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	0.00	0.00	0.1018	
	Pre-boiler				0.00	0.00	0.1018	
T _{water,in} (°C)			29.16		0.00	0.00	0.1018	
T _{water,out} (°C)			27.17					
m _{water} (kg/s)			2.65					
T _{ref,in} (°C)			-6.85					
P _{ref,in} (kPa)			101.73					
P _{ref,out} (kPa)			94.34					

Point ID	R-123, P/D 1.5, 20 15 0.35							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	18.29	16.16	15.35	15.10	49.40	21023.07	0.4660	20.23
T ₁ (°C)	17.90	16.02	15.31	15.10	44.70	22924.75	0.4631	
T ₂ (°C)	17.41	15.84	15.26	15.09	39.70	24267.76	0.4604	
T ₃ (°C)	17.00	15.67	15.22	15.09	34.71	24767.82	0.4578	
T ₄ (°C)	16.67	15.54	15.18	15.08	30.01	25353.25	0.4557	
T ₅ (°C)	16.36	15.46	15.16	15.09	18.98	18827.40	0.3908	
T _{out} (°C)	16.15	15.38	15.13	15.08	16.94	19553.08	0.3907	
m _{water} (kg/s)			0.26		14.77	19798.88	0.3907	
P _{water,in} (kPa)	690.70	N/A	N/A	335.47	12.60	18992.74	0.3908	
P _{water,out} (kPa)	567.73	N/A	N/A	190.96	10.55	17108.15	0.3910	
P _{sat} (kPa)	61.72	61.16	61.16	61.07	5.34	9328.25	0.3530	
P _{bundle,in} (kPa)			60.93		4.88	9100.30	0.3526	
P _{bundle,out} (kPa)			61.09		4.38	8741.56	0.3521	
m _{ref} (kg/s)			0.58		3.88	8175.95	0.3517	
	Path B	Path C	Path D	Path E	3.42	7360.77	0.3513	
T _{water,in} (°C)	18.30	18.28	18.30	18.29	0.00	0.00	0.3482	
T _{water,out} (°C)	15.49	15.51	15.48	15.47	0.00	0.00	0.3482	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	0.00	0.00	0.3482	
	Pre-boiler				0.00	0.00	0.3482	
T _{water,in} (°C)			48.32		0.00	0.00	0.3482	
T _{water,out} (°C)			44.10					
m _{water} (kg/s)			2.71					
T _{ref,in} (°C)			-7.30					
P _{ref,in} (kPa)			130.70					
P _{ref,out} (kPa)			131.84					

Point ID	R-123, P/D 1.5, 20 30 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	21.29	17.38	15.67	15.04	90.48	18854.65	0.3651	19.95
T ₁ (°C)	20.63	17.07	15.56	15.01	83.52	20603.87	0.3636	
T ₂ (°C)	19.76	16.69	15.42	14.98	76.12	22106.40	0.3627	
T ₃ (°C)	19.01	16.34	15.30	14.95	68.72	22948.75	0.3626	
T ₄ (°C)	18.43	16.06	15.20	14.92	61.75	24864.87	0.3633	
T ₅ (°C)	17.80	15.86	15.13	14.91	42.33	21033.94	0.2313	
T _{out} (°C)	17.37	15.69	15.06	14.89	37.95	22123.68	0.2286	
m _{water} (kg/s)			0.27		33.30	22971.35	0.2261	
P _{water,in} (kPa)	747.69	N/A	N/A	354.32	28.65	22764.69	0.2240	
P _{water,out} (kPa)	611.51	N/A	N/A	196.15	24.27	21236.96	0.2224	
P _{sat} (kPa)	60.98	60.33	60.26	60.13	15.17	15620.21	0.1450	
P _{bundle,in} (kPa)			60.31		13.70	15893.85	0.1459	
P _{bundle,out} (kPa)			60.12		12.13	15700.84	0.1470	
m _{ref} (kg/s)			0.57		10.56	15017.54	0.1482	
	Path B	Path C	Path D	Path E	9.08	13679.83	0.1495	
T _{water,in} (°C)	21.34	21.33	21.34	21.34	3.89	10415.26	0.1016	
T _{water,out} (°C)	15.78	15.80	15.74	15.74	3.53	10097.46	0.1013	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	3.15	9575.16	0.1010	
	Pre-boiler				2.78	8987.55	0.1006	
T _{water,in} (°C)			31.49		2.42	7872.20	0.1003	
T _{water,out} (°C)			24.59					
m _{water} (kg/s)			0.77					
T _{ref,in} (°C)			-7.50					
P _{ref,in} (kPa)			100.07					
P _{ref,out} (kPa)			93.10					

Point ID	R-123, P/D 1.5, 20 40 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	23.95	18.71	16.38	15.47	114.97	17856.07	0.4527	20.15
T ₁ (°C)	23.04	18.29	16.21	15.42	106.03	19469.39	0.4510	
T ₂ (°C)	21.89	17.77	16.01	15.36	96.53	20849.75	0.4501	
T ₃ (°C)	20.90	17.29	15.84	15.31	87.03	21694.52	0.4503	
T ₄ (°C)	20.11	16.91	15.69	15.27	78.10	23399.86	0.4514	
T ₅ (°C)	19.28	16.64	15.59	15.24	54.74	20638.21	0.2793	
T _{out} (°C)	18.70	16.39	15.49	15.21	49.11	21833.93	0.2760	
m _{water} (kg/s)			0.26		43.13	22867.98	0.2729	
P _{water,in} (kPa)	689.15	N/A	N/A	332.86	37.14	22983.12	0.2703	
P _{water,out} (kPa)	566.29	N/A	N/A	189.95	31.51	21672.04	0.2685	
P _{sat} (kPa)	61.67	61.05	61.03	60.93	21.07	17415.95	0.1667	
P _{bundle,in} (kPa)			60.95		18.89	17964.82	0.1679	
P _{bundle,out} (kPa)			60.96		16.57	17897.03	0.1693	
m _{ref} (kg/s)			0.58		14.25	17216.89	0.1709	
	Path B	Path C	Path D	Path E	12.06	15634.35	0.1727	
T _{water,in} (°C)	23.99	23.99	24.00	23.99	6.34	13740.88	0.1100	
T _{water,out} (°C)	16.54	16.55	16.45	16.48	5.69	13538.83	0.1094	
m _{water} (kg/s)	0.31	0.31	0.29	0.31	5.00	13009.66	0.1088	
	Pre-boiler				4.31	12257.29	0.1082	
T _{water,in} (°C)			34.56		3.66	10690.61	0.1076	
T _{water,out} (°C)			24.92					
m _{water} (kg/s)			0.51					
T _{ref,in} (°C)			-2.82					
P _{ref,in} (kPa)			103.23					
P _{ref,out} (kPa)			95.67					

Point ID	R-123, P/D 1.5, 25 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	15.92	15.07	14.82	14.83	21.25	19985.15	0.1258	25.00
T ₁ (°C)	15.77	15.04	14.87	14.84	19.25	21392.64	0.1251	
T ₂ (°C)	15.57	14.98	14.84	14.85	17.12	21999.73	0.1245	
T ₃ (°C)	15.41	14.93	14.85	14.86	14.99	21970.98	0.1238	
T ₄ (°C)	15.27	14.90	14.85	14.87	12.99	21732.92	0.1232	
T ₅ (°C)	15.15	14.87	14.87	14.89	6.30	12478.51	0.1043	
T _{out} (°C)	15.06	14.86	14.86	14.88	5.49	11857.54	0.1037	
m _{water} (kg/s)			0.27		4.63	10905.53	0.1031	
P _{water,in} (kPa)	750.58	N/A	N/A	355.55	3.77	9197.08	0.1025	
P _{water,out} (kPa)	614.30	N/A	N/A	194.79	2.96	7351.20	0.1019	
P _{sat} (kPa)	61.63	60.85	60.64	60.35	0.00	0.00	0.0998	
P _{bundle,in} (kPa)			61.10		0.00	0.00	0.0998	
P _{bundle,out} (kPa)			60.25		0.00	0.00	0.0998	
m _{ref} (kg/s)			0.71		0.00	0.00	0.0998	
	Path B	Path C	Path D	Path E	0.00	0.00	0.0998	
T _{water,in} (°C)	15.94	15.91	15.95	15.93	0.00	0.00	0.0998	
T _{water,out} (°C)	14.98	15.04	15.03	15.00	0.00	0.00	0.0998	
m _{water} (kg/s)	0.31	0.31	0.29	0.31	0.00	0.00	0.0998	
	Pre-boiler				0.00	0.00	0.0998	
T _{water,in} (°C)			32.49		0.00	0.00	0.0998	
T _{water,out} (°C)			29.93					
m _{water} (kg/s)			2.66					
T _{ref,in} (°C)			-7.95					
P _{ref,in} (kPa)			112.03					
P _{ref,out} (kPa)			104.40					

Point ID	R-123, P/D 1.5, 25 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	17.91	15.90	15.17	14.96	48.73	21241.99	0.1973	25.03
T ₁ (°C)	17.55	15.77	15.15	14.96	44.27	23146.32	0.1951	
T ₂ (°C)	17.09	15.60	15.09	14.97	39.53	24406.91	0.1929	
T ₃ (°C)	16.71	15.44	15.05	14.97	34.79	25098.49	0.1909	
T ₄ (°C)	16.39	15.33	15.03	14.97	30.33	25764.13	0.1891	
T ₅ (°C)	16.09	15.25	15.01	14.99	18.86	19172.52	0.1393	
T _{out} (°C)	15.89	15.17	14.98	14.98	16.79	19735.89	0.1392	
m _{water} (kg/s)			0.27		14.59	19822.16	0.1391	
P _{water,in} (kPa)	750.49	N/A	N/A	356.43	12.40	18747.52	0.1391	
P _{water,out} (kPa)	614.20	N/A	N/A	197.32	10.33	16644.55	0.1392	
P _{sat} (kPa)	61.51	60.82	60.67	60.48	5.31	9385.66	0.1103	
P _{bundle,in} (kPa)			60.88		4.74	9295.89	0.1099	
P _{bundle,out} (kPa)			60.43		4.14	8514.74	0.1095	
m _{ref} (kg/s)			0.72		3.53	7501.60	0.1090	
	Path B	Path C	Path D	Path E	2.97	6364.31	0.1086	
T _{water,in} (°C)	17.93	17.91	17.94	17.92	0.00	0.00	0.1065	
T _{water,out} (°C)	15.33	15.37	15.34	15.33	0.00	0.00	0.1065	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	0.00	0.00	0.1065	
	Pre-boiler				0.00	0.00	0.1065	
T _{water,in} (°C)			32.81		0.00	0.00	0.1065	
T _{water,out} (°C)			29.74					
m _{water} (kg/s)			2.19					
T _{ref,in} (°C)			-6.19					
P _{ref,in} (kPa)			113.90					
P _{ref,out} (kPa)			105.41					

Point ID	R-123, P/D 1.5, 35 5 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	16.14	15.31	15.06	15.06	20.95	20159.84	0.1140	35.04
T ₁ (°C)	15.99	15.28	15.10	15.08	18.93	21538.98	0.1135	
T ₂ (°C)	15.79	15.22	15.08	15.09	16.78	22048.87	0.1130	
T ₃ (°C)	15.63	15.17	15.08	15.10	14.63	21864.96	0.1126	
T ₄ (°C)	15.50	15.14	15.09	15.10	12.60	21432.38	0.1122	
T ₅ (°C)	15.38	15.11	15.10	15.12	6.17	12415.82	0.0990	
T _{out} (°C)	15.29	15.10	15.09	15.12	5.39	11794.30	0.0986	
m _{water} (kg/s)			0.27		4.55	10865.63	0.0982	
P _{water,in} (kPa)	751.00	N/A	N/A	354.95	3.71	9170.19	0.0977	
P _{water,out} (kPa)	613.80	N/A	N/A	194.63	2.92	7368.30	0.0973	
P _{sat} (kPa)	62.18	61.45	61.25	60.98	0.00	0.00	0.0958	
P _{bundle,in} (kPa)			61.58		0.00	0.00	0.0958	
P _{bundle,out} (kPa)			60.86		0.00	0.00	0.0958	
m _{ref} (kg/s)			1.00		0.00	0.00	0.0958	
	Path B	Path C	Path D	Path E	0.00	0.00	0.0958	
T _{water,in} (°C)	16.16	16.13	16.16	16.15	0.00	0.00	0.0958	
T _{water,out} (°C)	15.21	15.27	15.26	15.23	0.00	0.00	0.0958	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	0.00	0.00	0.0958	
	Pre-boiler				0.00	0.00	0.0958	
T _{water,in} (°C)			35.02		0.00	0.00	0.0958	
T _{water,out} (°C)			31.61					
m _{water} (kg/s)			2.67					
T _{ref,in} (°C)			-6.44					
P _{ref,in} (kPa)			120.97					
P _{ref,out} (kPa)			124.76					

Point ID	R-123, P/D 1.5, 35 15 0.10							
	Tube A1	Tube A2	Tube A3	Tube A4	q'' (kW/m)	h (W/m ² .°C)	x	G (kg/m ² .s)
T _{in} (°C)	18.18	16.21	15.50	15.30	47.71	21245.00	0.1620	
T ₁ (°C)	17.83	16.09	15.49	15.30	43.32	23128.05	0.1604	
T ₂ (°C)	17.38	15.92	15.42	15.31	38.66	24363.91	0.1589	
T ₃ (°C)	17.00	15.77	15.39	15.31	34.00	25043.91	0.1574	
T ₄ (°C)	16.69	15.66	15.36	15.31	29.62	25663.92	0.1562	
T ₅ (°C)	16.40	15.58	15.35	15.32	18.33	19110.88	0.1210	
T _{out} (°C)	16.20	15.50	15.32	15.32	16.35	19718.63	0.1209	
m _{water} (kg/s)		0.27			14.24	19843.85	0.1209	
P _{water,in} (kPa)	748.03	N/A	N/A	351.34	12.13	18859.65	0.1209	
P _{water,out} (kPa)	612.03	N/A	N/A	194.57	10.15	16864.72	0.1210	
P _{sat} (kPa)	62.36	61.67	61.54	61.34	5.13	9268.63	0.1004	34.79
P _{bundle,in} (kPa)		61.71			4.57	9139.83	0.1002	
P _{bundle,out} (kPa)		61.28			3.98	8318.19	0.0999	
m _{ref} (kg/s)		0.99			3.38	7283.49	0.0995	
	Path B	Path C	Path D	Path E	2.82	6134.88	0.0993	
T _{water,in} (°C)	18.20	18.18	18.22	18.20	0.00	0.00	0.0978	
T _{water,out} (°C)	15.65	15.69	15.66	15.64	0.00	0.00	0.0978	
m _{water} (kg/s)	0.31	0.31	0.30	0.31	0.00	0.00	0.0978	
	Pre-boiler				0.00	0.00	0.0978	
T _{water,in} (°C)		35.50			0.00	0.00	0.0978	
T _{water,out} (°C)		31.51						
m _{water} (kg/s)		2.20						
T _{ref,in} (°C)		-4.89						
P _{ref,in} (kPa)		126.82						
P _{ref,out} (kPa)		127.60						