

208
SIMULATION OF THE TRANSIENT BEHAVIOR OF
STRATIFIED AIR CONDITIONING SYSTEMS

by

ALAN THOMAS LEARD

B.S., Kansas State University, 1981

A THESIS

submitted in partial fulfillment of the
requirements for the degree


MASTER OF SCIENCE

Department of Mechanical Engineering

KANSAS STATE UNIVERSITY
Manhattan, Kansas

1983

Approved by:



Major Professor

LD
2668
.TY
1983
L42
C.2

A11202 570905

TABLE OF CONTENTS

Chapter	Page
I. INTRODUCTION	1
II. SYSTEM DESCRIPTION	3
III. COMPUTER MODEL DESCRIPTION	7
Finite-Difference Analysis	8
Mass Balance Model	9
Energy Balances of the Air Elements	11
Energy Balances of the Roof and Floor Elements	16
Buoyancy Approximation	20
IV. VERIFICATION	22
Verification of Steady-State Behavior	22
No-Load Verification of Transient Behavior	27
V. COMPUTED RESULTS	30
Effect of Supply Air Inlet Height	31
Effect of Return Air Extraction Height	33
Effect of Roof Construction	35
Effect of Lighting Height	37
Effect of Ventilation Air Extraction Height	39
Effect of Ventilation Rate	40
Effect of Occupancy Pattern	42
Summary of the Effects of System Variables Investigated	43
VI. RECOMMENDATIONS	45
LIST OF REFERENCES	47
APPENDIX A	48
List of Symbols	49
APPENDIX B	53
Detailed Description of Transient Cases Investigated	54
APPENDIX C	68
Listing of the Computer Program Using the Fortran Language	69

LIST OF TABLES

Table	Page
1. Effect of Supply Air Inlet Height on Plant Cooling Loads	33
2. Effect of Return Air Extraction Height on Plant Cooling Loads . . .	35
3. Effect of Roof Construction on Plant Cooling Loads	37
4. Effect of Lighting Height on Plant Cooling Loads	38
5. Effect of Ventilation Height on Plant Cooling Loads	40
6. Effect of Ventilation Rate on Plant Cooling Loads	41
7. Effect of Occupancy Pattern on Plant Cooling Loads	43

LIST OF FIGURES

Figure	Page
1. Energy and Mass Transfer Model as Approximated by the Computer Model	5
2. Daily Sol-Air and Ambient Air Temperatures	6
3. Energy and Mass Transfer Model of the Air Element Adjacent to the Floor	10
4. Energy and Mass Transfer Model of a Typical Air Element	12
5. Energy and Mass Transfer Model of the Air Element Adjacent to the Roof	15
6. Energy Transfer Model of the Roof	17
7. Energy Transfer Model of the Floor	17
8. Comparison of Computed and Measured Results; Roof Load Only . . .	24
9. Comparison of Computed and Measured Results; Floor Load Only . .	25
10. Comparison of Computed and Measured Results; Lighting Load Only .	26
11. Transient No-Load Behavior	28

CHAPTER I

INTRODUCTION

Recently there has developed increasing interest in air conditioning large industrial buildings and manufacturing facilities. This activity is due to reports of increases in worker productivity and reductions in absenteeism in air-conditioned surroundings (1). Concurrent with the increased use of air conditioning systems runs the desire to reduce the cost, both initial and operating, of these systems.

One proposed method of reducing plant cooling load, and therefore air conditioning system cost, is known as thermal stratification. A thermally stratified system operates by supplying conditioned air to only the lower occupied levels, known as the conditioned zone. The temperature of air above the conditioned zone, known as the stratified zone, is uncontrolled. At its lower boundary, the air temperature approaches the conditioned zone temperature and at the upper boundary it approaches the roof temperature. Hence the name thermal stratification.

It is currently believed that proper design of a stratified system will isolate certain loads (e.g., lighting loads, roof loads, and other load sources located in the stratified zone) from the plant cooling load.

Upon review of previous investigations in the area of cooling load reduction, the approaches taken can be separated into two general areas. One method essentially involves application of numerous methods of air conditioning load reduction (e.g., thermal storage, stratification, and spot cooling)

**THIS BOOK
CONTAINS
NUMEROUS PAGES
WITH THE ORIGINAL
PRINTING BEING
SKEWED
DIFFERENTLY FROM
THE TOP OF THE
PAGE TO THE
BOTTOM.**

**THIS IS AS RECEIVED
FROM THE
CUSTOMER.**

to a proposed building (2). The effects of these methods are then qualitatively estimated; savings from these systems is often reported to range from 30% to over 50%. As in many field investigations, these results are compared to poorly defined data, usually not noting all of the design parameters used to obtain the results.

Despite the general lack of quantitative evaluations of these systems, there are a number of them operating successfully (3). This success can, in most cases, be attributed to appropriate use of basic engineering judgement.

The other method of investigation attempts to discover the influence of geometric and load parameters on the temperature profile and cooling loads (3, 4, 5, 6, 7). One investigation was conducted under controlled steady-state load conditions in a scale model test chamber (5, 6). The model studies provided steady-state experimental temperature distributions under the actual range of operating conditions which occur in industrial plants.

Additionally, a computer model was developed to assist in analyzing the stratification process and to aid in experimental data reduction (5, 7). There appears to be reasonable correlation between the computed and experimental results.

Due to the steady-state load limitation of the previous investigation, it was proposed to extend this work to include non-steady-state load conditions. The purpose of the current work is to determine the transient effects of internal and external loads, supply, return, and ventilation rates, and also structural thermal storage on air temperature patterns and plant cooling load.

CHAPTER II

SYSTEM DESCRIPTION

To initiate discussion of a typical stratified air conditioning system, it is first necessary to identify the modes of energy transfer influencing the air temperature within the structure. Figure 1 is a representation of the energy and mass transfers included in the model developed here. These approximate the exchanges occurring in a typical installation.

The building envelope exchanges energy with the exterior environment by convection and radiation at the exterior roof surface and by transmission through the walls. For the exterior roof, radiation and convection effects (q_r) are combined in the model and treated purely as convection by the sol-air temperature (SAT) method (8). Figure 2 is a plot of the daily roof SAT and ambient air temperature patterns used in this analysis. Daily patterns may be adjusted according to building location.

For the walls, energy transfer by transmission (q_w) occurs between the ambient air and the air within the building. Transmission through the walls is approximated as occurring instantaneously (no storage) because of the common practice of employing low thermal mass walls in industrial building construction.

The plant cooling load is rejected to the ambient through the air conditioning system. Additionally, plant exhaust air (\dot{m}_v) and its associated energy may be rejected to the ambient via the ventilation system.

The floor slab conducts energy to the ground (q_f) beneath the slab. A relatively constant deep ground temperature is assumed for the transient conduction model of the floor slab.

Internally, the floor upper surface receives energy by radiation from the roof interior (q_{rr}) and from the lights (q_{lr}). The floor exchanges energy with the air in the conditioned space by convection (q_{fc}).

In addition to radiation to the floor, the interior roof surface exchanges energy by convection (q_{rc}) with air in contact with it in the stratified zone. Concentrated loads (q_{ic}) within the stratified zone contribute energy by convection to the air in this region.

The convective portion of the lighting load (q_{lc}) will be contributed to either the conditioned zone or the stratified zone depending upon the location of the lighting fixtures. Equipment and occupant loads (q_{id}) contribute energy by convection to the air within the conditioned zone.

If only the sensible portion of the energy transfer is considered, the energy balance of the entire system, shown in Figure 1, is as follows.

$$\begin{aligned} \dot{q}_r + \dot{q}_w + \dot{q}_{lc} + \dot{q}_{lr} + \dot{q}_{id} + \dot{q}_{ic} - \dot{q}_f - \dot{m}_v C T(M) - \dot{m}_r C T(MRET) \\ + \dot{m}_s C TS = \frac{\Delta(\text{Energy Stored})_{\text{air, roof, floor.}}}{\Delta\theta} \end{aligned}$$

**THIS BOOK
CONTAINS
NUMEROUS PAGES
WITH DIAGRAMS
THAT ARE CROOKED
COMPARED TO THE
REST OF THE
INFORMATION ON
THE PAGE.**

**THIS IS AS
RECEIVED FROM
CUSTOMER.**




Figure 1. Energy and Mass Transfer Model as Approximated by the Computer Model.




Figure 2. Daily Sol-Air and Ambient Air Temperatures.

**THIS BOOK
CONTAINS
NUMEROUS PAGES
THAT WERE
BOUND WITHOUT
PAGE NUMBERS.**

**THIS IS AS
RECEIVED FROM
CUSTOMER.**

CHAPTER III

COMPUTER MODEL DESCRIPTION

The computer model development is discussed in five distinct sections: Finite-Difference Analysis, Mass Balance Model, Energy Balances of Air Elements, Energy Balances of the Roof and Floor Elements, and the Buoyancy Approximation. A complete listing of the computer program is contained in Appendix C.

The following assumptions, based on the results of experimentation with the scale model test chamber (5, 7), are employed in development of the transient model.

1. The boundary between the conditioned zone and the stratified zone is assumed to lie directly above the level at which supply air is introduced.

2. Supply air is assumed to be distributed "perfectly" among all air elements below the level of supply (i.e., it is distributed uniformly in the conditioned zone).

3. Consistent with the above assumption, all convective loads that originate below the level of supply will be distributed evenly in the conditioned zone.

The last two assumptions represent the well-mixed assumption which approximates a well designed distribution system.

Finite-Difference Analysis

Due to the complex nature of the boundary conditions present in this investigation, analytical methods of solution are not practical or possible. However, the numerical finite-difference method of approximation is both possible and convenient. These methods are particularly well suited for use with digital computers.

In this analysis, the in-plant air, roof, and floor are each subdivided horizontally into a number of smaller elements. Each element is then assigned a reference point at its center, beginning with Element (I) in the floor, and continuing sequentially through Element (II) at the outside roof surface. Each discrete element is assumed to have constant physical properties throughout.

The next step is to perform a fundamental energy balance upon each element previously determined. The general form of the energy balance used is: $E_{in} - E_{out} = \Delta E_{stored}$, where E_{in} and E_{out} will consist of energy transfer rates in the forms of conduction, convection, radiation, and bulk mass transfer. The ΔE_{stored} term is approximated in the following manner.

$$\Delta E_{stored} = \frac{T^+(I) - T(I)}{\Delta \theta} \rho C \Delta x .$$

Finite-difference equations for all elements constitute a system of simultaneous equations of the following form, with the past temperatures, T , included in the constants, C .

$$\begin{aligned}
a_{1,1} T^+(1) + a_{1,2} T^+(2) + \dots + a_{1,n} T^+(n) &= C_1, \\
a_{2,1} T^+(1) + a_{2,2} T^+(2) + \dots + a_{2,n} T^+(n) &= C_2, \text{ and} \\
\vdots & \\
\vdots & \\
\vdots & \\
a_{n,1} T^+(1) + a_{n,2} T^+(2) + \dots + a_{n,n} T^+(n) &= C_n.
\end{aligned}$$

Solution of the above simultaneous equations by the Gauss-Jordan reduction method will yield the temperature profiles in the floor, air, and roof at the completion of the desired time step.

Mass Balance Model

A mass balance is performed on the entire building to determine the ventilation flow rate (\dot{m}_v) from the supply (\dot{m}_s) and return (\dot{m}_r) flow rates. Supply air is distributed evenly among all air layers below the level of supply. Even distribution of air within the conditioned zone simulates the assumption of "perfect" air distribution and uniform mixing (5, 6). The supply air flow rate to each element is determined by: $\dot{m}_{se}(I) = \dot{m}_s/N$, where N is the number of air elements that receive supply air. The total building return air and total building ventilation air, are each extracted from individual air elements. The following element flow rates apply: $\dot{m}_{re}(MRET) = \dot{m}_r$ and $\dot{m}_{ve}(M) = \dot{m}_v$, where $MRET$ and M are the integer number of the air elements where the system return and ventilation outlets are located.

Mass balances are applied to individual air elements. Supply, return, and ventilation flow rates for Element (1) have previously been determined as noted above. Refer to Figure 3 for the energy and mass transfer model of Air Element (1). Circulation with the element above (\dot{m}_{ce}) is the remaining unknown quantity, which can be calculated as follows.




Figure 3. Energy and Mass Transfer Model of Air Layer Adjacent to the Floor.

$$\dot{m}_{ce}(1) = \dot{m}_{se}(1) - \dot{m}_{re}(1) - \dot{m}_{ve}(1).$$

In this equation, if $MRET \neq 1$, then $\dot{m}_{re}(1) = 0$, and if $M \neq 1$, then $\dot{m}_{ve}(1) = 0$. Refer to Figure 4 for the energy and mass transfer model of the typical air elements: Air Elements (2) through (K-1). Beginning with Air Element (2) and continuing through Air Element (K-1), circulation with the element above is calculated in the following manner.

$$\dot{m}_{ce}(I) = \dot{m}_{se}(I) - \dot{m}_{re}(I) - \dot{m}_{ve}(I) + \dot{m}_{ce}(I-1).$$

Energy Balances of the Air Elements

Figure 3 represents the energy and mass transfer model of the air element adjacent to the floor. The following modes of energy transfer influence the element.

Conduction, from Air Element (2), which is calculated by:

$$\frac{k + k_{mix}}{\Delta x} [T^+(NAIR + 1) - T^+(NAIR)],$$

where k is the thermal conductivity, k_{mix} is a macroscopic mixing parameter representing turbulent mixing effects, and where NAIR is the integer number of the first air element.

Transmission, through the walls, which is calculated by:

$$U_{wall} \text{ PER } \Delta x [T_O - T^+(NAIR)].$$

The term LOAD represents convection from heat sources located within this element.

The term LTCLD represents the convective portion of the lighting load, if the lights are located in this element. Consistent with the "perfect" air distribution assumption, LOAD and LTCLD are evenly distributed within the conditioned zone.




Figure 4. Energy and Mass Transfer Model of a Typical Air Element.

The term FLDLD represents the portion of the floor convective load which is distributed to each individual air element in the conditioned zone, consistent with the "perfect" air distribution assumption. FLDLD(1) can be computed by:

$$FLDLD(1) = \frac{h_{fi}}{N} [T^+(NFL) - T^+(NAIR)],$$

where the inside floor surface convection coefficient (h_{fi}) is calculated according to (9):

$$h_{fi} = 1.7[T(NFL) - T(NAIR)]^{.25}.$$

Energy transfer due to supply, return, and ventilation flows respectively, are calculated by:

$$\dot{m}_{se}(1) C TS,$$

$$\dot{m}_{re}(1) C T^+(NAIR), \text{ and}$$

$$\dot{m}_{ve}(1) C T^+(NAIR).$$

The transient energy balance for Air Element (1) is written as follows.

$$\begin{aligned} \frac{T^+(NAIR) - T(NAIR)}{\Delta\theta} \rho C \Delta x = & \dot{m}_{se}(1) C TS + LOAD(1) + FLDLD(1) + LTCLD(1) \\ & + U_{wall} \text{ PER } \Delta x [TO - T^+(NAIR)] + \frac{(k + k_{mix})}{\Delta x} [T^+(NAIR + 1) - T^+(NAIR)] \\ & - \dot{m}_{ve}(1) C T^+(NAIR) - \dot{m}_{re}(1) C T^+(NAIR). \end{aligned}$$

By defining:

$$C_1 = \frac{\Delta\theta}{\rho C \Delta x},$$

$$C_2 = \frac{\Delta\theta}{\rho \Delta x},$$

$$C_3 = \frac{U_{wall} \text{ PER } \Delta\theta}{\rho C},$$

$$C_4 = \frac{(k + k_{mix}) \Delta\theta}{\rho C \Delta x^2}, \text{ and}$$

$$C_5 = \frac{h_{fi} \Delta\theta}{N \rho C \Delta x}.$$

This can be rewritten:

$$\begin{aligned} & T^+(NAIR) [1 + C_5 + C_3 + C_4 + C_2 \dot{m}_{ve}(1) + C_2 \dot{m}_{re}(1)] - T^+(NAIR + 1) [C_4] \\ & - T^+(NFL) [C_5] = T(NAIR) + C_2 \dot{m}_{se}(1) TS + C_1 LOAD(1) + C_1 LTCLD(1) \\ & + C_3 TO. \end{aligned}$$

Figure 4 represents the energy and mass transfer model of the typical air element. The result of the energy balance on this air element is given by:

$$\begin{aligned} & T^+(I + NFL) [1 + C_3 + 2 C_4 + C_2 \dot{m}_{ve}(I) + C_2 \dot{m}_{ce}(I) + C_2 \dot{m}_{re}(I)] \\ & + T^+(NAIR) [C_5] - T^+(NFL) [C_5] - T^+(I - 1 + NFL) [C_2 \dot{m}_{ce}(I - 1) + C_4] \\ & - T^+(I + 1 + NFL) [C_4] = T(I + NFL) + C_2 \dot{m}_{se}(I) TS + C_1 LOAD(I) \\ & + C_1 LTCLD(1) + C_3 TO. \end{aligned}$$

The air element adjacent to the roof is handled in a special manner due to the possible inclusion of the roof truss structure as a thermal storage mechanism in this element. Figure 5 represents the energy and mass transfer model of this element.

By defining:

$$C_6 = \frac{\Delta\theta}{[\rho C \Delta x + m_{tr} C_{tr}]},$$

$$C_7 = \frac{\Delta\theta}{[\rho \Delta x + m_{tr} C_{tr}]}$$




Figure 5. Energy and Mass Transfer Model of the Air Element Adjacent to the Roof.

$$C_8 = \frac{(k + k_{mix}) \Delta\theta}{[\rho C \Delta x + m_{tr} C_{tr} \Delta x]} ,$$

$$C_9 = \frac{U_{wall} PER \Delta\theta \Delta x}{[\rho C \Delta x + m_{tr} C_{tr}]} ,$$

$$C_{10} = \frac{h_{ri} \Delta\theta}{[\rho C \Delta x + m_{tr} C_{tr}]} , \text{ and}$$

$$C_{11} = \frac{h_{fi} \Delta\theta}{N[\rho C \Delta x + m_{tr} C_{tr}]} ,$$

the energy balance of Air Element (K) can be written:

$$\begin{aligned} & T^+(KAI) [1 + C_9 + C_8 + C_{10} + C_7 \dot{m}_{ve}(K) + C_7 \dot{m}_{re}(K)] + T^+(NAIR) [C_{11}] \\ & - T^+(NFL) [C_{11}] - T^+(KAI + 1) [C_{10}] - T^+(KAI - 1) [C_8 + C_7 \dot{m}_{ce}(K - 1)] \\ & = T(KAI) + C_7 \dot{m}_{se}(K) TS + C_6 LOAD(K) + C_6 LTCLD(K) + C_9 TO. \end{aligned}$$

Energy Balances of the Roof and Floor Elements

The roof and floor energy balances are handled in a similar manner, with the following exceptions.

1. Provisions have been made to allow for both the roof and floor to consist of a number of materials each with different thermal properties.
2. Each separate material consists of three elements arbitrarily chosen to include two surface nodes and one interior node.

Refer to Figures 6 and 7 for the energy transfer models of the roof and floor, respectively.

Consider the following constants for simplification of the energy balances of the roof elements.

$$D_1 = \frac{2 h_{ro} \Delta\theta}{\rho_r C_r \Delta x_r} ,$$




Figure 6. Energy Transfer Model of the Roof




Figure 7. Energy Transfer Model of the Floor

$$D_2 = \frac{2 k_r \Delta\theta}{\rho_r C_r \Delta x_r^2},$$

$$D_3 = \frac{2 h_{ri} \Delta\theta}{\rho_r C_r \Delta x_r}, \text{ and}$$

$$D_4 = \frac{2 \sigma_b SF \Delta\theta}{\rho_r C_r \Delta x_r} \frac{[(T(KAI) + 460)^3 - (T(NFL) + 460)^3]}{(1/\epsilon_1 + 1/\epsilon_2 - 1)}.$$

Where the outside roof surface convection coefficient (h_{ro}) is given by (8): $h_{ro} = 3.0$, also, the inside roof surface convection coefficient (h_{ri}) is given by:

$$h_{ri} = A + (B (\dot{m}_{ve}(K)/C)^{.8}),$$

$$A = .35,$$

$$B = .30, \text{ and}$$

$$C = 7.0.$$

Constants A, B, and C were chosen by comparison of computed results with results from the steady-state experiments.

The constant D_4 is calculated based on the principles of thermal radiation between parallel plates with surface emissivities (ϵ_1, ϵ_2) and an angle factor which is equal to unity. The floor surface density factor (SF) is included to allow for approximating the net transfer of thermal radiation between the roof and floor, considering various densities of equipment on the floor (acting as radiation shields).

The energy balance of the outside surface roof element may be written:

$$T^+(II) [1 + D_1 + D_2] - T^+(II - 1) [D_2] = T(II) + D_1 \text{ SAT.}$$

Similarly, the energy balance of the inside surface roof element may be written:

$$T^+(KAI + 1) [1 + D_2 + D_3 + D_4] - T^+(NFL) [D_4] - T^+(KAI + 2) [D_2] \\ - T^+(KAI) [D_3] = T(KAI + 1) .$$

Consider next, the similar set of constants for use in the development of the energy balances of the floor elements.

$$E_1 = \frac{2 k_f \Delta \theta}{\rho_f C_f \Delta x_f^2} ,$$

$$E_2 = \frac{2 \Delta \theta}{\rho_f C_f \Delta x_f} ,$$

$$E_3 = \frac{2 \sigma_b SF}{\rho_f C_f \Delta x_f} \frac{[(T(KAI + 1) + 460)^3 - (T(NFL) + 460)^3]}{(1/\epsilon_1 + 1/\epsilon_2 - 1)} , \text{ and}$$

$$E_4 = \frac{2 h_{fi} \Delta \theta}{\rho_f C_f \Delta x_f} .$$

The following equation represents the simplified energy balance of the inside surface floor element.

$$T^+(NFL) [1 + E_1 + E_3 + E_4] - T^+(NFL - 1) [E_1] - T^+(KAI + 1) [E_3] \\ - T^+(NFL + 1) [E_4] = T(NFL) + E_2 \text{ LTRLD.}$$

With the constant ground temperature boundary condition, the energy balance of the first floor element is written in the following manner.

$$\frac{T^+(1) - T(1)}{\Delta \theta} \frac{\Delta x_f}{2} \rho_f C_f = \frac{k_f}{\Delta x_f} [T^+(2) - T^+(1)] + \frac{k_s}{\Delta x_f} [T_{gr} - T^+(1)] .$$

By defining:

$$E_5 = \frac{2 k_s \Delta \theta}{\rho_f C_f \Delta x_f^2} ,$$

this can be rewritten:

$$T^+ [1 + E_1 + E_5] - T^+(2) [E_1] = T(1) + E_5 T_{gr} .$$

Continuing in the same manner as with the surface elements, energy balances are next performed on interior roof and floor elements. The following equations represent the simplified energy balances of the interior roof element and interior floor element respectively.

$$T^+(II - 1) [1 + D_2] - T^+(II) [D_2/2] - T^+(II - 2) [D_2/2] = T(II - 1), \text{ and}$$

$$T^+(2) [1 + E_1] - T^+(1) [E_1/2] - T^+(3) [E_1/2] = T(2) .$$

Hence the complete system of equations, in the desired form, that describe the relationships between the air, roof, and floor elements have been developed.

Buoyancy Approximation

The equations presented earlier have not accounted for mass flow of space air due to buoyancy effects. These flows occur when a fluid is locally heated which decreases the fluid density; differences in density are the driving forces behind buoyancy effects. Localized heating by convective heat transfer will possibly occur in the vicinity of lights or concentrated loads located in the stratified zone. "Perfect" air distribution will preclude the formation of buoyancy flows in the conditioned zone.

It is assumed that the buoyancy mechanism will operate naturally to prevent the formation of cool air layers above warm air layers.

Consistent with the above assumption, the following approximation is employed in place of a thorough buoyancy flow analysis. Upon determination of the temperature profile of the air elements, a check is made to locate an

element whose temperature is greater than the one above. This condition would indicate that the buoyancy action should operate. If an inversion is found to exist, the temperatures of the involved elements are averaged in the following manner.

$$XX = \frac{T(I) YY(I) + T(I + 1) YY(I + 1)}{YY(I) + YY(I + 1)} ,$$

where:

$$YY(I) = \rho C \Delta x ,$$

or:

$$YY(K) = [\rho C \Delta x + m_{tr} C_{tr}] .$$

Next the temperatures of the two affected air elements are reassigned in the following manners.

$$T(I) = XX, \text{ and}$$

$$T(I + 1) = XX .$$

This pattern is then repeated until no further temperature inversions remain. This procedure is justified by noting that the one hour computational time step used tends to disguise the details of buoyancy transport and reports only the larger scale effect of the energy transport during the one hour period.

CHAPTER IV

VERIFICATION

Initial verification of the validity of the computed results has been carried out for two specific areas: verification of steady-state behavior, and no-load verification of transient behavior.

Verification of Steady-State Behavior

Comparison has been made to the actual temperature profiles acquired from the steady-state model studies (4, 5, 6); Figures 8, 9, and 10 illustrate this comparison. Measured experimental results are shown as discrete points, while the computed results are shown as solid lines.

The transient computer program was modified to allow for steady-state heat input to the inside surface roof and floor elements. This approximates the heat input from the roof and floor heating panels used in the steady-state experiments. Further, the thermal properties of the floor, roof, and wall were assigned so as to approximate the conditions in the scale model test chamber.

Figure 8 shows the comparison of computed and experimental results when the applied load is within the inside surface roof element; floor and lighting loads are zero. The curves show very good agreement within the conditioned zone. Reasonable agreement, within four degrees maximum, is also shown in the stratified zone. Very close correlation is also shown for the inside surface roof temperature.

Figure 9 shows the comparison between the experimental and computer results with a floor level load only; roof and lighting loads are zero. Computed results yield a four degree higher inside roof temperature and a maximum difference in air temperature of five degrees at the six foot level. Predicted air temperatures within the conditioned zone are within one degree of those obtained from the scale model test chamber.

Representing results with only a lighting load at the five foot level, Figure 10 shows the comparison between computed and experimental results. Temperature correlation within the conditioned zone is very good, within one degree throughout. Computed results yield a four degree lower inside roof temperature. Predicted air temperatures within the stratified zone are a maximum of ten degrees higher at the four foot level, which is below the lighting level, and a minimum of three degrees higher near the roof.

The above situations were analyzed to demonstrate that the transient computer program properly accounts for the effects of loads that originate internally in the air or at the roof or floor. In all cases, temperature agreement between the computed and experimental results within the conditioned zone was within one degree. Considering the situations with only floor and roof level loads, the accuracy of prediction indicates radiation from the roof to floor and convection into the conditioned zone are properly accounted for.

With only a lighting load applied (Figure 10), the computed vs. experimental temperature profiles differ by the greatest amount of all cases. The largest temperature difference occurs at the four foot level, one foot below the lighting level. This difference is probably due to the fact that the buoyancy approximation does not properly account for actual flows in the presence of a concentrated heat source. In the actual case, buoyant plume




Figure 8. Comparison of Computed and Measured Results; Roof Load Only.




Figure 9. Comparison of Computed and Measured Results; Floor Load Only.




Figure 10. Comparison of Computed and Measured Results; Lighting Load Only.

originates below the actual level of heating and causes mixing below the level of the lights.

These three cases are intended to demonstrate that the transient computer model adequately represents the influence of the three individually occurring load sources. A more extensive comparison of experimental results and the referenced steady-state program, has been reported (5, 7). The previous report covers many more comparison cases for both individual load sources and combined load effects. The authors of that study concluded that the computed results provide an "adequate" representation of the experimental results for all cases investigated.

An extensive comparison of the transient program results to the steady-state program results was performed, but not reported here. The general conclusion was that the transient program and the steady-state program developed previously (5, 7), are accurate predictors of the internal conditions present in a stratified air conditioning system.

No-Load Verification of Transient Behavior

A trivial case with no internal loads has been investigated to verify the behavior of the computer program under transient conditions. The roof and air temperatures were initially set at 80°F while the floor was initialized at 55°F. Outside air temperatures and the supply air temperature were also set at 55°F. The supply air flowrate used was .25 cfm/sqft.

Figure 11 shows the variation of the building temperature profile as a function of time. Curves are presented to represent the initial conditions ($t = 0$), as well as the conditions after six hours ($t = 6$), and after twenty-four hours ($t = 24$).




Figure 11. Transient No-Load Behavior.

Due to the constant 55°F applied sol-air temperature, the exterior roof surface experiences a faster rate of cooling than does the interior roof surface which exchanges energy with the space air and also the upper floor surface. After six hours ($t = 6$), the temperature of the air in the stratified zone approaches the conditioned zone temperature at its lower boundary, and approaches the roof temperature at its upper boundary.

Considering the boundary conditions present, it is expected that the entire building temperature profile would eventually approach a uniform temperature of 55°F. This condition is reasonably approximated after twenty-four hours ($t = 24$).

CHAPTER V

COMPUTED RESULTS

The computed results discussed in this section were chosen to illustrate the effects of system variables on the peak plant cooling load (required capacity of the cooling equipment) and the total daily rejected cooling load (daily cooling system energy usage). Additionally, the time at which the peak plant cooling load occurs is reported. The system variables investigated were: supply air inlet height, return air extraction height, roof construction, lighting height, ventilation air extraction height, ventilation air flow rate, and occupancy patterns. A detailed description of all cases investigated is contained in Appendix B.

The temperatures of all elements (roof, air, and floor) were initialized ($T(I)$) and the temperatures of all elements at the end of the computational time step were calculated. Iterations in time, using hourly temperature, load, and flow rate patterns, were continued until hourly temperature profiles indicated a daily periodic pattern had been obtained which was independent of the initial condition.

A constant roof height of twenty feet was used throughout the transient portion of this investigation. Effects of variable roof height were discussed in detail in the previous steady-state investigation (5, 7).

A Δx of two feet for the air elements was used throughout this investigation. Average internal load values, lighting (8.0 Btu/hr-sqft) and equipment (30.0 Btu/hr-sqft), were chosen from typical values in the

literature. Equipment loads include the convective portion of both equipment and occupant loads.

The supply air flow rate was adjusted to maintain the conditioned space air temperature in the range 75°F-78°F while occupied. A supply air temperature of 55°F was used during periods of occupancy.

During periods of non-occupancy, where possible, 100% make-up air is introduced into the space to dissipate residual loads; space air temperature is maintained in the range 80°F-85°F, by varying supply air flow rate.

In all cases investigated, an incidental portion of the supply air was extracted as ventilation (to remove odors and fumes). Additionally, higher rates of ventilation flow were also investigated to establish the influence of ventilation rate on load.

Calculated results are discussed in related groups and the effects of system variables on air conditioning loads are determined.

Effect of Supply Air Inlet Height

Computed results of the effects of supply air inlet height on the plant cooling loads are shown in Table 1. The complete range of supply air inlet heights, Case 5 (supply at the ten foot level) to Case 3 (total volume --- supply to entire building), were investigated. In addition, an intermediate case, Case 10 (supply at the eighteen foot level), was investigated.

For all three cases, the return is located at the floor. Ventilation air for these cases is extracted directly below the roof.

If conditioned air is supplied to the entire building (total volume system) the interior convective roof load becomes a portion of the plant cooling load (in contrast to the stratified system, where the convective load is blocked as discussed below). In addition, a lower inside surface roof

temperature occurs. This lower temperature promotes added heat transfer from the ambient into the space.

In addition to the roof convective load, a small amount of energy due to heat transmission through the walls is added to the plant cooling load. In the case of the total volume cooling system, the added heat load due to wall transmission amounted to only 0.4 Btu/hr-sqft (0.6%) of the peak plant cooling load. The wall transmission load is small compared to the peak plant cooling load, therefore, it is not discussed in further cases.

Also, a part of the plant cooling load in the total volume system is the convective portion of the lighting load. Although this load is also relatively small, when supply air is introduced at the roof, there is no other choice except to locate the lights within the conditioned zone.

Comparison of Case 3 (total volume system) to Case 10 (supply to eighteen foot level) yields a 44.0 Btu/hr-sqft (45%) reduction in peak plant cooling load, accompanied by a 286.9 Btu/sqft (36%) reduction in total daily rejected cooling load. If the supply air inlet height is further lowered to the ten foot level (Case 5), an additional reduction in peak plant cooling load of only 1.0 Btu/hr-sqft will occur, accompanied by an 8.2 Btu/sqft total daily rejected cooling load reduction. This additional small change is due to the decreased temperature gradient between the upper air element in the conditioned zone, and the lower air element in the stratified zone.

Overall reductions in plant cooling loads from Case 3 to Case 5 were: 45 Btu/hr-sqft (46%) in peak plant cooling load (required capacity of cooling equipment), and 295.1 Btu/sqft (38%) in total daily rejected cooling load (daily cooling system energy usage).

From these examples it is abundantly clear that by supplying conditioned air below the actual roof height (even only two feet below as in Case 10), as opposed to supplying conditioned air to the entire system (as in Case 3), there are enormous plant cooling load savings to be realized. For actual system design purposes, this indicates that every effort must be made to allow formation of a stagnant, warm air layer immediately adjacent to the interior roof surface. Presence of this layer prevents convective cooling of the roof and thus "blocks" the convective portion of the roof load which occurs in the total volume system.

TABLE 1

EFFECT OF SUPPLY AIR INLET HEIGHT ON PLANT COOLING LOADS

<u>Case No.</u>	<u>Supply Air Inlet Height (Feet)</u>	<u>Time Of Peak Plant Cooling Load (Hour)</u>	<u>Peak Plant Cooling Load (Btu/hr-sqft)</u>	<u>Total Daily Rejected Cooling Load (Btu/sqft)</u>
5	10.0	17	53.3	485.5
10	18.0	17	54.3	493.7
3	20.0	17	98.3	780.6

Effect of Return Air Extraction Height

The cases run in this section were intended to compare the effect of the position of the return air duct on the plant cooling loads. The effects of return air heights of nineteen feet (Case 7), five feet (Case 6), and one foot (Case 5) were investigated. Air supply height was ten feet. Table 2 lists the computed results for all three cases investigated.

Results of the previous experimental steady-state model studies (5, 6) indicated that the return air duct location had no effect upon the temperature profile in the space, as long as the return was located in the conditioned zone. Computed results of Cases 5 and 6, return located in the conditioned zone, indicate that only negligible changes occur in the plant cooling loads when changes of return location within the conditioned zone occur. Results of the transient computer program, therefore, corroborate the results presented previously.

If, however, the return air duct is located directly below the roof, as is often considered standard practice with roof-top units, the plant cooling loads increase dramatically. Although the temperature of the conditioned zone is not affected appreciably by the return location, if the duct is located directly below the roof (Case 7) the desirable stagnant air layer is destroyed and the convective portion of the roof load is added to the plant cooling load.

Due mainly to the isolation of the convective roof load from the return air, the peak plant cooling load is reduced 12.2 Btu/hr-sqft (18%), from Case 7 to Case 6, with a 98.4 Btu/sqft (16%) reduction in total daily rejected cooling load.

In general, it can therefore be concluded that return air duct height is an easily controlled system variable that allows reduction of plant cooling loads.

TABLE 2

EFFECT OF RETURN AIR EXTRACTION HEIGHT ON PLANT COOLING LOADS

<u>Case No.</u>	<u>Return Air Extraction Height (Feet)</u>	<u>Time Of Peak Plant Cooling Load (Hour)</u>	<u>Peak Plant Cooling Load (Btu/hr-sqft)</u>	<u>Total Daily Rejected Cooling Load (Btu/sqft)</u>
5	1.0	17	53.3	485.5
6	5.0	17	54.1	501.3
7	19.0	16	66.3	599.7

Effect of Roof Construction

The purpose of this section is to determine the influence of roof construction on plant cooling loads. Table 3 lists the computed plant cooling loads for all four cases. Four different roof construction techniques were investigated.

1. Case 8 - Nine inches of concrete with two inches of insulation.
2. Case 5 - Four inches of concrete with two inches of insulation.
3. Case 4 - Steel sheet with two inches of insulation.
4. Case 25 - Steel sheet with no insulation.

Essentially, the effects of two separate system variables were analyzed. Cases 4 and 25 investigate the effects of roof insulation on the plant cooling loads, while Cases 4, 5, and 8 investigate the transient effects of thermal roof mass on plant cooling loads.

For the four cases investigated, supply air is distributed at the ten foot level.

Recently there is renewed interest in insulating the exterior envelope of buildings. However, the relative energy savings are rarely more

pronounced than when insulation is added to the exterior roof surface of an air-conditioned building. With only the addition of a two inch insulation layer, the peak plant cooling load was reduced, from Case 25 to Case 4, by 18%. Furthermore, the total daily rejected cooling load (daily cooling system energy usage) was reduced by 21%.

By adding insulation (low thermal conductivity material) to the exterior roof surface, a higher exterior roof temperature is possible without affecting the interior surface roof temperature. The elevated exterior roof surface temperature promotes added convective heat transfer to the surroundings which reduces the heat load imposed on the building.

Due to the low thermal mass of the steel sheet roof (Case 25), the peak plant cooling load occurs coincidentally with the peak sol-air temperature at hour fifteen (3 p.m.), whereas the peak plant cooling load in Case 4 is delayed by one hour until hour sixteen (4 p.m.). The time of occurrence of the peak plant cooling load may be used beneficially in conjunction with occupancy patterns to achieve a large reduction in peak plant cooling load.

Cases 4, 5, and 8 were investigated to determine the effects of roof mass (thermal storage) on plant cooling load. With these cases it can be seen that by increasing the roof mass, both the peak plant cooling load and the total daily rejected cooling load can be reduced.

It is currently believed, and verified by this group of cases, that some energy from solar loads, ambient convective loads, and to a limited extent, internal loads, can be stored in the roof and released at a later time. This thermal storage effect would account for the decrease from Case 8 to Case 4 of 8.6 Btu/hr-sqft (15%) in peak plant cooling load, and in the decrease of 47.6 Btu/sqft (9%) in the total daily rejected cooling load. Furthermore,

this storage effect would account for the delay in time of occurrence of the peak plant cooling load.

In general, it can be concluded that these roof construction features, insulation and thermal mass, can provide reduction of the plant cooling loads.

TABLE 3
EFFECT OF ROOF CONSTRUCTION ON PLANT COOLING LOADS

<u>Case No.</u>	<u>Roof Construction</u>	<u>Time Of Peak Plant Cooling Load (Hour)</u>	<u>Peak Plant Cooling Load (Btu/hr-sqft)</u>	<u>Total Daily Rejected Cooling Load (Btu/sqft)</u>
8	Heavy roof, with insulation.	17	49.5	476.1
5	Medium roof, with insulation.	17	53.3	485.5
4	Light roof, with insulation.	16	58.1	523.7
25	Light roof without insulation.	15	70.9	666.9

Effect of Lighting Height

Transient Cases 5 and 19 were investigated to determine the influence of light height on plant cooling load. The convective portion of the lighting load (here assumed to be 20% of the total lighting load) is contributed to either the conditioned zone or the stratified zone depending upon the location of the lighting fixtures. The convective portion of the lighting load (1.6 Btu/hr-sqft) is only a small portion of the total internal load (30.0 Btu/hr-sqft), and an even smaller portion of the total imposed load. The radiant portion of the lighting load (80% of the total lighting load) will strike and

be absorbed by interior surfaces irrespective of the light height.

Table 4 lists the computed plant cooling loads for Case 5 (lights in the stratified zone) and Case 19 (lights in the conditioned zone). For both cases the supply air is distributed at the ten foot level.

The peak plant cooling load occurs for both cases during hour seventeen (5 p.m.). It can be seen that the lighting height has an almost direct additive effect on both the peak plant cooling load and the total daily rejected cooling load.

If the lighting fixtures are located above the level of supply (in the stratified zone) a portion of the convective lighting load may be exhausted by ventilation air. The remainder of the convective lighting load may raise the air temperature within the stratified zone and the roof temperature, which will increase radiation to the floor and increase the plant cooling load.

Considering these cases it can be seen that the light height has only a negligible effect (less than 2%) on the peak plant cooling load, and also a negligible effect (6%) on the total daily rejected cooling load. However, if increased lighting loads were used, or internal loads were decreased, the effect of lighting height on air conditioning cooling load would become more pronounced.

TABLE 4

EFFECT OF LIGHTING HEIGHT ON PLANT COOLING LOADS

Case No.	Lighting Height (Feet)	Time Of Peak Plant Cooling Load (Hour)	Peak Plant Cooling Load (Btu/hr-sqft)	Total Daily Rejected Cooling Load (Btu/sqft)
5	12.0	17	53.3	485.5
19	10.0	17	54.4	518.4

Effect of Ventilation Air Extraction Height

The transient effects on plant cooling load of ventilation air extraction height were investigated. Using incidental ventilation only (0.1 cfm/sqft), Case 5 (ventilation directly below the roof) and Case 20 (ventilation at the twelve foot level) were computed for comparison purposes. For both cases, the supply air is distributed at the ten foot level. Table 5 lists the computed plant cooling loads for both cases.

One previous investigation into the design of stratified air conditioning systems (2) indicates that by ventilating near the roof (disturbing the stratified zone) the plant cooling load will be increased.

However, ventilating near the roof may in fact remove a portion of the convective loads affecting the stratified zone (e.g., convective lighting loads, concentrated loads). Furthermore, some cooling of the interior roof surface may occur. By reducing the interior surface roof temperature, radiation to the floor and thus the cooling load may be reduced.

Peak plant cooling load for both cases occurs during hour seventeen (5 p.m.). Although the peak plant cooling load reduction from Case 20 (ventilation at the twelve foot level) to Case 5 (ventilation directly below the roof) was only 1.6 Btu/hr-sqft (3% of the peak plant cooling load), and the reduction in the total daily rejected cooling load was only 38.4 Btu/sqft (7% of the total daily rejected cooling load), the effect of ventilation location may become more pronounced when increased convective loads are located in the stratified zone.

TABLE 5

EFFECT OF VENTILATION HEIGHT ON PLANT COOLING LOADS

<u>Case No.</u>	<u>Ventilation Air Extraction Height (Feet)</u>	<u>Time Of Peak Plant Cooling Load (Hour)</u>	<u>Peak Plant Cooling Load (Btu/hr-sqft)</u>	<u>Total Daily Rejected Cooling Load (Btu/sqft)</u>
5	19.0	17	53.3	485.5
20	12.0	17	54.9	523.9

Effect of Ventilation Rate

Cases 5, 21, and 22 were investigated to determine the effect of ventilation air flow rate on plant cooling load. Air that is extracted as ventilation must be replaced by make-up air; before make-up air is introduced into the conditioned space, it must be first cooled from the ambient air temperature (T_0) to the supply air temperature (T_S). Make-up air is, therefore, a portion of the plant cooling load.

Table 6 shows the computed plant cooling loads for Case 5 (incidental ventilation only), Case 22 (20% of supply flow to ventilation), and Case 21 (30% of supply flow to ventilation). Ventilation air is extracted for these cases directly below the roof. The remaining portion of the supply air is extracted through the return air system located at the floor. For all three cases investigated, supply air is distributed at the ten foot level.

Ventilation air may remove a portion of convective loads located within the stratified zone (e.g., lighting loads, and concentrated loads). Additionally, some cooling of the interior roof surface may occur, which will reduce the amount of radiation to the floor and reduce the cooling load.

The relative influence of removing a portion of the convective loads in the stratified zone and reducing radiation to the floor, must be related to the effect of additional make-up load.

As a rule, the minimum practical ventilation rate should be used whenever the ambient air temperature is greater than the temperature of the ventilation exhaust air.

The peak plant cooling load occurs for Case 5 during hour seventeen (5 p.m.) and for Cases 21 and 22 during hour sixteen (4 p.m.). The transient effect of reducing the interior surface roof temperature and, therefore, the radiation to the floor, are indicated by these cases.

Due to the increased make-up air load, both the peak plant cooling load and the total daily rejected cooling load increased with increases in ventilation rates. Increased ventilation rates may, however, be employed during periods of relatively low ambient air temperature to decrease the average roof temperature and increase its storage capacity in preparation for peak solar times.

TABLE 6

EFFECT OF VENTILATION RATE ON PLANT COOLING LOADS

<u>Case No.</u>	<u>Ventilation Rate (% of Supply)</u>	<u>Time Of Peak Plant Cooling Load (Hour)</u>	<u>Peak Plant Cooling Load (Btu/hr-sqft)</u>	<u>Total Daily Rejected Cooling Load (Btu/sqft)</u>
5	Incidental Only	17	53.3	485.5
22	20	16	57.7	514.5
21	30	16	61.0	538.3

Effect of Occupancy Pattern

In this set of cases, the effects of the internal occupancy pattern (load pattern) on plant cooling loads were investigated. Table 7 lists the computed plant cooling loads for Case 5 (ten hour load pattern), Case 17 (eighteen hour load pattern), and Case 15 (twenty-four hour load pattern). An occupancy pattern of eight hours is assumed to represent a load pattern of ten hours (add one hour before and one hour after occupancy).

For all three cases, supply air is distributed at the ten foot level. Additionally, the roof construction in all cases consisted of two inches of insulation over four inches of concrete.

There is no measurable effect of occupancy pattern on the time of occurrence of peak plant cooling load.

The total daily rejected cooling load (daily cooling system energy usage) increases with increases in the duration of internal occupancy, as might be expected. However, a reduction in peak plant cooling load will occur with an increase in the duration of occupancy.

During periods of occupancy, the conditioned zone temperature was maintained in the range 75°F-78°F. Conversely, during periods of non-occupancy, the conditioned zone temperature was controlled in the range 80°F-85°F.

For all three cases investigated, the primary periods of occupancy coincide with the periods of peak solar load. However, Cases 17 and 15 also extend their periods of occupancy (periods of reduced conditioned zone temperature) into periods of low solar load. The effects of an increased duration of reduced conditioned zone temperature, during periods of low

solar load, yield additional storage capacity in the roof (and floor) during periods of peak solar load.

It generally can be concluded that by maintaining a lower conditioned zone temperature during periods of low solar load, an increased thermal storage effect in the roof (and floor) during times of peak solar load will be realized.

TABLE 7

EFFECT OF OCCUPANCY PATTERN ON PLANT COOLING LOADS

<u>Case No.</u>	<u>Duration Of Internal Loads (Hours)</u>	<u>Time Of Peak Plant Cooling Load (Hour)</u>	<u>Peak Plant Cooling Load (Btu/hr-sqft)</u>	<u>Total Daily Rejected Cooling Load (Btu/sqft)</u>
5	10	17	53.3	485.5
17	18	17	52.4	783.2
15	24	17	50.8	1053.4

Summary of the Effects of System Variables Investigated

From the data presented and discussed in this chapter, the following conclusions may be drawn.

1. The height of the supply air inlet has a direct effect on the plant cooling load. If supply air is introduced below the roof level, allowing for stratification between the supply level and the roof, certain convective loads (e.g., lighting loads, solar loads, and other loads located in the stratified zone) will be partially isolated from the plant cooling load.

2. Although the return air duct height has a direct effect on plant cooling load, it has an almost negligible effect on the conditioned zone temperature.

3. The effects of roof construction influence not only the plant cooling loads (peak plant cooling load and total daily rejected cooling load) but also the time at which the peak plant cooling loads occur. A relatively massive, well insulated roof, compared to a low thermal mass, un-insulated roof, will not only reduce the plant cooling loads but also delay the time of occurrence of the peak.

4. The height at which the light fixtures are located (in the conditioned zone or in the stratified zone) will determine to which zone the convective portion of the lighting load is contributed. If the lights, or other convective loads can be isolated in the stratified zone, only a portion of their total convective load will appear as plant cooling load.

5. Ventilation air flow rate and ventilating near the roof can reduce cooling loads if a substantial convective load is located in the stratified zone. Also, increased ventilation flow rates during non-occupancy periods can increase the storage capacity of the roof during occupied periods.

6. Although longer periods of occupancy do promote increases in the total daily rejected cooling load, there is to some extent a limited reduction in the peak plant cooling load.

7. Results indicate reductions on the order of 50% in peak load, and 40% in energy conservation, are possible.

CHAPTER VI

RECOMMENDATIONS

This program attempts to include a wide variety of factors that influence the air temperature within the structure, however, certain important elements were represented by rather gross approximations (e.g., mass flow of space air due to buoyancy effects).

Further study to determine the behavior of buoyancy driven plumes in stratified environments should be considered. Particular attention should be placed upon experimental and analytical determination of mass flows in the vicinity of convective heat sources. Additionally, the effects of conflicting flows (e.g., supply, return, and ventilation air flows) which may alter the buoyant plume flow, should be carefully examined.

Before complete confidence can be placed in results acquired from the transient computer program, full-scale verification of the computed results is needed. Comparisons with data acquired from actual full-scale experimental testing would provide the means for achieving the desired levels of confidence in the computed results.

The intent of this investigation has been to determine the transient behavior of stratified air conditioning systems in an attempt to aid in proper building design. However, in the building design process, proper determination of the design heating load and system behavior is equally as important as determination of the design cooling load. Therefore, analytical as well as

experimental investigations into the cold weather (winter) behavior of stratified air conditioning systems is needed.

LIST OF REFERENCES

1. Dean, F. R., and Reese, J. A., "A New Approach to Factory Air Conditioning," Heating, Piping, and Air Conditioning, June 1974, pp. 45-49.
2. Kelsey, P. A., "Tempmaster Uses Thermal Storage, Stratification, Spot Cooling, to Cut Industrial A/C Energy Costs," Air Conditioning, Heating, and Refrigeration News, November 1981.
3. Beier, R. A., and Gorton, R. L., "Thermal Stratification in Factories - Cooling Loads and Temperature Profiles," ASHRAE Transactions, Vol. 84, Part 1, 1978.
4. Bagheri, H. M., "Design, Construction, and Calibration of a Model Chamber for Experimentation With Thermally Stratified Cooling Systems," M.S. Thesis, Kansas State University, 1981.
5. Sassi, M. M., "Temperature Profile and Load Distribution in Stratified System Air Conditioning as a Function of Load Characteristics, Temperature and Exhaust Air Ventilation Rate," Ph.D. Dissertation, Kansas State University, 1981.
6. Gorton, R. L., and Sassi, M. M., "Determination of Temperature Profiles and Loads in a Thermally Stratified, Air-Conditioned System: Part 1 - Model Studies," ASHRAE Transactions, Vol. 88, Part 2, 1982.
7. Gorton, R. L., and Sassi, M. M., "Determination of Temperature Profiles and Loads in a Thermally Stratified, Air-Conditioned System: Part 2 - Program Description and Comparison of Computed and Measured Results," ASHRAE Transactions, Vol. 88, Part 2, 1982.
8. American Society of Heating, Refrigerating, and Air Conditioning Engineers, Inc., ASHRAE Handbook of Fundamentals, New York, New York, 1981.
9. Vickers, J. M. F., "Thermal Scale Modeling," Astronautics and Aeronautics, May 1965, pp. 34-39.
10. Incropera, F. P., and DeWitt, D. P., Fundamentals of Heat Transfer, John Wiley and Sons, 1981.
11. Baturin, V. V., Fundamentals of Industrial Ventilation, by O. M. Blunn, 3d ed., Pergamon Press, Oxford, New York, 1972.

APPENDIX A

LIST OF SYMBOLS

APPENDIX A

LIST OF SYMBOLS

<u>Symbol</u>	<u>Significance</u>	<u>Units</u>
M	Number of level of ventilation.	---
N	Number of upper level of supply.	---
K	Number of upper level in building.	---
NAIR	Number of air node adjacent to floor.	---
MRET	Number of level of return.	---
NFL	Number of floor elements.	---
KAI	Number of air node adjacent to roof.	---
q_r	Convective and radiant heat transfer at outside of roof per unit floor area.	Btu/hr-sqft
q_w	Heat transfer by transmission through the walls per unit floor area.	Btu/hr-sqft
q_{lc}	Convective portion of lighting load per unit floor area.	Btu/hr-sqft
q_{lr}	Radiant portion of lighting load per unit floor area.	Btu/hr-sqft
q_{id}	Internal disperse load per unit floor area.	Btu/hr-sqft
q_{ic}	Internal concentrated load per unit floor area.	Btu/hr-sqft
q_f	Conduction from floor to soil per unit floor area.	Btu/hr-sqft
T^+	Temperature of element at completion of desired time step.	°F
T	Temperature of element at beginning of desired time step.	°F

APPENDIX A

(Continued)

<u>Symbol</u>	<u>Significance</u>	<u>Units</u>
TS	Supply air temperature.	°F
TO	Outside air temperature.	°F
T_{gr}	Deep-ground temperature.	°F
SAT	Sol-air temperature.	°F
$\Delta\theta$	Size of desired computational time step.	Hour
Δx	Thickness of air element.	Feet
Δx_f	Thickness of floor element.	Feet
Δx_r	Thickness of roof element.	Feet
ρ	Density of air.	lb/cuft
ρ_f	Density of floor material.	lb/cuft
ρ_r	Density of roof material.	lb/cuft
C	Specific heat of air.	Btu/lb-°F
C_f	Specific heat of floor material.	Btu/lb-°F
C_r	Specific heat of roof material.	Btu/lb-°F
C_{tr}	Specific heat of truss material.	Btu/lb-°F
m_{tr}	Mass of truss material per unit area of floor.	lb/sqft
\dot{m}_v	Ventilation flow rate per unit area of floor.	lb/hr-sqft
\dot{m}_s	Supply flow rate per unit area of floor.	lb/hr-sqft
\dot{m}_r	Return flow rate per unit area of floor.	lb/hr-sqft
\dot{m}_{re}	Return flow rate from each element per unit area of floor.	lb/hr-sqft
\dot{m}_{ve}	Ventilation flow rate from each element per unit area of floor.	lb/hr-sqft

APPENDIX A

(Continued)

Symbol	Significance	Units
\dot{m}_{se}	Supply flow rate to each element per unit area of floor.	lb/hr-sqft
\dot{m}_{ce}	Circulation flow rate between elements per unit area of floor.	lb/hr-sqft
k	Thermal conductivity of air.	Btu/hr-ft-°F
k_{mix}	Macroscopic mixing coefficient.	Btu/hr-ft-°F
k_f	Thermal conductivity of floor.	Btu/hr-ft-°F
k_r	Thermal conductivity of roof.	Btu/hr-ft-°F
k_s	Thermal conductivity of soil.	Btu/hr-ft-°F
h_{ri}	Convective heat transfer coefficient for inside roof surface.	Btu/hr-sqft-°F
h_{fi}	Convective heat transfer coefficient for inside floor surface.	Btu/hr-sqft-°F
h_{ro}	Convective and radiant heat transfer coefficient for outside roof surface.	Btu/hr-sqft-°F
U_{wall}	Transmission coefficient for walls.	Btu/hr-sqft-°F
PER	Perimeter of building per unit area of floor.	ft/sqft
LOAD	Hourly internal element loads per unit area of floor.	Btu/hr-sqft
LTCLD	Hourly convective portion of element lighting load per unit area of floor.	Btu/hr-sqft
LTRLD	Hourly radiant portion of lighting load per unit area of floor.	Btu/hr-sqft
FLDL	Distributed convective floor load per unit area of floor.	Btu/hr-sqft
σ_B	Stefan-Boltzman constant.	Btu/hr-sqft-°R ⁴
SF	Floor surface density factor.	---

APPENDIX A
(Continued)

<u>Symbol</u>	<u>Significance</u>	<u>Units</u>
ϵ_f	Emissivity of floor.	---
ϵ_r	Emissivity of roof.	---

APPENDIX B

DETAILED DESCRIPTION OF TRANSIENT CASES INVESTIGATED

CASE 3

<u>Roof Height (Feet)</u>	<u>Supply Height (Feet)</u>	<u>Return Height (Feet)</u>	<u>Ventilation Height (Feet)</u>	<u>Lighting Height (Feet)</u>
20.0	20.0	1.0	19.0	18.0

<u>Name Of Roof Material</u>	<u>Thickness (Feet)</u>	<u>Name Of Floor Material</u>	<u>Thickness (Feet)</u>
Roof Insulation	0.17	Floor Slab	0.33
Built Up Roofing	0.33	Soil	5.00

<u>Solar Time (Hour)</u>	<u>Supply Temp. (°F)</u>	<u>Supply Rate (cfm/sqft)</u>	<u>Return Rate (cfm/sqft)</u>	<u>Lighting Load (Btu/hr-sqft)</u>	<u>Internal Disperse Loads (Btu/hr-sqft)</u>
1	76.0	1.2	1.1		
2	76.0	1.2	1.1		
3	75.0	1.2	1.1		
4	74.0	1.2	1.1		
5	74.0	1.2	1.1		
6	74.0	1.2	1.1		
7	75.0	1.2	1.1		
8	55.0	1.8	1.7	8.0	30.0
9	55.0	1.9	1.8	8.0	30.0
10	55.0	1.9	1.8	8.0	30.0
11	55.0	2.2	2.1	8.0	30.0
12	55.0	2.4	2.3	8.0	30.0
13	55.0	2.9	2.8	8.0	30.0
14	55.0	3.0	2.9	8.0	30.0
15	55.0	3.1	3.0	8.0	30.0
16	55.0	3.4	3.3	8.0	30.0
17	55.0	3.7	3.6	8.0	30.0
18	55.0	1.1	1.0		
19	55.0	0.8	0.7		
20	55.0	0.6	0.5		
21	55.0	0.5	0.4		
22	55.0	0.5	0.4		
23	79.0	1.2	1.1		
24	77.0	1.2			

CASE 4

<u>Roof Height (Feet)</u>	<u>Supply Height (Feet)</u>	<u>Return Height (Feet)</u>	<u>Ventilation Height (Feet)</u>	<u>Lighting Height (Feet)</u>
20.0	10.0	1.0	19.0	12.0

<u>Name Of Roof Material</u>	<u>Thickness (Feet)</u>	<u>Name Of Floor Material</u>	<u>Thickness (Feet)</u>
Roof Insulation	0.17	Floor Slab	0.33
Steel Roof Decking	0.02	Soil	5.00

<u>Solar Time (Hour)</u>	<u>Supply Temp. (°F)</u>	<u>Supply Rate (cfm/sqft)</u>	<u>Return Rate (cfm/sqft)</u>	<u>Lighting Load (Btu/hr-sqft)</u>	<u>Internal Disperse Loads (Btu/hr-sqft)</u>
1	76.0	1.2	1.1		
2	76.0	1.2	1.1		
3	75.0	1.2	1.1		
4	74.0	1.2	1.1		
5	74.0	1.2	1.1		
6	74.0	1.2	1.1		
7	75.0	1.2	1.0		
8	55.0	1.4	1.3	8.0	30.0
9	55.0	1.4	1.3	8.0	30.0
10	55.0	1.4	1.3	8.0	30.0
11	55.0	1.7	1.6	8.0	30.0
12	55.0	1.7	1.6	8.0	30.0
13	55.0	2.0	1.9	8.0	30.0
14	55.0	2.0	1.9	8.0	30.0
15	55.0	2.0	1.9	8.0	30.0
16	55.0	2.1	2.0	8.0	30.0
17	55.0	2.1	2.0	8.0	30.0
18	55.0	0.6	0.5		
19	55.0	0.6	0.5		
20	55.0	0.3	0.2		
21	55.0	0.3	0.2		
22	81.0	1.2	1.1		
23	79.0	1.2	1.1		
24	77.0	1.2	1.1		

CASE 5

<u>Roof Height (Feet)</u>	<u>Supply Height (Feet)</u>	<u>Return Height (Feet)</u>	<u>Ventilation Height (Feet)</u>	<u>Lighting Height (Feet)</u>
20.0	10.0	1.0	19.0	12.0

<u>Name Of Roof Material</u>	<u>Thickness (Feet)</u>	<u>Name Of Floor Material</u>	<u>Thickness (Feet)</u>
Roof Insulation	0.17	Floor Slab	0.33
Built Up Roofing	0.33	Soil	5.00

<u>Solar Time (Hour)</u>	<u>Supply Temp. (°F)</u>	<u>Supply Rate (cfm/sqft)</u>	<u>Return Rate (cfm/sqft)</u>	<u>Lighting Load (Btu/hr-sqft)</u>	<u>Internal Disperse Loads (Btu/hr-sqft)</u>
1	76.0	1.2	1.1		
2	76.0	1.2	1.1		
3	75.0	1.2	1.1		
4	74.0	1.2	1.1		
5	74.0	1.2	1.1		
6	74.0	1.2	1.1		
7	75.0	1.2	1.1		
8	55.0	1.4	1.3	8.0	30.0
9	55.0	1.4	1.3	8.0	30.0
10	55.0	1.4	1.3	8.0	30.0
11	55.0	1.7	1.6	8.0	30.0
12	55.0	1.7	1.6	8.0	30.0
13	55.0	2.0	1.9	8.0	30.0
14	55.0	2.0	1.9	8.0	30.0
15	55.0	2.0	1.9	8.0	30.0
16	55.0	2.1	2.0	8.0	30.0
17	55.0	2.1	2.0	8.0	30.0
18	55.0	0.6	0.5		
19	55.0	0.6	0.5		
20	55.0	0.3	0.2		
21	55.0	0.3	1.2		
22	81.0	1.2	1.1		
23	79.0	1.2	1.1		
24	77.0	1.2	1.1		

CASE 6

<u>Roof Height (Feet)</u>	<u>Supply Height (Feet)</u>	<u>Return Height (Feet)</u>	<u>Ventilation Height (Feet)</u>	<u>Lighting Height (Feet)</u>
20.0	10.0	5.0	19.0	12.0

<u>Name Of Roof Material</u>	<u>Thickness (Feet)</u>	<u>Name Of Floor Material</u>	<u>Thickness (Feet)</u>
Roof Insulation	0.17	Floor Slab	0.33
Built Up Roofing	0.33	Soil	5.0

<u>Solar Time (Hour)</u>	<u>Supply Temp. (°F)</u>	<u>Supply Rate (cfm/sqft)</u>	<u>Return Rate (cfm/sqft)</u>	<u>Lighting Load (Btu/hr-sqft)</u>	<u>Internal Disperse Loads (Btu/hr-sqft)</u>
1	76.0	1.2	1.1		
2	76.0	1.2	1.1		
3	75.0	1.2	1.1		
4	74.0	1.2	1.1		
5	74.0	1.2	1.1		
6	74.0	1.2	1.1		
7	75.0	1.2	1.1		
8	55.0	1.4	1.3	8.0	30.0
9	55.0	1.5	1.4	8.0	30.0
10	55.0	1.6	1.5	8.0	30.0
11	55.0	1.8	1.7	8.0	30.0
12	55.0	1.8	1.7	8.0	30.0
13	55.0	2.1	2.0	8.0	30.0
14	55.0	2.1	2.0	8.0	30.0
15	55.0	2.1	2.0	8.0	30.0
16	55.0	2.2	2.1	8.0	30.0
17	55.0	2.2	2.1	8.0	30.0
18	55.0	0.8	0.7		
19	55.0	0.7	0.6		
20	55.0	0.3	0.2		
21	55.0	0.3	0.2		
22	81.0	1.2	1.1		
23	79.0	1.2	1.1		
24	77.0	1.2	1.1		

CASE 7

<u>Roof Height (Feet)</u>	<u>Supply Height (Feet)</u>	<u>Return Height (Feet)</u>	<u>Ventilation Height (Feet)</u>	<u>Lighting Height (Feet)</u>
20.0	10.0	19.0	19.0	12.0

<u>Name Of Roof Material</u>	<u>Thickness (Feet)</u>	<u>Name Of Floor Material</u>	<u>Thickness (Feet)</u>
Roof Insulation	0.17	Floor Slab	0.33
Built Up Roofing	0.33	Soil	5.00

<u>Solar Time (Hour)</u>	<u>Supply Temp. (°F)</u>	<u>Supply Rate (cfm/sqft)</u>	<u>Return Rate (cfm/sqft)</u>	<u>Lighting Load (Btu/hr-sqft)</u>	<u>Internal Disperse Loads (Btu/hr-sqft)</u>
1	76.0	1.2	1.1		
2	76.0	1.2	1.1		
3	75.0	1.2	1.1		
4	74.0	1.2	1.1		
5	74.0	1.2	1.1		
6	74.0	1.2	1.1		
7	75.0	1.2	1.1		
8	55.0	1.4	1.3	8.0	30.0
9	55.0	1.5	1.4	8.0	30.0
10	55.0	1.6	1.5	8.0	30.0
11	55.0	1.8	1.7	8.0	30.0
12	55.0	1.8	1.7	8.0	30.0
13	55.0	2.1	2.0	8.0	30.0
14	55.0	2.1	2.0	8.0	30.0
15	55.0	2.1	2.0	8.0	30.0
16	55.0	2.2	2.1	8.0	30.0
17	55.0	2.2	2.1	8.0	30.0
18	55.0	0.8	0.7		
19	55.0	0.7	0.6		
20	55.0	0.3	0.2		
21	55.0	0.3	0.2		
22	81.0	1.2	1.1		
23	79.0	1.2	1.1		
24	77.0	1.2	1.1		

CASE 8

<u>Roof Height (Feet)</u>	<u>Supply Height (Feet)</u>	<u>Return Height (Feet)</u>	<u>Ventilation Height (Feet)</u>	<u>Lighting Height (Feet)</u>
20.0	10.0	1.0	19.0	12.0

<u>Name Of Roof Material</u>	<u>Thickness (Feet)</u>	<u>Name Of Floor Material</u>	<u>Thickness (Feet)</u>
Roof Insulation	0.17	Floor Slab	0.33
Built Up Roofing	0.75	Soil	5.00

<u>Solar Time (Hour)</u>	<u>Supply Temp. (°F)</u>	<u>Supply Rate (cfm/sqft)</u>	<u>Return Rate (cfm/sqft)</u>	<u>Lighting Load (Btu/hr-sqft)</u>	<u>Internal Disperse Loads (Btu/hr-sqft)</u>
1	76.0	1.2	1.1		
2	76.0	1.2	1.1		
3	75.0	1.2	1.1		
4	74.0	1.2	1.1		
5	74.0	1.2	1.1		
6	74.0	1.2	1.1		
7	75.0	1.2	1.1		
8	55.0	1.4	1.3	8.0	30.0
9	55.0	1.5	1.4	8.0	30.0
10	55.0	1.6	1.5	8.0	30.0
11	55.0	1.8	1.7	8.0	30.0
12	55.0	1.8	1.7	8.0	30.0
13	55.0	2.1	2.0	8.0	30.0
14	55.0	2.1	2.0	8.0	30.0
15	55.0	2.1	2.0	8.0	30.0
16	55.0	2.2	2.1	8.0	30.0
17	55.0	2.2	2.1	8.0	30.0
18	55.0	0.8	0.7		
19	55.0	0.7	0.6		
20	55.0	0.3	0.2		
21	55.0	0.3	0.2		
22	81.0	1.2	1.1		
23	79.0	1.2	1.1		
24	77.0	1.2	1.1		

CASE 10

<u>Roof Height (Feet)</u>	<u>Supply Height (Feet)</u>	<u>Return Height (Feet)</u>	<u>Ventilation Height (Feet)</u>	<u>Lighting Height (Feet)</u>
20.0	18.0	1.0	19.0	12.0

<u>Name Of Roof Material</u>	<u>Thickness (Feet)</u>	<u>Name Of Floor Material</u>	<u>Thickness (Feet)</u>
Roof Insulation	0.17	Floor Slab	0.33
Built Up Roofing	0.33	Soil	5.00

<u>Solar Time (Hour)</u>	<u>Supply Temp. (°F)</u>	<u>Supply Rate (cfm/sqft)</u>	<u>Return Rate (cfm/sqft)</u>	<u>Lighting Load (Btu/hr-sqft)</u>	<u>Internal Disperse Loads (Btu/hr-sqft)</u>
1	76.0	1.2	1.1		
2	76.0	1.2	1.1		
3	75.0	1.2	1.1		
4	74.0	1.2	1.1		
5	74.0	1.2	1.1		
6	74.0	1.2	1.1		
7	75.0	1.2	1.1		
8	55.0	1.4	1.3	8.0	30.0
9	55.0	1.4	1.3	8.0	30.0
10	55.0	1.5	1.4	8.0	30.0
11	55.0	1.8	1.7	8.0	30.0
12	55.0	1.8	1.7	8.0	30.0
13	55.0	2.1	2.0	8.0	30.0
14	55.0	2.1	2.0	8.0	30.0
15	55.0	2.1	2.0	8.0	30.0
16	55.0	2.2	2.1	8.0	30.0
17	55.0	2.2	2.1	8.0	30.0
18	55.0	0.6	0.5		
19	55.0	0.6	0.5		
20	55.0	0.3	0.2		
21	55.0	0.3	0.2		
22	81.0	1.2	1.1		
23	79.0	1.2	1.1		
24	77.0	1.2	1.1		

CASE 15

<u>Roof Height (Feet)</u>	<u>Supply Height (Feet)</u>	<u>Return Height (Feet)</u>	<u>Ventilation Height (Feet)</u>	<u>Lighting Height (Feet)</u>
20.0	10.0	1.0	19.0	12.0

<u>Name Of Roof Material</u>	<u>Thickness (Feet)</u>	<u>Name Of Floor Material</u>	<u>Thickness (Feet)</u>
Roof Insulation	0.17	Floor Slab	0.33
Built Up Roofing	0.33	Soil	5.00

<u>Solar Time (Hour)</u>	<u>Supply Temp. (°F)</u>	<u>Supply Rate (cfm/sqft)</u>	<u>Return Rate (cfm/sqft)</u>	<u>Lighting Load (Btu/hr-sqft)</u>	<u>Internal Disperse Load (Btu/hr-sqft)</u>
1	55.0	2.0	1.9	8.0	30.0
2	55.0	2.0	1.9	8.0	30.0
3	55.0	2.0	1.9	8.0	30.0
4	55.0	2.0	1.9	8.0	30.0
5	55.0	2.0	1.9	8.0	30.0
6	55.0	2.0	1.9	8.0	30.0
7	55.0	2.0	1.9	8.0	30.0
8	55.0	2.0	1.9	8.0	30.0
9	55.0	2.0	1.9	8.0	30.0
10	55.0	2.0	1.9	8.0	30.0
11	55.0	2.0	1.9	8.0	30.0
12	55.0	2.0	1.9	8.0	30.0
13	55.0	2.0	1.9	8.0	30.0
14	55.0	2.0	1.9	8.0	30.0
15	55.0	2.0	1.9	8.0	30.0
16	55.0	2.0	1.9	8.0	30.0
17	55.0	2.0	1.9	8.0	30.0
18	55.0	2.0	1.9	8.0	30.0
19	55.0	2.0	1.9	8.0	30.0
20	55.0	2.0	1.9	8.0	30.0
21	55.0	2.0	1.9	8.0	30.0
22	55.0	2.0	1.9	8.0	30.0
23	55.0	2.0	1.9	8.0	30.0
24	55.0	2.0	1.9	8.0	30.0

CASE 17

<u>Roof Height (Feet)</u>	<u>Supply Height (Feet)</u>	<u>Return Height (Feet)</u>	<u>Ventilation Height (Feet)</u>	<u>Lighting Height (Feet)</u>
20.0	10.0	1.0	19.0	12.0

<u>Name Of Roof Material</u>	<u>Thickness (Feet)</u>	<u>Name Of Floor Material</u>	<u>Thickness (Feet)</u>
Roof Insulation	0.17	Floor Slab	0.33
Built Up Roofing	0.33	Soil	5.00

<u>Solar Time (Hour)</u>	<u>Supply Temp. (°F)</u>	<u>Supply Rate (cfm/sqft)</u>	<u>Return Rate (cfm/sqft)</u>	<u>Lighting Load (Btu/hr-sqft)</u>	<u>Internal Disperse Loads (Btu/hr-sqft)</u>
1	76.0	1.2	1.1		
2	76.0	1.2	1.1		
3	75.0	1.2	1.1		
4	74.0	1.2	1.1		
5	74.0	1.2	1.1		
6	74.0	1.2	1.1		
7	75.0	1.2	1.1		
8	55.0	1.4	1.3	8.0	30.0
9	55.0	1.4	1.3	8.0	30.0
10	55.0	1.4	1.3	8.0	30.0
11	55.0	1.6	1.5	8.0	30.0
12	55.0	1.7	1.6	8.0	30.0
13	55.0	2.0	1.9	8.0	30.0
14	55.0	2.0	1.9	8.0	30.0
15	55.0	2.0	1.9	8.0	30.0
16	55.0	2.0	1.9	8.0	30.0
17	55.0	2.0	1.9	8.0	30.0
18	55.0	2.0	1.9	8.0	30.0
19	55.0	1.9	1.8	8.0	30.0
20	55.0	1.9	1.8	8.0	30.0
21	55.0	1.7	1.6	8.0	30.0
22	55.0	1.7	1.6	8.0	30.0
23	55.0	1.5	1.4	8.0	30.0
24	55.0	1.5	1.4	8.0	30.0

CASE 19

<u>Roof Height (Feet)</u>	<u>Supply Height (Feet)</u>	<u>Return Height (Feet)</u>	<u>Ventilation Height (Feet)</u>	<u>Lighting Height (Feet)</u>
20.0	10.0	1.0	19.0	10.0

<u>Name Of Roof Material</u>	<u>Thickness (Feet)</u>	<u>Name Of Floor Material</u>	<u>Thickness (Feet)</u>
Roof Insulation	0.17	Floor Slab	0.33
Built Up Roofing	0.33	Soil	5.00

<u>Solar Time (Hour)</u>	<u>Supply Temp. (°F)</u>	<u>Supply Rate (cfm/sqft)</u>	<u>Return Rate (cfm/sqft)</u>	<u>Lighting Load (Btu/hr-sqft)</u>	<u>Internal Disperse Loads (Btu/hr-sqft)</u>
1	76.0	1.2	1.1		
2	76.0	1.2	1.1		
3	75.0	1.2	1.1		
4	74.0	1.2	1.1		
5	74.0	1.2	1.1		
6	74.0	1.2	1.1		
7	75.0	1.2	1.1		
8	55.0	1.4	1.3	8.0	30.0
9	55.0	1.5	1.4	8.0	30.0
10	55.0	1.6	1.5	8.0	30.0
11	55.0	1.8	1.7	8.0	30.0
12	55.0	1.8	1.7	8.0	30.0
13	55.0	2.2	2.1	8.0	30.0
14	55.0	2.2	2.1	8.0	30.0
15	55.0	2.2	2.1	8.0	30.0
16	55.0	2.3	2.2	8.0	30.0
17	55.0	2.3	2.2	8.0	30.0
18	55.0	1.0	0.9		
19	55.0	1.0	0.9		
20	55.0	0.6	0.5		
21	55.0	0.6	0.5		
22	81.0	1.2	1.1		
23	79.0	1.2	1.1		
24	77.0	1.2	1.1		

CASE 20

<u>Roof Height (Feet)</u>	<u>Supply Height (Feet)</u>	<u>Return Height (Feet)</u>	<u>Ventilation Height (Feet)</u>	<u>Lighting Height (Feet)</u>
20.0	10.0	1.0	12.0	12.0

<u>Name Of Roof Material</u>	<u>Thickness (Feet)</u>	<u>Name Of Floor Material</u>	<u>Thickness (Feet)</u>
Roof Insulation	0.17	Floor Slab	0.33
Built Up Roofing	0.33	Soil	5.00

<u>Solar Time (Hour)</u>	<u>Supply Temp. (°F)</u>	<u>Supply Rate (cfm/sqft)</u>	<u>Return Rate (cfm/sqft)</u>	<u>Lighting Load (Btu/hr-sqft)</u>	<u>Internal Disperse Loads (Btu/hr-sqft)</u>
1	76.0	1.2	1.1		
2	76.0	1.2	1.1		
3	75.0	1.2	1.1		
4	74.0	1.2	1.1		
5	74.0	1.2	1.1		
6	74.0	1.2	1.1		
7	75.0	1.2	1.1		
8	55.0	1.4	1.3	8.0	30.0
9	55.0	1.5	1.4	8.0	30.0
10	55.0	1.6	1.5	8.0	30.0
11	55.0	1.8	1.7	8.0	30.0
12	55.0	1.8	1.7	8.0	30.0
13	55.0	2.2	2.1	8.0	30.0
14	55.0	2.2	2.1	8.0	30.0
15	55.0	2.2	2.1	8.0	30.0
16	55.0	2.3	2.2	8.0	30.0
17	55.0	2.3	2.2	8.0	30.0
18	55.0	1.0	0.9		
19	55.0	1.0	0.9		
20	55.0	0.6	0.5		
21	55.0	0.6	0.5		
22	81.0	1.2	1.1		
23	79.0	1.2	1.1		
24	77.0	1.2	1.1		

CASE 21

<u>Roof Height (Feet)</u>	<u>Supply Height (Feet)</u>	<u>Return Height (Feet)</u>	<u>Ventilation Height (Feet)</u>	<u>Lighting Height (Feet)</u>
20.0	10.0	1.0	19.0	12.0

<u>Name Of Roof Material</u>	<u>Thickness (Feet)</u>	<u>Name Of Floor Material</u>	<u>Thickness (Feet)</u>
Roof Insulation	0.17	Floor Slab	0.33
Built Up Roofing	0.33	Soil	5.00

<u>Solar Time (Hour)</u>	<u>Supply Temp. (°F)</u>	<u>Supply Rate (cfm/sqft)</u>	<u>Return Rate (cfm/sqft)</u>	<u>Lighting Load (Btu/hr-sqft)</u>	<u>Internal Disperse Loads (Btu/hr-sqft)</u>
1	76.0	1.2	0.8		
2	76.0	1.2	0.8		
3	75.0	1.2	0.8		
4	74.0	1.2	0.8		
5	74.0	1.2	0.8		
6	74.0	1.2	0.8		
7	75.0	1.2	0.8		
8	55.0	1.4	1.0	8.0	30.0
9	55.0	1.4	1.0	8.0	30.0
10	55.0	1.4	1.0	8.0	30.0
11	55.0	1.7	1.2	8.0	30.0
12	55.0	1.7	1.2	8.0	30.0
13	55.0	2.0	1.4	8.0	30.0
14	55.0	2.0	1.4	8.0	30.0
15	55.0	2.0	1.4	8.0	30.0
16	55.0	2.1	1.5	8.0	30.0
17	55.0	2.1	1.5	8.0	30.0
18	55.0	0.6	0.4		
19	55.0	0.6	0.4		
20	55.0	0.3	0.2		
21	55.0	0.3	0.2		
22	81.0	1.2	0.8		
23	79.0	1.2	0.8		
24	77.0	1.2	0.8		

CASE 22

<u>Roof Height (Feet)</u>	<u>Supply Height (Feet)</u>	<u>Return Height (Feet)</u>	<u>Ventilation Height (Feet)</u>	<u>Lighting Height (Feet)</u>
20.0	10.0	1.0	19.0	12.0

<u>Name Of Roof Material</u>	<u>Thickness (Feet)</u>	<u>Name Of Floor Material</u>	<u>Thickness (Feet)</u>
Roof Insulation	0.17	Floor Slab	0.33
Built Up Roofing	0.33	Soil	5.00

<u>Solar Time (Hour)</u>	<u>Supply Temp. (°F)</u>	<u>Supply Rate (cfm/sqft)</u>	<u>Return Rate (cfm/sqft)</u>	<u>Lighting Load (Btu/hr-sqft)</u>	<u>Internal Disperse Loads (Btu/hr-sqft)</u>
1	76.0	1.2	1.0		
2	76.0	1.2	1.0		
3	75.0	1.2	1.0		
4	74.0	1.2	1.0		
5	74.0	1.2	1.0		
6	74.0	1.2	1.0		
7	75.0	1.2	1.0		
8	55.0	1.4	1.1	8.0	30.0
9	55.0	1.4	1.1	8.0	30.0
10	55.0	1.4	1.1	8.0	30.0
11	55.0	1.7	1.4	8.0	30.0
12	55.0	1.7	1.4	8.0	30.0
13	55.0	2.0	1.6	8.0	30.0
14	55.0	2.0	1.6	8.0	30.0
15	55.0	2.0	1.6	8.0	30.0
16	55.0	2.1	1.7	8.0	30.0
17	55.0	2.1	1.7	8.0	30.0
18	55.0	0.6	0.5		
19	55.0	0.6	0.5		
20	55.0	0.3	0.2		
21	55.0	0.3	0.2		
22	81.0	1.2	1.0		
23	79.0	1.2	1.0		
24	77.0	1.2	1.0		

CASE 25

Roof Height (Feet)	Supply Height (Feet)	Return Height (Feet)	Ventilation Height (Feet)	Lighting Height (Feet)
20.0	10.0	1.0	19.0	12.0

Name Of Roof Material	Thickness (Feet)	Name Of Floor Material	Thickness (Feet)
Steel Roof Decking	0.02	Floor Slab	0.33
		Soil	5.00

<u>Solar Time (Hour)</u>	<u>Supply Temp. (°F)</u>	<u>Supply Rate (cfm/sqft)</u>	<u>Return Rate (cfm/sqft)</u>	<u>Lighting Load (Btu/hr-sqft)</u>	<u>Internal Disperse Loads (Btu/hr-sqft)</u>
1	76.0	1.2	1.1		
2	76.0	1.2	1.1		
3	75.0	1.2	1.1		
4	74.0	1.2	1.1		
5	74.0	1.2	1.1		
6	74.0	1.2	1.1		
7	75.0	1.2	1.1		
8	55.0	1.6	1.5	8.0	30.0
9	55.0	1.6	1.5	8.0	30.0
10	55.0	1.8	1.7	8.0	30.0
11	55.0	2.0	1.9	8.0	30.0
12	55.0	2.0	1.9	8.0	30.0
13	55.0	2.6	2.5	8.0	30.0
14	55.0	2.6	2.5	8.0	30.0
15	55.0	2.7	2.6	8.0	30.0
16	55.0	2.8	2.7	8.0	30.0
17	55.0	2.8	2.7	8.0	30.0
18	55.0	1.5	1.4		
19	55.0	1.5	1.4		
20	55.0	1.0	0.9		
21	55.0	1.0	0.9		
22	81.0	1.2	1.1		
23	79.0	1.2	1.1		
24	77.0	1.2	1.1		

APPENDIX C

LISTING OF THE COMPUTER PROGRAM USING THE FORTRAN LANGUAGE

FILE: TRANS FORTRAN A1

KANSAS STATE UNIVERSITY VM/SP CMS

C		TRA00010
C	SIMULATION OF THE TRANSIENT BEHAVIOR OF	TRA00020
C	STRATIFIED AIR CONDITIONING SYSTEMS	TRA00030
C		TRA00040
C		TRA00050
C	NOTE: FOUR AIR NODES SHOULD BE CONSIDERED THE MINIMUM	TRA00060
C	PRACTICAL NUMBER	TRA00070
C		TRA00080
C		TRA00090
C	HSAT= HOURLY SOL-AIR TEMPERATURE (DEG F)	TRA00100
C	HTS=HOURLY SUPPLY AIR TEMPERATURE (DEG F)	TRA00110
C	HTO=HOURLY OUTSIDE AIR TEMPERATURE (DEG F)	TRA00120
C	HSUP=HOURLY SUPPLY AIR FLOWRATE (CFM/SQFT)	TRA00130
C	HRET=HOURLY RETURN AIR FLOWRATE (CFM/SQFT)	TRA00140
C	HLTS=HOURLY LIGHTING LOAD IN BUILDING (BTU/HR SQFT)	TRA00150
C	HLOAD=HOURLY INTERNAL LOAD FOR EACH ELEMENT(BTU/HR SQFT)	TRA00160
C		TRA00170
C	SOLL= SOLAR AND CONVECTIVE LOAD ON OUTSIDE OF ROOF (BTU/HR SQFT)	TRA00180
C	RFLD= CONVECTIVE ROOF LOAD INTO SPACE (BTU/HR SQFT)	TRA00190
C	RFRD=NET RADIANT ROOF LOAD ONTO FLOOR OR ROOF (BTU/HR SQFT)	TRA00200
C	FLCLD=CONVECTIVE FLOOR LOAD INTO SPACE (BTU/HR SQFT)	TRA00210
C	WLCLD=CONVECTIVE WALL LOAD INTO SPACE (INSTANTANEOUS) (BTU/HR SQFT)	TRA00220
C	LTCLD=CONVECTIVE PORTION OF LIGHTING LOAD (BTU/HR SQFT)	TRA00230
C	LTRLD=RADIANT PORTION OF LIGHTING LOAD (BTU/HR SQFT)	TRA00240
C	VENTLD=VENTILATION PORTION OF SPACE LOAD (BTU/HR SQFT)	TRA00250
C	RETLD=RETURN AIR PORTION OF SPACE LOAD (BTU/HR SQFT)	TRA00260
C		TRA00270
C	HRO=OUTSIDE ROOF FILM COEFFICIENT (BTU/HR SQFT DEGF)	TRA00280
C	HRI=INSIDE ROOF FILM COEFFICIENT (BTU/HR SQFT DEGF)	TRA00290
C	HFI=INSIDE FLOOR FILM COEFFICIENT (BTU/HR SQFT DEGF)	TRA00300
C		TRA00310
C	MSE=SUPPLY TO INDIVIDUAL ELEMENT(LB/HR SQFT)	TRA00320
C	MRE=RETURN FROM INDIVIDUAL ELEMENT(LB/HR SQFT)	TRA00330
C	MVE=VENTILATION FROM INDIVIDUAL ELEMENT(LB/HR SQFT)	TRA00340
C	MCE=CIRCULATION BETWEEN ELEMENTS (LB/HR SQFT)	TRA00350
C	MS=SUPPLY AIR FLOW TO ENTIRE BUILDING (LB/HR SQFT)	TRA00360
C	MV=VENTILATION AIR FLOW FROM ENTIRE BUILDING (LB/HR SQFT)	TRA00370
C	MR=RETURN AIR FLOW FROM ENTIRE BUILDING (LB/HR SQFT)	TRA00380
C		TRA00390
C	PER=PERIMETER OF BUILDING PER SQUARE FOOT OF FLOOR SPACE (FT/SQ FT)	TRA00400
C	TRMASS=MASS OF ROOF TRUSSES (LB/SQ FT)	TRA00410
C	CPSTL=SPECIFIC HEAT OF ROOF TRUSS MATERIAL (BTU/LB DEGF)	TRA00420
C	SF=RADIATION SHAPE FACTOR	TRA00430
C		TRA00440
C	M=NO OF LEVEL OF VENTILATION	TRA00450
C	N=NO OF LEVEL OF SUPPLY	TRA00460
C	K=NO OF UPPER LEVEL IN BUILDING	TRA00470
C	MRET=NO OF LEVEL OF RETURN	TRA00480
C	NLTS=NO OF LEVEL OF LIGHTS	TRA00490
C	NROOF=NUMBER OF ROOF MATERIALS	TRA00500
C	NFLOOR=NUMBER OF FLOOR AND SOIL MATERIALS	TRA00510
C	NN=NUMBER OF ROOF TEMPERATURE NODES	TRA00520
C	NFL=NUMBER OF FLOOR TEMPERATURE NODES	TRA00530
C	II=TOTAL NUMBER OF TEMPERATURE NODES IN MODEL	TRA00540
C	NAIR=FIRST AIR NODE	TRA00550
C	KAI=UPPER AIR NODE	TRA00560
C		TRA00570

FILE: TRANS FORTRAN A1

KANSAS STATE UNIVERSITY VM/SP CMS

```

7 FORMAT (18A4)
8 FORMAT (I2,2(3X,I2),8X,F10.2)
9 FORMAT (5A4,4F10.4)
11 FORMAT (12F6.2)
15 FORMAT (I2,4(3X,I2))
16 FORMAT (2F10.2,5F10.4)
18 FORMAT (' ',T15,'NAME OF FLOOR',T34,'THICKNESS'
+,T70,'CONDUCTIVITY',T90,'DENSITY',T106,'HEAT')
20 FORMAT ('0',40X,'HOURLY LOADS FOR DAY',2X,I2)
21 FORMAT ('0',6X,'SOLLD',T20,'RFCLD',T32,'RFRLD',T44,'RFST',T56,
+'FLCLD',T68,'WALCLD',T80,'LTLD',T92,'EXLD',T104,'RETLD',T116,
+'MUALD')
22 FORMAT (' ',1X,'TIME',10(1X,'BTU/HR-SQFT'))
23 FORMAT (' ',1X,'_____',10(1X,'_____'))
24 FORMAT ('0',2X,I2,1X,10(1X,F11.3))
30 FORMAT ('-',T5,'MASS OF ROOF TRUSSES',T30,
+'SPECIFIC HEAT OF TRUSS MATERIAL',T80,'RADIATION SHAPE FACTOR')
31 FORMAT (' ',T10,'(LB/SQFT)',T35,'(BTU/LB DEGF)')
32 FORMAT ('0',T10,F10.4,T35,F10.4,T88,F10.4)
39 FORMAT ('1',30X,18A4)
40 FORMAT ('-',5X,60('* '))
41 FORMAT ('0',5X,60('* '))
42 FORMAT ('0',52X,'GENERAL PROGRAM VARIABLES:')
43 FORMAT ('-',10X,'SPECIFIC HEAT',T34,'DENSITY CF',T50,
+'THERMAL CONDUCTIVITY',T80,'MIXING',T100,'INITIAL',T116,
+'SIZE OF')
44 FORMAT (' ',12X,'OF AIR',T38,'AIR',T56,'OF AIR',T78,
+'COEFFICIENT',T99,'TEMPERATURE',T115,'TIME STEP')
45 FORMAT (' ',9X,'(BTU/LB DEGF)',T34,'(LB/CUFT)',T53,
+'(BTU/HR FT DEGF)',T76,'(BTU/HR FT DEGF)',T101,
+'(DEGF)',T118,'(HR)')
48 FORMAT ('-',T12,'TOTAL NUMBER OF',T36,'NUMBER OF LAYERS',T58,
+'NUMBER OF LAYER',T78,'NUMBER OF LAYER',T98,'NUMBER OF LAYER')
49 FORMAT (' ',T10,'LAYERS IN BUILDING',T36,'WITH SUPPLY',T60,
+'WITH VENT',T78,'WITH RETURN',T98,'WITH LIGHTS')
50 FORMAT ('-',T20,'PERIMETER OF',T40,'FLOOR AREA OF',T61,
+'OVERALL H.T. COEFFICIENT',T90,'THICKNESS OF')
51 FORMAT (' ',T22,'BUILDING',T43,'BUILDING',T67,'OF WALLS',T92,
+'AIR LAYER')
52 FORMAT (' ',T24,'(FT)',T44,'(SQFT)',T63,'(BTU/HR SQFT DEGF)',T95,
+'(FT)')
53 FORMAT ('-',T72,'THERMAL',T104,
+'SPECIFIC')
54 FORMAT (' ',T15,'NAME OF ROOF',T34,'THICKNESS'
+,T70,'CONDUCTIVITY',T90,'DENSITY',T106,'HEAT')
55 FORMAT (' ',T17,'MATERIAL',T37,'(FT)',
+T68,'(BTU/HR FT DEGF)',T89,'(LB/CUFT)',T102,'(BTU/LB DEGF)')
60 FORMAT ('0',T30,'ELEMENT',T80,'TEMPERATURE PROFILE')
61 FORMAT (' ',T30,'HEAT LOADS',T84,'OF AIR')
62 FORMAT (' ',T30,'(BTU/HR SQFT)',T84,'(DEGF)')
74 FORMAT (' ',T30,F10.2,T80,F10.2)
75 FORMAT (' ',T80,F10.2)
80 FORMAT ('0',10X,F10.4,11X,F10.4,11X,F10.4,15X,
+F10.4,10X,F10.1,5X,F10.4)
81 FORMAT ('0',T16,I2,T40,I2,T62,I2,T82,I2,T102,I2)
82 FORMAT ('0',T20,F8.2,T40,F10.2,T65,F8.4,T91,F8.1)
83 FCRMAT ('0',T10,5A4,T31,F10.2,T71,F10.2,T88,

```

TRA00580
 TRA00590
 TRA00600
 TRA00610
 TRA00620
 TRA00630
 TRA00640
 TRA00650
 TRA00660
 TRA00670
 TRA00680
 TRA00690
 TRA00700
 TRA00710
 TRA00720
 TRA00730
 TRA00740
 TRA00750
 TRA00760
 TRA00770
 TRA00780
 TRA00790
 TRA00800
 TRA00810
 TRA00820
 TRA00830
 TRA00840
 TRA00850
 TRA00860
 TRA00870
 TRA00880
 TRA00890
 TRA00900
 TRA00910
 TRA00920
 TRA00930
 TRA00940
 TRA00950
 TRA00960
 TRA00970
 TRA00980
 TRA00990
 TRA01000
 TRA01010
 TRA01020
 TRA01030
 TRA01040
 TRA01050
 TRA01060
 TRA01070
 TRA01080
 TRA01090
 TRA01100
 TRA01110
 TRA01120
 TRA01130
 TRA01140

FILE: TRANS FORTRAN A1

KANSAS STATE UNIVERSITY VM/SP CMS

```

      +F10.2,T103,F10.4)
84  FORMAT (' ',T5,'SOL-AIR TEMP.',T25,'OUTSIDE AIR TEMP.',T46,
      +'SUPPLY AIR TEMP.',T67,'SUPPLY RATE',T85,'RETURN RATE',T100,
      +'VENT RATE')
85  FORMAT (' ',T10,'(DEGF)',T30,'(DEGF)',T51,'(DEGF)',T67,'(CFM/SQFT)
      +' ',T85,'(CFM/SQFT)',T100,'(CFM/SQFT)')
86  FORMAT (' ',T10,'_____',T30,'_____',T51,'_____',T67,
      +'_____',T85,'_____',T100,'_____')
87  FORMAT ('0',T5,F10.2,T25,F10.2,T46,F10.2,T67,F10.2,T85,F10.2,
      +T100,F10.2)
88  FORMAT ('0',T30,'HOURLY AIR TEMPERATURES AND FLOWS FOR DAY ',I2)
89  FORMAT ('0',T55,'SUMMATION FOR HOUR ',I2)
      REAL MSE(15),MVE(15),MRE(15),MCE(15),KAIR,KMIX,KRF(2),LOAD(15)
      REAL LTRLD,LTCLD(15),D5(15)
      REAL MS,MR,MV,RFRLD,KFL(2)
      DIMENSION A(25,26),T(25),YY(25)
      DIMENSION RHOF(2),CPFL(2),DELXFL(2),FLNAME(5,2),THFL(2)
      DIMENSION RHORF(2),CPRF(2),DELXX(2),RNAME(5,2),THRF(2)
      DIMENSION HLOAD(15,24),HLTS(24),HSAT(24),HTQ(24),HTS(24)
      DIMENSION HSUP(24),HRET(24),HVENT(24)
      DIMENSION DESCR(18),SOLD(7,24),SRFLD(7,24),SRFRLD(7,24)
      DIMENSION SRFST(7,24),SFLCLD(7,24),SWALCL(7,24),SLTLD(7,24)
      DIMENSION SEXLD(7,24),SRETLD(7,24),SVENLD(7,24)
C
C  DEFINE GENERAL PROGRAM VARIABLES
C
      TI=80.
C *****
C
C  THE INITIAL FLOOR TEMPERATURE SHOULD BE SET AT 55 DEG F FOR ALL
C  ACTUAL RUNS--DURING TESTING SET TO DESIRED VALUE
C
      TFI=55.
C *****
C
      CPAIR=.24
      RHOAIR=.075
      KAIR=.015
      KMIX=0.075
      PERRLT=.80
      EPS1=.80
      EPS2=.80
      SIGMA=.1714E-08
C
C  READ CASE DESCRIPTION
C
      READ (5,7) DESCR
C
C  READ TIME STEP VARIABLES
C
      READ (5,8) ND,NHO,NSTP,THETA
C
C  READ FLOOR MATERIALS
C
      READ (5,8) NFLOOR
      DO 100 I=1,NFLOOR
      READ(5,9) (FLNAME(J,I),J=1,5),KFL(I),RHOF(I),CPFL(I),THFL(I)

```

FILE: TRANS FORTRAN A1

KANSAS STATE UNIVERSITY VM/SP CMS

100 CONTINUE	TRA01720
C	TRA01730
C READ ROOF MATERIALS	TRA01740
C	TRA01750
READ (5,8) NROOF	TRA01760
DO 110 I=1,NROOF	TRA01770
READ(5,9) (RNAME(J,I),J=1,5),KRF(I),RHORF(I),CPRF(I),THRF(I)	TRA01780
110 CONTINUE	TRA01790
C	TRA01800
C READ BUILDING VARIABLES	TRA01810
C	TRA01820
READ(5,15) K,N,M,MRET,NLTS	TRA01830
READ(5,16) DELX,AREA,PER,UWALL,TRMASS,CPSTL,SF	TRA01840
C *****	TRA01850
C	TRA01860
C THE NEXT TWO LINES ARE JUST USED WHEN COMPARING TO THE STEADY STATE	TRA01870
C MODEL--- COMMENT THEM OUT IN ACTUAL RUNS	TRA01880
C READ (5,10) QROOF,QFLOOR	TRA01890
C 10 FORMAT (2F10.4)	TRA01900
C	TRA01910
C *****	TRA01920
C	TRA01930
C READ HOURLY HEAT LOADS, TEMPERATURES AND FLOWRATES	TRA01940
C	TRA01950
READ (5,11) (HSAT(I),I=1,24)	TRA01960
READ (5,11) (HTS(I),I=1,24)	TRA01970
READ (5,11) (HTO(I),I=1,24)	TRA01980
READ (5,11) (HSUP(I),I=1,24)	TRA01990
READ (5,11) (HRET(I),I=1,24)	TRA02000
READ (5,11) (HLTS(I),I=1,24)	TRA02010
DO 120 JJ=1,K	TRA02020
READ (5,11) (HLOAD(JJ,I),I=1,24)	TRA02030
120 CONTINUE	TRA02040
C	TRA02050
C	TRA02060
C	TRA02070
C	TRA02080
C SET ALL ELEMENT FLOWRATES AND LOADS TO ZERO AND INITIALIZE	TRA02090
C ALL ELEMENT TEMPERATURES	TRA02100
C	TRA02110
DO 200 I=1,K	TRA02120
MSE(I)=0.0	TRA02130
MRE(I)=0.0	TRA02140
MVE(I)=0.0	TRA02150
MCE(I)=0.0	TRA02160
200 CONTINUE	TRA02170
C	TRA02180
C INITIALIZE FLOOR TEMPERATURES	TRA02190
C	TRA02200
NFL=NFLCCR*2.+1	TRA02210
NFL1=NFL+1	TRA02220
DO 205 I=1,NFL	TRA02230
T(I)=TFI	TRA02240
205 CONTINUE	TRA02250
C	TRA02260
NN=2*NROOF+1	TRA02270
II=K+NFL+NN	TRA02280

FILE: TRANS FORTRAN A1

KANSAS STATE UNIVERSITY VM/SP CMS

```

      I11=I1+1
      NAIR=NFL+1
      KAI=NFL+K
      NAIR1=NAIR+1
      KAM1=KAI-1
C
C INITIALIZE ROOF AND AIR TEMPERATURES
C
      DO 210 I=NFL1,I1
      T(I)=TI
210 CONTINUE
C
C CALCULATE THE THERMAL CAPACITY OF AIR NODES
C
      KM1=K-1
      DO 220 I=1,KM1
      YY(I)=RHOAIR*CPAIR*DELX
220 CONTINUE
      YY(K)=(RHOAIR*CPAIR*DELX)+(TRMASS*CPSTL)
C
C
      WRITE (6,39) DESCR
C
C
      WRITE(6,40)
      WRITE(6,42)
      WRITE(6,41)
      WRITE(6,43)
      WRITE(6,44)
      WRITE(6,45)
      WRITE(6,80) CPAIR,RHOAIR,KAIR,KMIX,TI,THETA
      WRITE(6,48)
      WRITE(6,49)
      WRITE(6,81) K,N,M,MRET,NLTS
      WRITE(6,50)
      WRITE(6,51)
      WRITE(6,52)
      WRITE(6,82) PER,AREA,UWALL,DELX
      WRITE(6,30)
      WRITE(6,31)
      WRITE(6,32) TRMASS,CPSTL,SF
      WRITE(6,53)
      WRITE(6,54)
      WRITE(6,55)
      DO 225 I=1,NROOF
      WRITE(6,83) (RNAME(J,I),J=1,5),THRF(I),KRF(I),PHORF(I),
+CPRF(I)
225 CONTINUE
      WRITE (6,53)
      WRITE(6,18)
      WRITE (6,55)
      DO 230 I=1,NFLOOR
      WRITE (6,83) (FLNAME(J,I),J=1,5),THFL(I),KFL(I),PHOFL(I),CPFL(I)
230 CONTINUE
C

```

```

TRA02290
TRA02300
TRA02310
TRA02320
TRA02330
TRA02340
TRA02350
TRA02360
TRA02370
TRA02380
TRA02390
TRA02400
TRA02410
TRA02420
TRA02430
TRA02440
TRA02450
TRA02460
TRA02470
TRA02480
TRA02490
TRA02500
TRA02510
TRA02520
TRA02530
TRA02540
TRA02550
TRA02560
TRA02570
TRA02580
TRA02590
TRA02600
TRA02610
TRA02620
TRA02630
TRA02640
TRA02650
TRA02660
TRA02670
TRA02680
TRA02690
TRA02700
TRA02710
TRA02720
TRA02730
TRA02740
TRA02750
TRA02760
TRA02770
TRA02780
TRA02790
TRA02800
TRA02810
TRA02820
TRA02830
TRA02840
TRA02850

```

FILE: TRANS FORTRAN A1

KANSAS STATE UNIVERSITY VM/SP CMS

C REENTRY POINT AFTER EACH COMPLETE DAY	TRA02860
C	TRA02870
DO 1080 NDAYS=1,ND	TRA02880
C	TRA02890
WRITE (6,40)	TRA02900
WRITE (6,88) NDAYS	TRA02910
WRITE (6,41)	TRA02920
C	TRA02930
C	TRA02940
C REENTRY POINT AFTER EACH HOUR	TRA02950
C	TRA02960
DO 1050 NHOURLS=1,NHO	TRA02970
C	TRA02980
WRITE (6,41)	TRA02990
WRITE (6,89) NHOURLS	TRA03000
WRITE (6,41)	TRA03010
C	TRA03020
C	TRA03030
C SET ALL HOURLY LOAD SUMMATIONS TO ZERO	TRA03040
C	TRA03050
SOLLD=0.0	TRA03060
RFCLD=0.0	TRA03070
FLCLD=0.0	TRA03080
WALCLD=0.0	TRA03090
RFRLD=0.0	TRA03100
VENTLD=0.0	TRA03110
RETLD=0.0	TRA03120
RFST=0.0	TRA03130
EXLD=0.0	TRA03140
C	TRA03150
C INITIALIZE TEMPERATURES AND FLOWRATES FOR THIS HOUR	TRA03160
C	TRA03170
SAT=HSAT(NHOURLS)	TRA03180
TS=HTS(NHOURLS)	TRA03190
TO=HTO(NHOURLS)	TRA03200
C	TRA03210
C CALCULATE CONVECTIVE AND RADIANT PORTIONS OF LIGHTING LOAD	TRA03220
C	TRA03230
DO 240 I=1,K	TRA03240
LTCLD(I)=0.0	TRA03250
240 CONTINUE	TRA03260
LTRLD=HLTS(NHOURLS)*PERRLT	TRA03270
LTCLD(NLTS)=HLTS(NHOURLS)*(1-PERRLT)	TRA03280
C	TRA03290
C INITIALIZE ELEMENT HEAT LOADS FOR THIS HOUR	TRA03300
C	TRA03310
DO 250 I=1,K	TRA03320
LOAD(I)=HLOAD(I,NHOURLS)	TRA03330
250 CONTINUE	TRA03340
C	TRA03350
C THE NEXT TWO DO-LOOPS EVENLY DISTRIBUTE THE CONDITIONED SPACE LOADS	TRA03360
C	TRA03370
ATL=0.0	TRA03380
DO 260 I=1,N	TRA03390
ATL=LOAD(I)+ATL	TRA03400
260 CONTINUE	TRA03410
DO 270 I=1,N	TRA03420

FILE: TRANS FORTRAN A1

KANSAS STATE UNIVERSITY VM/SP CMS

```

      LOAD(I)=ATL/N
      270 CONTINUE
C
C
C THE NEXT TWO DO-LOOPS EVENLY DISTRIBUTE THE CONVECTIVE LIGHTING
C LOAD INTO THE CONDITIONED SPACE
C
      CMG=LTCLD(NLTS)
      DO 290 I=1,N
      LTCLD(I)=CMG/N
      290 CONTINUE
C
C
C
C INITIALIZE SUPPLY, RETURN AND VENTILATION IN ELEMENTS
C
      HVENT(NHOURS)=HSUP(NHOURS)-HRET(NHOURS)
      DO 300 I=1,N
      MSE(I)=HSUP(NHOURS)*60.*RHOAIR/N
      300 CONTINUE
      MRE(MRET)=HRET(NHOURS)*60.*RHOAIR
      MVE(M)=HVENT(NHOURS)*60.*RHOAIR
      MS=HSUP(NHOURS)*60.*RHOAIR
      MR=HRET(NHOURS)*60.*RHOAIR
      MV=MS-MR
C
C CALCULATE CIRCULATION BETWEEN ELEMENTS
C
      MCE(1)=MSE(1)-MRE(1)-MVE(1)
      KMI=K-1
      DO 305 I=2,KMI
      MCE(I)=MSE(I)+MCE(I-1)-MRE(I)-MVE(I)
      305 CONTINUE
C
C REENTRY POINT AFTER EACH TIME STEP
C
      DO 1010 NSTEPS=1,NSTP
C
C
C
      HRO=3.0
      DTFL=ABS(T(NFL)-T(NAIR))
      HFI=1.7*(DTFL)**.25
      HRI=.35+(.30*((MVE(M)/7.0)**.8))
C
C
C
C CALCULATE COMMON COEFFICIENTS (FOR AIR NODES)
C
      C1=THETA/(RHOAIR*CPAIR*DELX)
      C6=THETA/((RHOAIR*CPAIR*DELX)+(TRMASS*CPSTL))
      C2=THETA/(RHOAIR*DELX)
      C7=THETA*CPAIR/((RHOAIR*CPAIR*DELX)+(TRMASS*CPSTL))
      C3=(THETA*(KAIR+KMI))/(RHOAIR*DELX*DELX*CPAIR)
      C8=(THETA*(KAIR+KMI))/(((RHOAIR*DELX*CPAIR)+(TRMASS*CPSTL))*DELX)
      C4=(THETA*UWALL*PER)/(RHOAIR*CPAIR)
      C9=(THETA*DELX*UWALL*PER)/((RHOAIR*DELX*CPAIR)+(TRMASS*CPSTL))

```

TRA03430
 TRA03440
 TRA03450
 TRA03460
 TRA03470
 TRA03480
 TRA03490
 TRA03500
 TRA03510
 TRA03520
 TRA03530
 TRA03540
 TRA03550
 TRA03560
 TRA03570
 TRA03580
 TRA03590
 TRA03600
 TRA03610
 TRA03620
 TRA03630
 TRA03640
 TRA03650
 TRA03660
 TRA03670
 TRA03680
 TRA03690
 TRA03700
 TRA03710
 TRA03720
 TRA03730
 TRA03740
 TRA03750
 TRA03760
 TRA03770
 TRA03780
 TRA03790
 TRA03800
 TRA03810
 TRA03820
 TRA03830
 TRA03840
 TRA03850
 TRA03860
 TRA03870
 TRA03880
 TRA03890
 TRA03900
 TRA03910
 TRA03920
 TRA03930
 TRA03940
 TRA03950
 TRA03960
 TRA03970
 TRA03980
 TRA03990

FILE: TRANS FORTRAN A1

KANSAS STATE UNIVERSITY VM/SP CMS

```

      C5=(THETA*HFI)/(RHOAIR*DELX*CPAIR)
      C10=(THETA*HRI)/((RHOAIR*DELX*CPAIR)+(TRMASS*CPSTL))
C
C  INITIALIZATION OF A ARRAY
C
      DO 310 I=1,II
      DO 310 J=1,III
      A(I,J)=0.0
310 CONTINUE
      DO 312 I=1,II
      A(I,I)=1.0
312 CONTINUE
C
C  CALCULATE RADIATION COEFFICIENT(FLOOR TO ROOF)
C
      RC=(SIGMA*SF*((T(KAI+1)+460)**4.-(T(NFL)+460)**4.))
      +/(((1/EPS1)+(1/EPS2)-1)*(T(KAI+1)-T(NFL)))
C
C  CALCULATE COEFFICIENTS FOR ROOF NODES
C
      DO 315 I=1,NROOF
      DELXX(I)=THRF(I)/2.0
315 CONTINUE
      D1=(2*THETA*KRF(1))/(RHORF(1)*DELXX(1)*DELXX(1)*CPRF(1))
      D2=(2*THETA*HRO)/(RHORF(1)*DELXX(1)*CPRF(1))
      A(II,II-1)=-D1/(1+D1+D2)
      A(II,III)=(T(II)+D2*SAT)/(1+D1+D2)
      D1=(2*THETA*KRF(NROOF))/(RHORF(NROOF)*DELXX(NROOF)*DELXX(NROOF)
      +*CPRF(NROOF))
      D2=(2*THETA*HRI)/(RHORF(NROOF)*DELXX(NROOF)*CPRF(NROOF))
      D3=(2*THETA*RC)/(RHORF(NROOF)*DELXX(NROOF)*CPRF(NROOF))
      A(KAI+1,NFL)=-D3/(1+D1+D2+D3)
      A(KAI+1,KAI)=-D2/(1+D1+D2+D3)
      A(KAI+1,KAI+2)=-D1/(1+D1+D2+D3)
C *****
C
C  COMMENT OUT THIS LINE WHEN COMPARING THIS MODEL TO THE STEADY STATE
C  MODEL-- OTHERWISE LEAVE THIS LINE IN
C
      A(KAI+1,III)=T(KAI+1)/(1+D1+D2+D3)
C
C *****
C  THESE TWO LINES ARE TO BE USED ONLY FOR COMPARISON TO THE STEADY
C  STATE MODEL--COMMENT THEM OUT WHEN MAKING ACTUAL RUNS
C
      D4=2*THETA/(RHORF(NROOF)*CPRF(NROOF)*DELXX(NROOF))
      A(KAI+1,III)=(T(KAI+1)+QROCF*D4)/(1+D1+D2+D3)
C *****
C
      NM1=NN-1
      DO 318 I=2,NM1,2
      KK=I/2
      D1=(THETA*KRF(KK))/(RHORF(KK)*DELXX(KK)*DELXX(KK)*CPRF(KK))
      A(III-I,II-I)=-D1/(1+2*D1)
      A(III-I,III-I+1)=-D1/(1+2*D1)
      A(III-I,III)=T(III-I)/(1+2*D1)
318 CONTINUE

```

TRA04000
 TRA04010
 TRA04020
 TRA04030
 TRA04040
 TRA04050
 TRA04060
 TRA04070
 TRA04080
 TRA04090
 TRA04100
 TRA04110
 TRA04120
 TRA04130
 TRA04140
 TRA04150
 TRA04160
 TRA04170
 TRA04180
 TRA04190
 TRA04200
 TRA04210
 TRA04220
 TRA04230
 TRA04240
 TRA04250
 TRA04260
 TRA04270
 TRA04280
 TRA04290
 TRA04300
 TRA04310
 TRA04320
 TRA04330
 TRA04340
 TRA04350
 TRA04360
 TRA04370
 TRA04380
 TRA04390
 TRA04400
 TRA04410
 TRA04420
 TRA04430
 TRA04440
 TRA04450
 TRA04460
 TRA04470
 TRA04480
 TRA04490
 TRA04500
 TRA04510
 TRA04520
 TRA04530
 TRA04540
 TRA04550
 TRA04560

FILE: TRANS FORTRAN A1

KANSAS STATE UNIVERSITY VM/SP CMS

```

      IF(NROOF.LE.1.0) GO TO 320
      NM3=NN-3
      DO 319 I=2,NM3,2
      KK=I/2
      KK1=KK+1
      D1=(2*THETA)/(RHORF(KK)*DELXX(KK)*CPRF(KK))
      D2=(2*THETA)/(RHORF(KK1)*DELXX(KK1)*CPRF(KK1))
      A(II-I,II1-I)=(-(D1+D2)*KRF(KK)/DELXX(KK))/
      +(1+((D1+D2)*KRF(KK)/DELXX(KK)))+(D1+D2)*
      +KRF(KK1)/DELXX(KK1))
      A(II-I,II1-I)=(-(D1+D2)*KRF(KK1)/DELXX(KK1))/
      +(1+((D1+D2)*KRF(KK)/DELXX(KK)))+(D1+D2)*
      +KRF(KK1)/DELXX(KK1))
      A(II-I,II1)=T(II-I)/(1+((D1+D2)*KRF(KK)/DELXX(KK))+
      +(D1+D2)*KRF(KK1)/DELXX(KK1)))
319  CONTINUE
320  CONTINUE
C
C CALCULATE COEFFICIENTS FOR FLOOR NODES
C
      DO 415 I=1,NFLOOR
      DELXFL(I)=THFL(I)/2.0
415  CONTINUE
      E1=(2*THETA*KFL(1))/(RHOFL(1)*DELXFL(1)*DELXFL(1)*CPFL(1))
      A(1,2)=-E1/(1+2*E1)
      A(1,II1)=-(-T(1)-E1*TFI)/(1+2*E1)
      E1=(KFL(NFLOOR)*2*THETA)/(RHOFL(NFLOOR)*DELXFL(NFLOOR)*
      +DELXFL(NFLOOR)*CPFL(NFLOOR))
      E2=(2*THETA*HFI)/(RHOFL(NFLOOR)*CPFL(NFLOOR)*DELXFL(NFLOOR))
      E3=(2*THETA*RC)/(RHOFL(NFLOOR)*CPFL(NFLOOR)*DELXFL(NFLOOR))
      E4=(2*THETA)/(RHOFL(NFLOOR)*CPFL(NFLOOR)*DELXFL(NFLOOR))
      A(NFL,KAI+1)=-E3/(1+E1+E2+E3)
      A(NFL,NFL+1)=(-E2)/(1+E1+E2+E3)
      A(NFL,NFL-1)=(-E1)/(1+E1+E2+E3)
C *****
C
C COMMENT OUT THIS LINE WHEN COMPARING THIS MODEL TO THE STEADY STATE
C MODEL--OTHERWISE LEAVE IT IN
C
      A(NFL,II1)=-(-T(NFL)-E4*LTRLD)/(1+E1+E2+E3)
C *****
C
C THE NEXT LINE IS USED WHEN COMPARING TO THE STEADY STATE MODEL
C ONLY--WHEN MAKING ACTUAL RUNS COMMENT IT OUT
C
      A(NFL,II1)=(T(NFL)+E4*LTRLD+QFLOOR*E4)/(1+E1+E2+E3)
C *****
C
      NM1=NFL-1
      DO 418 I=2,NM1,2
      KK=I/2
      E1=(THETA*KFL(KK))/(RHOFL(KK)*DELXFL(KK)*DELXFL(KK)*CPFL(KK))
      A(I,I-1)=-E1/(1+2*E1)
      A(I,I+1)=-E1/(1+2*E1)
      A(I,II1)=T(I)/(1+2*E1)
418  CONTINUE

```

TRA04570
 TRA04580
 TRA04590
 TRA04600
 TRA04610
 TRA04620
 TRA04630
 TRA04640
 TRA04650
 TRA04660
 TRA04670
 TRA04680
 TRA04690
 TRA04700
 TRA04710
 TRA04720
 TRA04730
 TRA04740
 TRA04750
 TRA04760
 TRA04770
 TRA04780
 TRA04790
 TRA04800
 TRA04810
 TRA04820
 TRA04830
 TRA04840
 TRA04850
 TRA04860
 TRA04870
 TRA04880
 TRA04890
 TRA04900
 TRA04910
 TRA04920
 TRA04930
 TRA04940
 TRA04950
 TRA04960
 TRA04970
 TRA04980
 TRA04990
 TRA05000
 TRA05010
 TRA05020
 TRA05030
 TRA05040
 TRA05050
 TRA05060
 TRA05070
 TRA05080
 TRA05090
 TRA05100
 TRA05110
 TRA05120
 TRA05130

FILE: TRANS FORTRAN A1

KANSAS STATE UNIVERSITY VM/SP CMS

```

      IF(NFLOOR.LE.1.0) GO TO 420
      NM3=NFL-3
      DO 419 I=2,NM3,2
      KK=I/2
      KK1=KK+1
      E1=(2*THETA)/(RHOFL(KK)*DELXFL(KK)*CPFL(KK))
      E2=(2*THETA)/(RHOFL(KK1)*DELXFL(KK1)*CPFL(KK1))
      A(I+1,I)=(-(E1+E2)*KFL(KK)/DELXFL(KK))/
      +((1+((E1+E2)*KFL(KK)/DELXFL(KK))+((E1+E2)*
      +KFL(KK1)/DELXFL(KK1)))
      A(I+1,I+2)=(-(E1+E2)*KFL(KK1)/DELXFL(KK1))/
      +((1+((E1+E2)*KFL(KK)/DELXFL(KK))+((E1+E2)*
      +KFL(KK1)/DELXFL(KK1)))
      A(I+1,I1)=T(I+1)/(1+((E1+E2)*KFL(KK)/DELXFL(KK))+
      +((E1+E2)*KFL(KK1)/DELXFL(KK1)))
419  CONTINUE
420  CONTINUE
C
C CALCULATE COEFFICIENTS FOR AIR NODES
C
C
C CALCULATE FLOOR TO AIR CONVECTION COEFFICIENT TO DISTRIBUTE
C IN THE CONDITIONED SPACE
C
      DO 450 I=1,K
      D5(I)=0.0
450  CONTINUE
      DO 460 I=1,N
      D5(I)=C5/N
460  CONTINUE
C
C
      IF(MCE(1).LE.0.0) GO TO 500
      IF(MCE(1).GT.0.0) GO TO 520
500  A(NAIR,NAIR+1)=(-C3+MCE(1)*C2)/(1+MVE(1)*C2+MRE(1)*C2+C3+C4+D5(1))
      A(NAIR,I1)=-(-T(NAIR)-LOAD(1)*C1-MSE(1)*C2*TS-C4*TC-C1*LTCLD(1))
      +/(1+C3+MVE(1)*C2+MRE(1)*C2+C4+D5(1))
      A(NAIR,NAIR-1)=(-D5(1))/(1+MVE(1)*C2+MRE(1)*C2+C3+C4+D5(1))
      GO TO 550
520  A(NAIR,NAIR+1)=-C3/(1+C3+MCE(1)*C2+MVE(1)*C2+MRE(1)*C2+C4+D5(1))
      A(NAIR,NAIR-1)=(-D5(1))/(1+C3+MCE(1)*C2+MVE(1)*C2+MRE(1)*C2+C4+
      +D5(1))
      A(NAIR,I1)=-(-T(NAIR)-LOAD(1)*C1-MSE(1)*C2*TS-C4*TC-C1*LTCLD(1))
      +/(1+C3+MCE(1)*C2+MVE(1)*C2+MRE(1)*C2+C4+D5(1))
      GO TO 550
550  IF(MCE(K-1).LE.0.0) GO TO 560
      IF(MCE(K-1).GT.0.0) GO TO 570
560  A(KAI,I1)=-(-T(KAI)-LOAD(K)*C6-MSE(K)*C7*TS-C9*TC-C6*LTCLD(K))
      +/(1-MCE(K-1)*C7+MVE(K)*C7+MRE(K)*C7+C10+C8+C9)
      A(KAI,KAI-1)=(-C8)/(1-MCE(K-1)*C7+MVE(K)*C7+MRE(K)*C7+C10+C8+C9)
      A(KAI,KAI+1)=(-C10)/(1-MCE(K-1)*C7+MVE(K)*C7+MRE(K)*C7+C10+C8+C9)
      A(KAI,NFL)=-D5(K)/(1-MCE(K-1)*C7+MVE(K)*C7+MRE(K)*C7+C10+C8+C9)
      A(KAI,NAIR)=+D5(K)/(1-MCE(K-1)*C7+MVE(K)*C7+MRE(K)*C7+C10+C8+C9)
      GO TO 600
570  A(KAI,KAI-1)=(-MCE(K-1)*C7-C8)/(1+MVE(K)*C7+MRE(K)*C7+C10+C8+C9)
      A(KAI,I1)=-(-T(KAI)-LOAD(K)*C6-MSE(K)*C7*TS-C9*TC-C6*LTCLD(K))/
      +(1+MVE(K)*C7+MRE(K)*C7+C10+C8+C9)

```

FILE: TRANS FORTRAN A1

KANSAS STATE UNIVERSITY VM/SP CMS

```

A(KAI,KAI+1)=(-C10)/(1+MVE(K)*C7+MRE(K)*C7+C10+C8+C9)      TRA05710
A(KAI,NFL)=-D5(K)/(1+MVE(K)*C7+MRE(K)*C7+C10+C8+C9)          TRA05720
A(KAI,NAIR)=+D5(K)/(1+MVE(K)*C7+MRE(K)*C7+C10+C8+C9)          TRA05730
KM1=K-1                                                         TRA05740
600 DO 650 I=2,KM1                                              TRA05750
    IF(MCE(I).GT.0.0.AND.MCE(I-1).GT.0.0) GO TO 610             TRA05760
    IF(MCE(I).LE.0.0.AND.MCE(I-1).LE.0.0) GO TO 620             TRA05770
    IF(MCE(I).GT.0.0.AND.MCE(I-1).LE.0.0) GO TO 630             TRA05780
    IF(MCE(I).LE.0.0.AND.MCE(I-1).GT.0.0) GO TO 640             TRA05790
610 A(NFL+I,NFL+I+1)=-C3/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4+MCE(I)*C2) TRA05800
    A(NFL+I,NAIR)=(-C3-MCE(I-1)*C2)/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4+ TRA05810
    +MCE(I)*C2)                                                  TRA05820
    A(NFL+I,I11)=-(-T(I)-LOAD(I)*C1-MSE(I)*C2*TS-C4*TO-C1*LTCLD(I))/ TRA05830
    +(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4+MCE(I)*C2)                 TRA05840
    A(NFL+I,NFL)=-D5(I)/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4+MCE(I)*C2) TRA05850
    A(NFL+I,NAIR)=+D5(I)/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4+MCE(I)*C2) TRA05860
    IF (I.GT.2) GO TO 615                                         TRA05870
    A(NFL+I,NAIR)=(-C3-MCE(I-1)*C2+D5(I))/(1+MRE(I)*C2+MVE(I)*C2+ TRA05880
    +2*C3+C4+MCE(I)*C2)                                           TRA05890
615 GO TO 650                                                    TRA05900
620 A(NFL+I,NFL+I+1)=(-C3+MCE(I)*C2)/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4- TRA05910
    +MCE(I-1)*C2)                                                  TRA05920
    A(NFL+I,NFL+I-1)=(-C3)/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4-MCE(I-1)*C2) TRA05930
    A(NFL+I,I11)=-(-T(I)-LOAD(I)*C1-MSE(I)*C2*TS-C4*TO-C1*LTCLD(I))/ TRA05940
    +(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4-MCE(I-1)*C2)                 TRA05950
    A(NFL+I,NFL)=-D5(I)/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4-MCE(I-1)*C2) TRA05960
    A(NFL+I,NAIR)=+D5(I)/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4-MCE(I-1)*C2) TRA05970
    IF (I.GT.2) GO TO 625                                         TRA05980
    A(NFL+I,NAIR)=(-C3+D5(I))/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4-MCE(I-1) TRA05990
    +C2)                                                           TRA06000
625 GO TO 650                                                    TRA06010
630 A(NFL+I,NFL+I+1)=(-C3)/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4- TRA06020
    +MCE(I-1)*C2+MCE(I)*C2)                                         TRA06030
    A(NFL+I,NFL+I-1)=-C3/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4-MCE(I-1)*C2+ TRA06040
    +MCE(I)*C2)                                                  TRA06050
    A(NFL+I,I11)=-(-T(I)-LOAD(I)*C1-MSE(I)*C2*TS-C4*TO-C1*LTCLD(I))/ TRA06060
    +(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4-MCE(I-1)*C2+MCE(I)*C2)       TRA06070
    A(NFL+I,NFL)=-D5(I)/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4-MCE(I-1)*C2+ TRA06080
    +MCE(I)*C2)                                                  TRA06090
    A(NFL+I,NAIR)=+D5(I)/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4-MCE(I-1)*C2+ TRA06100
    +MCE(I)*C2)                                                  TRA06110
    IF (I.GT.2) GO TO 635                                         TRA06120
    A(NFL+I,NAIR)=(-C3+D5(I))/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4 TRA06130
    +MCE(I-1)*C2+MCE(I)*C2)                                         TRA06140
635 GO TO 650                                                    TRA06150
640 A(NFL+I,NFL+I+1)=(-C3+MCE(I)*C2)/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4) TRA06160
    A(NFL+I,NFL+I-1)=(-C3-MCE(I-1)*C2)/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4) TRA06170
    A(NFL+I,I11)=-(-T(I)-LOAD(I)*C1-MSE(I)*C2*TS-C4*TO-C1*LTCLD(I))/ TRA06180
    +(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4)                               TRA06190
    A(NFL+I,NFL)=-D5(I)/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4)         TRA06200
    A(NFL+I,NAIR)=+D5(I)/(1+MRE(I)*C2+MVE(I)*C2+2*C3+C4)         TRA06210
    IF (I.GT.2) GO TO 650                                         TRA06220
    A(NFL+I,NAIR)=(-C3+D5(I)-MCE(I-1)*C2)/(1+MRE(I)*C2+MVE(I)*C2+ TRA06230
    +2*C3+C4)                                                  TRA06240
650 CONTINUE                                                    TRA06250

```

C
C

FILE: TRANS FORTRAN A1

KANSAS STATE UNIVERSITY VM/SP CMS

```

C                                     TRA06280
      CALL GAUSS (II,I11,A)          TRA06290
      DO 800 I=1, I1                 TRA06300
      T(I)=A(I,I11)                  TRA06310
800 CONTINUE                          TRA06320
C                                     TRA06330
C SUMMATION OF LOADS FOR THIS TIME STEP TRA06340
C                                     TRA06350
      SOLLD=SOLLD+(SAT-T(I1))*THETA*HRO TRA06360
      RFCLD=RFCLD+(T(KAI+1)-T(KAI))*THETA*HRI TRA06370
      RFRLD=RFRLD+(THETA*SIGMA*SF*{(T(KAI+1)+460)**4.-(T(NFL)+460)**4.}) TRA06380
      +/(1/EP S1)+(1/EP S2)-1)        TRA06390
      FLCLD=FLCLD+(T(NFL)-T(NAIR))*THETA*HFI TRA06400
      DO 750 I=NAIR,KAI               TRA06410
      WALCLD=WALCLD+(TO-T(I))*UWALL*PER*DELX*THETA TRA06420
750 CONTINUE                          TRA06430
      EXLD=EXLD+(MV*CPAIR*T(M)*THETA) TRA06440
C                                     TRA06450
C CALCULATION OF VENT AND RETURN LOADS FOR THIS TIME STEP TRA06460
C                                     TRA06470
      VENTLD=(MV*CPAIR*(TO-TS)*THETA)+VENTLD TRA06480
      RETLD=(MR*CPAIR*(T(MRET+NFL)-TS)*THETA)+RETLD TRA06490
      RFST=SOLLD-RFCLD-RFRLD+RFST     TRA06500
C                                     TRA06510
C                                     TRA06520
C TEMPERATURE AVERAGING SEGMENT- TO SIMULATE THE TRA06530
C BUOYANCY FROM CONCENTRATED LOADS TRA06540
C                                     TRA06550
905 DO 910 I=NAIR,KAM1               TRA06560
      XX=T(I+1)+.1-T(I)              TRA06570
      IF (XX.LT.0.) GO TO 920         TRA06580
910 CONTINUE                          TRA06590
      GO TO 940                      TRA06600
920 DO 930 I=NAIR,KAM1               TRA06610
      IF (T(I).LE.T(I+1)) GO TO 930 TRA06620
      XX=(T(I)*YY(I-NFL)+T(I+1)*YY(I+1-NFL))/(YY(I-NFL)+YY(I+1-NFL)) TRA06630
      T(I)=XX                        TRA06640
      T(I+1)=XX                      TRA06650
930 CONTINUE                          TRA06660
      GO TO 905                      TRA06670
940 CONTINUE                          TRA06680
C                                     TRA06690
1010 CONTINUE                         TRA06700
      SOLD(NDAYS,NHOURS)=SOLLD       TRA06710
      SRFLD(NDAYS,NHOURS)=RFCLD      TRA06720
      SRFRLD(NDAYS,NHOURS)=RFRLD     TRA06730
      SRFST(NDAYS,NHOURS)=RFST       TRA06740
      SFLCLD(NDAYS,NHOURS)=FLCLD     TRA06750
      SWALCL(NDAYS,NHOURS)=WALCLD    TRA06760
      SLTLD(NDAYS,NHOURS)=LTCLD(NLTS)+LTRLD TRA06770
      SRETLD(NDAYS,NHOURS)=RETLD     TRA06780
      SVENLD(NDAYS,NHOURS)=VENTLD    TRA06790
      SEXLD(NDAYS,NHOURS)=EXLD       TRA06800
      WRITE (6,84)                   TRA06810
      WRITE (6,85)                   TRA06820
      WRITE (6,86)                   TRA06830
      WRITE (6,87) SAT,TO,TS,HSUP(NHOURS),HRET(NHOURS),HVENT(NHOURS) TRA06840

```

FILE: TRANS FORTRAN A1

KANSAS STATE UNIVERSITY VM/SP CMS

WRITE (6,60)	TRA06850
WRITE (6,61)	TRA06860
WRITE (6,62)	TRA06870
DO 1013 I=1,II	TRA06880
IF (I.LE.NFL.CR.I.GT.KAI) GO TO 1011	TRA06890
WRITE (6,74) LOAD (I-NFL),T(I)	TRA06900
GO TO 1012	TRA06910
1011 WRITE (6,75) T(I)	TRA06920
1012 CCNTINUE	TRA06930
1013 CONTINUE	TRA06940
1050 CCNTINUE	TRA06950
1090 CONTINUE	TRA06960
DO 1095 J=1,ND	TRA06970
WRITE (6,39) DESCR	TRA06980
WRITE (6,20) J	TRA06990
WRITE (6,21)	TRA07000
WRITE (6,22)	TRA07010
WRITE (6,23)	TRA07020
DO 1090 I=1,NHO	TRA07030
WRITE (6,24) I, SOLD(J,I),SRFCLD(J,I),SRFRLD(J,I),SRFST(J,I),	TRA07040
+SFLCLD(J,I),SWALCL(J,I),SLTLD(J,I),SEXLD(J,I),SRETLD(J,I),	TRA07050
+SVENLD(J,I)	TRA07060
1090 CONTINUE	TRA07070
1095 CONTINUE	TRA07080
STOP	TRA07090
END	TRA07100
SUBROUTINE GAUSS(N,N1,A)	TRA07110
REAL A(N,N1)	TRA07120
DO 200 J=1,N	TRA07130
DIV=A(J,J)	TRA07140
S=1.0/DIV	TRA07150
DO 201 K=J,N1	TRA07160
201 A(J,K)=A(J,K)*S	TRA07170
DO 202 I=1,N	TRA07180
IF (I-J) 203,202,203	TRA07190
203 AIJ=-A(I,J)	TRA07200
DO 204 K=J,N1	TRA07210
204 A(I,K)=A(I,K)+AIJ*A(J,K)	TRA07220
202 CONTINUE	TRA07230
200 CONTINUE	TRA07240
RETURN	TRA07250
END	TRA07260

ACKNOWLEDGEMENTS

I wish to extend sincere appreciation to Dr. Robert L. Gorton for providing guidance and encouragement during this investigation.

Prof. Robert E. Crank should be teaching courses in "life," as well as Mechanical Engineering; he is both inspiring and frustrating.

Appreciation is also extended to Dr. Richard G. Akins for serving as a committee member.

Special thanks go to my typist, Miss Carolyn M. Graham, who through no fault of her own will become my wife in April.

Moral as well as strategic financial support was provided by my father during all my years of study, for this I will be forever indebted.

VITA

Alan Thomas Leard

Candidate for the Degree of

Master of Science

Thesis: SIMULATION OF THE TRANSIENT BEHAVIOR OF STRATIFIED AIR CONDITIONING SYSTEMS

Major Field: Mechanical Engineering

Biographical:

Personal Data: Born in Kansas City, Missouri, September 30, 1958, the son of Loyal G. Leard and Agnes E. Barthol.

Education: Graduated from Shawnee Mission West High School in 1976; received the Associate of Arts degree from Johnson County Community College in 1979; received the Bachelor of Science degree from Kansas State University, with a major in Mechanical Engineering, in May of 1981; completed requirements for the Master of Science degree in February of 1983.

Honors and Societies: Tau Beta Pi, engineering honorary; American Society of Mechanical Engineers, Secretary 1980-1981.

SIMULATION OF THE TRANSIENT BEHAVIOR OF
STRATIFIED AIR CONDITIONING SYSTEMS

by

ALAN THOMAS LEARD

B.S., Kansas State University, 1981

AN ABSTRACT OF A MASTER'S THESIS

submitted in partial fulfillment of the

requirements for the degree

MASTER OF SCIENCE

Department of Mechanical Engineering

KANSAS STATE UNIVERSITY
Manhattan, Kansas

1983

ABSTRACT

Concurrent with the increased interest in air conditioning large industrial buildings and manufacturing facilities runs the desire to reduce the costs, both initial and operating, of these systems. One method of plant cooling load reduction is known as thermal stratification. Thermal stratification, in a single story high ceiling building, operates by supplying conditioned air to only the lower occupied level, known as the conditioned zone, while allowing the air above the conditioned zone, known as the stratified zone, to remain relatively unaffected.

The purpose of this investigation is to extend the applicability of previous work to include the transient effects present in full-scale industrial buildings. To this end a computer program has been developed, based on the finite-difference method of approximation, for use in calculation of building (roof, air, and floor) temperature profiles in the presence of transient internal, and boundary conditions. Loads are then determined from energy balances using the computed temperatures.

Full-scale experimental verification of the validity of the computed results was not attempted. Limited verification of the validity of these results has been carried out. Comparisons were made to the actual temperature profiles acquired, under steady-state conditions, from the previous model studies. It has been generally concluded that the transient computer program developed here provides an acceptable prediction of the internal conditions present in a stratified air conditioning system.

Computed results indicate that substantial savings (50% reduction of peak load) can be realized through proper location and timing of supply air introduction and of return and ventilation air extraction. Additional savings are possible by proper management of storage effects (e.g., roof mass) and internal load location.